

May 5, 1988

Docket Nos. 50-280
and 50-281

Mr. D. S. Cruden
Vice President - Nuclear
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Cruden:

SUBJECT: RESPONSE TO NRC BULLETIN 88-01, "DEFECTS IN WESTINGHOUSE
CIRCUIT BREAKERS" (TAC NOS. 67728 AND 67729)

Thank you for your letter of April 5, 1988, responding to NRC Bulletin 88-01
for the Surry Power Station, Units 1 and 2.

Since the Surry units do not use any of the Westinghouse Type DS breakers in
Class 1E circuits, no further action on your part is required. With regard
to the Surry units, your response to the Bulletin is complete and this matter
is closed.

Sincerely,

Original signed by

Chandu P. Patel, Project Manager
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File	CPatel
NRC & Local PDRs	OGC-WF
PDII-2 Rdg.	EJordan
SVarga	JPartlow
GLainas	ACRS(10)
DMiller	Gray File

LDN-2
D:PDII-2
05/5/88

CP
PM:PDII-2
CPatel:bd
05/5/88

D:PDII-2
HBerkow
05/5/88

8805170027 880505
PDR ADDCK 05000280
Q PDR

Mr. D. S. Cruden
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. William C. Porter, Jr.
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

James B. Kenley, M.D., Commissioner
Department of Health
109 Governor Street
Richmond, Virginia 23219

Michael W. Maupin, Esq.
Hunton and Williams
P. O. Box 1535
Richmond, Virginia 23212

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Mr. G. E. Kane
P. O. Box 402
Mineral, Virginia 23117

Ellyn R. Weiss, Esq.
Harmon, Weiss and Jordan
2001 S Street NW
Washington, DC 20009

Old Dominion Electric Cooperative
c/o Executive Vice President
Innsbrook Corporate Center
4222 Cox Road, Suite 102
Glen Allen, Virginia 23060

Mr. W. L. Stewart
Senior Vice President - Power
Virginia Electric and Power Co.
Post Office Box 26666
Richmond, Virginia 23261

Mr. Patrick A. O'Hare
Office of the Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Resident Inspector/North Anna
c/o U.S. NRC
Senior Resident Inspector
Route 2, Box 78
Mineral, Virginia 23117