

Virginia Electric And Power Company
Surry Power Station
5570 Hog Island Road
Surry, Virginia 23883

August 27, 1999

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No.: 99-436
SPS: BCB
Docket Nos.: 50-280, 50-281
License Nos.: DPR-32, DPR-37


Dear Sirs:

Pursuant to Technical Specifications Table 3.7-6, Virginia Electric and Power Company hereby submits the following Special Report applicable to Surry Power Station Units 1 and 2.

Report No. 50-280, 50-281/1999-005-00

This report has been reviewed by the Station Nuclear Safety and Operating Committee and will be forwarded to the Management Safety Review Committee for its review.

Very truly yours,



E. S. Grecheck
Site Vice President

Enclosure

Commitments contained in this letter:

1. To help minimize the potential for condensation within the system, heat trace is being installed on the radiation monitors' skid and sample discharge line.

9909020017 990827
PDR ADOCK 05000280
S PDR

020020

1/1
IE22

cc: U. S. Nuclear Regulatory Commission
Region II
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Mr. R. A. Musser
NRC Senior Resident Inspector
Surry Power Station