

**Virginia Electric And Power Company
Surry Power Station
5570 Hog Island Road
Surry, Virginia 23883**

May 22, 1998

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No.: 98-305
SPS: BCB
Docket No.: 50-280
50-281
License No.: DPR-32
DPR-37

Dear Sirs:

Pursuant to 10CFR50.73, Virginia Electric and Power Company hereby submits the following Licensee Event Report applicable to Surry Power Station Units 1 and 2.

Report No. 50-280, 50-281/1998-008-00

This report has been reviewed by the Station Nuclear Safety and Operating Committee and will be forwarded to the Management Safety Review Committee for its review.

Very truly yours,



D. A. Christian
Site Vice President

11
Jerr

Enclosure

Commitments contained in this letter:

1. Measures will be taken that will allow 1-VS-F-58A and 1-VS-F-58B to be functionally tested and ensure that the fans are maintained in a condition that is within the design basis of the plant.

9805280232 980522
PDR ADOCK 05000280
S PDR

cc: U. S. Nuclear Regulatory Commission
Region II
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Mr. R. A. Musser
NRC Senior Resident Inspector
Surry Power Station