

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

December 18, 1995

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 95-607
NL/RPC
Docket Nos. 50-280
License Nos. DPR-32

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT 1
SAFETY-RELATED MOTOR-OPERATED VALVE TESTING
AND SURVEILLANCE — GENERIC LETTER 89-10

On June 28, 1989, the NRC issued Generic Letter 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance." Virginia Electric and Power Company submitted its initial response to the generic letter on December 26, 1989 (Serial No. 89-530) stating that the necessary reviews, analyses, verifications, tests and inspections would be conducted in order to meet the specified schedule. Additional information was provided in letters dated June 29, 1993 and December 3, 1993 (Serial Nos. 93-333 and 93-664, respectively) in order to clarify the implementation of our Motor Operated Valve (MOV) Program.

Pursuant to Generic Letter 89-10, Virginia Electric and Power Company provides the required notification concerning Surry Power Station Unit 1. During the recent refueling outage which ended on October 21, 1995, Surry Power Station Unit 1 completed the actions described in the first paragraph of item i of Generic Letter 89-10.

NRC Inspection Report Nos. 50-280/94-18 and 50-281/94-18, dated August 25, 1994, identified that information concerning the valve stem coefficient of friction will require further NRC evaluation prior to closure of Generic Letter 89-10. A study including a test program and data evaluation has been completed. Plant-specific data support and justify the validity of using a 0.15 value for the coefficient of friction.

Should you have additional questions, please contact us.

Very truly yours,



James P. O'Hanlon
Senior Vice President - Nuclear

220026

9512220250 951218
PDR ADOCK 05000280
P PDR

A064
1/0

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. M. W. Branch
NRC Senior Resident Inspector
Surry Power Station

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by J. P. O'Hanlon, who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 18TH day of December, 1995.

My Commission Expires: May 31, 1998.

Vicki L. Hull
Notary Public

(SEAL)