

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9602120221 DOC.DATE: 96/02/07 NOTARIZED: NO DOCKET #  
 FACIL:50-281 Surry Power Station, Unit 2, Virginia Electric & Powe 05000281  
 AUTH.NAME AUTHOR AFFILIATION  
 O'HANLON,J.P. Virginia Power (Virginia Electric & Power Co.)  
 RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Requests relief from exam coverage requirements of ASME  
 Section XI for five welds identified in relief requests  
 SR-14 through SR-17.

DISTRIBUTION CODE: A047D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 20  
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES: 05000281

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	L	T	ID	CODE/NAME	L	T
	PD2-1	LA	1	1	PD2-1	PD	1	1
		BUCKLEY,B	1	1				
INTERNAL:	ACRS		6	0	AEOD/SPD/RAB		1	1
	<del>FILE CENTER</del>	01	1	1	NRR/DE/ECGB		1	1
	NRR/DE/EMCB		1	1	NRR/DE/EMEB		1	1
	NUDOCS-ABSTRACT		1	1	OGC/HDS2		1	0
	RES/DET/EMMEB		1	1	RES/DSIR/EIB		1	1
EXTERNAL:	LITCO ANDERSON		1	1	NOAC		1	1
	NRC PDR		1	1				
NOTES:			1	1				

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 15 *MAF*

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

February 7, 1996

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 96-009  
NLOS/ETS: R0  
Docket Nos. 50-281  
License Nos. DPR-37

Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNIT 2**  
**INSERVICE INSPECTION PROGRAM**  
**EXAMINATION RELIEF REQUESTS**

Surry Power Station Unit 2 is currently in the first period of its third ten year inservice inspection interval. The component examination program is conducted in accordance with ASME Section XI 1989 Edition. ASME Code Case N-460 has been incorporated into the Inservice Inspection Program as an alternative for examination coverage of class 1 and 2 welds. During the recent Surry refueling outage, the examination coverage requirements of Code Case N-460 and ASME Section XI could not be met for five weld examinations as detailed in the attached relief requests (SR-14 through SR-17). Therefore, pursuant to 10 CFR 50.55a, paragraph g(5), Virginia Electric and Power Company requests relief from the examination coverage requirements of ASME Section XI for these welds.

In addition, four of the five welds require additional examinations during the second and third periods of the third ten year inspection interval. However, the Code required examination coverage will not be possible for these examinations. Therefore, relief is also being requested from the examination coverage requirements of ASME Section XI for the four welds identified in Relief Requests SR-15, SR-16 and SR-17 for the remainder of the third ten year inservice inspection interval.

Justification from the partial examination coverage requirements are provided in the attached relief requests (SR-14 through 17).

Should you have any questions or require additional information, please contact us.

Very truly yours,



James P. O'Hanlon  
Senior Vice President - Nuclear

Attachments

A047  
11

120051  
9602120221 960207  
PDR ADDCK 05000281  
Q PDR

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. M. W. Branch  
NRC Senior Resident Inspector  
Surry Power Station

**Attachment 1**

Surry Unit 2

Weld Examination Partial Coverage Relief Requests

SR-14 through SR-17

RELIEF REQUEST SR-14

I. IDENTIFICATION OF COMPONENT

<u>Mark/Weld#</u>	<u>Line#</u>	<u>Drawing#</u>	<u>Class</u>
3-04A	3"-CH-381-1503	11548-WMKS-CH-11	2

II. IMPRACTICABLE CODE REQUIREMENTS

The 1989 edition of ASME Section XI Table IWC-2500-1, examination category C-F-1, item number C5.11 does not allow any limitations to the required volumetric or surface examinations. Code Case N-460, Alternative Examination Coverage for Class 1 and Class 2 Welds, allows a reduction in coverage, if it is less than 10%.

III. BASIS FOR RELIEF

The component listed is a three inch pipe to valve body weld. This weld is located on the upstream side of the discharge check valve for the "A" charging pump. The component listed above has been examined to the extent practical as required by the Code. Due to interferences from a branch connection and an adjacent valve body the reduction in coverage of the volumetric examination is detailed in Table SR-14-1. The required surface examination had no limitations. Figure SR-14-1 is provided detailing the limitations experienced.

IV. ALTERNATE PROVISIONS


It is proposed that the examination completed at the reduced coverage be counted as meeting the Code preservice requirements.

**Table SR-14-1**  
**Surry Unit 2**  
**Examination Coverage Estimates**  
**11548-WMKS-CH-11**  
**Category C-F-1, Item C5.11**

<u>Mark/Weld#</u>	<u>UT Scan Coverage %</u>				<u>Surface Examination Coverage %</u>	<u>Reason For Partial</u>
	<u>2</u>	<u>5</u>	<u>7</u>	<u>8</u>		
3-04A	73	73	100	100	100	A branch connection limits the 2 and 5 scan to 8 out of 11 inches. A valve body limits the examination to one side. The 2 scan was performed using an extended beam.

UT Scan Direction Definitions

- 2 - Axial scan, 180 degrees from isometric flow direction.
- 5 - Axial scan, the same direction as the isometric flow.
- 7 - Circumferential scan, clockwise rotation when viewing in the direction of isometric flow.
- 8 - Circumferential scan, counterclockwise rotation when viewing in the direction of isometric flow.



11548-WMKS-CH-11

Figure SR-14-1





RELIEF REQUEST SR-15

I. IDENTIFICATION OF COMPONENT

<u>Mark/Weld#</u>	<u>Drawing#</u>	<u>Class</u>
1-01	11548-WMKS-CH-E-2	2
1-02	11548-WMKS-CH-E-2	2

II. IMPRACTICABLE CODE REQUIREMENTS

The 1989 edition of ASME Section XI Table IWC-2500-1, examination category C-A, item numbers C1.10 and C1.20 do not allow any limitations to the required volumetric or surface examinations. Code Case N-460, Alternative Examination Coverage for Class 1 and Class 2 Welds, allows a reduction in coverage, if it is less than 10%.

III. BASIS FOR RELIEF

One third of the welds listed above have been examined to the extent practical as required by the Code. The examinations were limited due to interferences from the non-regenerative heat exchanger inlet nozzle and a component support. Similar restrictions are expected for the remaining two thirds. The anticipated reduction in coverage of the volumetric examination is detailed in Table SR-15-1. Figure SR-15-1 is provided detailing the limitations experienced.

IV. ALTERNATE PROVISIONS

It is proposed that the examinations completed at the reduced coverage and scheduled examinations at the coverage stated in Table SR-15-1 be counted as meeting the Code requirements.

Table SR-15-1  
 Surry Unit 2  
 Examination Coverage Estimates  
 11548-WMKS-CH-E-2  
 Category C-A, Items C1.10 and C1.20

Mark/Weld#	UT Scan Coverage %				Section XI Item Number	Reason For Partial
	2	5	7	8		
Completed Examinations 0" to 28"						
1-01	93.75	93.75	50	50	C1.20	A component support limits the 7 and 8 scan to 14 inches out of 28 inches (0 inches to 14 inches). An extended beam path was used for the 2 and 5 scans.
1-02	88.39	88.39	100	100	C1.10	A 3 inch OD inlet nozzle 0.6 inches from the toe of weld, a welded support between 17.75 inches and 19.5 inches, the 5 side of the weld is flanged with studs and nuts blocking access.
Scheduled Examinations 28" to 85"						
1-01	93.75	93.75	44	44	C1.20	Two component supports limit the 7 and 8 scans to 25 out of 57 inches. An extended beam path will be used for the 2 and 5 scans.
1-02	84.7	84.7	100	100	C1.10	The 2 and 5 scans will be restricted by two 3 inch OD nozzles 0.6 inches from the toe of weld, three welded supports restricting 1.25 inches. The 5 side of the weld is flanged with studs and nuts blocking access. Extended beam path will be used.
Total Coverage 0" to 85"						
1-01	93.75	93.75	46	46	C1.20	
1-02	85.93	85.93	100	100	C1.10	

UT Scan Direction Definitions

2 - Axial scan head side of weld

5 - Axial scan vessel side of weld

7 - Circumferential scan, clockwise when looking down on the vessel

8 - Circumferential scan, counterclockwise when looking down on the vessel





FIGURE SR-15-1




NOTES:

# ANSTEC APERTURE CARD

Also Available on Aperture Card

REFERENCE DRAWINGS:

- VIR-2-1148 WESTINGHOUSE ISOMETRIC
- 11548-CBM-071E SHEET 1 ISI CLASSIFICATION BOUNDARY DRAWING
- 11548-CBM-080A SHEET 2 ISI CLASSIFICATION BOUNDARY DRAWING



9602120221-02

		VIRGINIA POWER NORTH CAROLINA POWER NUCLEAR ENGINEERING SERVICES RICHMOND, VIRGINIA	
INSERVICE INSPECTION DETAIL DRAWING LETDOWN HEAT EXCHANGER: 2-CH-E-2 SURRY POWER STATION UNIT 2 VIRGINIA POWER			
DSGN	ENGR SUPV	ARE	CAD NO. 20516355.0221CHE0002.150
DRWN	ENGR SUPV	MBL	DRAWING NO.
CHKD	ENGR	BAK	11548-WMKS-CH-E-2
ENGR	SCALE	NONE	UNLESS OTHERWISE NOTED
REV.	2	SHEET	1 OF 1

REVISIONS 2 REVISED PER ISI REVIEW. 1 RE-DRAWN TO SUIT SINGLE SHEET FORMAT	
DSGN: [ ] ENGR SUPV: [ ] ENGR: [ ] CHKD: [ ] ENGR: [ ]	DSGN: [ ] ENGR SUPV: [ ] ENGR: [ ] CHKD: [ ] ENGR: [ ]

## RELIEF REQUEST SR-16

### I. IDENTIFICATION OF COMPONENT

<u>Mark/Weld#</u>	<u>Drawing#</u>	<u>Class</u>
1-01	11548-WMKS-CH-FL-4A	1

### II. IMPRACTICABLE CODE REQUIREMENTS

The 1989 edition of ASME Section XI Table IWC-2500-1, examination category C-A, item number C1.20 does not allow any limitations to the required volumetric or surface examinations. Code Case N-460, Alternative Examination Coverage for Class 1 and Class 2 Welds, allows a reduction in coverage, if it is less than 10%.

### III. BASIS FOR RELIEF

The component listed above is the lower head to shell weld of the "A" seal water injection filter. One third, 0" to 12", of the component listed above has been examined to the extent practical as required by the Code. Due to interferences from a support leg the reduction in coverage of the volumetric examination is detailed in Table SR-16-1. Figure SR-16-1 is provided detailing the limitations experienced. Interferences were encountered when the remaining two thirds of the weld was examined during the second interval. It is anticipated that the same limitations will exist when the remaining two thirds of the weld are examined during the third inspection interval.

### IV. ALTERNATE PROVISIONS

It is proposed that the examination completed at the reduced coverage be counted as meeting the Code requirements. The remaining two thirds will be examined to the extent practical. The estimated coverage is for the remaining two thirds is expected to be similar to the coverage presented in Table SR-16-1.

Table SR-16-1  
 Surry Unit 2  
 Examination Coverage Estimates  
 Category C-A, Item C1.20

<u>Mark/Weld#</u>	<u>Beam Angle</u>	<u>Exam Area</u>	<u>Scan Direction</u>	<u>% Exam</u>	<u>Reason For Partial</u>
1-01 (0" - 12")	45	Weld	2	62	Support leg
	45	Weld	5	62	
	45	Weld	7	82	
	45	Weld	8	82	
	45	Base	2	62	
	45	Base	5	60	
	45	Base	7	82	
	45	Base	8	82	

Surface Examination coverage 62.5% (7.5"/12")

UT Scan Direction Definitions

- 2 - Axial scan vessel side of weld
- 5 - Axial scan flange side of weld
- 7 - Circumferential scan, clockwise (looking down on flange)
- 8 - Circumferential scan, counterclockwise (looking down on flange)






Figure SR-16-1



NOTES:  
 1. WELD/ITEM NUMBERS ARE INDICATED AS FOLLOWS:  
 DRAWING REFERENCE NO. (SEE REF DWG)  
 INDIVIDUAL WELD/ITEM NUMBER

# ANSTEC APERTURE CARD

Also Available on Aperture Card

REFERENCE DRAWINGS:  
 VIR-2-1388 WESTINGHOUSE ISOMETRIC  
 11548-CBM-888C SHEET 2 IS1 CLASSIFICATION BOUNDARY DRAWING  
 D-9444-2883 COMMERCIAL FILTERS CORP  
 11448-1.85-17A COMMERCIAL FILTERS CORP (MFG DRG NO D-9444-2886)

9602120221-03

VIRGINIA POWER NORTH CAROLINA POWER NUCLEAR ENGINEERING SERVICES RICHMOND, VIRGINIA			
INSERVICE INSPECTION DETAIL DRAWING SEAL INJECTION FILTER: 2-CH-FL-4A SURRY POWER STATION UNIT 2 VIRGINIA POWER			
DSGN DRWN CHKD DTSP ENGR	DSGN SUPV ENGR SUPV SCALL	CAD NO. 2051(205)00210-PLS1A1.100 DRAWING NO. 11548-WMKS-CH-FL-4A	REV. 1
REDRAWN TO SUIT SINGLE SHEET FORMAT		UNLESS OTHERWISE NOTED	

REV	DATE	BY	CHKD	APPV	REASON	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
-----	------	----	------	------	--------	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----



## RELIEF REQUEST SR-17

### I. IDENTIFICATION OF COMPONENT

<u>Mark/Weld#</u>	<u>Drawing#</u>	<u>Class</u>
1-01	11548-WMKS-RC-R-1.2	1

### II. IMPRACTICABLE CODE REQUIREMENTS

The 1989 edition of ASME Section XI Table IWB-2500-1, examination category B-A, item number B1.40 does not allow any limitations to the required volumetric or surface examinations. Code Case N-460, Alternative Examination Coverage for Class 1 and Class 2 Welds, allows a reduction in coverage, if it is less than 10%.

### III. BASIS FOR RELIEF

The component listed above is the reactor head to flange weld. One third, 0" to 179", of the component listed above has been examined to the extent practical as required by the Code. Due to interferences from a lifting lug and the geometry of the weld the reduction in coverage of the volumetric examination is detailed in Table SR-17-1. Figures SR-17-1 and SR-17-2 are provided detailing the limitations experienced. The surface examination had no limitations.

Limitations were encountered when the remaining two thirds of the weld was examined during the second interval. It is anticipated that the same limitations will exist when the remaining two thirds of the weld are examined during the third interval.

### IV. ALTERNATE PROVISIONS

It is proposed that the examination completed at the reduced coverage be counted as meeting the Code requirements. The remaining two thirds will be examined to the extent practical. The estimated coverage for the remaining two thirds is expected to be similar to the coverage presented in Table SR-17-1 for 0" to 179".

Table SR-17-1  
 Surry Unit 2  
 Examination Coverage Estimates (Reactor Vessel)  
 Category B-A, Item B1.40

<u>Mark/Weld#</u>	<u>Beam Angle</u>	<u>Exam Area</u>	<u>Scan Direction</u>	<u>% Exam</u>	<u>Reason For Partial</u>
1 (0" - 179")	0	Weld & Base	-	96.65	Joint Configuration and Lifting Lug
	45	Weld	2	91.84	
	45	Weld	5	96.65	
	45	Weld	7	96.65	
	45	Weld	8	96.65	
	60	Weld	2	56.71	
	60	Weld	5	90.16	
	60	Weld	7	96.65	
	60	Weld	8	96.65	
	45	Base	2	70.96	
	45	Base	5	96.65	
	45	Base	7	95.19	
	45	Base	8	95.19	
	60	Base	2	44.23	
	60	Base	5	83.02	
	60	Base	7	94.86	
	60	Base	8	94.86	

Surface coverage 100%

UT Scan Direction Definitions

- 2 - Axial scan flange side of weld
- 5 - Axial scan head side of weld
- 7 - Circumferential scan, clockwise (looking down on head)
- 8 - Circumferential scan, counterclockwise (looking down on head)

60 5 SIDE STOP  
60 5 SIDE START  
45 2 SIDE STOP

60 5 SIDE START

5 SIDE




2 SIDE

60 2 SIDE START  
45 2 SIDE START

FLANGE SIDE

FIGURE SR-17-1

11548-WMKS-RC-R-1 .2 WELD 1-01











Figure SR-17-2



NOTES:  
 1. THE REACTOR VESSEL VENT PIPE AND CRDM HOUSINGS ARE PARTIAL PENETRATION WELDED AND CLASSIFIED CATEGORY B-E ITEM NUMBERS B4.11 AND B4.12 RESPECTIVELY. PER ASME SECTION VIII THE VISUAL EXAMINATION OF THESE WELDS WILL BE PERFORMED DURING THE REACTOR COOLANT SYSTEM HYDROSTATIC TEST.  
 2. HEAD DIAMETER AT WELD 1-21 IS 172.875"

# ANSTEC APERTURE CARD

Also Available on Aperture Card

REFERENCE DRAWINGS:  
 VIR-1-1328a WESTINGHOUSE ISOMETRIC  
 VIR-1-1300 WESTINGHOUSE ISOMETRIC  
 30678-1184 DE ROTTERDAMSCHЕ DROOGDOK (MANUFACTURER DRAWING)

9602120221-04

VIRGINIA POWER NORTH CAROLINA POWER NUCLEAR ENGINEERING SERVICES RICHMOND, VIRGINIA			
INSERVICE INSPECTION DETAIL DRAWING REACTOR VESSEL HEAD & CRDM WELDS SURRY POWER STATION UNIT 2 VIRGINIA POWER			
DSON DRAWN CHECKED DISPL ENCL	DSON SUPV ENGR SUPV SCALE	CAD NO. 10841850000000000000 DRAWING NO. 11548-WMKS-RC-R-1.2 UNLESS OTHERWISE NOTED	REV. 2 SH. 1 OF 1

REVISIONS		REVISION NO.	DATE	DESCRIPTION
2				REVISED PER ISI REVIEW.
1				DRAWN TO FIT SINGLE SHEET FORMAT