

VIRGINIA ELECTRIC AND POWER COMPANY

RICHMOND, VIRGINIA 23261

May 6, 1996

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 96-224
SPS/JDK/MAE R1
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 and 2
SAFETY-RELATED MOTOR-OPERATED VALVE TESTING
AND SURVEILLANCE - GENERIC LETTER 89-10

On March 29, 1996, Mr. E. H. Girard of the NRC held an exit meeting regarding his inspection for the closure of Generic Letter (GL) 89-10, Safety-Related Motor-Operated Valve Testing and Surveillance. This letter documents the following commitments discussed during the GL 89-10 close-out inspection:

PORV Block Valves


The available margin will be increased an additional 10-15% for PORV block valves RC-1535, -1536, and -2535 during the next refueling outages. The next refueling outages are currently scheduled for February 1997 and May 1996 for Units 1 and 2, respectively.

96 Inch Pratt Butterfly Valves

Within the next year, torque data will be obtained on a representative 96 inch Pratt MOV during a valve stroke under system flow and differential pressure conditions to support the sizing methodology.

If you have questions regarding these commitments, please contact us.

Very truly yours,



James P. O'Hanlon
Senior Vice President - Nuclear

100045

9605100158 960506
PDR ADOCK 05000280
Q PDR

A064
1/

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. M. W. Branch
NRC Senior Resident Inspector
Surry Power Station