

August 16, 1995

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-95-048A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by Region II staff (Atlanta, Georgia) on this date.

Facility

Carolina Power & Light Co.
Brunswick 1 2
Southport, North Carolina
Dockets: 50-325, 50-324

Licensee Emergency Classification

X Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
Not Applicable

Virginia Power Co.
Surry 1 2
Surry, Virginia
Dockets: 50-280, 50-281

General Electric Co.
General Electric Co.
Wilmington, North Carolina
Dockets: 07001113 License No: SNM-1097

Subject: HURRICANE FELIX

Hurricane Felix continued to move toward the West Northwest near 14 mph. A decrease in forward speed is expected over the next 24 hours with a wind speed of 80 mph and no sign of strengthening.

The Center of Hurricane Felix is located at latitude 34.6N and longitude 72.5W as of 8:00 a.m., August 16, 1995. This location is about 280 miles ESE of Surry and 318 miles ESE of Brunswick.

Region II personnel closely tracked Hurricane Felix's progress throughout the evening and night from the Incident Response Center.

Brunswick, Surry and General Electric continue to make preparations for the hurricane.

Brunswick Unit 1 is at 100% and Unit 2 is at 43% increasing power to 60% following a condenser leak repair. The EDG's have been tested, hurricane preparations have been made, and no emergency equipment is out of service. Surry Unit 1 is at 91% end of life coastdown, Unit 2 is at 100%, the EDG's have been tested and preparations for hurricane arrival are in progress with no safety equipment out of service.

General Electric Fuel Fabrication facility is located near Wilmington, North Carolina. General Electric completed preparations for the hurricane yesterday afternoon, cleaning up construction materials and securing outside radwaste boxes. They have made contingency preparations to staff their Emergency Control Center, if necessary.

Region II personnel are onsite to augment the Surry and Brunswick Resident staff. The Emergency Response Vehicle and a Region II Manager

Sent 8/16/95
ppg JE34

have arrived in Raleigh, N. C. and are prepared to respond as needed. The Region II State Liaison Officer has departed the Atlanta area for the State Emergency Center in Raleigh, N. C., and will be diverted to the Virginia EOC, Richmond, Virginia, in the event that the hurricane continues northward.

Region I has positioned two support staff at Fredricksburg, Virginia, to assist at Surry, North Anna or Calvert Cliff.

The Region has been in contact with both the Commonwealth of Virginia and the State of North Carolina.

The Federal Emergency Management Agency, Region IV, activated the Regional Operations Center (ROC) at 8:00 a.m. this morning and the Region will establish and maintain a dialogue with this facility.

This information is current as of 8:00 a.m.

The licensee has notified the State and local officials.

Contact: K. D. LANDIS
(404) 331-5089