

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 28, 1994

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 93-698
NL&P/ETS R3
Docket Nos. 50-280
50-281
50-338
50-339
License Nos. DPR-32
DPR-37
NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
NORTH ANNA POWER STATION UNITS 1 AND 2
ASME SECTION XI and 10 CFR 50.55a INTERFACE

The NRC has issued several documents, including Generic Letter (GL) 90-05 and Generic Letter 91-18, which provide guidance for implementation of ASME Code Section XI and 10 CFR 50.55a requirements. In addition to this generic guidance, the NRC has provided several interpretations of the Code and its implementation and interface with 10 CFR 50.55a on the subject of structural integrity and operational leakage in Code Class piping. These interpretations were provided to Virginia Electric and Power Company in your letter of October 22, 1993. In certain cases, we believe this guidance and interpretations impose a backfit of regulations without a commensurate cost benefit analysis. Also, it would appear that the ASME Code Committee and the NRC differ in their interpretation of the Code requirements for structural integrity/leakage referenced in GL 91-18 as evidenced by the attached Code interpretation.

Virginia Electric and Power Company's nuclear safety policy and operating philosophy are consistent with the intent of the GL 91-18. Our assessment of degraded or nonconforming conditions is based on their safety significance and Technical Specifications requirements. Specifically, for systems, structures, and components outside the scope of Technical Specifications, engineering assessments are used to evaluate safety significance and the need for corrective actions. During the evaluation process there must be a reasonable expectation that the systems, structures, or components are and will continue to remain operable (i.e., assurance that the capability exists for the system, structure or component to perform its specified function). If reasonable assurance cannot be demonstrated that the system can

9403090094 940228
PDR ADOCK 05000280
P PDR


Adol
11/11

perform its intended function, a JCO is developed or appropriate actions to place the plant in a safe condition are taken.

In contrast, the NRC tends to require additional actions that are largely administrative and only marginal to safety because it expects verbatim compliance with the guidance in these generic letters and its Code interpretations. For example, GL 90-05 requires the provisions of the generic letter to be met and NRC approval to be granted prior to making a temporary repair. The delays required to obtain prior-to-use relief requests from the ASME Code can be inconsistent with safe and prudent operation. In addition, we believe that the existing NRC guidance results in the unnecessary submittal of numerous relief requests for low energy Class 3 systems. These submittals present an undue burden on both NRC and utility resources without a significant increase in the safe operation of the affected system.

At the regional workshops held on GL 91-18 in 1992, questions were raised and concerns identified about numerous portions of the guidance. Based on this industry feedback and subsequent interpretations by the NRC on this subject of operational leakage in Code Class piping, we believe there was inadequate resolution and communication of the fundamentals of this issue. If the existing review process for generic communications had been in place before the issuance of GLs 90-05 and 91-18, we believe that the controversy and communication deficiencies would have been resolved prior to issuance. Based on the varying interpretations and implementation of the Code requirements for operational leakage, it is appropriate for the NRC to consider rulemaking to clarify the intent of 10 CFR 50.55a and its interface with ASME Section XI as it applies to structural integrity and operational leakage.

Very truly yours,



W. L. Stewart
Senior Vice President Nuclear

Attachment

cc: U.S. Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. M. W. Branch
NRC Senior Resident Inspector
Surry Power Station

Mr. R. D. McWhorter
NRC Senior Resident Inspector
North Anna Power Station

Mr. W. T. Russell, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. F. Colvin
President and Chief Executive Officer
Nuclear Management and Resource Council
1776 Eye Street N.W.
Suite 300
Washington, D. C. 20006-3706

Mr. W. H. Rasin
Vice President and Director
Technical Division
Nuclear Management and Resource Council
1776 Eye Street N.W.
Suite 300
Washington, D. C. 20006-3706

Mr. T. E. Tipton
Vice President and Director
Operations, Management and Support Services Division
Nuclear Management and Resource Council
1776 Eye Street N.W.
Suite 300
Washington, D. C. 20006-3706

Attachment 1
ASME Code Inquiry



March 10, 1992

A. McNeill
Virginia Power
ISI/NDE Services
5000 Dominion Blvd
Glen Allen, VA 23060

Subject: Section XI, Table IWA-5210-1, IWA-5250 and IWB-3000,
IWC-3000, IWD-3000; Corrective Measures - Prior to
Continued Service (1980 Edition With the Winter 1980
Addenda, and Later Edition and Addenda Through Summer
1983 Addenda)

Item: IN92-005

Reference: Your letter dated January 9, 1992

Dear Mr. McNeill:

Our understanding of the questions in your inquiry, and our
replies are as follows:

Question (1): Does leakage identified during the conduct of a
visual (VT-2) examination performed in conjunction with a Section
XI required pressure test (Table IWA-5210-1), exceeding the
acceptance criteria of IWB-3000, IWC-3000, and IWD-3000, require
corrective measures in accordance with IWA-5250(a) prior to
continued service?

Reply (1): Yes.

Question (2): Does leakage identified during the conduct of
normal plant operation not in conjunction with a Section XI
required pressure test (Table IWA-5210-1) require corrective
measures in accordance with IWA-5250(a)?

Reply (2): No, Section XI, IWA-5250(a) does not apply during
normal plant operation.

Very truly yours,

Steve Weinman
Assistant Secretary,
Boiler & Pressure Vessel Committee
(212) 605-4720