

September 23, 1993

Docket Nos. 50-280
and 50-281

Mr. W. L. Stewart
Senior Vice President - Nuclear
Virginia Electric and Power Co.
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2 - EMERGENCY CORE COOLING SYSTEM ANALYSIS

Our review of your submittal dated April 19, 1993, relating to the above subject matter, indicates compliance with 10 CFR 50.46 Paragraph b. However, your submittal should also have included "a proposed schedule for providing a reanalysis or taking other action as may be needed to show compliance with 10 CFR 50.46 requirements" for large break loss-of-coolant accidents, per 10 CFR 50.46 paragraph a.(3).(ii).

We request that you provide a proposed schedule for submittal of your reanalysis within thirty days of the date of this letter.

Sincerely,

Bart C. Buckley

Bart C. Buckley, Sr. Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II

cc: See next page

NRC FILE CENTER COPY

Distribution

Docket File	H. Berkow
NRC & Local PDRs	B. Buckley
PDII-2 Reading	ACRS (10)
S. Varga	M. Sinkule, RII
G. Lainas	

*See previous concurrence

OFFICE	LA:PDII-2	PM:PDII-2 <i>13015</i>	SRXB	D:PDII-2	
NAME	ETana <i>ETT</i>	BBuckley:ms	RJones*	HBerkow	
DATE	09/23/93	09/23/93	09/18/93	09/23/93	

OFFICIAL RECORD COPY - DOCUMENT NAME:C:\AUTOS\WPDOCS\SURRY\ECCS.LTR

9309280344 930923
PDR ADDCK 05000280
P PDR

270039

DF01 1/0

Mr. W. L. Stewart
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:
Mr. William C. Porter, Jr.
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

Michael W. Maupin, Esq.
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Regional Administrator, RII
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Dr. W. T. Lough
Virginia State Corporation Commission
Division of Energy Regulation
P.O. Box 1197
Richmond, Virginia 23209

Mr. G. E. Kane, Manager
North Anna Power Station
P.O. Box 402
Mineral, Virginia 23117

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. M. L. Bowling, Manager
Nuclear Licensing & Programs
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
Route 2, Box 78
Mineral, Virginia 231172