

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

October 19, 1993

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 93-632
NL/RPC
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGE
RSHX SERVICE WATER OUTLET RADIATION MONITORS


Pursuant to 10 CFR 50.90, Virginia Electric and Power Company requests amendments, in the form of changes to the Technical Specifications, to Operating License Nos. DPR-32 and DPR-37 for Surry Power Station Units 1 and 2.

The proposed changes will add operability requirements, action statements, and surveillance requirements for the Recirculation Spray Heat Exchanger service water outlet radiation monitors. Also, surveillance requirements for several Post Accident Instruments are being reinstated. Attachment 1 identifies the proposed changes which are indicated by revision bars in the right margin.

The proposed changes have been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Management Safety Review Committee. It has been determined that these changes do not involve an unreviewed safety question as defined in 10 CFR 50.59. Also, as shown in Attachment 2, this submittal involves no significant hazards considerations according to 10 CFR 50.92.

Should you have any questions, please do not hesitate to contact us.

Very truly yours,



W. L. Stewart
Senior Vice President - Nuclear

Attachments

1. Proposed Technical Specification Changes
2. Discussion and Significant Hazards Consideration Evaluation

9310260051 931019
PDR ADOCK 05000280
P PDR

A001
11

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. M. W. Branch
NRC Senior Resident Inspector
Surry Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 19th day of October, 1993.

My Commission Expires: May 31, 1994.

Vicki L. Hull
Notary Public

(SEAL)

ATTACHMENT 1

**PROPOSED TECHNICAL
SPECIFICATION CHANGES**

SURRY POWER STATION