



Federal Emergency Management Agency

Washington, D.C. 20472

JUL 14 1988

MEMORANDUM FOR: Frank J. Congel
Director
Division of Radiation Protection and
Emergency Preparedness
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission

FROM: *William B. Wark, Jr.*
Richard W. Krimm
Assistant Associate Director
Office of Natural and Technological Hazards

SUBJECT: Final Exercise Report of the October 8, 1987, Exercise
of Offsite Radiological Emergency Preparedness Plans
for the Surry Power Station

Attached are two copies of the final exercise report of the October 8, 1987, exercise of offsite radiological emergency preparedness plans site-specific to the Surry Power Station. This final exercise report was prepared by the Region III office staff of the Federal Emergency Management Agency.

There was one deficiency identified as a result of this exercise due to significant delays on the part of the Director of Operations and the State Emergency Operations Center staff in approving and implementing protective action recommendations following their receipt from the emergency operations facility. In addition, there were several areas requiring corrective actions and areas recommended for improvement.

The deficiency was corrected on June 28, 1988, during the offsite radiological emergency preparedness exercise at the North Anna Nuclear Power Station. You will be provided a copy of the results of the remedial exercise as soon as it becomes available. Therefore, based on the results of the exercise and the correction of the deficiency at the North Anna exercise, the offsite radiological emergency plans and preparedness remain adequate to provide reasonable assurance that appropriate measures can be taken offsite to protect the health and safety of the public in the event of an accident at the Surry Power Station, and the 44 CFR 350 approval granted on February 23, 1983, remains in effect.

If I can be of further assistance, please let me know.

Attachment

TESS
11

8808010224 880714
PDR ADDCK 05000280
F PNU