

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. R. CARTWRIGHT  
VICE PRESIDENT  
NUCLEAR

April 6, 1989

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 89-133  
NO/ETS:vlh R1  
Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Gentlemen:


VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION UNITS 1 AND 2  
TECHNICAL SPECIFICATION CHANGE REQUEST  
INSIDE RECIRCULATION SPRAY PUMP  
INSERVICE INSPECTION AND TESTING

Pursuant to 10 CFR 50.90, Virginia Electric and Power Company requests an amendment in the form of changes to the Technical Specifications to Operating Licenses No. DPR-32 and DPR-37, for Surry Power Station Units 1 and 2. The proposed changes include modifying the requirement for dry rotation testing of the inside recirculation spray pump (IRSP) from monthly to quarterly, incorporation of full flow testing of IRSP each refueling period, and requiring a visual inspection of containment sumps each refueling and after major maintenance to verify sump component integrity and the exclusion of foreign materials. Attachment 1 provides the Technical Specification change request.

On April 11, 1988 we submitted a Technical Specification change request that reformatted several sections of our Technical Specifications to be consistent with standard Technical Specifications. Attachment 2 provides revised pages for that submittal which reflect the changes that are being requested in Attachment 1 for inside recirculation pump testing and containment sump inspections.

Attachment 3 provides a discussion of the proposed change and includes the 10 CFR 50.92 evaluation. This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question nor a significant hazards consideration.

Very truly yours,



W. R. Cartwright

Attachments

1. Proposed Technical Specification Changes
2. Proposed Technical Specification Changes - Supplemental Pages for April 11, 1988, Submittal (Serial No. 88-114)
3. Discussion of Proposed Changes

8904140442 890406  
PDR ADOCK 05000280  
P FDC

AO47  
11

cc: United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. W. E. Holland  
NRC Senior Resident Inspector  
Surry Power Station

Commissioner  
Department of Health  
Room 400  
109 Governor Street  
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA )  
 )  
COUNTY OF HENRICO )

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. R. Cartwright who is Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 6 day of April, 1989.

My Commission Expires: February 25, 1990.

Vicki L. Hull  
Notary Public



(SEAL)