

ENCLOSURE 1

NOTICE OF VIOLATION

Virginia Electric and Power Company  
Surry

Docket No. 50-280  
License No. DPR-32

During the Nuclear Regulatory Commission (NRC) inspection conducted on April 10-14, 1989 and May 10-12, 1989, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1989), the violation is listed below:

10 CFR 50.12 permits requests for exemption from specific requirements of Appendix R, Section III.G2(d) requiring redundant cables and equipment be separated by 20 horizontal feet with no intervening combustibles. An SER dated September 16, 1987 approved Exemption No. 6 which required cable tray covers to be installed on cable trays in the vicinity of the cable vault tunnel penetration area of both unit containments.

Contrary to the above, on March 10, 1989 a station deviation report was issued identifying several instances where cable tray covers had been found missing.

This is a Severity Level IV violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, Virginia Electric and Power Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include [for each violation]: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause

8906270130 890607  
PDR ADOCK 05000280  
Q PNU

Virginia Electric and Power Company 2  
Surry

Docket No. 50-280  
License No. DPR-32

why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION

original signed by  
Thomas Conlon

Caudle A. Julian, Chief  
Engineering Branch  
Division of Reactor Safety

Dated at Atlanta, Georgia  
this 7th day of June 1989