

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

December 29, 1989

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 89-868
NO/ETS
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGE
EMERGENCY DIESEL GENERATOR
LOAD SEQUENCING SURVEILLANCE

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests amendments, in the form of changes to the Technical Specifications, to Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station Units 1 and 2 respectively. This change will delineate the surveillance requirements for the Emergency Diesel Generator load sequencing modification completed earlier this year. The proposed change is included in Attachment 1.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee. It has been determined that the proposed changes do not involve an unreviewed safety question as defined in 10 CFR 50.59 or a significant hazards consideration as defined in 10 CFR 50.92. The basis for our no significant hazards consideration determination is included in Attachment 2.

Very truly yours,


W. L. Stewart
Senior Vice President - Nuclear

Attachments

1. Proposed Technical Specification Change
2. Discussion of Changes and Significant Hazards Consideration Determination

9001080076 891229
PDR ADOCK 05000280
P PDC

A001
11

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by J. L. Wilson who is Assistant Vice President - Nuclear Operations, for W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 29 day of December, 1989.

My Commission Expires: February 25, 1990.

Picki L. Hull
Notary Public

(SEAL)