

ATTACHMENT 1

NIS-2 FORMS

9003160391 900308
PDR ADOCK 05000280
Q PDC

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Virginia Power Date 11/7/89
P.O. Box 26666 (Name)
 (Address)
 Sheet 1 of 1
2. Plant Surry Power Station Unit ONE
P.O. Box 315 Surry, VA 23883 (Name)
 (Address)
3. Work Performed by VA. Power 38000.22118
 (Name) Repair Organization P.O. No., Job No., etc.
Same (Address)
4. Identification of System REACTOR COOLANT
5. (a) Applicable Construction Code B31-1 19 67 Edition, NA Addenda, Code Cases NA
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80, W80 Addenda, Code Cases NA
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
(60A) STUDS	-	-	-	-	1-RC-HCV-1556A	-	REPLACED	NO
(60A) NUTS	-	-	-	-	"	-	"	NO

7. Description of Work OVERHAUL VALVE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2325 psi Test Temp. 542 °F
9. Remarks STUD PO# 54-12147(1), NUT PO# 54-12178(4)
 (Applicable Manufacturer's Data Reports to be attached)
WORK WAS PERFORMED DURING JUNE/JULY TIME FRAME 1986 BUT THE NIS-2 WAS NOT COMPLETED AT THAT TIME.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 (Repair or replacement)
 Signed D. L. Rosen ISI Nov 7 19 89
 (Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of VA, employed by HSB I&I CO. of Hartford, CT. have inspected the Replacement described in this Report on 11-9, 1989
 (Repairs or Replacements)
 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 11-9-89 Robert L. Cohen Commissions NB7009 VA543
 (Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Virginia Power Date 10/31/89
P.O. Box 26666 (Name) Sheet 1 of 1
 (Address)
2. Plant Surry Power Station Unit 1
P.O. Box 315 Surry, VA 23883 (Name)
 (Address)
3. Work Performed by VA Power 38000 35284
Same (Name) Repair Organization P.O. No., Job No., etc.
 (Address)
4. Identification of System Residual Capacity
5. (a) Applicable Construction Code B31-1 19 67 Edition, NA Addenda, Code Cases NA
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80, W80 Addenda, Code Cases NA
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfr. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>STUDS & NUTS</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>1-RC-SU-1851C</u>	<u>-</u>	<u>REPLACED</u>	<u>NO</u>

7. Description of Work OVERHAUL AND TEST VALVE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2225 psi Test Temp. 547 °F
9. Remarks STUDS PO# 54171400 NUTS PO# 5417172(3)
WORK WAS PERFORMED DURING JUNE-JULY SHUTDOWNS 1986 BUT
THE NIS-2 FORM WAS NOT COMPLETED AT THAT TIME.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code (repair or replacement)

Signed David L. Rozen ISI 31 Oct. 19 89
 (Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of VA, employed by HSB I&I CO. of Hartford, CT. have inspected the Replacement described in this Report on 10-31, 19 89 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10-31-89 Robert F. Corbin Commissions NB7009 Va 543
 (Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.