

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

May 22, 1990

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 90-114
NO/
Docket No. 50-280
50-281
License No. DPR-32
DPR-37


Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATION
PRESSURIZER SAFETY VALVES

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests amendments, in the form of changes to the Technical Specifications, to Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station Units 1 and 2, respectively. This change deletes the requirement to have one pressurizer safety valve operable whenever the head is on the reactor vessel and reactor coolant average temperature is below 350°F. At low temperatures (below 350°F) overpressure protection is provided by the low temperature overpressure protection system. In addition, a typographical error is being corrected for the Containment High-High actuation setpoint and the associated basis. The proposed Technical Specification changes are included in Attachment 1.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee. It has been determined that the proposed changes do not involve an unreviewed safety question as defined in 10 CFR 50.59 or a significant hazards consideration as defined in 10 CFR 50.92. The basis for our determination of no significant hazard is included in Attachment 2.

Very truly yours,



W. L. Stewart
Senior Vice President - Nuclear

Attachments

1. Proposed Technical Specification Change
2. Significant Hazards Consideration

9005290099 900522
PDR - ADOCK 05000280
P FDC

Adol
11

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30323

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 22 day of May, 1990.

My Commission Expires: May 31, 1994.

Vicki L. Nuce
Notary Public

(SEAL)