

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

May 25, 1990

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 90-297
NO/ETS
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
EXPLOSIVE GAS CONCENTRATION
TECHNICAL SPECIFICATION CHANGE REQUEST

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment, in the form of a change to the Technical Specifications, to Operating Licenses No. DPR-32 and DPR-37 for Surry Power Station Units 1 and 2, respectively. We are requesting that the requirements for explosive gas concentration be modified to conform to the applicable section of NUREG-0472, Section 3.11.2.5.B. The requested Technical Specification change is provided in Attachment 1.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee. It has been determined that the proposed Technical Specification change does not involve an unreviewed safety question as defined in 10 CFR 50.59 or a significant hazards consideration as defined in 10 CFR 50.92. The basis for our no significant hazards consideration determination is included in Attachment 2.

Should you have any additional questions, please call.

Very truly yours,



W. L. Stewart
Senior Vice President - Nuclear

Attachments

1. Proposed Technical Specification Change
2. Discussion of Proposed Change and Significant Hazards Consideration

9006010256 900525
PDR ADOCK 05000280
P FDC

A001
111

cc:
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 25 day of May, 1990.

My Commission Expires: May 31, 1994.

Vicki L. Hulse
Notary Public

(SEAL)