

DOCKET FILE



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
July 9, 1990

Docket Nos. 50-280
and 50-281

LICENSEE: Virginia Electric and Power Company
FACILITIES: Surry Power Station, Units 1 & 2
SUBJECT: MEETING SUMMARY OF JUNE 28, 1990

A meeting was held with representatives of Virginia Electric and Power Company (VEPCO) in Rockville, Maryland on June 28, 1990. The purpose of the meeting was to discuss planned modifications to the component cooling water (CCW) piping to mitigate the consequences of a reactor coolant pump thermal barrier tube leak. The meeting handout and a list of attendees are enclosed.

VEPCO representatives discussed various design options they had evaluated, and concluded that, based on long-term maintenance, ALARA, and cost considerations the modifications as shown on Figure 2 of the meeting handout was the most practical approach to resolve this concern. The current CCW piping configuration is shown on Figure 1 of the handout. The section of piping of interest consists of two high pressure check valves to prevent backflow, a safety valve set at 2500 psig located upstream of the reactor coolant pump and an isolation valve that will automatically close should the normal CCW flowrate of 40 gallons per minute (gpm) increase to 50 gpm. Other means are available in the CCW System, such as CCW temperature and radiation monitors to alert plant personnel of thermal barrier leakage.

The proposed changes as shown on Figure 2 consist of replacing the existing containment isolation valve located outside containment with a 1500 lb. valve and installing another 1500 lb. containment isolation valve and a local, manually operated 1500 lb. block valve inside containment. In addition to the two aforementioned automatic containment isolation valves closing on containment hi-hi pressure, they will also close on a high CCW flowrate signal. The emergency operating procedures will be revised to address this accident scenario. In response to NRC staff questions the licensee will inform the NRC how they will address post-LOCA thermal expansion between the two new automatic containment isolation valves which has the potential to result in unacceptably high pressures between these two closed valves. VEPCO was also asked to advise the NRC staff if the two new containment isolation valves and associated new piping are being designed to current regulatory requirements or to the original plant licensing basis. Because of long lead times associated with the procurement of the new valves and instrumentation, these modifications will not be completed until the Cycle 11 refueling outage, currently scheduled for the first quarter of 1992.

9007130071 900709
PDR ADOCK 05000280
P PDC

DF01
11

Memo
efw

The NRC staff agreed that VEPCO's design approach and implementation schedule appeared reasonable.

Original signed by

Bart C. Buckley, Project Manager
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. List of Attendees
- 2. Meeting Handout

cc w/enclosures:
See next page

~~DISTRIBUTION~~
DISTRIBUTION

Docket File
 NRC & Local PDRs
 PD22 Reading
 F. Miraglia 12/G/18
 J. Partlow 12/G/18
 S. Varga
 G. Lainas
 H. Berkow
 B. Buckley
 G. Belisle RII
 J. Pulsipher 8/D/1
 B. LeFave 8/D/1
 OGC
 E. Jordan MNBB-3302
 ACRS (10)
 R. Borchardt 17G21
 D. Miller

OFC	:LA:PDII-2	:PM:PDII-2	:D:PDII-2	:	:	:
NAME	:DMiller	:BBuckley	:HBerkow	:	:	:
DATE	:07/6/90	:07/6/90	:07/9/90	:	:	:

Virginia Electric and Power Company

Surry Power Station

cc:

Michael W. Maupin, Esq.
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23212

Mr. Michael R. Kansler, Manager
Surry Power Station
Post Office Box 315
Surry, Virginia 23883

Senior Resident Inspector
Surry Power Station
U.S. Nuclear Regulatory Commission
Post Office Box 166, Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Mr. W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
Post Office Box 1197
Richmond, Virginia 23209

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

C. M. G. BATTERY, M.D., M.P.H.
Department of Health
109 Governor Street
Richmond, Virginia 23219

Mr. W. L. Stewart
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Mr. E. Wayne Harrell
Vice President - Nuclear Operations
Virginia Electric and Power Company
5000 Old Dominion Blvd.
Glen Allen, Virginia 23060

Mr. J. P. O'Hanlon
Vice President - Nuclear Services
Virginia Electric and Power Company
5000 Old Dominion Blvd.
Glen Allen, Virginia 23060

Mr. R. F. Saunders
Manager - Nuclear Licensing
Virginia Electric and Power Company
5000 Old Dominion Blvd.
Glen Allen, Virginia 23060

Enclosure 1

MEETING WITH SURRY AND NRC STAFF
REGARDING COMPONENT COOLING WATER (CCW)

June 28, 1990

NRC

B. Buckley
G. Belisle (RII)
J. Pulsipher
B. LeFave

VEPCO

D. Sommers
B. Benthall
E. Grecheck
G. Nash
T. Shaub

VIRGINIA POWER



**COMPONENT COOLING
THERMAL BARRIER MEETING
JUNE 28, 1990**

PROPOSED MODIFICATION AND BASIS

- **SIX OPTIONS INVESTIGATED**
 - **MITIGATION OF EVENT**
 - **MAINTAIN REACTOR COOLANT WITHIN CONFINES OF CONTAINMENT**
 - **ALARA CONSIDERATIONS - INSTALLATION/MAINTENANCE**
 - **COSTS**

PROPOSED MODIFICATION AND BASIS

- **SELECTED OPTION**
 - **NONSAFETY TRIP VALVE**
 - **ANALYZED PIPING**
 - **REDUNDANT SAFETY-RELATED TRIP VALVES AT CONTAINMENT PENETRATION**
- **BASIS FOR SELECTED OPTION**
 - **CONTAINMENT ISOLATION ARRANGEMENT**
 - **INSTRUMENT LOOP DESIGN**
 - **PIPING DESIGN**

CURRENT SYSTEM CONFIGURATION

- **RCP THERMAL BARRIER UPSTREAM CC SYSTEM DESIGN**
- **RCP THERMAL BARRIER DOWNSTREAM CC SYSTEM DESIGN**
- **ADMINISTRATIVE**
 - **PERIODIC TESTING**
 - **PROCEDURES**

IMPLEMENTATION SCHEDULES

- **DESIGN CHANGE PACKAGES**
- **DELIVERY OF ENGINEERED EQUIPMENT**
- **INSTALLATION**




FIGURE 1

FIGURE 2

