

July 25, 1990

Docket Nos. 50-280
and 50-281

DISTRIBUTION
See attached list

Mr. W. L. Stewart
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: SURRY, UNITS 1 AND 2 - NRC BULLETIN 88-04, "POTENTIAL SAFETY-RELATED PUMP LOSS" (TAC Nos. 69979 AND 69980)

By letters dated July 11 and August 8, 1988, July 28, 1989 and June 18, 1990, you responded to NRC Bulletin 88-04, "Potential Safety-Related Pump Loss," for the Surry Power Station, Units 1 and 2. Your response of June 18, 1990, confirmed that the long-term actions associated with the issues in the bulletin (disassembly and inspection of one auxiliary feedwater (AFW) pump in each unit and the installation of larger minimum recirculation lines on all AFW pumps) will be completed during the end of the Cycle 10 outage for both units. We understand that your present schedule for completion of the end-of-Cycle 10 outages is the fourth quarter of 1990 (Unit 1) and the second quarter of 1991 (Unit 2). In accordance with the bulletin, a written response describing the actions taken will be submitted to the NRC within 30 days of completion of the long-term actions. You are reminded that an evaluation of your actions in response to this bulletin should be documented and maintained at the station for a minimum of 2 years.

Accordingly, your responses have addressed the issues in the bulletin, and we are closing the subject TAC numbers. Further NRC review, if any, will be by future auditing.

Sincerely,

[Original signed by]

Bart C. Buckley, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

LA: PDII-2
DMS:ler
07/25/90

BCB
PM: PDII-2
BBuckley: cp
07/25/90

PM: PDIV-3
TAL: [signature]
07/15/90

D: PDII-2
H: Berlow
07/25/90

10
[signature]
DF04

9008010143 900725
PDR ADOCK 05000280
Q FDC

DISTRIBUTION:

Docket File
NRC & LPDRs
PD22 Rdg File
SVarga 14/E/4
GLainas 14/H/3
HBerkow
BBuckley
DMiller
EJordan MNBB-3302
OGC
ACRS(10)
MSinkule RII
TAlexion 11/D/23