

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

November 13, 1990

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 89-436A
NO/RFB R0
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:


VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
SUPPLEMENTAL RESPONSE TO NRC NOTICE OF VIOLATION
INSPECTION REPORT NO. 50-280, -281/89-12

In response to a violation cited in Inspection Report No. 89-12, we committed (in letter Serial No. 89-436 dated July 6, 1989) to marking cable trays to indicate whether covers were required. This method of identifying required cable tray cover locations was intended to serve as a backup to station drawings, specifications, and procedures, which were also revised in response to this violation. Cable tray marking has been completed with the exception of Unit 1 cable trays in containment.

Marking of Unit 1 cable trays had initially been planned to be completed during the Cycle 10 refueling outage. Due to the significant amount of work currently scheduled for this outage, we intend to modify the schedule for completion of this activity to more efficiently apply resources. Where scaffolding has been or will be erected for other work or where the cable trays are safely accessible by ladders, we intend to complete marking of those cable trays. Cable tray marking not completed during this outage will be rescheduled for future refueling outages. During the outage, surveillance is routinely scheduled to be performed to verify that the required cable tray covers are properly installed.

If you have any further questions, please contact us.

Very truly yours,


W. L. Stewart
Senior Vice President - Nuclear

9011190124 901113
PDR ADDOCK 05000280
PDC

IF 01
/10

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station