

December 12, 1990

Docket Nos. 50-280
and 50-281

DISTRIBUTION

~~Docket File~~
NRC & Local PDR
PD22 Rdg
SVarga
GLainas
BBuckley
RScholl
DMiller
OGC
EJordan
HBerkow

ACRS (10)
MSinkule,RII

Mr. W. L. Stewart
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT SURRY UNITS 1 AND 2

On April 25, 1990 the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated July 6, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at Surry Units 1 and 2. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

Original signed by

Bart C. Buckley, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

OFC	: LA:PD22	: PM:PD22	: D:PD22	:	:
NAME	: DMiller	: BBuckley	: HBerkow	:	:
DATE	: 11/9/90	: 12/11/90	: 12/12/90	:	:

OFFICIAL RECORD COPY
Document Name: SURRY GSI LETTER

9012140125 901212
PDR ADOCK 05000280
PDC

DF03

Mr. W. L. Stewart
Virginia Electric and Power Company

Surry Power Station

cc:

Michael W. Maupin, Esq.
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23212

Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Mr. Michael R. Kansler, Manager
Surry Power Station
Post Office Box 315
Surry, Virginia 23883

Mr. E. Wayne Harrell
Vice President - Nuclear Operations
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Senior Resident Inspector
Surry Power Station
U.S. Nuclear Regulatory Commission
Post Office Box 166, Route 1
Surry, Virginia 23883

Mr. J. P. O'Hanlon
Vice President - Nuclear Services
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Mr. R. F. Saunders
Manager - Nuclear Licensing
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
Post Office Box 1197
Richmond, Virginia 23209

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

C. M. G. Buttery, M.D., M.P.H.
Department of Health
109 Governor Street
Richmond, Virginia 23219

ENCLOSURE

UNIMPLEMENTED GSIs AT SURRY UNITS 1 AND 2

<u>GSi NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
51	Improving the Reliability of Open-Cycle Service Water Systems	12/93-Unit 1 2/93-Unit 2	
67.3.3	Improved Accident Monitoring	06/04/91 - Unit 1* 06/04/91 - Unit 2	
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	09/30/91**	
99	RCS/RHR Suction Line Valve Interlock on PWRs	06/91 - Unit 2 only	

*The licensee recently verbally informed the NRC staff of a delay in the completion of this issue on Unit 1. The original projected completion date was 12/90. The delay is due to difficulty in procuring the special fiber optic material necessary for implementation of the required instrumentation. The licensee expects to complete this issue no later than the Unit 2 scheduled completion date of 6/91.

**The only remaining open item is the upgrading of administrative procedures which are scheduled to be completed by 9/30/91.