

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

April 8, 1993

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 93-034  
NL&P/ETS  
Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Gentlemen:


**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNITS 1 AND 2**  
**COMPUTER PROGRAMS FOR PIPE STRESS ANALYSIS**

Surry Units 1 and 2 used the NUPIPE computer code to complete the reanalysis of safety-related piping pursuant to NRC Bulletin 79-14. Use of the NUPIPE computer code for pipe stress analysis was approved for Units 1 and 2 in NRC Safety Evaluation Reports, dated August 22, 1979 and March 26, 1980, respectively. Since that time, the NUPIPE computer code has been used as the analysis of record for all safety-related piping analysis.

With the recent advancement in the capabilities of personal computers (PC), numerous PC-based pipe stress analysis programs are available as alternatives to main-frame computation using NUPIPE. These alternatives provide greater flexibility and an enhanced response capability for engineering to support operational requirements. In addition, pipe stress analysis is considerably less expensive when performed with a PC-based program. Therefore pursuant to 10 CFR 50.59, Virginia Electric and Power Company intends to use PC-based pipe stress analysis programs for future modifications or reanalysis of safety-related piping systems at Surry Units 1 and 2.

Prior to using any computer program other than NUPIPE as the analysis of record, the program will be verified in accordance with our software control program. In addition, a safety evaluation will be performed for each new computer code to be used. The UFSAR will be revised accordingly to reflect the use and acceptability of each new computer pipe stress analysis program.

Very truly yours,



W. L. Stewart  
Senior Vice President - Nuclear

9304150049 930408  
PDR ADDCK 05000280  
P PDR

*Accol  
4/10*

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. M. W. Branch  
NRC Senior Resident Inspector  
Surry Power Station