

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

July 16, 1993

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 93-437
NO/ETS
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGES
SERVICE WATER TEMPERATURE LIMIT

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests changes to the Technical Specifications for Operating License Nos. DPR-32 and DPR-37, Surry Power Station Units 1 and 2, respectively. The proposed changes will permit operation with a three degree increase in the service water temperature limit for containment air partial pressures of 9.1, 9.2, and 9.35 psia. The proposed changes are included in Attachment 1.

The proposed changes have been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Management Safety Review Committee. It has been determined that the proposed changes do not involve an unreviewed safety question as defined in 10 CFR 50.59, or create a significant hazards consideration as defined in 10 CFR 50.92. A discussion of the changes and the basis for our no significant hazards consideration determination are included in Attachment 2.

If you have any questions or require additional information, please contact us.

Very truly yours,



for W. L. Stewart
Senior Vice President - Nuclear

Attachments

1. Proposed Technical Specification
2. Discussion and Significant Hazards Consideration

9307230230 930716
PDR - ADCK 05000280
P PDR

ADD 1/1

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. M. W. Branch
NRC Senior Resident Inspector
Surry Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by J. P. O'Hanlon who is Vice President - Nuclear Operations, for W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 16TH day of July, 1993.
My Commission Expires: May 31, 1994.


Notary Public

(SEAL)