

IPEC EMERGENCY PLAN DISTRIBUTION LIST

LOCATION	COPY HOLDER	ADDRESS	NUMBER OF COPIES
IP3 CONTROL ROOM	DELIVERED BY DOCUMENTS	IP3 53FT. CCR	1 COPY OF ALL EP'S
IP3 SHIFT MANAGER	DELIVERED BY DOCUMENTS	IP3 53FT. ELEVATION	1 COPY OF ALL EP'S
IP2 CONTROL ROOM	DELIVERED BY DOCUMENTS	IP2 53FT. CCR	1 COPY OF ALL EP'S
IPEC TSC	DELIVERED BY DOCUMENTS	IP2 53FT. ELEVATION	1 COPY OF ALL EP'S
IP2 SIMULATOR	DELIVERED BY DOCUMENTS	IP2 SIMULATOR BLDG.	1 COPY OF ALL EP'S
IP2 SIMULATOR - CLASSROOM 4	DELIVERED BY DOCUMENTS	IP2 SIMULATOR BLDG.	1 COPY OF ALL EP'S
IP2 SIMULATOR - CLASSROOM 5	DELIVERED BY DOCUMENTS	IP2 SIMULATOR BLDG.	3 COPIES OF ALL EP'S EXCEPT E-PLAN
NRC RESIDENT INSPECTOR	NRC	IP2 88FT. ELEVATION	1 COPY OF ALL EP'S
DOC CONTROL DESK	NRC - ROCKVILLE, MD ADDRESS	OFFSITE	1 COPY OF ALL EP'S AND GENERAL RECORDS EXCEPT IP-EP-115
NRC	JAMES DANNA	OFFSITE	1 COPY OF ALL EP'S AND GENERAL RECORDS EXCEPT IP-EP-115
NRC	DEPUTY DIRECTOR	OFFSITE	1 COPY OF ALL EP'S AND GENERAL RECORDS EXCEPT IP-EP-115
NEW YORK STATE OEM	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <p style="text-align: center;">EFFECTIVE TED FISCH MAY 30 2013 DATE</p> </div>	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <p style="text-align: center;">LENORE TO UPDATE WEBSITE NO MAIL COPIES</p> </div>	1 COPY OF THE FOLLOWING: E-PLAN , IP-EP-115, 120, 210, 220, 230, 250, 310, 320, 340, 360, 410, 420, 430, 620 & IP-1055
WESTCHESTER COUNTY OEM	DENNIS DELBORGO	OFFSITE	1 COPY OF E-PLAN, IP-EP-310 & 340
ROCKLAND COUNTY FIRE AND EMERGENCY SERVICES	NICHOLAS LONGO	OFFSITE	1 COPY OF E-PLAN, IP-EP-310 & 340
ORANGE COUNTY EMERGENCY SERVICES CENTER	SHANNON FISHER	OFFSITE	1 COPY OF E-PLAN, IP-EP-310 & 340
PUTNAM COUNTY BUREAU OF EMERGENCY SERVICES	KEN CLAIR	OFFSITE	1 COPY OF E-PLAN, IP-EP-310 & 340

*THE FOLLOWING LOCATIONS ARE *ELECTRONIC DISTRIBUTIONS*

AX45
NRR



Entergy

Indian Point Energy Center
Document Control
450 Broadway
Buchanan, NY 10511

CONTROLLED DOCUMENT TRANSMITTAL

TO: DISTRIBUTION

DATE: May 24, 2018

FROM: IPEC DOCUMENT CONTROL -- 3RD FLOOR ADMIN BLDG

PHONE #: 914-254-6835

TRANSMITTAL #: **EP-18-0016**

The Document(s) identified below are forwarded for use. Please review to verify receipt, incorporate the document(s) into your controlled document file, properly disposition superseded, voided, or inactive document(s).

Sign and return the receipt acknowledgement below within ten (10) working days.

AFFECTED DOCUMENT: **IPEC EMERGENCY PLAN PROCEDURES**

DOC #	REV #	TITLE	INSTRUCTIONS
-------	-------	-------	--------------

THE FOLLOWING PROCEDURE IS BEING "VOIDED", PLEASE REMOVE FROM YOUR BOOKS:

IP-1055 REV.18

EFFECTIVE
MAY 30 2018
DATE

RECEIPT OF THE ABOVE LISTED DOCUMENT(S) IS HEREBY ACKNOWLEDGED. I CERTIFY THAT ALL SUPERSEDED, VOID, OR INACTIVE COPIES OF THE ABOVE LISTED DOCUMENT(S) IN MY POSSESSION HAVE BEEN REMOVED FROM USE AND ALL UPDATES HAVE BEEN PERFORMED IN ACCORDANCE WITH EFFECTIVE DATE(S) (IF APPLICABLE) AS SHOWN ON THE DOCUMENT(S).

Doc Control Dept

NAME (PRINT)

SIGNATURE

DATE

COPY LOCATION

Procedure/Document Number:	IP-1055	Revision:	18
Equipment/Facility/Other: IPEC			
Title: Fire Emergency Response			

Part I. Description of Activity Being Reviewed (event or action, or series of actions that have the potential to affect the emergency plan or have the potential to affect the implementation of the emergency plan):

- Procedure being revised due to QA CR, CR-IP2-2018-02682.
- Added new date for approval - Revision 17 had an approval date of 6/29/1 on the front cover page. Revised the cover page to include a correct date.
- Replaced IP-SMM-DC-001 "IPEC Fire Protection Program Plan" with SEP-FPP-IP-001 "IPEC Fire Protection Program Plan".
- Replaced IP-EP-115 Form EP-6 "Emergency Exposure Authorization" with EP-4-ALL "Exposure Authorization Form"
- Replaced IP-EP-115 Form EP 29 "Individuals Exposure Tracking Log" with EP-6-ALL "Team Tracking Form".
- Reference procedures were moved to interface procedures. This better aligns the procedures' functions.
- 10CFR20 was removed from interface procedures, since this is only a reference procedure.

Part II. Emergency Plan Sections Reviewed (List all emergency plan sections that were reviewed for this activity by number and title. IF THE ACTIVITY IN ITS ENTIRETY IS AN EMERGENCY PLAN CHANGE OR EAL OR EAL BASIS CHANGE, ENTER THE SCREENING PROCESS. NO 10 CFR 50.54(q)(2) DOCUMENTATION IS REQUIRED.

Part II Section A: Assignment of Responsibility

Part II Section B: Station Emergency Response Organization

Part II Section D: Emergency Classification System

Part II Section E: Notification Methods and Procedures

Part II Section H: Emergency Facilities and Equipment

Part II Section K: Radiological Exposure Control

Part II Section L: Medical and Public Health Support

Procedure/Document Number:	IP-1055	Revision:	18
Equipment/Facility/Other: IPEC			
Title: Fire Emergency Response			

Part III. Ability to Maintain the Emergency Plan (Answer the following questions related to impact on the ability to maintain the emergency plan):

1. Do any elements of the activity change information contained in the emergency plan (procedure section 3.0(6))?
YES NO IF YES, enter screening process for that element
2. Do any elements of the activity change an emergency classification Initiating Condition, Emergency Action Level (EAL), associated EAL note or associated EAL basis information or their underlying calculations or assumptions?
YES NO IF YES, enter screening process for that element
3. Do any elements of the activity change the process or capability for alerting and notifying the public as described in the FEMA-approved Alert and Notification System design report?
YES NO IF YES, enter screening process for that element
4. Do any elements of the activity change the Evacuation Time Estimate results or documentation?
YES NO IF YES, enter screening process for that element
5. Do any elements of the activity change the Onshift Staffing Analysis results or documentation?
YES NO IF YES, enter screening process for that element

Part IV. Maintaining the Emergency Plan Conclusion The questions in Part II do not represent the sum total of all conditions that may cause a change to or impact the ability to maintain the emergency plan. Originator and reviewer signatures in Part IV document that a review of all elements of the proposed change have been considered for their impact on the ability to maintain the emergency plan and their potential to change the emergency plan.

1. Provide a brief conclusion that describes how the conditions as described in the emergency plan are maintained with this activity.
2. Check the box below when the 10 CFR 50.54(q)(2) review completes all actions for all elements of the activity – no 10 CFR 50.54(q)(3) screening or evaluation is required for any element. Otherwise, leave the checkbox blank.
 I have completed a review of this activity in accordance with 10 CFR 50.54(q)(2) and determined that the effectiveness of the emergency plan is maintained. This activity does not make any changes to the emergency plan. No further actions are required to screen or evaluate this activity under 10 CFR 50.54(q)(3).

All changes are considered editorial in nature. The form changes were previously reviewed under a separate 50.54Q review. A review of this activity in accordance with 10 CFR 50.54(q)(2) has been completed and determined that the effectiveness of the emergency plan and the intent of the procedure is maintained. This activity does not make any changes to the IPEC Emergency Plan. No further actions are required to screen or evaluate this activity under 10 CFR 50.54(q)(3).

Procedure/Document Number:	IP-1055	Revision:	18
Equipment/Facility/Other: IPEC			
Title: Fire Emergency Response			

Part V. Signatures:		
Preparer Name (Print) Rebecca A. Martin Sr. EP Project Manager	Preparer Signature <i>Rebecca A. Martin</i>	Date: 5/23/18
(Optional) Reviewer Name (Print)	Reviewer Signature	Date:
Reviewer Name (Print) Timothy F. Garvey Nuclear EP Project Manager	Reviewer Signature	Date:
Reviewer Name (Print) Frank J. Mitchell Manager, Emergency Planning or designee	Reviewer Signature	Date:

Procedure/Document Number:	IP-1055	Revision:	18
Equipment/Facility/Other: IPEC			
Title: Fire Emergency Response			

Part V. Signatures:		
Preparer Name (Print) Rebecca A. Martin Sr. EP Project Manager	Preparer Signature <i>Rebecca A Martin</i>	Date: 5/23/18
(Optional) Reviewer Name (Print)	Reviewer Signature	Date:
Reviewer Name (Print) Timothy F. Garvey Nuclear EP Project Manager	Reviewer Signature <i>Tim Garvey</i>	Date: 5/24/18
Reviewer Name (Print) Frank J. Mitchell Manager, Emergency Planning or designee	Reviewer Signature <i>Frank Mitchell</i>	Date: 5/29/18

**IPEC IMPLEMENTING PROCEDURE
PREPARATION, REVIEW, AND APPROVAL**

IP-SMM-AD-102 Rev: 15

Page 35 of 43

ATTACHMENT 10.2

IPEC PROCEDURE REVIEW AND APPROVAL

Procedure Title: Fire Emergency Response

Procedure No. IP-1055 Existing Rev: 17 New Rev: 18 DRN/EC No: DRN-18-0680

Procedure Activity (MARK Applicable)	<input type="checkbox"/> Converted To IPEC, Replaces:	Temporary Procedure Change (MARK Applicable)
<input type="checkbox"/> NEW PROCEDURE <input type="checkbox"/> GENERAL REVISION <input type="checkbox"/> PARTIAL REVISION <input checked="" type="checkbox"/> EDITORIAL REVISION <input type="checkbox"/> VOID PROCEDURE <input type="checkbox"/> SUPERSEDED	Unit 1 Procedure No. _____ Unit 2 Procedure No: _____ Unit 3 Procedure No: _____	<input type="checkbox"/> EDITORIAL Temporary Procedure Change <input type="checkbox"/> ADVANCE Temporary Procedure Change <input type="checkbox"/> CONDITIONAL Temporary Procedure Change Terminating Condition: _____ _____
<input type="checkbox"/> RAPID REVISION	Document in Microsoft Word: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> VOID DRN/TPC No(s): _____

Revision Summary Editorial changes made. Updated approval date. Updated procedures/forms that were superseded procedures, moved reference procedures to interface procedures.

Implementation Requirements

Implementation Plan? Yes No Formal Training? Yes No Special Handling? Yes No

RPO Dept: Emergency Planning Writer: (Print Name/Ext/Sign): Rebecca A. Martin / x7106 / *Rebecca A. Martin*

Review and Approval (Per Attachment 10.1, IPEC Review And Approval Requirements)

1. Technical Reviewer: _____
(Print Name/ Signature/ Date)

2. Cross-Disciplinary Reviewers:
 Dept: _____ Reviewer: _____
 Print Name/ Signature/ Date)
 Dept: _____ Reviewer: _____
 Print Name/ Signature/ Date)

3. RPO- Responsibilities/Checklist: Frank Mitchell / *Frank Mitchell 5/23/18*
 (Print Name/ Signature/ Date)

- PAD required and is complete (PAD Approver and Reviewer qualifications have been verified)
- Previous exclusion from further LI-100 Review is still valid
- PAD not required due to type of change as defined in 4.6


4. Non-Intent Determination Complete: _____
 (Print Name/ Signature/ Date)

- NO change of purpose or scope
- NO reduction in the level of nuclear safety
- NO voiding or canceling of a procedure, unless requirements are incorporated into another procedure or the need for the procedure was eliminated
- NO change to less restrictive acceptance criteria
- NO change to steps previously identified as commitment steps
- NO deviation from the Quality Assurance Program Manual
- NO change that may result in deviations from Technical Specifications, FSAR, plant design requirements,

5. On-Shift Shift Manager/CRS: _____
 (Print Name/ Signature/ Date)

6. User Validation: User: _____ Validator: _____

7. Special Handling Requirements Understood: _____
 (Print Name/ Signature/ Date)

 IPEC EMERGENCY PLAN ADMINISTRATIVE PROCEDURES	NON-QUALITY RELATED PROCEDURE	IP-EP-AD2	Revision 10
	REFERENCE USE	Page 1	of 1

Attachment 9.1

Emergency Planning Document Change Checklist Form

(All sections must be completed, N/A or place a check on the line where applicable)

Section 1

Doc/Procedure Type:	Administrative <input type="checkbox"/> Implementing <input checked="" type="checkbox"/> EPLAN <input type="checkbox"/> N/A <input type="checkbox"/>
Doc/Procedure No:	IP-1055
Doc/Procedure Title:	Fire Emergency Response
Corrective Action:	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/> CR#: <u>CR-2-18-2682</u>

Section 2

Change Description

1. Ensure the following are completed, or are not applicable and are so marked:
 - a. 50.54q N/A
 - b. EN-FAP-OM-023 N/A
 - c. IP-SMM- AD-102 N/A
 - d. OSRC N/A

2. Transmittals are completed: N/A Date: _____

3. Ensure the proper revision is active in Merlin: N/A


4. Approved doc/procedure delivered to Doc. Control for distribution: N/A Date: _____

5. Position Binders updated: N/A Date: _____

6. Copy of EPDCC placed in EP file: N/A Date: _____

7. Supporting documentation is submitted as a general record in MERLIN: N/A Date: _____

8. Word files are moved from working drafts folder to current revision folder in the EP drive: N/A Date: _____

 IPEC EMERGENCY PLAN IMPLEMENTING PROCEDURES	NON-QUALITY RELATED PROCEDURE REFERENCE USE	IP-1055 Revision 18 Page 1 of 9
---	--	--

Fire Emergency Response

Prepared by:

Rebecca A. Martin
Print Name

Rebecca A Martin
Signature

5/23/18
Date

Approval:

Frank J. Mitchell
Print Name

FL Mitchell
Signature

5/23/18
Date

Effective Date: May 30, 2018

This procedure is controlled document. All changes must be approved.



Entergy

**IPEC
EMERGENCY PLAN
IMPLEMENTING
PROCEDURES**

**NON-QUALITY RELATED
PROCEDURE**

REFERENCE USE

IP-1055

Revision 18

Page

2

of

9

Table of Contents

1.0 PURPOSE3

2.0 REFERENCES3

3.0 DEFINITIONS3

4.0 RESPONSIBILITIES4

5.0 DETAILS4

6.0 INTERFACES6

7.0 RECORDS6

8.0 REQUIREMENTS AND COMMITMENT6

9.0 ATTACHMENTS6

 9.1 WATCH RP FIRE RESPONSE7

 9.2 SECURITY FIRE RESPONSE.....9



Fire Emergency Response

1.0 PURPOSE

This procedure describes the actions to be taken by personnel who respond to a fire emergency at Indian Point Energy Center (IPEC). This procedure shall also be followed during normal plant operations and when a fire exists in the Radiological Controlled Area (RCA).

2.0 REFERENCES

- 2.1 IP-EP-AD13 IPEC Emergency Action Level Technical Bases
- 2.2 SEP-FPP-IP-001, "IPEC Fire Protection Program Plan"
- 2.3 2-ONOP-FP-001, "Plant Fires"
- 2.4 3-ONOP-FP-1, "Plant Fires"
- 2.5 10CFR20

3.0 DEFINITIONS

- 3.1 Contamination – Radioactive material where it's not wanted
- 3.2 Control Room Operator – Licensed individual in control room operations
- 3.3 Decon – process to remove contamination from a person or piece of equipment
- 3.4 Dosimeter – Equipment used to measure radiation and provide the wearer with a reading of accumulated exposure.
- 3.5 Emergency Telephone Directory – IPEC telephone directory for emergency numbers and Emergency Response Organization; this is located on the Emergency Planning website.
- 3.6 Radiation Protection Technician – Trained individual in radiation protection and detection
- 3.7 NPO – Nuclear Plant Operator – non-licensed operator in the plant
- 3.8 Shift Manger – Licensed operator in charge of plant operations
- 3.9 DLR – Permanent record of an individual's radiation exposure



4.0 RESPONSIBILITIES

- 4.1 When a fire is discovered, all personnel are responsible for notifying the Control Room (CR). Notification of a fire should be made using emergency phone extensions **5911** for both Unit 2 and Unit 3, and should include the caller's name along with the location and nature of the fire.
- 4.2 In accordance with 2-ONOP-FP-001, "Plant Fire" and 3-ONOP-FP-1, "Plant Fires", the CR is responsible for making the required notifications and sounding the fire alarm.
- 4.3 The CR is responsible for determining activation of the Emergency Plan as per the Emergency Action Levels (EALs) found in IP-EP-AD-13, "IPEC Emergency Action Level Technical Bases".
- 4.4 The Shift Manager (SM) or Emergency Director (ED) is authorized to allow fire fighters to exceed 10CFR20 limits. Exposure Authorization Form (EP-4-ALL) shall be used.
- 4.5 "Emergency Use of Potassium Iodine (KI)", the SM or ED determines the need to issue potassium iodine (KI) tablets by discussions with Radiological Coordinator or Radiological Assessment Coordinator.
- 4.6 In accordance with "Site Fire Protection" and "Fire Emergency" the Site Fire Brigade is responsible for responding to any fire emergency at IPEC and for requesting offsite fire fighting assistance, if needed. Requests for offsite assistance are made via the Unit 2 Control Room.
- 4.7 In accordance with the appropriate procedures, Security is responsible for directing site personnel and offsite fire assistance, and evacuating unnecessary personnel from the fire area.
- 4.8 In accordance with this procedure, the Watch Radiation Protection Technician/designee is responsible for responding to any fire in the Radiological Controlled Area (RCA).

5.0 DETAILS

- 5.1 When requested by the Fire Brigade Leader and as directed by the SM the Off-Site Fire Department will be called, from the Unit 2 Control Room for assistance.
- 5.2 The Control Room will notify Security of the impending arrival of the Verplanck Fire Department.
- 5.3 When required, the EP Manager will ensure activation of the Emergency Plan.



A. **IF** the Emergency Response Facilities (ERFs) are staffed, **THEN**:

1. Via the Radiological Coordinator in the Technical Support Center (TSC), the Plant Operations Manager (POM) will assess the radiological conditions that exist at the fire scene.
2. Prior to dispatching the Fire Brigade, the POM shall assess the following conditions. (If radiological conditions exist where there is a potential to exceed the 10CFR20 limits, refer to EP-4-ALL, Exposure Authorization Form.

- Area dose rate < 10 R/hr.:

The fire Brigade shall be dispatched from the CR to the fire scene. Notification shall then be made to the OSC to dispatch a Radiation Protection Technician to the fire scene to provide radiological guidance.

- Area dose rate > 10 R/hr.:

The POM shall designate a briefing area (e.g., entry into the RCA). Notify the OSC to dispatch a Radiation Protection Technician to the briefing location where he will provide radiological guidance. Authorize dispatch of Fire Brigade to the briefing location prior to responding to the fire scene.

3. **CONDUCT** a debriefing to ensure that the POM and OSC Manager are cognizant of the Fire Brigade actions.
- 5.4 **ENSURE** Radiation Protection Technicians are performing all necessary duties as listed on Attachment 9.1, "Watch Radiation Protection Fire Response".
- 5.5 **ENSURE** Security Officers are performing all necessary duties as listed on Attachment 9.2, "Security Fire Response".

NOTE

Provided full turnout gear is worn, when fighting a fire in a contaminated area, Anti-C clothing is not required to be worn by the Site Fire Brigade and offsite fire fighters.

FOR UNIT 3: Access through the Turnstile at the 4th floor Control Point may be obtained by using the key located in the glass box attached to the Turnstile.

FOR UNIT 2: Enter without use of the Turnstile



6.0 INTERFACES

- 6.1 EN-EP-900, Emergency Preparedness Forms
 - 6.1.1 EP-4-ALL , "Exposure Authorization Form"
 - 6.1.2 EP-6-ALL , "Team Tracking Log"
- 6.2 FP-7, Fire Notification Guidelines
- 6.3 IP-EP-AD13, *IPEC Emergency Action Level Technical Bases*

7.0 RECORDS


All forms and logs completed by the Emergency Response Organization during a declared emergency are Quality Records and shall be maintained for the life of the plant plus twenty (20) years.

8.0 REQUIREMENTS AND COMMITMENT CROSS-REFERENCE

- 8.1 This procedure does not degrade any requirements or commitments

9.0 ATTACHMENTS

- 9.1 Watch Radiation Protection Technician Fire Response
- 9.2 Security Fire Response

 IPEC SITE EMERGENCY PLAN IMPLEMENTING PROCEDURE	NON-QUALITY RELATED PROCEDURE	IP-1055 Revision18
	REFERENCE USE	Page 7 of 9

Attachment 9.1
Watch Radiation Protection Fire Response
Page 1 of 2

1. **RESPOND** to all fires in the RCA and have a Self-Contained Breathing Apparatus (SCBA) available for use if needed.
2. For communications with the CR and the Fire Brigade Leader, **BRING** a radio tuned to Frequency #2.
3. **UPON** arrival to the fire scene, **NOTIFY** the Fire Brigade Leader.
4. **EVALUATE** the location of the fire and address any radiological concerns directly to the Fire Brigade Leader at the fire scene or at a briefing designated by the POM.
5. **MAKE** every effort to keep exposures to fire fighters As Low As Reasonably Achievable (ALARA).
6. When possible, **CHECK** all fire fighters to ensure they have the appropriate Dosimetry. If not already done, issue Dosimetry.
7. **SET UP** an air sampler (particulate and iodine) as close as practical to where the smoke may be venting. If available at the fire scene, use a Continuous Air Monitor (CAM) as per approved Radiation Protection procedures.
8. **IF** it becomes necessary for any fire fighter to exceed 10CFR20 limits, **THEN** notify the SM/ED/POM.
9. **IF** it becomes necessary for the offsite fire fighters to exceed Entergy Nuclear Northeast's radiation exposure limits (500 mRem per year) **THEN** notify the SM/ED/POM.
10. **DURING** the fire fighting operations, **EVALUATE** the potential for the spread of radioactive contamination from the use of water.
11. **EVALUATE** airborne activity through the use of the Counting Room. If the air sample activity is greater than 3E-9 µCi/cc, an isotopic analysis is required.
12. **NOTIFY** the Fire Brigade Leader of any restrictions you are imposing on the fire fighters.



Attachment 9.1

Watch HP Fire Response


Page 2 of 2

13. As directed by the SM/ED/POM or-Radiological Assessment Coordinator, **ISSUE** KI.
14. When venting smoke, **ADVISE** the Fire Brigade Leader as to proper control of airborne activity. Depending on the heat involved, secondary fires may arise in the ventilation system/filters. The Radiation Protection Technician and the Fire Brigade Leader should consider shutting down the ventilation system if such a possibility exists.
15. **EVALUATE** the need for decontamination and whole body counting of personnel as described in approved Radiation Protection procedures.
16. **DETERMINE** if internal exposure should be assigned.
17. AFTER the fire has been extinguished, **RECORD** the name of each fire fighter and their DLR number on EP-6-ALL, "Team Tracking Log". In addition, obtain a DLR Badge Request Form from Dosimetry and complete it at this time.
 - **IF** the SM/ED/POM has authorized an extension to receive emergency personnel exposure above 10CFR20 limits, **THEN** complete EP-4-ALL, "Exposure Authorization Form".
 - **RETURN** completed forms to the Dosimetry Office.
18. BEFORE allowing the fire fighters to leave the RCA for the last time, **CHECK** them, their clothing and equipment for possible contamination as per approved Radiation Protection procedures.

NOTE

In order to prevent interference with fire fighting efforts, repeated exits from the RCA WITHOUT frisking is permitted.

19. All clothing and equipment which is not permitted to be removed from the RCA due to contamination should be inventoried for compensation.

 IPEC SITE EMERGENCY PLAN IMPLEMENTING PROCEDURE	NON-QUALITY RELATED PROCEDURE	IP-1055 Revision18
	REFERENCE USE	Page 9 of 9

Attachment 9.2

Security Fire Response

Page 1 of 1

1. **DIRECT** responding personnel and offsite fire fighters and accompanying apparatus' through the nearest gate to the fire area.
2. **IF** responding to the fire, **THEN** wear a SCBA.
3. **EVACUATE** unnecessary personnel from the fire area.
4. **IF** fire is located in the RCA, **THEN** do the following:
 - **ENSURE** access for Fire Brigade at 4th floor HP Control Point (**Unit 3**)
 - **ENSURE** the Fire Truck is given the Fire Fighter Kit located at the Main Gate Security Station.