



Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, Pennsylvania 16066
USA

U.S. Nuclear Regulatory Commission
Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

Direct tel: (412) 374-5541
Direct fax: (724) 940-8542
e-mail: mercieej@westinghouse.com

LTR-NRC-18-40

June 15, 2018

Subject: Westinghouse Comments and Proprietary Markings Regarding Draft NRC Safety Evaluation (by NRR) for WCAP-17203-P/WCAP-17203-NP, Revision 0-2, "Fast Transient and ATWS Methodology" (Proprietary/Non-Proprietary)

Reference 1: NRC letter, D.C. Morey to J.A. Gresham, "Draft Safety Evaluation For Westinghouse Electric Company Topical Report WCAP-17203-P/WCAP-17203-NP, Revision 0-2, 'Fast Transient and ATWS Methodology' " April 30, 2018

Attached are copies of the proprietary and non-proprietary versions of "Westinghouse Comments and Proprietary Markings Regarding Draft NRC Safety Evaluation (by NRR) for WCAP 17203-P/WCAP-17203-NP, Revision 0-2, 'Fast Transient and ATWS Methodology' " This information is being submitted by Westinghouse to provide comments and proprietary markings regarding the Draft NRC Safety Evaluation provided in Reference 1. Please note that Westinghouse still has one issue remaining to resolve and that a telecon with the NRC may be requested to discuss the issue.

This submittal contains proprietary information of Westinghouse Electric Company LLC ("Westinghouse"). In conformance with the requirements of 10 CFR Section 2.390, as amended, of the Nuclear Regulatory Commission's ("Commission's") regulations, we are enclosing with this submittal an application for Withholding Proprietary Information from Public Disclosure and an Affidavit. The Affidavit sets forth the basis on which the information identified as proprietary may be withheld from public disclosure by the Commission.

Correspondence with respect to the proprietary aspects of the application for withholding or the Westinghouse Affidavit should reference AW-18-4759 and be addressed to Edmond J. Mercier, Manager, Fuels Licensing and Regulatory Support, Westinghouse Electric Company, 1000 Westinghouse Drive, Building 2, Suite 256, Cranberry Township, Pennsylvania 16066.

A handwritten signature in black ink, appearing to read "Edmond J. Mercier".

Edmond J. Mercier, Manager

Fuels Licensing & Regulatory Support

Enclosures

cc: Ekaterina Lenning
Dennis Morey



Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, Pennsylvania 16066
USA

U.S. Nuclear Regulatory Commission
Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

Direct tel: (412) 374-5541
Direct fax: (724) 940-8542
e-mail: mercieej@westinghouse.com

AW-18-4759

June 15, 2018

APPLICATION FOR WITHHOLDING PROPRIETARY
INFORMATION FROM PUBLIC DISCLOSURE

Subject: LTR-NRC-18-40 P-Attachment, "Westinghouse Comments and Proprietary Markings Regarding Draft NRC Safety Evaluation (by NRR) for WCAP 17203-P/WCAP-17203-NP, Revision 0-2, "Fast Transient and ATWS Methodology" (Proprietary)

Reference: Letter from Edmond Mercier to Document Control Desk, LTR-NRC-18-40, June 15, 2018

The Application for Withholding Proprietary Information from Public Disclosure is submitted by Westinghouse Electric Company LLC (Westinghouse), pursuant to the provisions of paragraph (b)(1) of Section 2.390 of the Commission's regulations. It contains commercial strategic information proprietary to Westinghouse and customarily held in confidence.

The proprietary information for which withholding is being requested in the above-referenced report is further identified in Affidavit AW-18-4759 signed by the owner of the proprietary information, Westinghouse Electric Company LLC. The Affidavit, which accompanies this letter, sets forth the basis on which the information may be withheld from public disclosure by the Commission and addresses with specificity the considerations listed in paragraph (b)(4) of 10 CFR Section 2.390 of the Commission's regulations.

Correspondence with respect to the proprietary aspects of this Application for Withholding or the accompanying Affidavit should reference AW-18-4759 and should be addressed to Edmond J. Mercier, Manager, Fuels Licensing & Regulatory Support, Westinghouse Electric Company, 1000 Westinghouse Drive, Building 2, Suite 256, Cranberry Township, Pennsylvania 16066.

A handwritten signature in black ink, appearing to read "Edmond J. Mercier", with a long horizontal line extending to the right.

Edmond J. Mercier, Manager

Fuels Licensing & Regulatory Support

June 15, 2016

AFFIDAVIT


COMMONWEALTH OF PENNSYLVANIA:

ss

COUNTY OF BUTLER:

I, Edmond J. Mercier, am authorized to execute this Affidavit on behalf of Westinghouse Electric Company LLC (Westinghouse), and declare that the averments of fact set forth in this Affidavit are true and correct to the best of my knowledge, information, and belief.

Executed on: 6/15/2018



Edmond J. Mercier, Manager

Fuels Licensing & Regulatory Support

- (1) I am the Manager ,Fuels Licensing & Regulatory Support, Westinghouse Electric Company LLC (Westinghouse), and as such, I have been specifically delegated the function of reviewing the proprietary information sought to be withheld from public disclosure in connection with nuclear power plant licensing and rule making proceedings, and am authorized to apply for its withholding on behalf of Westinghouse.
- (2) I am making this Affidavit in conformance with the provisions of 10 CFR Section 2.390 of the Commission's regulations and in conjunction with the Westinghouse Application for Withholding Proprietary Information from Public Disclosure accompanying this Affidavit.
- (3) I have personal knowledge of the criteria and procedures utilized by Westinghouse in designating information as a trade secret, privileged or as confidential commercial or financial information.
- (4) Pursuant to the provisions of paragraph (b)(4) of Section 2.390 of the Commission's regulations, the following is furnished for consideration by the Commission in determining whether the information sought to be withheld from public disclosure should be withheld.
 - (i) The information sought to be withheld from public disclosure is owned and has been held in confidence by Westinghouse.
 - (ii) The information is of a type customarily held in confidence by Westinghouse and not customarily disclosed to the public. Westinghouse has a rational basis for determining the types of information customarily held in confidence by it and, in that connection, utilizes a system to determine when and whether to hold certain types of information in confidence. The application of that system and the substance of that system constitute Westinghouse policy and provide the rational basis required.

Under that system, information is held in confidence if it falls in one or more of several types, the release of which might result in the loss of an existing or potential competitive advantage, as follows:

 - (a) The information reveals the distinguishing aspects of a process (or component, structure, tool, method, etc.) where prevention of its use by any of Westinghouse's competitors without license from Westinghouse constitutes a competitive economic advantage over other companies.

- (b) It consists of supporting data, including test data, relative to a process (or component, structure, tool, method, etc.), the application of which data secures a competitive economic advantage, e.g., by optimization or improved marketability.
 - (c) Its use by a competitor would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing a similar product.
 - (d) It reveals cost or price information, production capacities, budget levels, or commercial strategies of Westinghouse, its customers or suppliers.
 - (e) It reveals aspects of past, present, or future Westinghouse or customer funded development plans and programs of potential commercial value to Westinghouse.
 - (f) It contains patentable ideas, for which patent protection may be desirable.
- (iii) There are sound policy reasons behind the Westinghouse system which include the following:
- (a) The use of such information by Westinghouse gives Westinghouse a competitive advantage over its competitors. It is, therefore, withheld from disclosure to protect the Westinghouse competitive position.
 - (b) It is information that is marketable in many ways. The extent to which such information is available to competitors diminishes the Westinghouse ability to sell products and services involving the use of the information.
 - (c) Use by our competitor would put Westinghouse at a competitive disadvantage by reducing his expenditure of resources at our expense.
 - (d) Each component of proprietary information pertinent to a particular competitive advantage is potentially as valuable as the total competitive advantage. If competitors acquire components of proprietary information, any one component

may be the key to the entire puzzle, thereby depriving Westinghouse of a competitive advantage.

- (e) Unrestricted disclosure would jeopardize the position of prominence of Westinghouse in the world market, and thereby give a market advantage to the competition of those countries.
 - (f) The Westinghouse capacity to invest corporate assets in research and development depends upon the success in obtaining and maintaining a competitive advantage.
- (iv) The information is being transmitted to the Commission in confidence and, under the provisions of 10 CFR Section 2.390, is to be received in confidence by the Commission.
- (v) The information sought to be protected is not available in public sources or available information has not been previously employed in the same original manner or method to the best of our knowledge and belief.
- (vi) The proprietary information sought to be withheld in this submittal is that which is appropriately marked in LTR-NRC-18-40 P-Attachment, "Westinghouse Comments and Proprietary Markings Regarding Draft NRC Safety Evaluation (by NRR) for WCAP-17203-P/WCAP-17203-NP, Revision 0-2, 'Fast Transient and ATWS Methodology' " (Proprietary), for submittal to the Commission, being transmitted by Westinghouse Letter, LTR-NRC-18-40, and Application for Withholding Proprietary Information from Public Disclosure, to the Document Control Desk. The proprietary information as submitted by Westinghouse is that associated with Westinghouse's request for NRC approval of WCAP-17203-P/WCAP-17203-NP, and may be used only for that purpose.
- (a) This information is part of that which will enable Westinghouse to obtain NRC approval for a methodology for analyzing limiting and non-limiting fast transients in initial and reload cores for operating BWRs, and for a new Monte Carlo based uncertainty analysis, as documented in WCAP-17203-P/WCAP-17203-NP, Revision 0-2, "Fast Transient and ATWS methodology."

- (b) Further, this information has substantial commercial value as follows:
- (i) Westinghouse plans to sell the use of similar information to its customers for the purpose of assisting customers in obtaining license changes with respect to the fast transient analysis methodology and Monte Carlo based uncertainty analysis.
 - (ii) Westinghouse can sell support and defense of the fast transient analysis and uncertainty analysis methods for plant-specific applications.
 - (iii) The information requested to be withheld reveals the distinguishing aspects of a methodology which was developed by Westinghouse.

Public disclosure of this proprietary information is likely to cause substantial harm to the competitive position of Westinghouse because it would enhance the ability of competitors to provide similar technical evaluation justifications and licensing defense services for commercial power reactors without commensurate expenses. Also, public disclosure of the information would enable others to use the information to meet NRC requirements for licensing documentation without purchasing the right to use the information.

The development of the technology described in part by the information is the result of applying the results of many years of experience in an intensive Westinghouse effort and the expenditure of a considerable sum of money.

In order for competitors of Westinghouse to duplicate this information, similar technical programs would have to be performed and a significant manpower effort, having the requisite talent and experience, would have to be expended.

Further the deponent sayeth not.

Proprietary Information notice

Transmitted herewith are proprietary and non-proprietary versions of a document, furnished to the NRC in connection with requests for generic and/or plant-specific review and approval.

In order to conform to the requirements of 10 CFR 2.390 of the Commission's regulations concerning the protection of proprietary information so submitted to the NRC, the information which is proprietary in the proprietary versions is contained within brackets, and where the proprietary information has been deleted in the non-proprietary versions, only the brackets remain (the information that was contained within the brackets in the proprietary versions having been deleted). The justification for claiming the information so designated as proprietary is indicated in both versions by means of lower case letters (a) through (f) located as a superscript immediately following the brackets enclosing each item of information being identified as proprietary or in the margin opposite such information. These lower case letters refer to the types of information Westinghouse customarily holds in confidence identified in Sections (4)(ii)(a) through (4)(ii)(f) of the Affidavit accompanying this transmittal pursuant to 10 CFR 2.390(b)(1).

Copyright Notice

The reports transmitted herewith each bear a Westinghouse copyright notice. The NRC is permitted to make the number of copies of the information contained in these reports which are necessary for its internal use in connection with generic and plant-specific reviews and approvals as well as the issuance, denial, amendment, transfer, renewal, modification, suspension, revocation, or violation of a license, permit, order, or regulation subject to the requirements of 10 CFR 2.390 regarding restrictions on public disclosure to the extent such information has been identified as proprietary by Westinghouse, copyright protection notwithstanding. With respect to the non-proprietary versions of these reports, the NRC is permitted to make the number of copies beyond those necessary for its internal use which are necessary in order to have one copy available for public viewing in the appropriate docket files in the public document room in Washington, DC and in local public document rooms as may be required by NRC regulations if the number of copies submitted is insufficient for this purpose. Copies made by the NRC must include the copyright notice in all instances and the proprietary notice if the original was identified as proprietary.

**Westinghouse Comments and Proprietary Markings Regarding Draft
NRC Safety Evaluation (by NRR) for WCAP 17203-P/WCAP-17203-NP,
Revision 0-2, “Fast Transient and ATWS Methodology”**

(Non-Proprietary)

June 2018

Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066

© 2018 Westinghouse Electric Company LLC
All Rights Reserved

**Westinghouse Comments and Proprietary Markings Regarding Draft
NRC Safety Evaluation (by NRR) for WCAP 17203-P/WCAP-17203-NP,
Revision 0-2, “Fast Transient and ATWS Methodology”**

Westinghouse has reviewed the NRCs draft Safety Evaluation and offers the following comments.

Our proposed identification of information proprietary to Westinghouse is also included, beginning on the following page and is indicated by the typical Westinghouse bracketing.

	<u>SE Location</u>	<u>Comment</u>
1.	Page 3, Line 7	“AOOSs” should be “AOOs”
2.	Page 3, Line 9	Suggest rewording to be: “...accidents are defined...”
	Page 3, Line 10	Suggest that this sentence be reworded: “Therefore, the specific categorization of IE and postulated accidents is not included in this methodology.”
4.	Page 10, Line 5	For consistency with the rest of the paragraph, revise to read: Pressure Increase/Pressure Decrease (PI/PD)
5.	Page 10, Line 21	“increase” should be “decrease”
6.	Page 10, Line 25	“increase” should be “decrease”
7.	Page 10, Line 27	Remove “no”. The sentence should read: “In the absence of actions in the plant system...”
8.	Page 10, Line 50	Revise to read: “...due to a decrease in core void.”
9.	Page 11, Line 11	Suggest this sentence be reworded: “...from the fuel, potentially causing fuel safety limits to be exceeded.”
10.	Page 14, Line 49	“A11which” should be “A11 which” (space added)
11.	Page 38, Line 6	Delete “draft”.

OFFICIAL USE ONLY – PROPRIETARY INFORMATION**U. S. NUCLEAR REGULATORY COMMISSION****OFFICE OF NUCLEAR REACTOR REGULATION****DRAFT SAFETY EVALUATION FOR TOPICAL REPORT****WCAP-17203-P/WCAP-17203-NP. REVISION 0-2.****“FAST TRANSIENT AND ATWS METHODOLOGY”****WESTINGHOUSE ELECTRIC COMPANY****PROJECT NO. 99902038****1.0 INTRODUCTION AND BACKGROUND****1.1 INTRODUCTION**

By letter dated June 30, 2010 (Reference 1), South Texas Project Nuclear Operating Company (STPNOC or STP) submitted Topical Report (TR) WCAP-17203-P, Revision 0, “Fast Transient and ATWS [anticipated transient without scram] Methodology,” for U. S. Nuclear Regulatory Commission (NRC) review and approval. The TR submittal provided a methodology for analyzing both limiting and non-limiting fast transients in initial and reload cores for currently operating boiling water reactors (BWRs) and advanced boiling-water reactors (ABWRs). As a result of the NRC staff review, several requests for additional information (RAIs) were issued. The applicant incorporated issues resolved through the RAI process into a revised version of WCAP-17203-P submitted by letter dated October 20, 2014, Nuclear Innovation North America LLC (NINA) submitted WCAP-17203-P, Revision 0-2, “Fast Transient and ATWS Methodology,” for the NRC staff review and approval (Reference 2). By letter dated May 6 2015, the NRC staff issued revised acceptance for review of WCAP-17203-P/WCAP-17203-NP, Revision 0-2, “Fast Transient and ATWS Methodology” (ADAMS Accession No. ML15111A272).

The purpose of the TR is to augment the existing methodology for fast transients and ATWS described in TR CENPD-300-P-A, “Reference Safety Report for Boiling Water Reactor Reload Fuel” (Reference 3). While the methodology is applicable for the analysis of anticipated operational occurrences (AOOs) including ATWS for BWR product lines 2-6 (BWR/2 through BWR/6), it does so within the context of reload analysis and not first cores. The objective of this TR is to establish a methodology for analyzing both limiting and non-limiting fast transients in initial and reload cores for currently operating BWRs and the ABWR design. However, this safety evaluation (SE) concentrates on the application of this TR only on BWR/2 through BWR/6 plants.

This TR describes the methodology of the evaluation model (EM) as stipulated in the NRC guidance (Reference 4) for non-limiting and limiting AOOs including ATWS and Infrequent Events (IE) for BWR/2 through BWR/6 plants. An AOO is defined as a condition of normal operation that is expected to occur one or more times during the life of the nuclear power unit (Reference 5). Since ATWS events are considered AOOs that are followed by a failure of the scram protection system, they are addressed separately in the methodology. Licensing basis documents for individual plants will define categorization of each condition, AOO, IE, or postulated accident.

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 2 -

1 NUREG-0800, "Standard Review Plan" (SRP), Chapter 15 events are regrouped according to
2 the acceptance criteria for AOOs including ATWS events as outlined in Chapter 4 and
3 Section 15.8 of the SRP and a Phenomena Identification and Ranking Table (PIRT) which
4 defines the phenomena that have to be addressed when evaluating the operating limits verified
5 by Westinghouse methodology experts. Ranking of the phenomena is on a high/medium/low
6 scale based on its influence on the figures-of-merit (FOM) defined in the acceptance criteria.
7 FOM are those quantitative standards of acceptance that are used to define acceptable
8 answers for a safety analysis. Once the operating limits and safety margins to acceptance
9 criteria are determined for fast transients and ATWS, uncertainty analysis is conducted to
10 evaluate the impact of uncertainties and biases on these limits in order to account for the
11 uncertainty in the best-estimate result.

12
13 Westinghouse specifically requests the NRC review and approval of:

- 14
- 15 • The ranking designations in the PIRT
- 16 • The analysis methodology for evaluating fast transients
- 17 • The Monte Carlo-based uncertainty analysis methods
- 18

19 Even though the submitted TR is applicable to BWR/2 through BWR/6 and ABWR, the Office of
20 Nuclear Reactor Regulation (NRR) review focused on the aspects of the TR that are pertinent to
21 the consideration of future submittals related to fuel amendments regarding the BWR/2 through
22 BWR/6 design. Therefore, this SE addresses the application of the methodology only to the
23 BWR/2 through BWR/6 design.

24
25 This SE provides details of the review results of TR WCAP-17203-P/WCAP-17203-NP,
26 Revision 0-2. The scope of the review is discussed in Section 1.0. The regulatory evaluation of
27 the review is discussed in Section 2.0. Section 3.0 describes the NRC staff's technical
28 evaluation of the TR, including the discussion of the responses to the RAIs. The conditions,
29 limitations, and the applicant's commitments resulting from the review are included in
30 Section 4.0. Section 5.0 lists the NRC staff's conclusions and Section 6.0 lists all references
31 cited in the SE.

32 33 1.2 BACKGROUND

34
35 Prior to this TR, Westinghouse used the NRC licensed methodology for fast transient analyses
36 that is described in Reference 3. Though this methodology is applicable for the analysis of fast
37 and slow transients for BWR/2 through BWR/6 reload analysis, it does not address all the
38 transients required for first (initial) core applications. The objective of this TR is to establish a
39 methodology for analyzing both limiting and non-limiting fast transients in initial and reload cores
40 for currently operating BWRs as required by the initial safety analysis report (SAR).

41
42 According to Reference 3, ABB/CE/Westinghouse has differentiated between fast and slow
43 transients as follows:

44
45
46 These events are grouped into fast and slow transients based on the dynamic characteristics
47 of the transient. "Fast transients" are those events of relatively short duration such that the
48 impact of the spatial and temporal dynamics on the system nuclear and thermal-hydraulics is
49 important to the overall plant response. "Slow transients" are defined as those transients for

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 3 -

1 which the dynamic changes during the transient are sufficiently slow that the assumption that
2 steady state conditions are achieved at each time step is either realistic or conservative.
3
4

5 WCAP-17203-P/WCAP-17203-NP, Revision 0-2, TR methodology is based on the NRC
6 guidance for transients and accidents, Regulatory Guide (RG) 1.203, "Transients and Accident
7 Analysis Methods," for AOOs, ATWS, and IE. Since ATWS events are considered AOOs that
8 are followed by a failure of the reactor protection system (RPS) to scram, they are discussed
9 separately in the TR. The IE or postulated accidents is defined in plant-specific documentation.
10 Therefore, it is not included in this methodology.
11

12 The PIRT provided in the TR defines the phenomena that have to be addressed when
13 evaluating the operating limits and safety margins to acceptance criteria. Each identified
14 phenomena is assigned an importance ranking corresponding to its influence on a FOM. The
15 PIRT also provides the rationale for each ranking. Separate importance rankings are defined
16 for different AOOs and ATWS events. Using the PIRT table as input the analysis methodology
17 describes the evaluation process for determining the operating limits and the safety margins to
18 the acceptance criteria.
19

20 The TR proposes a transient analysis statistical methodology that accounts for uncertainties and
21 biases in the models, inputs, and parameters to ensure that operating limits and safety margins
22 meet the required acceptance criteria. In order to do this, the TR proposes a statistical analysis
23 method using 95 percent probability with a 95 percent confidence level (95/95) for calculating
24 uncertainties associated with operating limits and safety margins.
25

26 This TR describes the methodology part of the EM as defined in the RG 1.203 and the
27 Chapter 15 of SRP.
28

29 The SRP defines six areas of review for AOOs and ATWS analyses methods:
30

- 31 • Documentation
- 32 • Evaluation Model
- 33 • Accident Scenario Identification Process
- 34 • Code Assessment
- 35 • Uncertainty Analysis, and
- 36 • Quality Assurance Plan
37

38 Each of these areas are briefly discussed below:
39

40 Documentation 41

42 The SRP guidance on documentation requires that the EM documentation must be scrutable,
43 complete, unambiguous, accurate, and reasonably self-contained. The documentation must be
44 consistent nomenclature and must be used throughout the entire model documentation. Also
45 the code documentation must be sufficiently detailed that a qualified engineer can understand
46 the documentation without recourse to the originator as required of any design calculation that
47 meets the design control requirements of Appendix B to *Title 10 of the Code of Federal*
48 *Regulations* (10 CFR) Part 50, and the documentation requirement in Appendix K to 10 CFR
49 Part 50. The documentation must contain (1) an overview of the EM, (2) a complete description
50 of the accident scenario, (3) a complete description of code assessment, (4) a determination of

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 4 -

1 code uncertainty for a sample plant accident calculation, (5) a theory manual that contains field
2 equations, closure relationships, numerical solution techniques and limits, and limits of
3 applicability, (6) a user manual that provides details of how the code is used, and (7) a quality
4 assurance plan that provides the procedures and controls under which the code was developed.

5
6 The TR provides sufficient documentation for the above criteria.

7
8 **Evaluation Model**

9
10 Per the SRP, an EM needs to include one or more computer programs necessary for application
11 of the calculation framework to a specific transient or accident, such as mathematical models
12 used, assumptions included in the programs, a procedure for treating the program input and
13 output information, specification of those portions of the analysis not included in the computer
14 programs, values of parameters, and other information necessary to specify the calculation
15 procedure.

16
17 The TR provides the description of the program(s) used or the programs that will be used for
18 transient analyses.

19
20 **Accident Scenario Identification Process**

21
22 The purpose of the accident scenario identification process is to identify and rank the reactor
23 components and physical phenomena modeling requirements based on their importance and
24 their impact on FOM for the calculations. This process is highly dependent on the type of
25 reactor and the accident scenario of interest. A separate accident scenario identification
26 description is needed for each accident or transient class for which the code is to be used in
27 order to describe the accident progression and dominant physical phenomena for that particular
28 accident.

29
30 **Code Assessment**

31
32 The SRP guidance establishes that all code models used in the evaluation must be assessed
33 with the frozen version of the EM. Also the guidance requires that separate effects testing must
34 be performed to demonstrate the adequacy of the physical models to predict physical
35 phenomena that were determined to be important by the accident scenario identification
36 process.

37
38 The applicant states in TR Section 7.2.1 that the transient methodology presented is
39 code-independent and therefore can be applied regardless of the computer code used. A
40 complete code assessment is thus not presented in the TR; the assessment performed in the
41 TR is for demonstration purposes only.

42
43 Since the TR introduces no models, this portion of the guidance is only applicable in that the
44 RAIs and responses discuss the performance or acceptability of certain models to address
45 issues related to scope of applicability changes by the TR (e.g., BWR/2 through BWR/6). The
46 separate effects test (SET), integral effects test (IET), and scaling aspects of the guidance are
47 also similarly applicable.

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 5 -

Uncertainty Analysis

The SRP guidance establishes that the uncertainty analysis must address all important sources of code uncertainty, including mathematical models in the code and user modeling such as nodalization. The major source of uncertainty should be assessed in a manner consistent with the results of the accident sequence identification process which this TR addresses. The uncertainty analysis must include those in theoretical models or closure relationships determined from comparison to separate effects tests, uncertainties due to scaling of the basic models, and closure relationships. Also, the sources of uncertainties in plant model input parameters for plant operating conditions, such as, accident initial conditions, set points, and boundary conditions.

The SRP guidance also states that when a code is used in a licensing calculation, the combined code and application uncertainty must be less than the design margin for the safety parameter of interest. Examples of safety parameters applicable to BWR/2 through BWR/6 analysis are reactor vessel pressure (RVP), linear heat generation rate (LHGR), and minimum critical power ratio (MCPR). The analysis should include a sample uncertainty evaluation for a typical plant application.

Quality Assurance Plan

The SRP states that the EM is maintained under quality assurance program that meets the requirements of Appendix B of 10 CFR Part 50. As a minimum, the program must address design control, document control, software configuration control and testing, and corrective actions.

2.0 REGULATORY EVALUATION

The NRC staff used certain sections of 10 CFR 50.34, "Contents of Applications: Technical Information," that require the licensee/applicant (or vendor) to provide safety analysis reports to the NRC detailing the performance of systems, structures, and components provided for the prevention or mitigation of potential accidents.

General Design Criterion (GDC) 10 (Reference 6) requires that the reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits (SAFDL) are not exceeded during any condition of normal operation, including the effects of AOOs.

The SAFDLs that are addressed in GDC 10 are divided into two limits on MCPR and LHGR for clad strain and fuel centerline temperature (FCT), and peak fuel enthalpy. The MCPR safety limit is used as an acceptance limit to protect fuel cladding from overheating as described in Section 4.4 of SRP. The overpower LHGR limit protects the fuel cladding from exceeding 1 percent plastic strain and the fuel pellet from centerline melting per Section 4.2 of SRP.

The acceptance criteria for AOO events are defined in Section 15.0 of SRP and meet the GDC specified in Reference 6 that are applicable to AOOs (i.e., GDC 10, 13, 15, 17, 20, 26, 29, 60, and 64).

Criterion 13 requires that the instrumentation be provided to monitor variables and systems over their anticipated ranges for normal operation, for AOOs, and for accident conditions as appropriate to assure adequate safety, including those variables and systems that can affect the

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 6 -

1 fission process, the integrity of the reactor core, the reactor coolant pressure boundary, and the
2 containment and its associated systems.

3
4 Criterion 15 requires that reactor coolant system and associated auxiliary, control, and
5 protection systems shall be designed with sufficient margin to assure that the design conditions
6 of the reactor coolant pressure boundary are not exceeded during any condition of normal
7 operation, including AOOs.

8
9 Criterion 17 requires onsite electric power system and an offsite electric power system shall be
10 provided to permit functioning of structures, systems, and components important to safety.

11
12 Criterion 20 requires that protection system be designed (1) to initiate automatically the
13 operation of appropriate systems including the reactivity control systems, to assure that SAFDLs
14 are not exceeded as a result of AOOs and (2) to sense accident conditions and to initiate the
15 operation of systems and components important to safety.

16
17 Criterion 26 requires two independent reactivity control systems of different design principles be
18 provided by means of control rods and a reactivity control system with capability of reliably
19 controlling the rate of reactivity changes.

20
21 Criterion 29 requires protection and reactivity control systems be designed to assure an
22 extremely high probability of accomplishing their safety functions in the event of AOOs.

23
24 Criterion 60 requires that the nuclear power unit design shall include means to control suitably
25 the release of radioactive materials in gaseous and liquid effluents and to handle radioactive
26 solid wastes produced during normal reactor operation, including AOOs.

27
28 Section 15.0 of SRP specifies the following acceptance criteria for AOO events:

- 29
- 30 • Pressure in the reactor coolant and main steam systems should be maintained below
31 110 percent of the design values in accordance with the American Society of Mechanical
32 Engineers (ASME) Boiler and Pressure Vessel Code.
 - 33
 - 34 • Fuel cladding integrity shall be maintained by ensuring that the critical power ratio (CPR)
35 remains above the MCPR safety limit for BWRs.
 - 36
 - 37 • An AOO should not generate a postulated accident without other faults occurring
38 independently or result in a consequential loss of function of the RCS or reactor
39 containment barriers.
 - 40

41 The design requirements for ATWS events for evolutionary plants are defined in SRP
42 Section 15.8, Subsection 15.8.II in Paragraph 3.C of “Specific Acceptance Criteria” and restated
43 as follows:

- 44
45
- 46 • Coolable geometry for the reactor core. If fuel and clad damage were to occur following
47 a failure to scram, GDC 35 requires that this condition should not interfere with
48 continued effective core cooling. 10 CFR 50.46 defines three specific core-coolability
49 criteria: (1) Peak clad temperature shall not exceed 1221°C (2200°F), (2) Maximum
50 cladding oxidation shall not to exceed 17% the total cladding thickness before oxidation,

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 7 -

1 and (3) Maximum hydrogen generation shall not exceed 1% of the maximum
2 hypothetical amount if all the fuel clad had reacted to produce hydrogen.

- 3 • Maintain reactor coolant pressure boundary integrity. Appendix A to WASH-1270 states
4 that in evaluating the reactor coolant system boundary for ATWS events, “the calculated
5 reactor coolant system transient pressure should be limited such that the maximum
6 primary stress anywhere in the system boundary is less than that of the ‘emergency
7 conditions’ as defined in the ASME Nuclear Power Plant Components Code, Section III.”
8 The acceptance criteria for reactor coolant pressure, based upon the ASME Service
9 Level C limits, are approximately 10.3 MPa (1500 psig) for BWRs and approximately
10 22MPa (3200 psig) for PWRs (pressurized water reactors).
- 11 • Maintain containment integrity. Following a failure to scram, the containment pressure
12 and temperature must be maintained at acceptably low levels based on GDC 16 and 38.
13 The containment pressure and temperature limits are design dependent; but to satisfy
14 GDC 50, those limits must ensure that containment design leakage rates are not
15 exceeded when subjected to the calculated pressure and temperature conditions
16 resulting from any ATWS event.

19 **3.0 TECHNICAL EVALUATION**

21 **3.1 INTRODUCTION**

22
23 TR WCAP-17203-P/WCAP-17203-NP, Revision 0-2, discusses methods for BWR fast
24 transients including ATWS and IE that are occurring in ABWRs as well as BWR/2-6 designs,
25 while extending their applicability to first core analysis and introduce a new Monte Carlo based
26 uncertainty analysis. The TR includes the following sections:

- 27
- 28 • Transient Grouping and Plant Specification
- 29 • Acceptance Criteria
- 30 • Phenomenological Description
- 31 • Phenomena Identification and Ranking
- 32 • Analysis Methodology
- 33 • Uncertainty Analysis
- 34 • Demonstration Analysis

36 **3.2 TRANSIENT GROUPING AND PLANT SPECIFICATIONS**

37
38 The NRC staff in a RAI requested the applicant to provide a list of all fast transients as they
39 pertain to the BWR/2 through BWR/6 contained in the TR in comparison to the similar ones
40 provided in CENPD-300-P-A. The applicant states that CENPD-300-P-A is a comprehensive
41 umbrella document that describes the application of the NRC approved fuel and core design
42 and analysis codes in the licensing safety analysis process to evaluate any plant modification.
43 In addition, it also describes methodologies applied to core and fuel design and for evaluating
44 potentially limiting events for reload applications. WCAP-17203-P/WCAP-17203-NP,
45 Revision 0-2, provides a generic, code-independent methodology for evaluating only fast
46 transients including both potentially limiting as well as non-limiting events.

47
48 TR WCAP-17203-P/WCAP-17203-NP, Revision 0-2, provides a generic evaluation methodology
49 for all fast transients considered in Table 2-1 of Reference 2 and the special event ATWS. In

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 8 -

1 WCAP-17203-P/WCAP-17203-NP, Revision 0-2, the fast transients are divided into groups to
2 facilitate the identification and ranking of the important phenomena in the following categories:
3

- 4 • Pressure Increase Events (PI)
- 5 • Pressure Decrease Events (PD)
- 6 • Reactor Coolant Flow Increase Events (RCFI)
- 7 • Reactor Coolant Flow Decrease Events (RCFD)
- 8 • Feedwater Flow Increase Events (FWFI)
- 9 • Feedwater Flow Decrease Events (FWFD)
- 10 • Reactor Coolant Temperature Increase Events (RCTI)
- 11 • Reactor Coolant Temperature Decrease Events (RCTD)
- 12 • Anticipated Transients without Scram (ATWS)

13
14 Specific transients and their frequency of occurrence are established in the plant licensing
15 bases and documented in the SAR or design control document (DCD). AOOs and IE capture
16 the phenomena classified in the PIRT which consists of identifying and ranking dominant
17 phenomena during a transient with respect to their influence on the FOM.
18

19 The ATWS events that are evaluated are mitigated by the following manual and automatic
20 shutdown process:
21

- 22 1. Reactor shutdown by alternate control-rod insertion (ARI), (10 CFR 50.62).
- 23 2. Reactor shutdown by fine-motion control rod drive (FMCRD) run-in (Only in ABWR
24 design).
- 25 3. Reactor shutdown by activation of standby liquid control system (SLCS).

26 27 3.3 ACCEPTANCE CRITERIA

28
29 Section 3.1 of the TR provides the applicant's acceptance criteria for AOOs and ATWS events.
30 Section 3.2 of the TR lists the FOM that are derived from the regulatory requirements
31 corresponding to the acceptance criteria described in Section 3.1 of the TR. The acceptance
32 criteria for AOOs are defined to meet the requirements related to the GDC for nuclear power
33 plants specified in Appendix A to 10 CFR Part 50.
34

35 The acceptance criteria for AOOs are listed below:
36

- 37 • Limit for radioactive effluents must comply with regulations in 10 CFR Part 20 and
38 10 CFR Part 100.
39
- 40 • SAFDLs that are addressed in GDC 10 is divided into limits on MCPR, LHGR and clad
41 strain and FCT, and peak fuel enthalpy. The MCPR safety limit protects the fuel
42 cladding from overheating as per SRP, Section 4.4. The overpower LHGR limit protects
43 the fuel cladding from exceeding 1 percent plastic strain and protects the fuel pellet from
44 centerline melting as required by SRP Section 4.2.
45
- 46 • The upset limit for peak reactor vessel pressure is 110 percent of the reactor pressure
47 vessel (RPV) design pressure, as per SRP, Section 5.2.2.
48

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 9 -

- 1 • Fuel enthalpy limit is applied to provide protection from rapid energy deposition events
2 and therefore not used for the fast transients and the ATWS events listed in Table 2-1 of
3 the TR.
4

5 For fast transients categorized as postulated accidents, the acceptance criteria considered are
6 the radiological consequences within regulatory limit and the primary system pressure be
7 maintained below the acceptable design. The evaluation of radiological consequences is
8 beyond the scope of this TR, however, the number of failed fuel rods can be determined. For
9 calculating the fuel rod failures, the MCPR or the cladding temperatures are evaluated based on
10 the plant's licensing bases.
11

12 The acceptance criteria for ATWS event are listed below:
13

- 14 • Long term core cooling must be assured by meeting the cladding temperature and
15 oxidation criteria according 10 CFR 50.46 and SRP, Section 4.2
16
17 • The RPV integrity should be maintained by limiting the maximum primary stress within
18 the RCPB to the limits defined in ASME Section III, RPV integrity as required by GDC 14
19 of 10 CFR Part 50, Appendix A.
20
21 • The long-term containment capability must be assured by limiting the maximum
22 containment pressure to the design pressure of the containment structure and the
23 suppression pool temperature to the wetwell design temperature in order to ensure
24 compliance with GDC 16.
25
26 • Long term shutdown cooling must be assured subsequent to an ATWS event and the
27 reactor be maintained in a cold shutdown condition as required by GDC 35.
28

29 FOM (as defined in SRP Section 15.0.2) are quantitative standards of acceptance that are used
30 to define acceptable answers to safety analysis, such as, departure from nucleate boiling ratio
31 (DNBR) limits and fuel temperature limits. Table 3.1 of the submittal provides a list of FOMs for
32 both AOOs and ATWS events.
33

34 The FOM identified in the TR for the AOOs are:
35

- 36 • Minimum critical power ratio (MCPR)
37
38 • Reactor vessel pressure (RVP)
39
40 • Linear heat generation rate (LHGR)

41 The FOM identified for the ATWS events are:
42

- 43 • Cladding temperature
44
45 • Reactor Vessel Pressure (RVP)
46
47 • Mass and energy release to containment
48

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 10 -

1 3.4 PHENOMINOLOGICAL DESCRIPTION

2

3 3.4.1 Pressure Increase (PI)

4

5 A general description of each of the transient groups, PI/PD, Reactor Coolant Flow
6 Increase/Decrease (RI/RD), Feedwater Flow Increase/Decrease (FI/FD), and Reactor Coolant
7 Temperature Increase/Decrease (TI/TD) is provided in the TR. The events pertaining to each
8 category are discussed briefly.

9

10 The methodology described in the TR is general and the actual EM will be described sufficiently
11 in plant licensing submittals. This is acceptable to the NRC staff.

12

13 In response to NRR RAI-17 and NRR RAI-18 (Reference 30), the applicant responded and
14 modified the PI section of TR. Generally a PI transient is initiated by a disturbance in the valve
15 position in the steam lines that causes a decrease in steam flow. For example, in the feedwater
16 flow increase transient, the closure of the turbine stop valve initiates the transition of the event
17 that was originally a feedwater flow increase event into the pressure increase event group listed
18 in Table 4-1 of the TR. The pressure upstream of the closed valve will start to increase and will
19 lead to a steam compression wave which will eventually increase the pressure inside the RPV.
20 This increase in RPV pressure will result in an increase in the core inlet subcooling and cause
21 the boiling boundary in the core to move upwards, resulting in a core average void increase.
22 The resulting negative void reactivity will increase the fission power and will result in larger
23 power increase.

24

25 The core average void increase will be interrupted by one of the following phenomena:

26

27 (1) In the absence of no action in the plant system, the resulting increase in heat flux
28 generates more boiling and the resultant increase in voids reduces the fission power and
29 causes a fuel surface heat flux decrease causing an increase in CPR.

30

31 (2) If the reactor scrams, the power will be rapidly decreasing due to insertion of control rods
32 (CRs), the fission power decreases while the CPR starts to increase.

33

34 3.4.2. Pressure Decrease (PD)

35

36 Table 4-2 of TR lists the increase in steam flow (SRP Section 15.1.3) and inadvertent opening
37 of a safety/relief valve (SRP Section 15.1.4/15.6.1) as pressure decrease transients. A PD
38 transient results when steam flow is increased caused by malfunction of a valve in the steam
39 line or when several safety/relief valves inadvertently open. The PD results in decreased core
40 inlet subcooling and causes the core boiling boundary to move downwards in the core. This
41 causes void increase and fission power decrease. The core average void increase will be
42 interrupted in all cases when the power decreases and when the CPR increases.

43

44 3.4.3 Reactor Coolant Flow Increase/Decrease (RCFI/D)

45

46 Reactor Coolant Flow Increase (RCFI)

47

48 As Table 4-3 of TR indicates, the RCFI transient results from startup of an inactive recirculation
49 pump or an operator/controller error, causes the amount of water flowing into the reactor core to
50 increase, resulting in a gradual power increase due to an increase in core void. The core
51 average void decrease is interrupted by either (1) if no action is taken by safety systems, the

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 11 -

1 core average void will continue to decrease, power increases, followed by steam flow increase
2 leading to an increase in pressure in the steam dome resulting in a large steam pressure drop,
3 or (2) if a reactor scram is initiated, power is reduced and due to negative reactivity inserted by
4 the CRs, the resulting in the increase in CPR.

5
6 Reactor Coolant Flow Decrease (RCFD)

7
8 RCFD transients, caused by a trip of a pump or a flow controller malfunction, result in a smaller
9 amount of coolant entering the reactor core and will cause an increase in average void resulting
10 in a reduction of power. The effect of this transient on the core is a miss-match between the
11 heat generated in fuel and transferred from the fuel, causing fuel safety limits violated.

12
13 3.4.4 Feedwater Flow Increase/Decrease

14
15 Feedwater Flow Increase (FWFI)

16
17 A FWFI transient causes the amount of water flowing in to the core to increase, which causes
18 excess heat removal causing the moderator void and temperature to decrease, thereby,
19 reducing the CPR. The core average void decrease will be interrupted by one or more of the
20 following:

- 21
- 22 • If there is no intervening action, the core average void will continue to increase causing
23 increase in power and increase in steam flow leading to increase in steam dome
24 pressure. The CPR is also reduced as a result of increase in power.
 - 25 • If a turbine trip occurs, turbine stop valves close, resulting in decrease in steam flow.
26 This results in pressure increase and decrease in core void followed by increase in
27 power as the neutron flux increases. This is treated as a pressure increase transient.
 - 28 • If the reactor scram is initiated, power will decrease from the core bottom due to inserted
29 CRs resulting in an increase in CPR.
- 30

31 Feedwater Flow Decrease (FWFD)

32
33 During the loss of feedwater flow transient, the downcomer water level decreases while the
34 temperature increases to saturation. This causes core inlet temperature to increase. The
35 decreasing water level causes a reduction in core inlet subcooling, thereby, increasing the core
36 average void while decreasing power. The core effects that are possible are: (1) decreased
37 power will reduce the fuel temperature and limits the power reduction due to positive Doppler
38 effect; and (2) One or more auxiliary feedwater system starts and a recirculation pump runback
39 or trip and a reactor scram may be initiated.

40
41 3.4.5 Reactor Coolant Temperature Increase/Decrease

42
43 Reactor Coolant Temperature Increase (RCTI)

44
45 Loss of normal feedwater flow will result in RCTI. The impact of this group of transients on the
46 system is similar to that under feedwater flow decrease.

47

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 12 -

1 Reactor Coolant Temperature Decrease (RCTD)

2
3 Transients that cause RCTD are decrease in feedwater temperature and inadvertent startup
4 of an emergency core cooling system (ECCS). These transients will lead to a decrease in
5 downcomer temperature, increase in core subcooling leading to a reduction in the core average
6 void. Power increases causing steam flow to increase. This transient will result in the steam
7 dome pressure increase, as well as a high average power range monitor may cause the reactor
8 to scram.

9
10 3.5 PHENOMENA IDENTIFICATION AND RANKING TABLE (PIRT)

11
12 As stated in Section 1.1.4 of RG 1.203, “Transient and Accident Analysis Methods,” the EM
13 development and assessment should be based on a credible and scrutable PIRT. The
14 development of this PIRT is an important step in the EM development and assessment process.
15 The PIRT is used to determine the requirements for the physical model development, scalability,
16 validation, and sensitivity studies. The importance rankings used are “high,” “medium,” and
17 “low” and all such rankings are quoted to indicate that they are rankings in the main body of this
18 text.

19
20 The phenomena identified under the first seven categories defined in the TR (i.e., Categories A
21 through G) are very similar to the phenomena identified in the PIRT developed in
22 NUREG/CR-6744 (Reference 7), which was developed by the NRC for loss-of-coolant accidents
23 (LOCAs) in operating BWRs. The last category in the TR PIRT (i.e., Category H) identifies
24 components/systems important specifically for AOO and ATWS events.

25
26 Revision 0 of the TR (Reference 1) did not include the MSIV in the Category H of PIRT. Since
27 the modeling of MSIV operation is essential for many AOOs considered in the TR, the NRC staff
28 in NRO-RAI 8 requested the applicant to provide the basis for not including the MSIV
29 components and the associated phenomena in the PIRT. Subsection 1.1.4 of RG 1.203,
30 recommends PIRT development down to the component function or component performance
31 parameter level. In such cases, MSIVs are different from steam lines, as are feedwater lines
32 from feedwater pumps. In response to the RAI (Reference 8), the applicant clarified that the

33 []
34]^{a,c} and committed to update the discussion of component H8 in Tables 5-2 and A-1
35 accordingly. The applicant further added as H17, []^{a,c} H18, []
36]^{a,c} and H19, []^{a,c} to the list of components in PIRT.

37
38 3.5.1 Phenomenon Identification and Ranking Table Importance Ranking

39
40 A PIRT for the AOOs and ATWS is presented in Section 5 of the TR and is stated to be
41 applicable to ABWR and BWR/2 through BWR/6. The TR indicates that the phenomena
42 identified in the PIRT are based on the following previously developed PIRTs, with some
43 additions based on the opinions of an expert panel:

- 44
45
- 46 • “Phenomenon Identification and Ranking Tables (PIRTs) for Loss-of-Coolant Accidents
47 in Pressurized and Boiling Water Reactors Containing High Burn up Fuel” (Reference 7)
 - 48 • “Phenomenon Identification and Ranking Tables (PIRTs) for Rod Ejection Accidents in
49 Pressurized Water Reactors Containing High Burnup Fuel” (Reference 31)
 - 50 • “Phenomenon Identification and Ranking Tables (PIRTs) for Power Oscillations Without
Scram in Boiling Water Reactors Containing High Burnup Fuel” (Reference 32)

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 13 -

1 The phenomena identified in the PIRT are defined in Appendix A of the TR and are grouped into
2 eight categories:

- 3
- 4 1. Initial conditions
- 5 2. Transient power distribution
- 6 3. Steady-state and transient cladding to coolant heat transfer and core spray heat transfer
- 7 4. Transient coolant conditions as a function of elevation and time
- 8 5. Fuel rod response
- 9 6. Multiple rod mechanical effects
- 10 7. Multiple rod thermal effects
- 11 8. Plant component/system data
- 12

13 The PIRT presented in the TR provides the rationale for importance ranking of each
14 phenomenon. However, the rationales for some phenomena were not adequately described in
15 the TR, and RAIs were used to seek additional information as follows:

16
17 A1. []^{a,c}

18
19 In the TR, [

20]^{a,c} The reason for these transient-specific
21 ranking differences is not clear from the rationale provided in Table 5-2 of the TR, as was
22 pointed out in NRR-RAI 8a (Reference 8). [

23
24
25
26
27
28
29
30
31
32
33
34]^{a,c}
35
36 A2. []^{a,c}

37
38 In the BWR LOCA PIRT, [

39]^{a,c} The NRC staff in RAI-9b asked the applicant for a valid rationale for this
40 ranking.

41
42 In the response to NRO-RAI 9b (Reference 8), the applicant clarified that [

43
44
45
46
47]^{a,c}

48
49 Through the RAI process, the NRC staff asked for the clarification on the ranking of [

50]^{a,c} The RAI responses (References 8, 9, and 33) provided detailed analyses of
51

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 14 -

1 the effect of variation of the [
2]^{a,c} the response
3 is acceptable, and NRO-RAI 9b and its supplements are resolved and closed.

4
5 A7. []^{a,c} and A18. []^{a,c}
6

7 The NRC staff asked clarifications for A7 and A18 in Revision 0 of the TR through an
8 NRO-RAI-9e (Reference 8). The rationale for A7 and A18 was simply that both have significant
9 impact on determining the outcome of the transient. Table A-1 of the revised TR for A7 has
10 indicated that the [
11
12
13
14

15
16]^{a,c}
17

18 The rationale for A18 was revised in the latest version of the TR as [
19

20]^{a,c}
21

22 A8. []^{a,c}
23

24 This initial condition is ranked as being of [
25

26]^{a,c} (A2) raised in NRO-RAI 9c. As a result of the RAI response
27 (Reference 9), the rationale for this initial condition was appropriately updated.
28

29 A11. []^{a,c}
30

31 [
32
33
34
35
36

37]^{a,c} NRO-RAI 9d pointed out this inconsistency.
38

39 In response (Reference 8), the applicant agreed to revise the TR to make the ranking of [
40

41]^{a,c} However, NRO-RAI 9d S01 (Reference 17) asked the applicant to
42 justify this ranking. In response (Reference 24), the applicant reported results from sensitivity
43 calculations that show phenomena A11 and A14 should actually be ranked []^{a,c}
44 transients and committed to rank them as such in the TR. This is acceptable to the NRC staff,
45 and Phenomenon A11 accurately reflects the latest response.
46

47 NRR-RAI 9b raised similar issues, and in response, the applicant performed additional
48 sensitivity calculations for all transient classes (PI/PD, RCFI/D, FWFI/D, and RCTI/D) including
49 ATWS to assess the rankings of Phenomenon A11 which demonstrated that [
50

51]^{a,c}

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

- 15 -

1 Consequently, the applicant proposed a [
 2]^{a,c} for Phenomenon A11 and committed to update Table 5-2 of the TR, including
 3 the rationale (Reference 12).

4 B2. []^{a,c}
 5
 6
 7 [
 8]^{a,c} While it is important that this be correctly modeled, it was not clear why the
 9 TR ranks it []^{a,c} This issue was raised in NRO-RAI 9f. The applicant
 10 explained that the [
 11]^{a,c} (Reference
 12 8).

13
 14 C1. []^{a,c}
 15
 16 Since the rationale given for this phenomenon was not meaningful, the NRC staff requested
 17 clarifications in NRR-RAI 8 (Reference 12). The applicant clarified in its response, that this
 18 phenomenon has insignificant impact on the system response or the outcome of the transient
 19 and committed to revise the rationale in the TR accordingly. The TR was revised and the
 20 response does not alter the conclusions regarding acceptability for BWR/2 through BWR/6.

21
 22 C2. []^{a,c}
 23
 24 These phenomena are assigned a []^{a,c} in the TR. However, in BWRs, these
 25 phenomena typically [
 26]^{a,c} Because the basis for the []^{a,c} is not described in the TR,
 27 NRO-RAI 9g sought clarification. In response (Reference 8), the applicant explained that the
 28 [
 29]
 30
 31
 32]^{a,c} of Phenomenon C2 is reasonable. The issue is
 33 resolved and closed.

34
 35 D4. []^{a,c}
 36
 37 In response to NRR-RAI 10 S1 (Reference 10) that requested the applicant to update the
 38 definition of this item, the applicant revised the definition in TR Table A-1 to clarify that it
 39 indicates []^{a,c} This does not alter the conclusions
 40 regarding acceptability for BWR/2 through BWR/6.

41
 42 D5. []^{a,c}
 43
 44 As discussed for Phenomenon A7 []^{a,c} the applicant revised the definitions
 45 of Phenomena A7 and D5 and updated TR Table A-1 accordingly in response to
 46 NRO-RAI 10g S01 (Reference 17). The new rationale specifies that the [
 47]
 48]^{a,c}
 49 This is acceptable, and the issue is resolved and closed.
 50

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 16 -

1 D6. []^{a,c}
2
3 In NRO-RAI 9h, the applicant was asked to provide the basis for the []^{a,c} of this
4 phenomenon. In response (Reference 8), the applicant stated that, due to the []
5
6 []^{a,c} The NRC
7 staff agrees, and the issue is resolved and closed.
8
9 E1. []^{a,c}
10 []
11
12
13
14
15
16 []^{a,c} The NRC staff agrees with this
17 explanation, and the issue is resolved and closed.
18
19 E4. []^{a,c}
20
21 This phenomenon is assigned a []
22
23 []^{a,c} In response (Reference 17),
24 the applicant provided a scaling analysis to estimate the []
25
26
27 []^{a,c} This
28 response is acceptable to the NRC staff, and the issue is resolved and closed.
29
30 E6. []^{a,c}
31
32 This phenomenon is assigned a []
33 []^{a,c} and NRO-RAI 9k S01
34 requested the applicant to explain the rationale for this ranking. In the response (Reference 17),
35 the applicant clarified that this phenomenon refers to the []
36 []^{a,c} The applicant agreed to update the description
37 of Phenomenon E6 in TR Tables 5-2 and A-1 to reflect this clarification. This response and
38 resulting change to the TR are acceptable, so this issue is resolved and closed.
39
40 G1. []^{a,c}
41
42 These phenomena are assigned a []
43
44
45 []^{a,c} Therefore, NRO-RAI 9l sought a basis for the ranking. In
46 response (Reference 8), the applicant stated that in []
47
48 []^{a,c} The NRC staff agrees with this explanation. Therefore, the issue is resolved
49 and closed.
50

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

- 17 -

1 H1. []^{a,c}

2
3 As discussed previously in this section, in response to concerns in NRR-RAI 11 (Reference 30)
4 and NRR-RAI 11 S1 (Reference 10) about []^{a,c} the applicant revised the
5 definition of Phenomenon H1 in the TR and created the new Phenomenon H18, []^{a,c}. The
6 RAI response does not alter the conclusions regarding acceptability for BWR/2 through BWR/6.
7

8 H5. []^{a,c}

9
10 NRR-RAI 9c S1 questioned the applicant's statement that []
11 []^{a,c} In response (Reference
12 22), the applicant committed to update the rationale for this phenomenon to clarify that its
13 purpose is []
14

15
16 []^{a,c} The change has been confirmed in the TR, and the response
17 does not alter the conclusions regarding acceptability for BWR/2 through BWR/6.
18

19 In summary, the responses to the RAIs and their supplements in the above list are acceptable,
20 and the stated concerns are resolved. The applicant revised the PIRT in Table 5-2 of the TR
21 and the phenomena definitions in Table A-1 in accordance with the responses provided.
22

23 3.5.2 Additional PIRT Phenomena

24
25 The NRC staff found that several phenomena were not directly identified in the TR PIRT even
26 though they may be expected to play an important role under the conditions of the AOO and
27 ATWS events. RAIs requested the applicant to provide an explanation for the lack of inclusion
28 of the following phenomena in the PIRT:
29

30 []^{a,c}

31
32 Operation of safety/relief valves (SRVs) is typically important for the transients identified in the
33 TR. As NRO-RAI 10a pointed out, the flow through SRVs is expected to be governed by the
34 []^{a,c} In response to NRO-RAI 10a (Reference 8), the applicant
35 explained that the []^{a,c} is covered in the PIRT under Phenomenon H9,
36 []^{a,c} The response is acceptable, so the issue is resolved and closed.
37

38 []^{a,c}

39
40 []
41 []^{a,c} (i.e., due to trip of the reactor internal
42 pumps (RIPs) in ABWR or recirculation pumps in BWR/2 through BWR/6). In the responses to
43 NRO-RAI 10b S01 (Reference 17) and NRR-RAI 10a (Reference 30), the applicant proposed to
44 update the PIRT to include Phenomenon D7 []^{a,c}, as a separate phenomenon
45 and to update TR Tables 5-2 and A-1 accordingly. The applicant provided a detailed description
46 of this phenomenon and its rankings for AOOs and ATWS events. The applicant's rationale for
47 []
48
49
50
51

[]^{a,c} Table A-1, Item D7 of

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

- 18 -

1 the TR defines [
2
3

4]^{a,c}
5

6 This phenomenon is modeled as an output of the steam separators. The NRC staff noted this in
7 NRO-RAI 10c. In response (Reference 8), the applicant clarified that the [
8]^{a,c} in the PIRT. This is
9 also indicated by the description of Phenomenon H2 provided in Table A-1 of the TR. The
10 response is acceptable.
11

12 [
13]^{a,c}

14 The NRC staff in NRO-RAI 10d, requested information regarding the [
15]^{a,c} in the PIRT phenomena. This RAI also noted the phenomenological
16 description of fast transients and ATWS events in Section 4 of the TR that there is a substantial
17 interaction between the thermal-hydraulic system behavior and the neutronics due to the
18 reactivity feedback effects. In response (Reference 8), the applicant clarified that [
19

20]^{a,c} in the PIRT. The response is acceptable.
21

22 [
23]^{a,c}

24 Modeling of [
25]^{a,c} as NRO-RAI 10f S01 and NRR-RAI 10b noted. In the
26 responses, the applicant proposed to update TR Tables 5-2 and A-1 to include D8,
27 [
28

29]^{a,c}
30

31 [
32]^{a,c}
33

34 The applicant clarified that the [
35]^{a,c} in the PIRT. The response is

36 acceptable.
37

38 [
39]^{a,c}

40 As requested in NRO-RAI 10i S01 and NRR-RAI 10b, interfacial transfer of mass, momentum,
41 and energy are highly dependent on two-phase flow regime or phase topology. The prediction
42 of flow regime and use of appropriate flow-regime-dependent interfacial mass, momentum, and
43 energy transfer constitutive relations (closure relations) are essential for the prediction of two-
44 phase flow and void fraction distribution in the reactor. In its response (Reference 30), the
45 applicant proposed [
46

47]^{a,c} The applicant committed to
48 update TR Tables 5-2 and A-1 accordingly. The applicant also provided descriptions of these
49 phenomena and their rankings for the AOOs and ATWS. The response is acceptable, and the
50 changes have been confirmed in the TR.
51

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 19 -

1 The responses to the above NRO-RAIs and their supplements are acceptable, and the changes
2 listed above have been confirmed. Therefore, the stated concerns are resolved, and the
3 corresponding RAIs are closed. The responses to the NRR-RAIs do not alter the conclusions
4 regarding acceptability for BWR/2 through BWR/6.

5
6 3.6 ANALYSIS METHODOLOGY

7
8 TR Section 6 presents the analysis methodology for each transient category defined in
9 Section 2. The evaluation process for each transient group consists of the following steps:

- 10
11 • Definition of the limiting condition(s) that most significantly affect(s) the analysis
12
13 • Evaluation of core and fuel operating limits
14
15 • Parameter selection process
16
17 • Specification of input parameters used in the uncertainty analysis

18
19 3.6.1 Limiting Plant States and Events

20
21 The NRC staff requested clarification in NRO-RAI 14 (Reference 34) on the statement in
22 Section 6.1 of the revised TR:

23
24 *Each potentially limiting transient event is evaluated for the limiting plant condition(s)
25 throughout the plant operating domain.*

26
27 The applicant responded that the limiting events are determined on a plant-specific basis. This
28 is consistent with other supplied RAI responses that emphasize the need to maintain a plant-
29 specific licensing basis that will include plant-specific transient grouping, parameter input, and
30 analysis code(s). The response is acceptable to the NRC staff.

31
32 The NRR RAI 23 requested the applicant to expand the above discussion to ensure
33 conservatism in the methodology. The revised TR defines the limiting conditions by initial power
34 level, recirculation flow, system pressure and feedwater temperature, and associated
35 uncertainties. The nominal reactor power plus a 2 percent uncertainty is used in the analysis
36 complying with the SRP requirement. A lower power level can be used in the analysis if it can
37 be justified. Figure 6-1 of the TR provides a graphical relationship for nuclear safety-related
38 setpoints, such as, safety limit and its analytical limit, trip setpoint, and nominal setpoint. [

39]^{a,c} According to 10 CFR 50.36(c)(ii)(A) the LSSS
40 for nuclear reactors are settings for automatic protective devices related to those variables
41 having significant safety functions. When a LSSS is specified for a variable, the setting must be
42 so chosen that automatic protective action will correct the abnormal situation before a safety
43 limit is exceeded. If automatic safety system does not function as required, the licensee shall
44 take appropriate action including shutting down the reactor.

45 The applicant revised several sections in Chapter 6 of the TR which will be discussed below.
46

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 20 -

1 3.6.2 Fuel and Core Operating Limits
2

3 Fuel and core operating limits consist of different limiting parameters that cannot be violated
4 during operation of the plant, such as the Operating Limit MCPR (OLMCPR) and LHGR
5 limitations introduced by transient overpower.
6

7 Based on several RAIs (NRO-RAI 15, NRO-RAI 15 S01, NRO-RAI 16, and NRR-RAI 22)
8 (References 8, 17, and 31), the applicant made several changes in Sections 6.2 of the TR.
9 Section 6.2.1 of the TR describes how the OLMCPR would be calculated for full-power
10 conditions. A formula is presented for calculating a generalized limiting MCPR based on the
11 OLMCPR and factors representing deviations from operating power and flow rate. NRO-RAI 16
12 requested that the applicant provide details on how these factors in the formula are determined.
13 The applicant responded (Reference 8) with a correction to the formula contained within TR
14 Revision 0 and with details on how the two factors will be derived based on the reactor's
15 power-flow map. This response is acceptable, the correction was made in the revised TR, and
16 the RAI is resolved and closed.
17

18 [

19

20

21

22

23

] ^{a,c}

24 The applicant specifies that some AOO events can be more restrictive at off-rated conditions
25 depending on the plant-specific allowable operating domain. In a response to NRO-RAI 17, to
26 clarify the statement the some AOOs can be more restrictive at off-rated conditions, the
27 applicant responded in Reference 11 that [

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

40] ^{a,c} The applicant's explanation is satisfactory, and the issue is closed and
41 resolved.

43

44

45

46

47

43 The potentially limiting events are analyzed using a detailed thermal-hydraulic code that are
44 selected during this licensing event selection process. Expert engineering judgement or
45 analytical processes are used to eliminate certain events and this disposition of events is
46 documented.
47

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 21 -

1 3.6.2.1 MCPR Operating Limit with Uncertainty

2

3 For OLMCPR with uncertainty, the following procedures are followed:

4

5 • [

6

7 •

8

9 •

10

] ^{a,c}

11

12 3.6.2.2 LHGR Operating Limit

13

14 The LHGR operating limit is specified for each fuel type in a given cycle. The plant LHGR
15 operating limit is the most restrictive of the following:

16

17 • [

18 •

19

20 •

21

22

23

] ^{a,c}

24

25

26 3.6.2.3 Overpressurization Protection Methodology

27

28 [

29

30] ^{a,c} These events are used to confirm the
31 adequacy of the plant's pressure relief system prior to each reload cycle. The evaluation
32 procedure are listed in Section 6.2.3.2 of the revised TR and in the response to NRR
33 RAI-41.S1 (Reference 10). These evaluation procedures are:

34

35 • [

36 •

37

38

39 •

40

41

42 •

43

] ^{a,c}

44

45

46

47

44 The overpressurization MSIV closure event could be treated as an emergency condition
45 consistent with the current version of the ASME code with acceptable results compared to
46 ASME emergency condition limits, i.e., the reactor pressure acceptance limit of 120% of design
47 pressure. However, [] ^{a,c}

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

- 22 -

1 []^{a,c}
2
3
4 NRO RAI 28 asked the applicant to provide the rationale for choosing []
5 ^{a,c} as the dominant overpressurization event. In response, the applicant
6 explained that, based on the sequence of events during an overpressurization transient, the []
7
8

9 ^{a,c} The supplement to the RAI asked for information on the
10 process and methodology used to determine other pressurization events that may be more
11 severe than MSIV closure and the steps taken to ensure the most severe pressurization event is
12 identified and analyzed. The response (Reference 24) indicated that []
13
14

15
16
17 ^{a,c} The issue is closed and resolved.
18

19 3.6.3 Analysis Codes

20
21 Section 6.3 of the TR states that the methods under discussion are applicable to the
22 NRC-approved 1D and 3D dynamic codes. For fast transients, NRC approved 1-D and 3-D
23 system dynamic computational code is used for analysis.
24

25 For 1-D analysis, the []
26 ^{a,c} Fuel performance and
27 thermal hydraulic data is integrated into the 1-D transient analysis.
28

29 The 3-D analysis of fast transients uses a 3-D kinetics dynamic code, all nuclear and
30 thermal-hydraulic data taken directly from a static core simulator.
31

32 In the RAI response (Reference 8) and in complying with the Section 15.02 of NUREG-0800 for
33 the requirements of the EM such as an overview, accident scenario identification process, code
34 assessment, and uncertainty analysis, the applicant provided documentation for the same in the
35 TR. The EM that captures the calculational framework for assessing the behavior of the reactor
36 coolant system during postulated accident or transient uses BISON (RPA-90-90-P-A) and
37 POLCA-T (WCAP-16747-P-A) and their appendices. For analyzing special events such ATWS
38 the codes used are BISON, POLCA-T, and GOTHIC (WCAP-16608-P-A).
39

40 3.6.4 Analysis Methodology

41
42 Section 6.4 of the TR discusses the analysis methodology for AOOs and separates the
43 discussion into subsections according to the categorization of the AOOs listed in Section 4 of
44 the TR: PI/PD, RCFI/D, FWFI/D, and RCTI/D. For each AOO category, there is a discussion of
45 the analysis code requirements and the modeling techniques required to address the transient
46 category. Also presented is a list of parameters deemed to provide conservative assumptions in
47 the analysis of each AOO event in Tables 6-1 through 6-8. For example, according to
48 Table 6-1, analysis of PI transients shall use a []
49 ^{a,c}
50

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 23 -

1 Section 6.4.1.1, "Analysis Code Requirements," of the TR lists PI/PD analysis code
2 requirements and the requirement that conservative input data is required for the transient
3 analysis. This section specifies that [

4
5
6
7]^{a,c} The NRC staff requested
8 more information on how combinations of transient categories will be determined to be more
9 limiting than the conditions analyzed in the PIRT and to discuss how the combinations of
10 categories will be chosen for evaluation.

11
12 The applicant responded to the RAI in Reference 8. The applicant states that combinations of
13 transient categories are not explicitly determined and analyzed. In the proposed methodology,
14 [

15
16
17
18
19
20
21]^{a,c}
22
23 NRR RAI-26 (Reference 11) sought clarification for limiting PI and PD transients, including
24 transients from one category to the other. The response to the NRR-RAI 26 (Reference 11)
25 presented a sensitivity analysis for a PD transient (opening of all turbine and bypass valves)
26 evolving into a PI transient to demonstrate the application of the information summarized in the
27 response to the NRO-RAI 29 S01 (Reference 9).

28
29 Section 6.4.1.2 and Section 6.4.1.3 of the TR, respectively, provides details of the PI and PD
30 transients' methodology and modeling techniques. [

31
32
33
34
35
36]^{a,c} Table 6-1 of the TR lists pressure increase
37 transients' input parameters with conservative assumptions. Section 6.4.1.3 lists methodology
38 and modeling techniques for PD transient methodology.

39
40 Section 6.4.2.1 of the TR lists the analysis code requirements for RCFI/D that are based on the
41 phenomenological descriptions used as the basis for PIRT. The requirements for the physical
42 EM are: [

43
44
45
46]^{a,c} Section 6.4.2.2 lists analysis code requirements, transient modeling
47 techniques, and conservative assumptions for the RCFI transient input parameters.
48 Section 6.4.2.3 provided analysis code requirements, transient modeling techniques, and
49 conservative assumptions for the RCFD transient input parameters.

50
OFFICIAL USE ONLY – PROPRIETARY INFORMATION

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 24 -

1 Section 6.4.3 of the TR describes the general analysis code requirements for the FWFI/D,
2 modeling techniques used for FWFI and the FWFD, and how to conservatively bias the input
3 parameters for the FWFI/D transients' analyses. Similarly, Section 6.4.4 provides the analysis
4 code requirements for RCTI/D transients and how the input parameters for the RCTI/D
5 transients must be biased for conservatism.
6

7 The NRC staff in an RAI (Reference 12) asked for technical justification and to perform
8 sensitivity study to confirm that for [
9]^{a,c} as per Section 6.4.3.3.2 of the TR. The applicant responded in Reference 13 that for a
10 FWFD, [
11
12
13
14
15
16
17
18
19
20

] ^{a,c}

21
22
23 The NRC staff asked for additional information (Reference 12) for validation of the fuel time
24 constant in Section 6.4 of TR to be conservative for both hot and average rods, or commit to
25 performing code-specific confirmatory calculations to validate the conservative direction of the
26 fuel time constant prior to making assumptions for various transients in plant licensing
27 calculations. The NRC staff asked to clarify whether a hot rod/average rod fuel assembly model
28 is capable of accurately predicting a quantity of failed fuel rods for a pump seizure or shaft break
29 accident, as opposed to verifying that the limiting rod is undamaged.
30

31 The applicant in Reference 15 stated that they intend to [
32
33

34]^{a,c} as shown in the
35 response to NRR RAI-16.S 1.
36

37 In response to staff's RAI for clarification of whether a hot rod / average rod fuel assembly
38 model is capable of accurately predicting a quantity of failed fuel rods for a pump seizure or
39 shaft break accident. The applicant provided further details on the use of the hot rod and
40 average channel approach to determine the number of failed fuel rods in response to NRR-
41 RAI 43 (Reference 12). According to the applicant, the [
42
43
44
45
46
47
48
49
50

] ^{a,c}

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 25 -

1 []^{a,c} (see
2 Commitment 2 in Section 4.2 of the SE).

3
4 In summary, the responses to the RAIs related to TR Section 6.4 and their supplements are
5 acceptable, and the RAIs are closed and resolved. The responses supplied from RAIs for TR
6 Section 6.4 do not alter the evaluation for BWR/2 through BWR/6 aside from specifying
7 Commitment 2, as discussed above. Furthermore, the NRC staff has reviewed Section 6.4 of
8 the revised TR for the analysis methodology of the transients and determined that the
9 applicant's procedure for analyses is acceptable.

10
11 3.6.5 Anticipated Transients Without Scram (ATWS)

12
13 TR Section 6.5 addresses the analysis methodology for ATWS event. The initiators for an
14 ATWS event are usually caused by a rapid reduction in steam flow (rapid pressurization events)
15 or events that can evolve to a rapid pressurization event during the course of the transient. For
16 rapid pressurization events, there is a rapid increase in the reactor coolant pressure boundary
17 pressure, and core power. The pressure and power increase is limited by the reactor protection
18 system, typically an automatic recirculation pump trip (ATWS-RPT) on high reactor pressure
19 and operation of the SRVs. Reactor shutdown is accomplished by automatic or manual
20 initiation depending on the plant design. The different plant systems that can shut down the
21 reactor are: alternate rod insertion (ARI), fine motion control rod drive (FMCRD), and SLCS
22 (shutdown with boron injection in to vessel coolant).

23
24 []^{a,c} NRC staff requested clarification (Reference 8) for this and to obtain
25 explanation for the statement in the TR that, according to the PIRT, code capability assessment
26 (CCA), data uncertainty assessment (DUA), and []^{a,c} The applicant responded that
27 the ATWS uncertainties may be grouped into categories such as;

- 28
29
30
31 • []
32 •
33
34 •

35
36
37
38
39
40]^{a,c}

41
42 The applicant revised the TR to clarify the text in Subsections 6.5.1.1 and 6.5.1.2. The NRC
43 staff finds this response and the changes in the TR acceptable.

44
45 As previously stated, the analysis methodology for ATWS events is developed to comply with
46 the requirements of 10 CFR 50.62, which requires the availability of certain equipment to
47 automatically shut down the reactor. However, the systems specified in Section 6.5 of the TR
48 did not include the requirement for a trip of the reactor coolant recirculating pumps in BWRs.
49 The NRC staff requested clarification regarding the requirement of coolant recirculation pump
50 trip to mitigate the ATWS. The applicant responded to the RAI in Reference 8. The applicant

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 26 -

1 stated that the mitigation of ATWS events is accomplished by a multitude of equipment and
2 procedures. These include ARI, fine motion control rod drive (FMCRD) run-in, feedwater
3 runback, recirculation pump trip (RPT), recirculation runback, automatic depressurization
4 system (ADS) inhibit, and SLCS initiation. The methods and procedures applied for ATWS
5 mitigation are determined by the plant design and can be manually or automatically initiated.
6 The analysis for three separate cases investigated (ARI, FMCRD run-in, and SLCS activation)
7 showed sufficiency to demonstrate the adequacy of all ATWS mitigation actions including RPT,
8 per SRP Section 15.8.

9
10 The NRC staff requested the applicant (RAI-12, Reference 8) to explain the statement that
11 boron transport in the analysis for ATWS events will be “conservatively modeled.” The applicant
12 responded that boron transport will be modeled using a method that has been reviewed and
13 approved by the NRC in POLCA-T, and BISON (References 13, 14, and 15). Boron transport
14 model used by POLCA-T is described in Section 7.1 of the TR and justification for this is done in
15 Reference 16 which is currently under review by NRC staff. The boron transport model used by
16 BISON is documented in Section 4 of Reference 15.

17
18 The applicant has further clarified the response to RAI-12 regarding the statement for
19 “conservatism” for the phenomena of boron transport in RAI-12 S01 (Reference 16). The
20 applicant defined [

21
22
23
24
25]^{a,c}

26
27 NRR RAI-20 and its supplement NRR RAI 20 S1 requested information on how control systems
28 and balance of plant equipment are relevant to performing bounding analyses of transient and
29 ATWS events in the TR. In the responses (References 18 and 19, respectively), the applicant
30 explained that the control systems are treated consistently with Table 7-1 of the TR. The control
31 system may be treated conservatively, nominally with uncertainty analysis or nominally without
32 uncertainty analysis depending on PIRT ranking, CCA ranking, and the DUA. [

33
34
35
36
37
38
39
40]^{a,c} The NRC staff
41 accepts the RAI response regarding the treatment of control systems.

42 3.6.6 Conclusions on Analysis Methodology

43
44 The TR provides guidance for fast transient and ATWS analysis methodology, including code
45 requirements, analysis requirements, and assumptions used to preserve the conservative
46 nature of the results generated.

47
48
49 This review is limited to a general assessment of the applicability of the methodology to fast
50 transient and ATWS analyses. Although the analysis methodology provides detailed guidance

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 27 -

1 for code assessment, a code assessment that demonstrates the full use of this guidance is not
2 used in TR Section 8.4 for the demonstration case.

3
4 The analysis methodology described in the TR is generally similar to the previous analysis
5 methodology for BWR reload cores (Reference 3) for those parameters that have a medium or
6 low effect on a FOM. [
7]^{a,c}
8

9 The TR explains that the analyses will be performed using 1D and/or 3D NRC-approved
10 dynamic analysis codes. When 1D analysis codes are used, the process for obtaining a 1D
11 model from a 3D model is required. This process is not described in detail in this TR, but it is
12 the subject of the updated BISON and POLCA-T TRs (References 20 and 15). This TR also
13 describes some of the general code calculation capabilities needed for analyses and
14 demonstrates the use of the PIRT and the CCA to justify the code selection. These descriptions
15 are acceptable.

16
17 The TR explains that an ATWS analysis is performed to verify the adequacy of the mitigating
18 equipment required by 10 CFR 50.62. [
19

20]^{a,c} Additional specific analysis assumptions are provided for the SLCS
21 ATWS analyses. The assumptions are acceptable.
22

23 As noted in the TR and in the responses to the NRC staff's RAIs discussed in Sections 3.6.1
24 through 3.6.5 of SE, the methodology that will be employed during actual licensing will be
25 plant-specific. Consequently, the review and approval of this TR is necessarily limited to a
26 determination regarding the soundness of the approach described. The analysis methodology
27 is generally acceptable. In addition, it has been confirmed that the applicant has incorporated
28 the updates into the TR as committed to in RAI responses. The responses supplied from
29 NRO-RAIs do not alter the evaluation based upon NRR-RAIs.
30

31 3.7 UNCERTAINTY ANALYSIS 32

33 This section describes how the applicant performed the uncertainty analysis to predict a best
34 estimate value accounting for uncertainties and biases of the input and modeling parameters to
35 ensure operating limits and safety margins meet the acceptance criteria. The statistical analysis
36 for uncertainty calculations is based on 95% probability with a 95% confidence level that results
37 in conservative values.
38

39 NRO RAI 19, NRO-RAI 19 S01, and NRO-RAI 19 S02 requested details regarding what
40 precedent exists for use of [
41

42]^{a,c} In response, the applicant
43 provided examples of when NRC has previously accepted best-estimate methods for fast
44 transients and noted that Section 4.4 of the SRP directs the applicant to treat uncertainties in
45 the values of process parameters, core design parameters, and modeling parameters with at
46 least a 95/95 level when evaluating thermal margins during AOOs. In addition, the applicant
47 stated that it intends to use the best-estimate method (95/95 calculations) with respect to the
48 CPR remaining above the MCPR, consistent with the guidance of SRP Chapter 15 and SRP
49 Section 4.4. The applicant stated that it would use [
50]^{a,c}

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 28 -

1 Regarding NRC's rejection of best-estimate methods during the review of CENPD-300-P
2 (Reference 3), the applicant noted in the response that Method B in the original CENPD-300-P
3 submittal, which most closely resembles the proposed uncertainty analysis in this TR, is based
4 on the assumption of normally distributed input parameters. The applicant stated that it would
5 not apply Method B to determine thermal margins and noted that the new method of treating
6 uncertainties in this TR imposes [
7]^{a,c} The responses to NRO-RAI 19 and its supplements are acceptable, and
8 the issue is resolved and closed.
9

10 The uncertainty analysis methodology is described in detail in Section 7 and Appendix B of the
11 TR. The analysis provides for a best-estimate value and a 95/95 value to be determined.
12 Appendix B provides theoretical basis for the statistical method used in the uncertainty
13 evaluation. The applicant has used two methods: the statistical properties of the normal
14 distribution method and the order statistics method. The details of the statistical analysis will be
15 discussed in detail in the next sub-sections.
16

17 3.7.1 Selection of Input Parameters for Uncertainty Analysis

18
19 Table 7-1 that lists the uncertainty evaluation matrix shows how the uncertainty methods are
20 assigned in accordance with the PIRT and CCA ranking. Based on this guidance, [
21

22]^{a,c} Section 7.1 of the TR
23 states that when the [
24
25

26
27]^{a,c} In
28 response to the NRC staff's request for additional information regarding this issue, the applicant
29 explained how biases and uncertainties for parameters with a "high" PIRT ranking are treated.
30 A follow-up RAI on why the applicant [
31

32
33
34]^{a,c}
35 The NRC staff has determined that this response has been adequately resolved.
36

37 Table 7-1 lists three different types of treatment for code input and modeling parameters:
38 nominal with uncertainty analysis, conservative, and nominal without uncertainty analysis. [
39

40
41
42
43]^{a,c} In
44 conservative treatment, the relevant input and modeling parameters are set to bounding value
45 which leads to the conservative influence on the FOMs. [
46

47
48
49]^{a,c}

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 29 -

1 The NRC staff reviewed Section 7.1 of the TR and the related RAI responses described above
2 and determined that the definition for input and modeling parameters uncertainty analysis and
3 processes are acceptable.

4 3.7.2 Code Capability Assessment

6 CCA evaluates the computer code for performing analysis of fast transients and ATWS events.
7 CCA requires that the PIRT listed in the TR and the importance must be considered. The
8 applicant states in the TR that the transient methodology is code-independent and therefore it
9 can be applied independent of the code and therefore it will be included in a code-specific TR.

11 The database to determine the code accuracy, code ranking and the establishment of
12 uncertainties requires the following items:

- 14 • Separate effect tests (SETs) needed to develop and assess empirical correlations and
15 other closure models.
- 17 • Integral effect tests (IETs) to assess system interaction and global code capability.
- 18 • Benchmark with other codes (optional).
- 19 • Plant transient data (if available).
- 20 • Simple test problems (or analytical solutions) to illustrate fundamental calculational
21 device capability.

22 Code accuracy focuses on the capability and performance of the code. Model accuracy for
23 each of the phenomena identified in the PIRT must be examined by an evaluation panel of
24 subject matter experts. The data qualification is determined based on quality of test data,
25 uncertainties, knowledge of the test facility and its operations. The model capability is
26 determined according to a three-level scale: High/Medium/Low (related to how the phenomenon
27 is calculated or used in determining the FOM). An example of CCA matrix is demonstrated in
28 Table 7-2 of the TR.

29 The NRC staff requested in RAI-21 to elaborate the CCA process and criteria used to assess
30 model accuracy and include examples. The applicant stated in Reference 34 that the model
31 accuracy is judged by subject matter experts based on the validation against the SET and/or
32 IET data. [

33
34
35
36]^{a,c} As an example, the applicant
37 provided an advanced control rod hydraulic insertion model that has been verified against
38 measurements of control rod hydraulic insertion []^{a,c} at different reactor dome
39 pressures and different pressures in the hydraulic rod insertion system gas tanks. Figure 1 of
40 RAI-21 response shows that the code model is in good agreement with measurements.

41
42 The NRC staff asked the applicant to provide a description of the criteria against which the
43 qualification data will be judged in determining the sufficiency and relevancy of data to the
44 phenomenon of interest. In addition, the RAI asked the applicant to provide additional
45 information describing how scaling considerations are incorporated in the bias and uncertainty
46 evaluation. In the response (Reference 30), the applicant indicated that the relevancy of a
47 particular test record is based on the level of applicability of the test data to a particular

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 30 -

1 phenomenon or model. [
2
3

4]^{a,c} This response
5 provides sufficient information to understand the “relevancy” and “sufficiency” terminology but
6 does not provide specific acceptance criteria.

7 The CCA presented in this Section is limited in scope and does not serve as a full examination
8 of a particular code. However, the CCA process presented is acceptable for the demonstration
9 of TR.

10 3.7.3 Data Uncertainty Assessment

11 The SRP Section 15.0.2 establishes criteria which ensures that the method for calculating
12 uncertainty contains all important sources of uncertainty. The SRP Section 15.0.2 acceptance
13 criteria must provide the source of uncertainties in theoretical models or closure relationships be
14 determined from comparison of separate effects tests, uncertainties due to scaling of the basic
15 models and closure relationships, and uncertainties due to plant nodalization and solution
16 techniques. Uncertainties in the experimental data such as measurement errors and
17 experimental distortions must be addressed. For separate effects, tests and integral effects
18 tests, the reviewers should confirm that the differences between calculated results and
19 experimental data for important phenomena have been quantified for bias and deviation.
20
21

22 The applicant in the TR states that the DUA process links corresponding code-dependent input
23 and model parameters (Candidate Parameters (CP)) for pertinent phenomena to allow for
24 further uncertainty and sensitivity analyses. The CPs that have very small uncertainties are
25 eliminated from further analyses while the remaining parameters (Relevant Parameters (RPs))
26 are subject to further uncertainty and sensitivity analyses. Probabilistic distribution functions
27 (PDFs) and respective bounding values are then assigned for each of the RPs. These
28 parameters are then input to further uncertainty analysis. The DUA consists of three steps:
29 identification of CPs, specification of RPs and establishment of PDFs, and respective bounding
30 values for further uncertainty analysis.
31

32 The CPs are code input and modeling parameters to simulate high ranked phenomena
33 identified in the PIRT. CPs are developed based on code documentation. The RPs are
34 parameters that have significant influence on FOM and serve as input to further analysis.
35

36 The RPs uncertainty intervals are developed based on the guidelines defined in Code Scaling,
37 Applicability, and Uncertainty (CSAU) (Reference 22) which stipulates that there is no single
38 method providing the uncertainty range or bias for all RPs. Instead RPs are grouped according
39 to the following methods:
40

41 • [
42
43

44 •
45
46

47 •
48
49

]^{a,c}

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 31 -

1 The NRC staff in RAI-25 asked the applicant to clarify how the DUA is addressed in the
2 methodology and how the uncertainty analysis in the TR takes into account the uncertainties in
3 the mathematical models, closure relationships in the underlying codes, and user modeling
4 (e.g., nodalization and solution techniques) (Reference 21). The NRC staff also asked how
5 uncertainties in the experimental database are factored into the uncertainty analysis. The
6 applicant explained that the DUA described in Section 7.3 of the TR provides the process by
7 which the mathematical models and closure relationships are performed. The response
8 contained examples (such as void correlation) and discussed the closure relationships in codes,
9 user modeling, and uncertainty analysis.

10
11 Uncertainty evaluation is a part of the DCA process. [
12
13
14
15
16

17 •

18
19 •

20
21]^{a,c}
22

23 The NRC staff requested that the applicant describes how uncertainties in the experimental data
24 such as those arising from measurement errors and experimental distortions are factored in to
25 the uncertainty analysis. The response explained that the uncertainties in experimental
26 databases are addressed in two ways: [
27
28
29
30

31]^{a,c}
32

33 The NRC staff requested additional information on the uncertainty methodology for experimental
34 databases (RAI-25 S01, Reference 21). In the response, the applicant explained that
35 the number of leading parameters identified for each important phenomenon (PIRT) is based on
36 the number of output parameters associated with this phenomenon that have a relevant effect
37 on the FOM. According to the RAI-23 S01 response, the “relevant” parameter is numerically
38 defined for each FOM. The response further explains how experimental and modeling
39 uncertainties are mathematically combined, depending on whether the uncertainties or errors
40 are relative or absolute in nature. The process discussed is mathematically correct. The
41 applicant also explained that [
42

43]^{a,c} The NRC staff accepts this
44 interpretation of how the uncertainty methodology is applied to the experimental database.

45 In RAI-25 S02 (an extension of RAI-25 S01), the NRC staff requested clarification and mode
46 explanation on the “Leading Parameter” which was inadequately explained in applicant’s
47 response to RAI-25 S01 (Reference 21). The applicant stated that the “Leading Parameter” is
48 defined as a [
49

50]^{a,c} In an example provided by the applicant, a model validation against SET was performed

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 32 -

1 with a plot of measured (from an experiment) versus calculated values. [

2
3]^{a,c} This is a “Relevant
4 Parameter,” accounting for model uncertainty. Since it does not account for experimental
5 uncertainty, it is not a “Leading Parameter.” To account for both the experimental and model
6 uncertainty, a model validation against SET is performed and the calculated results are
7 compared to experimental data with uncertainty. To consider both the experimental and model
8 uncertainties a different method of creating the envelope of 2-dimensional uncertainties is used
9 as described in Section B-7.2 of WCAP-16747-P-A (Appendix B). The leading parameter is one
10 of the uncertainty input parameters (See Table 8-3 of TR). It is sampled according to a defined
11 distribution function, together with other parameters such as MCPR, PCT as demonstrated in
12 Section 8 of the TR.

13
14 The applicant has summarized the definitions for various parameters. Candidate parameters
15 are all code input and modeling parameters needed to simulate the high ranked phenomena
16 identified in PIRT.

17
18 Relevant parameters are selected from the candidate parameters having a significant influence
19 on FOM. This process is described in response to RAI-23 S01 and is demonstrated in response
20 to RAI-25 S02 (Reference 24).

21
22 Leading parameters are relevant parameters for which the uncertainty from comparison to the
23 experimental database (SET) is combined with model uncertainty.

24
25 The DUA presented in this section provides a general guidance by which uncertainty
26 determination process for parameters required for analyses is performed. It does not provide a
27 full examination of any particular code. However, the NRC staff has determined that the
28 process described in the TR and in the RAI responses are acceptable for the purpose stated in
29 the TR.

30 31 3.7.4 Uncertainty Analysis Methodology

32
33 This section describes the methodology for calculation of combined bias and uncertainty when
34 evaluating operating limits or safety margins to the acceptance criteria. The stated purpose of
35 the uncertainty analysis in the TR is to predict a best estimate value of a FOM by accounting for
36 uncertainties and biases of the input and modeling parameters to ensure that operating limits
37 and safety margins meet the acceptance criteria. The TR describes the process for defining
38 applicable input and model parameters as well as the process of uncertainty evaluation. [

39
40]^{a,c}
41
42 The parameters for the EMs are ranked “high,” “medium,” or “low” importance in the PIRT.
43 Each phenomena is assigned an “importance” grade corresponding to their influence on the
44 FOM. In the TR, [

45
46]^{a,c}
47
48 There are several steps the applicant uses in the transient uncertainty evaluation process.
49 Tolerance limits with 95/95 level is used in the uncertainty evaluation for all operating limits or
50 safety margins to acceptance criteria. [

] ^{a,c}

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 33 -

1 []^{a,c} The number of output parameters that depend on the type of analysis must be
 2 specified. The output parameters are discussed in Section 6 of the TR. Using the tolerance
 3 limits and the number of output parameters, the number of code runs is calculated using
 4 Equation 11 or 22 of Appendix B of the TR. Based on PIRT and CCA the input parameters are
 5 defined in terms of probabilistic distribution using the Table 7-1 as guidance. A run matrix is
 6 created for the Monte-Carlo simulation generated by sampling the probabilistic distributions of
 7 the input parameters n-times where the “n” is determined from the above two steps. Using the
 8 run matrix parameters the transient event is computed for each case and the event acceptance
 9 criteria are extracted from the output files. Finally, the results are tested for normality using the
 10 procedure in Appendix B of the TR. If the data passes the normality test, then the 95/95 value
 11 is calculated using the Equation 28 of Appendix B of TR. If the normality test fails, then the
 12 order statistics method is used instead to determine 95/95 value. The results are tallied, and
 13 using order statistics with the 95/95 methodology, the upper and lower limits are determined
 14 from the results. [

] ^{a,c}

16
 17 Section 7.4.1 of the TR describes how the parameters are selected in the uncertainty analysis
 18 using the guide according to Table 7-1 of the TR. The parameters fall in to three categories:

- 19
 20 • Nominal with uncertainty: [

] ^{a,c}

- 21
 22 • Nominal without uncertainty: [

] ^{a,c}

- 23
 24
 25
 26 • Conservative: [

] ^{a,c}

27
 28
 29
 30
 31
 32
 33
 34 3.7.5 Uncertainty Evaluation Methods

35 Appendix B.1 of the TR provides a summary of theoretical basis for the statistical method used
 36 in the uncertainty evaluation, namely, the statistical properties of the Normal Distribution and the
 37 Order Statistics method. Appendix B.1 of the TR describes the technical basis for single
 38 parameter uncertainty evaluation using the order statistics method. Appendix B.2 describes the
 39 technical basis for multiple parameter uncertainty evaluation by the order statistics method.
 40 Appendix B.3 of the TR provides the technical basis for the uncertainty evaluation by statistical
 41 properties of the normal distribution methods. The following sections will briefly discuss the
 42 above three methodologies.

43
 44 The uncertainty analysis methodology discussed in Subsection 6.2.1.1, Section 7.4, and
 45 Appendix B.1 of the TR alludes to the choice and use of an estimator grade, which influences
 46 the number of calculations that must be performed. In RAI 27, the NRC staff requested the
 47 applicant to clarify the method for determining the estimator grade for a specific type of analysis
 48 and to provide a discussion of, or reference to, the decision-making process for the selection of
 49 the estimator grade as a function of the tradeoff between the number of calculations and the
 50 “risk of over-conservatism.” The applicant’s response provided information (References 25, 26,

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 34 -

1 and 27) that describes the use of non-parametric and order statistics in estimating uncertainties
 2 in PCT, local maximum clad oxidation for large break LOCAs. The response includes a detailed
 3 discussion on the influence of the estimator grade on the analysis output. The estimator is the
 4 smallest number of a code runs in order to estimate the tolerance limit with a specified
 5 probability on a specified confidence interval. The response to RAI-27 shows different estimator
 6 grade for different combinations of probability and confidence levels. The values listed in the
 7 Table for RAI-27 response is calculated using Equation 11 of Appendix B of the TR and is
 8 repeated in the SE as Table 1. The Table from RAI-27 response lists the confidence estimator
 9 grades for probability interval ranging from 95 percent to 99 percent and for trials 59, 93, 124,
 10 and 153 trials. For example, the confidence represents the probability of exceeding an upper
 11 X^{th} quantile for the output parameter.

12
 13 Table-1. Confidence level for various probability
 14

Probability Interval (quantile) (%)	Confidence -1 st Estimator Grade (59 Trials) (%)	Confidence -2 nd Estimate grade (93 Trials) (%)	Confidence -3 rd Estimator grade (124 Trials) (%)	Confidence -4 th Estimator grade (153 Trials) (%)
95	95	95	95	95
97	83	77	72	68
98	70	56	45	37
99	45	24	13	7

15
 16 For example, Table-1 shows that using the 1st estimator grade may be seen to be bounding, as
 17 the probability (confidence) of exceeding the higher value quantiles (>95%) is largest for this
 18 case. First order estimator leads to higher estimates of 95/95 value with higher probability than
 19 higher order estimators. This estimator grade requires the lowest amount of code runs and is
 20 therefore primarily used to evaluate the FOMs. Higher estimator grade may be chosen based
 21 on the analysis type. The applicant recognizes the importance of the estimator grade in the
 22 analysis and the corresponding number of code runs will be determined on a case-by-case
 23 basis and documented with the results of the analysis. The applicant identifies two types of
 24 analysis that influence the estimator grade: (1) simultaneous analysis of several output
 25 parameters (FOM) for the ATWS event and (2) uncertainty analysis of one output parameter
 26 typical for AOO analysis where MCPR is the parameter under consideration.

27
 28 For the first case, where several output parameters are evaluated, the 1st estimator grade is
 29 used in the analysis. This is due to the relatively large amount of code runs necessary to fulfill
 30 the 95/95 criterion even for the 1st estimator grade.

31
 32 For the second case where the uncertainty of one output parameter is evaluated, all relevant
 33 input and modeling parameters are set to their bounding values. In this case, first estimator
 34 grade may be chosen, as this choice bounds all other estimators.

35
 36 In case extra conservatism is needed, a higher estimator grade may be used in the analysis.
 37 The number of code runs will be documented together with the analysis result.

38
 39 Appendix B.2 of the TR describes multiple parameter uncertainty evaluation where
 40 simultaneous evaluation of several output parameters such as OLMCPR and reactor vessel
 41 pressure. The treatment for the multiple parameter uncertainty calculations is described in an

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 35 -

1 extension of Guba's treatment in Reference 28. In this extension of Guba's formulation to
 2 multiple variables, the dependency of output variables is represented by an unknown joint
 3 density distribution function. In order to solve the problem of setting tolerance limits using an
 4 unknown density function, except that it is continuous, the order statistics is found to be a
 5 satisfactory solution suggested by Wilks (Reference 27) in which the distribution free limits can
 6 be given only by means of order statistics. Order statistics is unable to exploit the total amount
 7 of information from the sample when the density function is unknown. With probability and
 8 confidence known, the analyst can anticipate either a wider tolerance interval as in the case of
 9 known density function (Reference 28). Appendix B.2 summarizes the detailed analysis in
 10 Reference 28 which defines the number of code runs needed to obtain a specific probability (%)
 11 at a confidence interval (%) for one-sided probability interval and a specie number of
 12 parameters evaluated simultaneously. The solution of Equation 22 for probability of 0.95 and
 13 confidence of 0.95 for 1 through 3 parameters is listed in Table-2.

14
 15
 16
 17

Table-2 Number of Code Runs for Simultaneous Evaluation of 1-3 Event Acceptance
 Criteria

Number of Parameters	Number of Code Runs
1	59
2	93
3	124

18

19 Appendix B.3 of the TR lists several properties of the normal distribution uncertainty evaluation
 20 methods based on the assumption that the output parameter is distributed normally. Ideally for
 21 normally distributed continuous parameters, Appendix B.3 defines mean value and standard
 22 deviation. For practical situations, the finite number of code runs, this appendix provides
 23 sample mean and sample standard deviation.

24

25 If mean (μ) and standard deviation (σ) are known the upper estimate of the 95th probability level
 26 for the parameter under investigation ($X_{95,95}$) could be calculated with 100 percent confidence by
 27 the formula:

28

$$X_{95,95} = \mu + 1.645\sigma$$

29

30 In practice, both μ and σ are unknown and are estimated by the sample mean and sample
 31 standard deviation from a vector of N random parameter X. For this case, a 95th probability
 32 level of the parameter under investigation is estimated with 95 percent confidence by the
 33 equation:

34

$$X_{95,95} = \bar{\mu} + z_{95,95} s_n,$$

35

36 Where $X_{95,95}$ is the 95/95 estimate of the parameter under investigation and $z_{95,95} > 1.645$ is a
 37 factor for the one-sided normal tolerance limit and s_n is the standard deviation calculated using
 38 Equation (26) of Appendix B.3 of the TR.

39

40

41

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 36 -

1 For an example, if the OLMCPR (i) value has to be obtained from the sample of 59 runs on a
2 95 percent probability level, with 95 percent confidence, then the sample mean is calculated
3 using Equation 25 of Appendix B.3, the sample standard deviation according to Equation 26,
4 $Z_{95,95} = 2.024$, and the OLMCPR(i) per Equation 28 of Appendix B.3.

5
6 3.7.6. Summary and Conclusion for Uncertainty Analysis

7
8 This section considers the statistical treatment of uncertainties as well as biases. As discussed
9 in Subsection 3.7.3 of the SE, the applicant provided an acceptable response to RAI 25 S02
10 regarding how biases are reflected in its uncertainty analysis. The NRC staff considered
11 several related guidance documents in the process of evaluating the uncertainty methodology in
12 the TR, namely RG 1.203 (Reference 4), which provides guidance regarding the subject of
13 uncertainties in a very broad sense and RG 1.157 which explains the acceptance of the
14 95 percent probability (Reference 29).

15
16 RG 1.157 states that:

17
18
19 The basis for selecting the 95% probability level is primarily for consistency with
20 standard engineering practice in regulatory matters involving thermal hydraulics.
21 Many parameters, most notably the departure from nucleate boiling ratio
22 (DNBR), have been found acceptable by the NRC staff in the past at the 95%
23 probability level.

24
25
26 The applicant's uncertainty analysis is intended to predict a best estimate value to account for
27 uncertainties and biases of the relevant input and modeling parameters to ensure operating
28 limits and safety margins meet the acceptance criteria. The methods outlined above can
29 correctly result in the determination of FOM with 95/95 interval provided the uncertainty
30 methodology is correctly implemented. The NRC staff has noted that there are many areas
31 where engineering and statistical methods are applied appropriately and successfully in
32 evaluating nuclear reactor operating limits and margins to safety including areas that are
33 deterministic in nature.

34
35 The uncertainty analysis as described in the TR has been verified and found mathematically
36 correct and acceptable. It can provide statistically correct 95/95 values for FOM and can be
37 used to establish operating limits and safety margins. The TR and responses to RAIs
38 address sources of code uncertainty, including the mathematical models in the code and the
39 user-selected inputs. However, appropriate care and review should be performed regarding
40 the chosen distributions for input parameters that are subject to the Monte Carlo sampling.

41
42 The NRC staff has found the uncertainty analyses methodology acceptable in the determination
43 of operating parameters, safety limits, and margins to safety for operating BWR/2 through
44 BWR/6 plants.

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 37 -

1 3.8 DEMONSTRATION ANALYSIS
2

3 Chapter 8 of the TR describes the application of the Fast Transients and ATWS methodology
4 for Load Rejection without Bypass transient (LRWBP) event. The description consists of
5 transient group and power plant specification, definition of operating limits or safety margins to
6 acceptance criteria, PIRT selection, computational tool selection, CCA, DUA, nominal case
7 analysis, and uncertainty evaluation. The plant type used for the demonstration analysis is the
8 ABWR design. Therefore the details of the demonstration analysis is not described in this
9 Section.

10
11 **4.0 LIMITATIONS, CONDITIONS, AND COMMITMENTS**
12

13 The NRC staff's approval of WCAP-17203-P/WCAP-17203-NP, Revision 0-2, for use in the
14 BWR/2 through BWR/6 designs is subject to the following conditions/limitations and in
15 accordance with the commitments made by the applicant in the cited RAI responses.

16
17 4.1 Limitations and Conditions
18

- 19 1. Since the CCA and DUA are review acceptance criteria per SRP Section 15.0.2 for
20 transients and accidents EM, in order to support the approval of changes to any EM, any
21 licensing submittal that uses the EM methodology defined in the approved version of the
22 TR must include a detailed description of the changes to the EM.
- 23 2. Even though the TR is applicable to BWR/2 through BWR/6 and ABWR, this SE
24 addresses the application of the methodology only to BWR/2 through BWR/6.
- 25 3. The applicant provided a response to the RAI-1 (Reference 30) indicating that the EM
26 capturing calculational framework for evaluating the behavior of the RCS during a
27 postulated accident is contained in code specific TRs: RPA-90-90-P-A (BISON) and
28 WCAP-16747-P (POLCA-T) and its appendices. For AOO fast transients and ATWS
29 events (design bases and methodology for WCAP-17203-P) the code methods listed
30 within the TR are WCAP-16747-P-A (POLCA-T) and qualification codes are
31 WCAP-16747-P Appendices C and D, as well as BISON series of codes. Only
32 NRC-approved codes shall be utilized for fast transients and ATWS analysis.

33
34 4.2 Commitments
35

- 36 1. In the response to RAI-5 regarding TR Section 3.1, "AOO Acceptance Criteria,"
37 Westinghouse states that the reactor coolant system design pressure for ATWS event
38 should not exceed the ASME Service Level C limit consistent with SRP Section 15.8,
39 "Anticipated Transients Without Scram." In the same response (to RAI-5) Westinghouse
40 commits to using a value of 120% design pressure when evaluating reactor pressure
41 vessel integrity during an ATWS event.
- 42 2. In the response to NRR-RAI 43, the applicant committed to validate the assumed biases
43 for the hot and average rods in Section 6.4, "Analysis Methodology," of the TR by
44 performing code-specific confirmatory calculations on first application.
- 45 3. In the response to NRR RAI-34 S1, the applicant committed to use the generically
46 approved CCA and DUA processes to determine the final list of both code and input
47 uncertainty parameters specified on a plant specific basis which will be used in licensing
48 applications.
49
50

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 38 -

5.0 CONCLUSION

Westinghouse presented a methodology of the EM for analyzing fast transients and ATWS events for first and reload cores. The methodology presented in WCAP-17203-P/ WCAP-17203-NP, Revision 0-2, for fast transients and ATWS events can be analyzed using 1D or 3D dynamic transient analysis computer codes as described in the draft SE. Using transient grouping and acceptance criteria for AOOs and ATWS events as per Chapters 4 and 15 of the SRP, a PIRT is created. The PIRT defines the phenomena which have to be addressed when evaluating operating limits and safety margins to acceptance criteria. Once the operating limits and safety margins to acceptance criteria are determined for AOOs, uncertainty analysis is performed to evaluate the impact of uncertainties and biases on these limits in order to account for the uncertainty in the best-estimate result.

The NRC staff has reviewed WCAP-17203-P/WCAP-17203-NP, Revision 0-2, TR with respect to the transient grouping, acceptance criteria, PIRT parameters, transient analysis methodology, and uncertainty analysis, and determined that the methodology is acceptable for analysis of fast transients and ATWS events for BWR/2 through BWR/6 subject to limitations/conditions contained within this SE and the commitments made by the applicant listed in Section 4 of this SE.

6.0 REFERENCES

1. Submittal of WCAP-17203-P/WCAP-17203-NP, Revision 0, "Fast Transient and ATWS Methodology," South Texas Project, Westinghouse Electric Company, dated June 30 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML101830262).
2. Submittal of WCAP-17203-P/WCAP-17203-NP, Revision 0-2, "Fast Transient and ATWS Methodology," South Texas Project, Westinghouse Electric Company, dated October 20 2014 (ADAMS Accession No. ML14301A278).
3. CENPD-300-NP-A, "Reference Safety Report for Boiling Water Reactor Reload Fuel," ABB Combustion Engineering, Inc., dated July 1996 (ADAMS Accession No. ML110260388).
4. U. S. Nuclear Regulatory Commission Regulatory Guide 1.203, "Transient and Accident Analysis Methods," dated December 2005 (ADAMS Accession No. ML053500170).
5. U. S. Nuclear Regulatory Commission NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition," dated March 2007.
6. *U.S. Code of Federal Regulations*, "General Design Criteria for Nuclear Power Plants," 10 CFR Part 50, Appendix A.
7. U. S. Nuclear Regulatory Commission NUREG/CR-6744, "Phenomenon Identification and Ranking Tables (PIRTs) for Loss of- Coolant Accidents in Pressurized and Boiling Water Reactors Containing High Burnup Fuel," September 2001 (ADAMS Accession No. ML013540628).

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

- 39 -

- 1 8. Letter from Scott Head (Nuclear Innovation North America LLC (NINA)) to U. S. Nuclear
2 Regulatory Commission, U7-STP-NRC-110015, South Texas Project Units 3 and 4,
3 “Response to Request for Additional Information” (RAI-1, RAI-2, RAI-3, RAI-4, RAI-5,
4 RAI-8, RAI-9, RAI-10, RAI-11, RAI-12, RAI-15, RAI-16), dated January 18 2011
5 (ADAMS Accession No. ML110200121).
6
- 7 9. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
8 Project Units 3 and 4, “Response to Supplemental Request for Additional Information,
9 (RAI-9 S01, RAI-17 S01, RAI-19 S01, RAI-20 S01, RAI-23 S01 through RAI-29 S01),
10 dated June 13 2011 (ADAMS Accession No. ML11166A048).
11
- 12 10. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
13 Project Units 3 and 4, “Response to Request for Additional Information” (NRR RAI 2S1,
14 NRR RAI 10S1, NRR RAI 11 S1, NRR RAI 33 S1, NRR RAI 24 S1, NRR RAI 26 S1,
15 NRR RAI 28 S1, NRR RAI 31 S1, NRR RAI 37 S1, NRR RAI 38 S1, NRR RAI 41 S1,
16 NRR RAI 44), dated May 3, 2012 (ADAMS Accession No. ML12130A250).
17
- 18 11. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
19 Project Units 3 and 4, “Response to Request for Additional Information” (RAI-6, RAI-7,
20 RAI-17, RAI-18, RAI-23, RAI-24, RAI-27, RAI-29, RAI-30, and RAI-33), dated March 21,
21 2011 (ADAMS Accession No. ML110840711).
22
- 23 12. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
24 Project Units 3 and 4, “Response to Request for Additional Information” (NRR RAI-6
25 through NRR RAI-9, NRR RAI-23, NRR RAI-26 through NRR RAI-30, NRR-RAI-32,
26 NRR-RAI-36, NRR RAI-37), dated December 28 2011 (ADAMS Accession
27 No. ML12006A089).
28
- 29 13. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
30 Project Units 3 and 4, “Response to Request for Additional Information” (NRR RAI-6
31 through NRR RAI 9 S1, NRR RAI 12 S1, NRR RAI 15 S1, NRR RAI 32 S1,
32 NRR RAI 34 S1, NRR RAI 42, NRR RAI 43), dated July 3 2012 (ADAMS Accession
33 No. ML12191A070).
34
- 35 14. WCAP-16747-P-A, “POLCA-T: System Analysis Code with Three-Dimensional Core
36 Model,” September 14 2010 (ADAMS Accession No. ML102770087).
37
- 38 15. WCAP-16747-P, Appendices C and D, “POLCA-T System Analysis Code with Three-
39 dimensional Core Model, Appendices C and D,” October 2010 (ADAMS Accession
40 No. ML103060251).
41
- 42 16. WCAP-16606-P-A/WCAP-16606-NP-A, “Supplement 2 to BISON Topical Report
43 RPA 90-90-P-A,” Westinghouse, dated April 22, 2008 (ADAMS Accession
44 No. ML081280714).
45
- 46 17. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
47 Project Units 3 and 4, “Response to Supplemental Request for Additional Information”
48 (RAI-1b S01, RAI-2 S01, RAI-3 S01, RAI-9b S01 through RAI 9e S01, RAI-9j S01,
49 RAI-9k S01, RAI-10b S01, RAI 10e S01 through RAI 10g S01, RAI-10i S01, RAI-11 S01,
50 RAI-12 S01, RAI-15 S01), dated May 31, 2011 (ADAMS Accession No. ML11152A187).
51

~~OFFICIAL USE ONLY – PROPRIETARY INFORMATION~~

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 40 -

- 1 18. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
2 Project Units 3 and 4, "Response to Request for Additional Information" (NRR RAI-3,
3 NRR RAI-19, NRR RAI-20, NRR RAI-40, NRR RAI-41), dated December 19, 2011
4 (ADAMS Accession No. ML11361A387).
5
- 6 19. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
7 Project Units 3 and 4, "Response to Request for Additional Information" (NRR RAI 8 S1,
8 NRR RAI 16 S1, NRR RAI 20 S1, NRR RAI 23 S1, NRR RAI 25 S1, NRR RAI 27 S1),
9 dated June 4, 2012 (ADAMS Accession No. ML12159A017).
10
- 11 20. Submittal of Westinghouse Electric Company Topical Report WCAP-17202-P
12 Revision 0-1, "Supplement 4 to BISON Topical Report RPA 90-90-P-A," dated
13 September 30, 2014 (ADAMS Accession No. ML14276A444).
14
- 15 21. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
16 Project Units 3 and 4, "Responses to Supplemental Request for Additional Information"
17 (RAI-9b S01, RAI-9c S01, RAI-9d S01, RAI-17 S01, RAI-19 S01, RAI-20 S01, RAI-23
18 S01 through RAI-25 S01, RAI-28 S01, RAI-29 S01), dated June 13, 2011 (ADAMS
19 Accession No. ML110550673).
20
- 21 22. U. S. Nuclear Regulatory Commission NUREG/CR-5249, "Quantifying Reactor Safety
22 Margins, Application of Code, Scaling, Applicability, and Uncertainty Evaluation
23 Methodology to a Large Break Loss-of-Coolant Accident," B. Boyack, et.al. US NRC,
24 December 1989.
25
- 26 23. WCAP-17202-P, Revision 0-1, "Supplement 4 to BISON Topical Report
27 RPA 90-90-P-A," dated May 18, 2017 (ADAMS Accession No. ML17156A815).
28
- 29 24. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
30 Project Units 3 and 4, "Response to Supplemental Request for Additional Information"
31 (Response to RAI-25 S02), NINA Reference Number U7-C-NINA-NRC-110129, dated
32 October 27, 2011 (ADAMS Accession No. ML11307A240).
33
- 34 25. Frepoli, C., Oriani, L., "Notes of the Implementation of Non-parametric Statistics within
35 the Westinghouse Realistic Large Break LOCA Evaluation Model (ASTRUM),"
36 Proceedings of ICAPP 2006, Reno, NV, Paper 6257, June 4-8, 2006.
37
- 38 26. Frepoli, C. "An Overview of Westinghouse Realistic Large Break LOCA Evaluation
39 Model," Science and Technology of Nuclear Installations, Volume 2008, Article ID
40 498737, October 2008.
41
- 42 27. Wilks, S.S., "Determination of Sample Sizes for Setting Tolerance Limits," The Annals of
43 Mathematical Statistics, Vol. 12, pp. 91-96, 1941.
44
- 45 28. Attila Guba, Mihlay Makai, and Lenard Pal, "Statistical Aspects of Best Estimate
46 Methods -1, Elsevier Science Direct, Reliability Engineering and System Safety 80
47 (20030 pp. 217-232).
48
- 49 29. Regulatory Guide 1.157, "Best-Estimate Calculations of Emergency Core Cooling
50 System Performance," U.S. Nuclear Regulatory Commission, May 1989.
51

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

OFFICIAL USE ONLY – PROPRIETARY INFORMATION

- 41 -

- 1 30. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
2 Project Units 3 and 4, "Response to Request for Additional Information" (NRR RAI-1,
3 NRR RAI 5, NRR RAI 10 through 12, NRR RAI-15 through 18, NRR RAI 21,
4 NRR RAI-22, NRR RAI-24, NRR RAI-31, NRR-RAI-31, NRR RAI-33, NRR RAI-35,
5 NRR-RAI-38, NRR RAI-39), dated November 8, 2011 (ADAMS Accession
6 No. ML11318A019).
7
- 8 31. NUREG/CR-6742, "Phenomenon Identification and Ranking Tables (PIRTs) for Rod
9 Ejection Accidents in Pressurized Water Reactors Containing High Burnup Fuel," US
10 NRC, September 2001 (ADAMS Accession No. ML012890487).
- 11 32. NUREG/CR-6743, "Phenomenon Identification and Ranking Tables (PIRTs) for Power
12 Oscillations Without Scram in Boiling Water Reactors Containing High Burnup Fuel,"
13 USNRC, September 2001 (ADAMS Accession No. ML012850324).
- 14 33. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
15 Project Units 3 and 4, "Response to Supplemental Requests for Additional Information"
16 (RAI-9b S02, RAI-19 S02, RAI-20 S02), dated October 19, 2011 (ADAMS Accession
17 No. ML11297A108).
18
- 19 34. Letter from Scott Head (NINA) to U. S. Nuclear Regulatory Commission, South Texas
20 Project Units 3 and 4, "Responses to Request for Additional Information" (RAI-13, RAI-4,
21 RAI-19 through RAI-22, RAI-25, RAI-26, RAI-28, RAI-31, RAI-32), dated February 17,
22 2011 (ADAMS Accession No. ML110550637).
23

24 Principal Contributor: Mathew Panicker, NRR/DSS/SNPB

25
26 Date: April 30, 2018