

Non-Proprietary

Evaluation of Main Steam and Feedwater Piping applied
to the graded approach for the APR1400

APR1400-E-B-NR-16001-NP, Rev. 0

Evaluation of Main Steam and Feedwater Piping applied to the graded approach for the APR1400

Revision 0

Non-Proprietary

July 2017

Copyright © 2017

Korea Electric Power Corporation &

Korea Hydro & Nuclear Power Co., Ltd

All Rights Reserved

REVISION HISTORY

Revision	Date	Page	Description
0	July 2017	All	Standard Issue

This document was prepared for the design certification application to the U.S. Nuclear Regulatory Commission and contains technological information that constitutes intellectual property of Korea Hydro & Nuclear Power Co., Ltd..

Copying, using, or distributing the information in this document in whole or in part is permitted only to the U.S. Nuclear Regulatory Commission and its contractors for the purpose of reviewing design certification application materials. Other uses are strictly prohibited without the written permission of Korea Electric Power Corporation and

ABSTRACT

This report is in response to the Question No. 03.12-2 in RAI No. 35-7955, and provides summary information on the piping analysis approach and results as well as methodology of the piping analysis, necessary to support safety determination of the Main Steam (MS) and Feedwater (FW) piping systems. To demonstrate that the subject piping, which has been structurally evaluated based on the graded approach described in DCD Tier 2, Section 14.3.2.3, conforms to the requirements of ASME B&PV Code, Section III, mandated by 10CFR50.55a, the following information is provided:

- A tabulated, quantitative summary of the calculated maximum stresses and fatigue usage factors (if applicable) with a comparison to ASME B&PV Code allowable for each Code equation.
- For equipment nozzles, a tabulated quantitative summary of the calculated reaction loads compared to the specific nozzle allowable values.
- For containment penetrations, quantitative maximum calculated results compared to the allowable values.

Based on the review of summary information and component design drawings provided in this report, it is concluded that the APR1400 Main Steam and Feedwater piping that are included in the scope of Class 2 piping system design based on the graded approach, demonstrates the conformance to the requirements of ASME B&PV Code, Section III.

TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1	Graded Approach.....	1
1.2	Scope of Report.....	1
1.3	Piping Subsystem Description.....	2
1.3.1	MS101	2
1.3.2	MS102	2
1.3.3	MS103	3
1.3.4	MS104	3
1.3.5	FW101	4
1.3.6	FW102	4
1.3.7	MS271	5
1.3.8	MS272	5
1.3.9	FW209	6
1.3.10	FW219	6
2.0	SUMMARY OF RESULTS AND CONCLUSIONS	7
2.1	Conclusions	7
2.2	MS101	7
2.3	MS102	8
2.4	MS103	8
2.5	MS104	9
2.6	FW101	9
2.7	FW102	10
2.8	MS271	10
2.9	MS272	11
2.10	FW209	11

2.11	FW219	12
3.0	NOMENCALTURE	13
4.0	ASSUMPTIONS AND OPEN ITEMS	14
4.1	Assumptions	14
4.2	Open Items	14
5.0	ACCEPTANCE CRITERIA	15
5.1	Design Basis for Thermal and Mechanical Loading	15
5.2	Functional Capability Criteria.....	15
5.3	High Energy Line Pipe Break Postulation Criteria.....	16
6.0	LOADS AND LOAD COMBINATIONS	17
6.1	Design Basis for Thermal and Mechanical Loading	17
6.1.1	Thermal Loading (TRNG).....	17
6.1.2	Normal Operation Weight Loading (WGHT).....	17
6.1.3	IRWST Hydro Dynamics Inertia Loading (IRWST).....	17
6.1.4	Safe Shutdown Earthquake Inertia Loading (SSE)	17
6.1.5	RCS Branch Line Pipe Break Loading (BLPB).....	17
6.1.6	Safe Shutdown Earthquake Building Displacement Loading (SSBD).....	17
6.1.7	Safe Shutdown Earthquake RCS Header Displacement Loading (SSHD).....	17
6.1.8	Feedwater Pump Trip Loading (FWPT).....	18
6.1.9	Turbine Main Stop Valve Closure Loading (TSVC)	18
6.1.10	Postulated Line Break in FW System (FWLB)	18
6.1.11	Postulated Line Break in FW System (MSLB).....	18
6.1.12	Safety Relief Valve Transient Loading(SRV).....	18
6.1.13	Atmospheric Dump Valve Transient Loading(ADV).....	18
6.1.14	Aux Feedwater Pump Turbine Driven Line Break in MS System (AFPTLB).....	18
6.1.15	Drip Leg Line Break in MS System (DRLB)	18
6.1.16	Coincident Pressure Loadings.....	18

6.2	Loading Combination.....	19
6.2.1	Main Steam piping inside the containment building	19
6.2.2	Main Feedwater piping inside the containment building.....	19
6.2.3	Main Steam piping inside the Auxiliary building.....	20
6.2.4	Main Steam piping inside the Auxiliary building.....	20
6.2.5	Main Feedwater piping inside the Auxiliary building.....	21
6.2.6	Main Feedwater piping inside the Auxiliary building.....	21
7.0	ANANYSIS RESULT	22
7.1	MS101	22
7.1.1	Subsystem Plot.....	22
7.1.2	Pipe Data Sheet.....	23
7.1.3	Piping Stress Evaluation Results.....	24
7.2	MS102	28
7.2.1	Subsystem Plot.....	28
7.2.2	Pipe Data Sheet.....	29
7.2.3	Piping Stress Evaluation Results.....	30
7.3	MS103	34
7.3.1	Subsystem Plot.....	34
7.3.2	Pipe Data Sheet.....	35
7.3.3	Piping Stress Evaluation Results.....	36
7.4	MS104	40
7.4.1	Subsystem Plot.....	40
7.4.2	Pipe Data Sheet.....	41
7.4.3	Piping Stress Evaluation Results.....	42
7.5	FW101	46
7.5.1	Subsystem Plot.....	46
7.5.2	Pipe Data Sheet.....	47

7.5.3	Piping Stress Evaluation Results	48
7.6	FW102	56
7.6.1	Subsystem Plot	56
7.6.2	Pipe Data Sheet	57
7.6.3	Piping Stress Evaluation Results	58
7.7	MS271	66
7.7.1	Subsystem Plot	66
7.7.2	Pipe Data Sheet	67
7.7.3	Piping Stress Evaluation Results	68
7.8	MS272	89
7.8.1	Subsystem Plot	89
7.8.2	Pipe Data Sheet	90
7.8.3	Piping Stress Evaluation Results	91
7.9	FW209	112
7.9.1	Subsystem Plot	112
7.9.2	Pipe Data Sheet	113
7.9.3	Piping Stress Evaluation Results	113
7.10	FW219	121
7.10.1	Subsystem Plot	121
7.10.2	Pipe Data Sheet	122
7.10.3	Piping Stress Evaluation Results	122
8.0	COMPUTER CODE	132
8.1	PIPESTRESS 3.9.0	132
9.0	REFERENCE	133

LIST OF TABLES

Table 2.2-1	Location of Highest Stress in MS101.....	7
Table 2.3-1	Location of Highest Stress in MS102.....	8
Table 2.4-1	Location of Highest Stress in MS103.....	8
Table 2.5-1	Location of Highest Stress in MS104.....	9
Table 2.6-1	Location of Highest Stress in FW101.....	9
Table 2.7-1	Location of Highest Stress in FW102.....	10
Table 2.8-1	Location of Highest Stress in MS271.....	10
Table 2.9-1	Location of Highest Stress in MS272.....	11
Table 2.10-1	Location of Highest Stress in FW209.....	11
Table 2.11-1	Location of Highest Stress in FW219.....	12
Table 5.1-1	Code Allowable	15
Table 5.3-1	Pipe Break Location.....	16
Table 6.1-1	Pressure.....	19
Table 6.2-1	MS101, MS102, MS103, MS104 Load Combination.....	19
Table 6.2-2	FW101, FW102 Load Combination.....	19
Table 6.2-3	MS271 Load Combination	20
Table 6.2-4	MS272 Load Combination	20
Table 6.2-5	FW209 Load Combination	21
Table 6.2-6	FW219 Load Combination	21
Table 7.1-1	Criteria Check at Main Steam Outlet Nozzle in MS101	24
Table 7.1-2	Load Check at Main Steam Outlet Nozzle in MS101.....	25
Table 7.1-3	The Stress at the Flued Head Penetration Anchor in MS101.....	26
Table 7.1-4	The Stress at the Pipe Support Location in MS101.....	27
Table 7.2-1	Criteria Check at Main Steam Outlet Nozzle in MS102.....	30
Table 7.2-2	Load Check at Main Steam Outlet Nozzle in MS102.....	31
Table 7.2-3	The Stress at the Flued Head Penetration Anchor in MS102.....	32

Table 7.2-4	The Stress at the Pipe Support Location in MS102.....	33
Table 7.3-1	Criteria Check at Main Steam Outlet Nozzle in MS103.....	36
Table 7.3-2	Load Check at Main Steam Outlet Nozzle in MS103.....	37
Table 7.3-3	The Stress at the Flued Head Penetration Anchor in MS103.....	38
Table 7.3-4	The Stress at the Pipe Support Location in MS103.....	39
Table 7.4-1	Criteria Check at Main Steam Outlet Nozzle in MS104.....	42
Table 7.4-2	Load Check at Main Steam Outlet Nozzle in MS104.....	43
Table 7.4-3	The Stress at the Flued Head Penetration Anchor in MS104.....	44
Table 7.4-4	The Stress at the Pipe Support Location in MS104.....	45
Table 7.5-1	Criteria Check at Main Feedwater Economizer Nozzle in FW101.....	48
Table 7.5-2	The Stress at the Flued Head Penetration Anchor in FW101.....	49
Table 7.5-3	The Stress at Branch Pipe Connection in FW101.....	49
Table 7.5-4	The Stress at Pipe Support Location in FW101.....	50
Table 7.5-5	The Stress at the Valve Location in FW101.....	54
Table 7.6-1	Criteria Check at Main Feedwater Economizer Nozzle in FW102.....	58
Table 7.6-2	The Stress at the Flued Head Penetration Anchor in FW102.....	59
Table 7.6-3	The Stress at Branch Pipe Connection in FW102.....	59
Table 7.6-4	The Stress at Pipe Support Location in FW102.....	60
Table 7.6-5	The Stress at the Valve Location in FW102.....	64
Table 7.7-1	The Stress at Flued Head Penetration Anchor in MS271.....	68
Table 7.7-2	Load Input for Penetration Assembly.....	70
Table 7.7-3	Allowable Load Check for Penetration Assembly.....	71
Table 7.7-4	The Stress at Branch Pipe Connection in MS271.....	73
Table 7.7-5	The Stress at Pipe Support Location in MS271.....	77
Table 7.7-6	The Stress at Valve Location in MS271.....	80
Table 7.7-7	The Stress at Flanged Connection in MS271.....	85
Table 7.8-1	The Stress at Flued Head Penetration Anchor in MS272.....	91

Table 7.8-2	Load Input for Penetration Assembly.....	93
Table 7.8-3	Allowable Load Check for Penetration Assembly	94
Table 7.8-4	The Stress at Branch Pipe Connection in MS272	96
Table 7.8-5	The Stress at Pipe Support Location in MS272	100
Table 7.8-6	The Stress at Valve Location in MS272	104
Table 7.8-7	The Stress at Flanged Connection in MS272	108
Table 7.9-1	The Stress at Flued Head Penetration Anchor in FW209.....	114
Table 7.9-2	Load Input for Penetration Assembly.....	115
Table 7.9-3	Allowable Load Check for Penetration Assembly	116
Table 7.9-4	The Stress at the Pipe Support Location in FW209.....	118
Table 7.9-5	The Stress at Valve Location in FW209.....	119
Table 7.10-1	The Stress at Flued Head Penetration Anchor in FW219.....	123
Table 7.10-2	Load Input for Penetration Assembly.....	124
Table 7.10-3	Allowable Load Check for Penetration Assembly	125
Table 7.10-4	The Stress at Pipe Support Location in FW219.....	127
Table 7.10-5	The Stress at Valve Location in FW219.....	130

LIST OF FIGURES

Figure 1.3-1	Subsystem MS101 Boundary	2
Figure 1.3-2	Subsystem MS102 Boundary	2
Figure 1.3-3	Subsystem MS103 Boundary	3
Figure 1.3-4	Subsystem MS104 Boundary	3
Figure 1.3-5	Subsystem FW101 Boundary	4
Figure 1.3-6	Subsystem FW102 Boundary	4
Figure 1.3-7	Subsystem MS271 Boundary	5
Figure 1.3-8	Subsystem MS272 Boundary	5
Figure 1.3-9	Subsystem FW209 Boundary	6
Figure 1.3-10	Subsystem FW219 Boundary	6
Figure 7.1-1	Subsystem MS101 Plot.....	22
Figure 7.1-2	Subsystem MS101 Pipe Data Sheet.....	23
Figure 7.2-1	Subsystem MS102 Plot.....	28
Figure 7.2-2	Subsystem MS102 Pipe Data Sheet.....	29
Figure 7.3-1	Subsystem MS103 Plot.....	34
Figure 7.3-2	Subsystem MS103 Pipe Data Sheet.....	35
Figure 7.4-1	Subsystem MS104 Plot.....	40
Figure 7.4-2	Subsystem MS104 Pipe Data Sheet.....	41
Figure 7.5-1	Subsystem FW101 Plot	46
Figure 7.5-2	Subsystem FW101 Pipe Data Sheet	47
Figure 7.6-1	Subsystem FW102 Plot	56
Figure 7.6-2	Subsystem FW102 Pipe Data Sheet	57
Figure 7.7-1	Subsystem MS271 Plot.....	66
Figure 7.7-2	Subsystem MS271 Pipe Data Sheet.....	67
Figure 7.7-3	Penetration Assembly Model – MS System.....	72
Figure 7.8-1	Subsystem MS272 Plot.....	89

Figure 7.8-2	Subsystem MS272 Pipe Data Sheet.....	90
Figure 7.8-3	Penetration Assembly Model – MS System.....	95
Figure 7.9-1	Subsystem FW209 Plot	112
Figure 7.9-2	Subsystem FW209 Pipe Data Sheet	113
Figure 7.9-3	Penetration Assembly Model – FW System	117
Figure 7.10-1	Subsystem FW219 Plot	121
Figure 7.10-2	Subsystem FW219 Pipe Data Sheet	122
Figure 7.10-3	Penetration Assembly Model – FW System	126

Non-Proprietary

Evaluation of Main Steam and Feedwater Piping applied
to the graded approach for the APR1400

APR1400-E-B-NR-16001-NP, Rev. 0

1.0 INTRODUCTION

1.1 Graded Approach

Design of Class 1, 2 and 3 piping and components contained in the piping subsystems shall comply with the requirements of ASME Section III (Reference 9.1), subsections NB, NC and ND, respectively, for the conditions described in Section 5.0 of this report. In determination of the scope of piping system and component design for APR1400 DC, the concept of graded approach consistent with SECY-90-377 is taken as documented in DCD Tier 2, Subsection 14.3.2.3.

Piping subsystems analyzed for design certification are selected based on the safety significance. The scope of design for ASME code Class 2 piping includes MS and main FW piping located inside the containment building. MS and main FW piping is the largest ASME Class 2 piping connected to the steam generators and has the highest structural load. The scope of design for MS and main FW piping outside the containment building covers piping (1 Division) from the containment penetration anchors to MSVH (Main Steam Valve House) penetration anchors beyond isolation valves which are located in the break exclusion area in auxiliary building. This report summarizes the stress analyses results for Class 2 piping based on the graded approach.

1.2 Scope of Report

The scope of this report consists of the documentation of Code (NC-3650) compliance of the Class 2 piping components identified on the analytical drawings for the ten representative piping subsystems, namely, MS101 thru MS104, FW101, FW102, MS271, MS272, FW209 and FW219, for which boundaries are described in Figure 1.3-1, 1.3-2, 1.3-3, 1.3-4, 1.3-5, 1.3-6, 1.3-7, 1.3-8, 1.3-9 and 1.3-10, respectively.

1.3 Piping Subsystem Description

1.3.1 MS101

The subject piping subsystem is routed from SG 2 steam outlet nozzle to containment shell penetration.



Figure 1.3-1 Subsystem MS101 Boundary

1.3.2 MS102

The subject piping subsystem is routed from SG 2 steam outlet nozzle to containment shell penetration.



Figure 1.3-2 Subsystem MS102 Boundary

1.3.3 MS103 :

The subject piping subsystem is routed from SG 1 steam outlet nozzle to containment shell penetration.




Figure 1.3-3 Subsystem MS103 Boundary

1.3.4 MS104 :

The subject piping subsystem is routed from SG 1 steam outlet nozzle to containment shell penetration.



Figure 1.3-4 Subsystem MS104 Boundary

1.3.5 FW101 :

The subject piping subsystem is routed from SG 1 economizer nozzle to containment shell penetration.



Figure 1.3-5 Subsystem FW101 Boundary

1.3.6 FW102 :

The subject piping subsystem is routed from SG 2 economizer nozzle to containment shell penetration.



Figure 1.3-6 Subsystem FW102 Boundary

1.3.7 MS271

The subject piping subsystem is routed from containment penetration anchor to MSVH(Main Steam Valve House) penetration anchors.

TS



Figure 1.3-7 Subsystem MS271 Boundary

1.3.8 MS272 :

The subject piping subsystem is routed from containment penetration anchor to MSVH(Main Steam Valve House) penetration anchors.

TS



Figure 1.3-8 Subsystem MS272 Boundary

1.3.9 FW209

The subject piping subsystem is routed from containment penetration anchor to MSVH(Main Steam Valve House) penetration anchors. TS




Figure 1.3-9 Subsystem FW209 Boundary

1.3.10 FW219

The subject piping subsystem is routed from containment penetration anchor to MSVH(Main Steam Valve House) penetration anchors. TS



Figure 1.3-10 Subsystem FW219 Boundary

2.0 SUMMARY OF RESULTS AND CONCLUSIONS

2.1 Conclusions

The class 2 piping systems which are applied to the grade approach were designed to the requirements of the ASME Boiler and Pressure Vessel Code, Section III, 2007 Edition with 2008 Addenda in accordance with the requirements of NC-3600, Service Loadings, Operating Conditions and Test Conditions as specified in the Design Specification.

From the results summarized in this report, it is concluded that the class 2 piping systems of MS101, MS102, MS103, MS104, FW101, FW102, MS271, MS272, FW209 and FW219 satisfy all of the requirements of the Design Specification (Reference 9.5).

2.2 MS101

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.2-1
Location of Highest Stress in MS101**

TS

2.3 MS102

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.3-1
Location of Highest Stress in MS102**

TS

2.4 MS103

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.4-1
Location of Highest Stress in MS103**

TS

2.5 MS104

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.5-1
Location of Highest Stress in MS104**

TS

2.6 FW101

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.6-1
Location of Highest Stress in FW101**

TS

2.7 FW102

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.7-1
Location of Highest Stress in FW102**

TS




2.8 MS271

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.8-1
Location of Highest Stress in MS271**

TS



2.9 MS272

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.9-1
Location of Highest Stress in MS272**

TS



2.10 FW209

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.10-1
Location of Highest Stress in FW209**

TS



2.11 FW219

All pipe stresses meet applicable Code allowables.

The highest stress for each Code equation is tabulated below.

**Table 2.11-1
Location of Highest Stress in FW219**

TS



3.0 NOMENCALTURE

SG	Steam Generator
MS	Main steam
FW	Main FeedWater
S_c	Basic material allowable stress value at room temperature
S_h	Basic material allowable stress value at normal service temperature
S_y	Yield strength
S_a	Allowable stress range for expansion stresses

4.0 ASSUMPTIONS AND OPEN ITEMS

4.1 Assumptions

The vendor information in this report is assumed based on the reference plant.

4.2 Open Items

The small bore branch piping of the main line is not included in this analysis based on the decoupling criteria, which is not designed in DC design stage. The small bore piping should be evaluated after the design is accomplished.

5.0 ACCEPTANCE CRITERIA

5.1 Design Basis for Thermal and Mechanical Loading

The thermal and mechanical loading evaluations of all piping products, used in the design of these subsystems, are performed in accordance with the design rules specified in Paragraphs NC-3652, NC-3653, and NC-3655 for Class 2 piping. The design basis and acceptance criteria listed in Tables 5.1-1 of this report are used as a basis for the calculations.

Table 5.1-1 Code Allowable

Source of Criterion	Allowable Stress	Condition
NC-3652	$1.5 S_h$	Design
NC-3653	<p style="text-align: center;">Lesser of $1.8 S_h$ and $1.5 S_y$ (for Occasional Loads)</p> <p style="text-align: center;">$SA = f(1.25 S_c + 0.25 S_h)$ (for Thermal Expansion)</p> <p style="text-align: center;">$S_h + S_A$ (for Sustained Loads including Thermal Expansion)</p>	Service Level A/B
NC-3655	Lesser of $3.0 S_h$ and $2.0 S_y$	Service Level D
NC-3655(b)(4)	$6.0 S_h$	Service Level D

5.2 Functional Capability Criteria

These piping subsystems (or a portion of this piping subsystem) are designated as “Required for Safe Shutdown” per Section 902 of the system PSDS(Reference 9.5). The requirements for assurance of functional capability are provided in Section 902 of the general PSDS(Reference 9.5).

- a. Piping functional capability is assured by verifying that the maximum stress in Eq.(9) of ASME B&PV Code, Section III NC-3650, regardless of service level, does not exceed Service C limits.
- b. Based on NUREG-1367, functional capability of a piping system is assured by meeting the present code(ASME B&PV Code, Section III NC/ND-3650) Eq.(9), Level D, stress limit of $2S_y$, provided that:
 - Dynamic loads are reversing. This includes loads due to earthquake and pressure wave loads(not slug-flow fluid hammer).
 - Dynamic moments are calculated using an elastic response spectrum analysis with $\pm 15\%$ peak broadening and not more than 5% damping.

- Steady-state(e.g., weight) stresses including non-reversing dynamic loads do not exceed 0.25 Sy.
- Do/t(pipe outer diameter divided by thickness) does not exceed 50.
- External pressure does not exceed internal pressure.

5.3 High Energy Line Pipe Break Postulation Criteria

The portions of the subsystem designated as High Energy Lines requiring break postulation per Reference 9.7 are designed using the acceptance criteria specified below.

Table 5.3-1 Pipe Break Location

Source of Requirement	Acceptance Criteria
Reference 9.7	ASME NC, Eq.(9)+ Eq.(10) $\leq 0.8(1.8S_h+S_A)$

Note : See applicable Code paragraphs for nomenclature.

6.0 LOADS AND LOAD COMBINATIONS

6.1 Design Basis for Thermal and Mechanical Loading

6.1.1 Thermal Loading (TRNG)

6.1.1.1 Thermal Expansion Modes

This piping subsystem contains ASME Code, Section III, piping and the applicable design basis thermal expansion modes are defined in the System (Reference 9.5). The thermal expansion modes are interpreted using the rules specified in the General PSDS (Reference 9.5).

6.1.1.2 Equipment Nozzle Movement (RCS Nozzle Movement)

RCS Nozzle Movements induced by thermal loading are used in stress analysis.

6.1.2 Normal Operation Weight Loading (WGHT)

Normal Operation Weight Loading is that loading due to the weight of the pipe metal, insulation and its contents during the subsystem normal operating service conditions, all valves and in-line equipment, and any significant support or restraint hardware that is directly supported by the pipe.

6.1.3 IRWST Hydro Dynamics Inertia Loading (IRWST)

IRWST Hydro Dynamics Inertia Loading is the inertia portion of the total loading induced by POSRV operation. The inertia loading is the result of excitation amplified by building response motion.

6.1.4 Safe Shutdown Earthquake Inertia Loading (SSE)

Safe Shutdown Earthquake Inertia Loading is the inertia portion of the total loading induced by Safe Shutdown Earthquake excitation amplified by building response motion.

6.1.5 RCS Branch Line Pipe Break Loading (BLPB)

Branch Line Pipe Break Loading is the total loading that is induced by the vibration of unbroken RCS branch line. The subject vibration is the result of excitations of reactor vessel, hot and cold legs, pressurizer and steam generator caused by a RCS branch line pipe break.

6.1.6 Safe Shutdown Earthquake Building Displacement Loading (SSBD)

Safe Shutdown Earthquake Building Displacement load analysis is performed and the maximum building displacements of the building structure are included the seismic analysis report for the applicable building.

6.1.7 Safe Shutdown Earthquake RCS Header Displacement Loading (SSHD)

Safe Shutdown Earthquake RCS Header Displacement load analysis is performed and the maximum header displacements of the RCS are included in the report of interface requirements for RCS branch piping for the applicable RCS header.

6.1.8 Feedwater Pump Trip Loading (FWPT)

Feedwater Pump Trip Loading is the total loading that is induced by Water hammer due to Feedwater Pump Trip.

6.1.9 Turbine Main Stop Valve Closure Loading (TSVC)

Turbine Main Stop Valve Closure Loading is the total loading that is induced by Steam hammer due to Valve fast closure.

6.1.10 Postulated Line Break in FW System (FWLB)

Postulated Line Break Loading in FW System is the total loading that is induced by Line Break in FW System.

6.1.11 Postulated Line Break in MS System (MSLB)

Postulated Line Break Loading in MS System is the total loading that is induced by Line Break in MS System.

6.1.12 Safety Relief Valve Transient Loading(SRV)

Safety Relief Valve Transient Loading is the total loading that is induced by safety relief valve actuation.

6.1.13 Atmospheric Dump Valve Transient Loading(ADV)

Atmospheric Dump Valve Transient Loading is the total loading that is induced by dump valve actuation.

6.1.14 Aux Feedwater Pump Turbine Driven Line Break in MS System (AFPTLB)

Postulated Line Break Loading in MS System is the total loading that is induced by Line Break in MS System.

6.1.15 Drip Leg Line Break in MS System (DRLB)

Postulated Line Break Loading in MS System is the total loading that is induced by Line Break in MS System.

6.1.16 Coincident Pressure Loadings

Two coincident internal pressure loading cases are used for primary load design. Two cases are listed below. Specific descriptions concerning the combination of these pressure loading

conditions with the individual primary loadings identified are contained in Section 6.2.

Table 6.1-1 Pressure

Load Abbreviation	Description
DPRE	Individual component design pressure per Reference 9.5
PPRS	Individual component peak pressure coincident with service level being considered per Reference 9.5

6.2 Loading Combination

The combined loadings described in Table 6.2-1, 6.2-2, 6.2-3, 6.2-4, 6.2-5 and 6.2-6 are used as a design basis for all NC-3650. These conditions address all requirements specified in Reference 9.5.

6.2.1 Main Steam piping inside the containment building

Table 6.2-1 MS101, MS102, MS103, MS104 Load Combination

TS

6.2.2 Main Feedwater piping inside the containment building

Table 6.2-2 FW101, FW102 Load Combination

TS

6.2.3 Main Steam piping inside the Auxiliary building

Table 6.2-3 MS271 Load Combination

TS

A large red bracket is drawn on the page, spanning the width of the table area. It consists of two vertical lines on the left and right sides, connected at the top and bottom by curved lines, indicating that the content of the table is missing or redacted.

6.2.4 Main Steam piping inside the Auxiliary building

Table 6.2-4 MS272 Load Combination

TS

A large red bracket is drawn on the page, spanning the width of the table area. It consists of two vertical lines on the left and right sides, connected at the top and bottom by curved lines, indicating that the content of the table is missing or redacted.

6.2.5 Main Feedwater piping inside the Auxiliary building

Table 6.2-5 FW209 Load Combination

TS

A large red bracket is drawn on the page, spanning the width of the table area. It consists of two vertical lines on the left and right sides, connected at the top and bottom by short horizontal lines, forming a large open bracket shape. This indicates that the content of Table 6.2-5 is missing or redacted.

6.2.6 Main Feedwater piping inside the Auxiliary building

Table 6.2-6 FW219 Load Combination

TS

A large red bracket is drawn on the page, spanning the width of the table area. It consists of two vertical lines on the left and right sides, connected at the top and bottom by short horizontal lines, forming a large open bracket shape. This indicates that the content of Table 6.2-6 is missing or redacted.

7.0 ANANYSIS RESULT

7.1 MS101

7.1.1 Subsystem Plot

TS




Figure 7.1-1 Subsystem MS101 Plot

7.1.2 Pipe Data Sheet

TS




Figure 7.1-2 Subsystem MS101 Pipe Data Sheet

7.1.3 Piping Stress Evaluation Results

7.1.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the main steam outlet nozzle against maximum nozzle load criteria.

7.1.3.1.1 Criteria Check

Table 7.1-1 Criteria Check at Main Steam Outlet Nozzle in MS101

TS

7.1.3.1.2 Loads Check

Table 7.1-2 Load Check at Main Steam Outlet Nozzle in MS101

TS



7.1.3.1.3 Conclusion

Base on the above evaluation, it can be concluded that loads applying on SG steam outlet nozzle safe end are within the allowable, and therefore acceptable.

7.1.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.1-3 The Stress at the Flued Head Penetration Anchor in MS101

TS

7.1.3.3 Branch Pipe Connection

There is no Branch Pipe Connection in this piping subsystem.

7.1.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.1-4 The Stress at the Pipe Support Location in MS101

TS



7.1.3.5 Valve

There is no valve in this piping subsystem.

7.1.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.2 MS102

7.2.1 Subsystem Plot

TS




Figure 7.2-1 Subsystem MS102 Plot

7.2.2 Pipe Data Sheet

TS




Figure 7.2-2 Subsystem MS102 Pipe Data Sheet

7.2.3 Piping Stress Evaluation Results

7.2.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the main steam outlet nozzle against maximum nozzle load criteria.

7.2.3.1.1 Criteria Check

Table 7.2-1 Criteria Check at Main Steam Outlet Nozzle in MS102

TS

7.2.3.1.2 Loads Check

Table 7.2-2 Load Check at Main Steam Outlet Nozzle in MS102

TS



7.2.3.1.3 Conclusion

Base on the above evaluation, it can be concluded that loads applying on SG steam outlet nozzle safe end are within the allowable, and therefore acceptable.

7.2.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.2-3 The Stress at the Flued Head Penetration Anchor in MS102

TS

7.2.3.3 Branch Pipe Connection

There is no Branch Pipe Connection in this piping subsystem.

7.2.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.2-4 The Stress at the Pipe Support Location in MS102

TS

7.2.3.5 Valve

There is no valve in this piping subsystem.

7.2.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.3 MS103

7.3.1 Subsystem Plot




Figure 7.3-1 Subsystem MS103 Plot

7.3.2 Pipe Data Sheet

TS




Figure 7.3-2 Subsystem MS103 Pipe Data Sheet

7.3.3 Piping Stress Evaluation Results

7.3.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the main steam outlet nozzle against maximum nozzle load criteria.

7.3.3.1.1 Criteria Check

Table 7.3-1 Criteria Check at Main Steam Outlet Nozzle in MS103

TS

7.3.3.1.2 Loads Check

Table 7.3-2 Load Check at Main Steam Outlet Nozzle in MS103

TS



7.3.3.1.3 Conclusion

Base on the above evaluation, it can be concluded that loads applying on SG steam outlet nozzle safe end are within the allowable, and therefore acceptable.

7.3.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.3-3 The Stress at the Flued Head Penetration Anchor in MS103

TS

7.3.3.3 Branch Pipe Connection

There is no Branch Pipe Connection in this piping subsystem.

7.3.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.3-4 The Stress at the Pipe Support Location in MS103

TS

7.3.3.5 Valve

There is no valve in this piping subsystem.

7.3.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.4 MS104

7.4.1 Subsystem Plot

TS



Figure 7.4-1 Subsystem MS104 Plot

7.4.2 Pipe Data Sheet

TS




Figure 7.4-2 Subsystem MS104 Pipe Data Sheet

7.4.3 Piping Stress Evaluation Results

7.4.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the main steam outlet nozzle against maximum nozzle load criteria.

7.4.3.1.1 Criteria Check

Table 7.4-1 Criteria Check at Main Steam Outlet Nozzle in MS104

TS

7.4.3.1.2 Loads Check

TS

Table 7.4-2 Load Check at Main Steam Outlet Nozzle in MS104

7.4.3.1.3 Conclusion

Base on the above evaluation, it can be concluded that loads applying on SG steam outlet nozzle safe end are within the allowable, and therefore acceptable.

7.4.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.4-3 The Stress at the Flued Head Penetration Anchor in MS104

TS

7.4.3.3 Branch Pipe Connection

There is no Branch Pipe Connection in this piping subsystem.

7.4.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.4-4 The Stress at the Pipe Support Location in MS104

TS

7.4.3.5 Valve

There is no valve in this piping subsystem.

7.4.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.5 FW101

7.5.1 Subsystem Plot

TS



Figure 7.5-1 Subsystem FW101 Plot

7.5.2 Pipe Data Sheet

TS




Figure 7.5-2 Subsystem FW101 Pipe Data Sheet

7.5.3 Piping Stress Evaluation Results

7.5.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the S/G feedwater economizer nozzle against maximum nozzle load criteria.

7.5.3.1.1 Criteria Check

Table 7.5-1 Criteria Check at Main Feedwater Economizer Nozzle in FW101

TS

7.5.3.1.2 Conclusion

Base on the above evaluation, it can be concluded that loads applying on S/G feedwater economizer nozzle safe ends are within the allowable, and therefore acceptable.

7.5.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.5-2 The Stress at the Flued Head Penetration Anchor in FW101

TS

7.5.3.3 Branch Pipe Connection

The stresses at the branch pipe connection meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.5-3 The Stress at Branch Pipe Connection in FW101

TS

7.5.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.5-4 The Stress at Pipe Support Location in FW101 (1/4)

TS




Table 7.5-4 The Stress at Pipe Support Location in FW101 (2/4)

TS



Table 7.5-4 The Stress at Pipe Support Location in FW101 (3/4)

TS





Table 7.5-4 The Stress at Pipe Support Location in FW101 (4/4)

TS



7.5.3.5 Valve

The stresses calculated at the valve location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.5-5 The Stress at the Valve Location in FW101 (1/2)

TS

Table 7.5-5 The Stress at the Valve Location in FW101 (2/2)

TS

7.5.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.6 FW102

7.6.1 Subsystem Plot

TS




Figure 7.6-1 Subsystem FW102 Plot

7.6.2 Pipe Data Sheet

TS




Figure 7.6-2 Subsystem FW102 Pipe Data Sheet

7.6.3 Piping Stress Evaluation Results

7.6.3.1 Nozzle Load

The purpose of this evaluation is to check the loads at safe-end of the S/G feedwater economizer nozzle against maximum nozzle load criteria.

7.6.3.1.1 Criteria Check

Table 7.6-1 Criteria Check at Main Feedwater Economizer Nozzle in FW102

TS

7.6.3.1.2 Conclusion

Base on the above evaluation, it can be concluded that loads applying on S/G feedwater economizer nozzle safe ends are within the allowable, and therefore acceptable.

7.6.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.6-2 The Stress at the Flued Head Penetration Anchor in FW102

TS

7.6.3.3 Branch Pipe Connection

The stresses at the branch pipe connection meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.6-3 The Stress at Branch Pipe Connection in FW102

TS

7.6.3.4 Pipe Support

The stresses calculated at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.6-4 The Stress at Pipe Support Location in FW102 (1/4)

TS



Table 7.6-4 The Stress at Pipe Support Location in FW102 (2/4)

TS



Table 7.6-4 The Stress at Pipe Support Location in FW102 (3/4)

TS


A large, empty red bracketed area that encompasses the majority of the page, indicating that the content of Table 7.6-4 is missing or redacted.

Table 7.6-4 The Stress at Pipe Support Location in FW102 (4/4)

TS



7.6.3.5 Valve

The stresses calculated at the valve location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.6-5 The Stress at the Valve Location in FW102 (1/2)

TS



Table 7.6-5 The Stress at the Valve Location in FW102 (2/2)

TS

7.6.3.6 Flanged Connection

There is no flanged connection in this piping subsystem.

7.7 MS271

7.7.1 Subsystem Plot

TS




Figure 7.7-1 Subsystem MS271 Plot

7.7.2 Pipe Data Sheet

TS




Figure 7.7-2 Subsystem MS271 Pipe Data Sheet

7.7.3 Piping Stress Evaluation Results

7.7.3.1 Nozzle Load

There is no nozzle in this piping subsystem.

7.7.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.7-1 The Stress at Flued Head Penetration Anchor in MS271 (1/2)

TS

Table 7.7-1 The Stress at Flued Head Penetration Anchor in MS271 (2/2)

TS

7.7.3.3 Penetration Sleeve Anchor Allowable Load Check

7.7.3.3.1 Purpose

The piping penetration anchor is checked to verify to meet the structural integrity not to exceed allowable loads in accordance with the criteria in the applicable codes for the given loads.

7.7.3.3.2 Piping Information

Piping Information

Penetration No.	PC-0612
Side A Subsystem	1-325-P397-MS271, Rev. 04, Node Point 5
Side B Subsystem	1-314-P397-MS103, Rev. 04, Node Point N037

7.7.3.3.3 Analysis Input

Inputs used for the analysis are provided in the following table. Applied loads such as SSE, Pipe Break, Weight, Pressure, etc., are combined to envelop worst case scenario and separate piping loads for both sides of the penetration are considered to the analysis model acting at the same time.

Table 7.7-2 Load Input for Penetration Assembly

TS

7.7.3.3.4 Allowable Load Check for Penetration Assembly

Following table summarizes analysis result for the piping penetration assembly of main steam line. Fatigue evaluation is performed for the MC component to have the result meeting the allowable factor.

Applicable Codes

Piping and Head fitting	ASME Sec. III, Subsection NC
Sleeve	ASME Sec. III, Subsection NE

Table 7.7-3 Allowable Load Check for Penetration Assembly

TS





Figure 7.7-3 Penetration Assembly Model – MS System

7.7.3.4 Branch Pipe Connection

The stresses calculated at branch pipe connections meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.7-4 The Stress at Branch Pipe Connection in MS271 (1/4)

TS

Table 7.7-4 The Stress at Branch Pipe Connection in MS271 (2/4)

TS



Table 7.7-4 The Stress at Branch Pipe Connection in MS271 (3/4)

TS



Table 7.7-4 The Stress at Branch Pipe Connection in MS271 (4/4)

TS



7.7.3.5 Pipe Support

The stresses at the support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.7-5 The Stress at Pipe Support Location in MS271 (1/3)

TS




Table 7.7-5 The Stress at Pipe Support Location in MS271 (2/3)

TS



Table 7.7-5 The Stress at Pipe Support Location in MS271 (3/3)

TS



7.7.3.6 Valve

The stresses at valve connections meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.7-6 The Stress at Valve Location in MS271 (1/5)

TS

Table 7.7-6 The Stress at Valve Location in MS271 (2/5)

TS



Table 7.7-6 The Stress at Valve Location in MS271 (3/5)

TS



Table 7.7-6 The Stress at Valve Location in MS271 (4/5)

TS



Table 7.7-6 The Stress at Valve Location in MS271 (5/5)

TS



7.7.3.7 Flanged Connection

The stresses at flanged connections meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.7-7 The Stress at Flanged Connection in MS271 (1/4)

TS

Table 7.7-7 The Stress at Flanged Connection in MS271 (2/4)

TS

A large, empty red bracketed area that encompasses the majority of the page, indicating that the content of Table 7.7-7 is missing or redacted.

Table 7.7-7 The Stress at Flanged Connection in MS271 (3/4)

TS



Table 7.7-7 The Stress at Flanged Connection in MS271 (4/4)

TS



7.8 MS272

7.8.1 Subsystem Plot

TS



Figure 7.8-1 Subsystem MS272 Plot

7.8.2 Pipe Data Sheet

TS



Figure 7.8-2 Subsystem MS272 Pipe Data Sheet

7.8.3 Piping Stress Evaluation Results

7.8.3.1 Nozzle Load

There is no nozzle in this piping subsystem.

7.8.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.8-1 The Stress at Flued Head Penetration Anchor in MS272 (1/2)

TS



Table 7.8-1 The Stress at Flued Head Penetration Anchor in MS272 (2/2)

7.8.3.3 Penetration Sleeve Anchor Allowable Load Check

7.8.3.3.1 Purpose

The piping penetration anchor is checked to verify to meet the structural integrity not to exceed allowable loads in accordance with the criteria in the applicable codes for the given loads.

7.8.3.3.2 Piping Information

Piping Information


Penetration No.	PC-0611
Side A Subsystem	1-325-P397-MS272, Rev. 04, Node Point 5
Side B Subsystem	1-314-P397-MS104, Rev. 04, Node Point N037

7.8.3.3.3 Analysis Input

Inputs used for the analysis are provided in the following table. Applied loads such as SSE, Pipe Break, Weight, Pressure, etc., are combined to envelop worst case scenario and separate piping loads for both sides of the penetration are considered to the analysis model acting at the same time.

Table 7.8-2 Load Input for Penetration Assembly

TS

A large, empty rectangular area with a thin red border and rounded corners, intended for the content of Table 7.8-2. The area is currently blank.

7.8.3.3.4 Allowable Load Check for Penetration Assembly

Following table summarizes analysis result for the piping penetration assembly of main steam line. Fatigue evaluation is performed for the MC component to have the result meeting the allowable factor.


Applicable Codes

Piping and Head fitting	ASME Sec. III, Subsection NC
Sleeve	ASME Sec. III, Subsection NE

Table 7.8-3 Allowable Load Check for Penetration Assembly

TS





TS

Figure 7.8-3 Penetration Assembly Model – MS System

7.8.3.4 Branch Pipe Connection

The stresses at branch pipe connection meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.8-4 The Stress at Branch Pipe Connection in MS272 (1/4)

TS

Table 7.8-4 The Stress at Branch Pipe Connection in MS272 (2/4)




Table 7.8-4 The Stress at Branch Pipe Connection in MS272 (3/4)

TS



Table 7.8-4 The Stress at Branch Pipe Connection in MS272 (4/4)

A large, empty red bracketed area that spans most of the width of the page, positioned below the table caption. It appears to be a placeholder for a table that is not present in this version of the document.

7.8.3.5 Pipe Support

The stresses at the support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.8-5 The Stress at Pipe Support Location in MS272 (1/4)

TS

Table 7.8-5 The Stress at Pipe Support Location in MS272 (2/4)

TS



Table 7.8-5 The Stress at Pipe Support Location in MS272 (3/4)

TS



Table 7.8-5 The Stress at Pipe Support Location in MS272 (4/4)

TS

A large red bracket is drawn on the page, spanning from the top of the table caption area down to the bottom of the page, indicating that the table content is missing or redacted.

7.8.3.6 Valve

The stresses at valve connections meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.8-6 The Stress at Valve Location in MS272 (1/4)

TS



Table 7.8-6 The Stress at Valve Location in MS272 (2/4)



Table 7.8-6 The Stress at Valve Location in MS272 (3/4)

TS



Table 7.8-6 The Stress at Valve Location in MS272 (4/4)

TS



7.8.3.7 Flanged Connection

The stresses at flanged connection meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.8-7 The Stress at Flanged Connection in MS272 (1/4)

TS

Table 7.8-7 The Stress at Flanged Connection in MS272 (2/4)

TS

A large, empty red bracketed area that encompasses the majority of the page, indicating that the content of the table (Table 7.8-7) is missing or redacted.

Table 7.8-7 The Stress at Flanged Connection in MS272 (3/4)

TS

A large, empty red bracketed area that encompasses the majority of the page, indicating that the content of Table 7.8-7 is missing or redacted.

Table 7.8-7 The Stress at Flanged Connection in MS272 (4/4)

TS



7.9 FW209

7.9.1 Subsystem Plot

TS




Figure 7.9-1 Subsystem FW209 Plot

7.9.2 Pipe Data Sheet

TS




Figure 7.9-2 Subsystem FW209 Pipe Data Sheet

7.9.3 Piping Stress Evaluation Results

7.9.3.1 Nozzle Load

There is no nozzle in this piping subsystem.

7.9.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.9-1 The Stress at Flued Head Penetration Anchor in FW209

TS

7.9.3.3 Penetration Sleeve Anchor Allowable Load Check

7.9.3.3.1 Purpose

The piping penetration anchor is checked to verify to meet the structural integrity not to exceed allowable loads in accordance with the criteria in the applicable codes for the given loads.

7.9.3.3.2 Piping Information

Piping Information

Penetration No.	PC-0511
Side A Subsystem	1-325-P397-FW209, Rev. 03, Node Point 5
Side B Subsystem	1-315-P397-FW101, Rev. 06, Node Point N165

7.9.3.3.3 Analysis Input

Inputs used for the analysis are provided in the following table. Applied loads such as SSE, Pipe Break, Weight, Pressure, etc., are combined to envelop worst case scenario and separate piping loads for both sides of the penetration are considered to the analysis model acting at the same time.

Table 7.9-2 Load Input for Penetration Assembly

TS



7.9.3.3.4 Allowable Load Check for Penetration Assembly

Following table summarizes analysis result for the piping penetration assembly of main steam line. Fatigue evaluation is performed for the MC component to have the result meeting the allowable factor.

Applicable Codes

Piping and Head fitting	ASME Sec. III, Subsection NC
Sleeve	ASME Sec. III, Subsection NE

Table 7.9-3 Allowable Load Check for Penetration Assembly

TS





TS

Figure 7.9-3 Penetration Assembly Model – FW System

7.9.3.4 Branch Pipe Connection

There is no branch pipe connection in this piping subsystem.

7.9.3.5 Pipe Support

The stresses at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.9-4 The Stress at the Pipe Support Location in FW209

TS

7.9.3.6 Valve

The stresses at valve connection meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.9-5 The Stress at Valve Location in FW209 (1/2)

TS



Table 7.9-5 The Stress at Valve Location in FW209 (2/2)

7.9.3.7 Flanged Connection

There is no flange connection in this piping subsystem.

7.10 FW219

7.10.1 Subsystem Plot

TS




Figure 7.10-1 Subsystem FW219 Plot

7.10.2 Pipe Data Sheet

TS




Figure 7.10-2 Subsystem FW219 Pipe Data Sheet

7.10.3 Piping Stress Evaluation Results

7.10.3.1 Nozzle Load

There is no nozzle in this piping subsystem.

7.10.3.2 Flued Head Penetration Anchor

The stresses at the flued head penetration anchor meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.10-1 The Stress at Flued Head Penetration Anchor in FW219

TS

7.10.3.3 Penetration Sleeve Anchor Allowable Load Check

7.10.3.3.1 Purpose

The piping penetration anchor is checked to verify to meet the structural integrity not to exceed allowable loads in accordance with the criteria in the applicable codes for the given loads.

7.10.3.3.2 Piping Information

Piping Information

Penetration No.	PC-0512
Side A Subsystem	1-325-P397-FW219, Rev. 03, Node Point 5
Side B Subsystem	1-315-P397-AF101, Rev. 03, Node Point 425

7.10.3.3.3 Analysis Input

Inputs used for the analysis are provided in the following table. Applied loads such as SSE, Pipe Break, Weight, Pressure, etc., are combined to envelop worst case scenario and separate piping loads for both sides of the penetration are considered to the analysis model acting at the same time.

Table 7.10-2 Load Input for Penetration Assembly

TS

7.10.3.3.4 Allowable Load Check for Penetration Assembly

Following table summarizes analysis result for the piping penetration assembly of main steam line. Fatigue evaluation is performed for the MC component to have the result meeting the allowable factor.

Applicable Codes

Piping and Head fitting	ASME Sec. III, Subsection NC
Sleeve	ASME Sec. III, Subsection NE

Table 7.10-3 Allowable Load Check for Penetration Assembly

TS



Figure 7.10-3 Penetration Assembly Model – FW System

7.10.3.4 Branch Pipe Connection

There is no branch pipe connection in this piping subsystem.

7.10.3.5 Pipe Support

The stresses at the pipe support location meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.10-4 The Stress at Pipe Support Location in FW219 (1/3)

TS

Table 7.10-4 The Stress at Pipe Support Location in FW219 (2/3)

A large, empty red bracketed area that encompasses the majority of the page, indicating that the content of the table is missing or redacted.

Table 7.10-4 The Stress at Pipe Support Location in FW219 (3/3)

TS

A large, empty red bracketed area that spans most of the page width and height, indicating that the content of the table (Table 7.10-4) is missing or redacted.

7.10.3.6 Valve

The stresses at valve connections meet all stress limitations specified in paragraphs NC-3650. The stress for each Code equation is tabulated below.

Table 7.10-5 The Stress at Valve Location in FW219 (1/2)

TS



Table 7.10-5 The Stress at Valve Location in FW219 (2/2)

7.10.3.7 Flanged Connection

There is no flange connection in this piping subsystem.

8.0 COMPUTER CODE

8.1 PIPESTRESS 3.9.0

PIPESTRESS is a piping analysis program that is applied to the static and dynamic analyses including response spectra and time-history analyses. PIPESTRESS is used for the analysis of ASME Section III, Class 1, 2, and 3 as well as ASME B31.1 and B31.3 piping systems.

9.0 REFERENCE

1. ASME B&PV Code Section III, 2007 Edition with 2008 Addenda.
2. APR1400 DC Piping Stress Reports for Subsystem 1MS101, 1MS102, 1MS103, 1MS104, 1FW101, 1FW102, 1MS271, 1MS272, 1FW209 and 1FW219:
Calculation No. 1-314-P397-MS101, Rev. 7, dated 05/15/17.
Calculation No. 1-314-P397-MS102, Rev. 4, dated 04/20/17.
Calculation No. 1-314-P397-MS103, Rev. 4, dated 04/20/17.
Calculation No. 1-314-P397-MS104, Rev. 4, dated 04/20/17.
Calculation No. 1-313-P397-FW101, Rev. 7, dated 05/15/17.
Calculation No. 1-313-P397-FW102, Rev. 4, dated 04/20/17.
Calculation No. 1-325-P397-MS271, Rev. 4, dated 07/18/17.
Calculation No. 1-325-P397-MS272, Rev. 4, dated 07/18/17.
Calculation No. 1-325-P397-FW209, Rev. 3, dated 04/20/17.
Calculation No. 1-325-P397-FW219, Rev. 3, dated 04/20/17.
3. Piping and Instrumentation Diagram for MS System and FW System:
Drawing No. 1-521-M105-001, Rev. 1 dated 01/08/16.
Drawing No. 1-541-M105-003, Rev. 1, dated 05/22/17.
4. Piping Design Tables and Standard Details, 1-037-P443-001, Rev. 4, dated 08/25/15.
5. Piping System Design Specification (PSDS) :
General PSDS, 1-037-N407-001, Rev. 1, dated 12/30/14
IRWST System PSDS, 1-447-N407-001, Rev. 1, dated 02/28/12
MS System PSDS, 1-521-M407-001, Rev. 0, dated 06/29/15
FW System PSDS, 1-541-M407-001, Rev. 1, dated 07/30/15
6. PIPESTRESS Computer Program /
KEPCO E&C Register No. : E-P-PD-1338-3.9.0/DC, and User's Manual.
7. Standard Review Plan, Section 3.6.2, Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping.