



- NOTES:**
- FOR GENERAL CONDUIT & TRAY NOTES, SYMBOLS & DETAILS SEE DWG. 13-E-ZAC-050
  - ALL RACEWAY NUMBERS SHOWN ON THIS DWG. ARE PREFIXED BY ERABA UNLESS OTHERWISE NOTED.
  - ALL CABLE TRAY FITTINGS ARE 24-INCH RADIUS UNLESS OTHERWISE NOTED.
  - FOR ELECTRICAL OPENINGS & CONDUIT SLEEVES THRU WALLS & FLOOR REFER TO Q/S DWGS. 13-C-ZAS-119, 205 THRU 210.
  - ALL EMBEDDED CONDUITS SHALL BE TERMINATED AT BOTH ENDS WITH A COUPLING FLUSH TO FINISHED CONCRETE & PLUGGED, UNLESS OTHERWISE NOTED.
  - RACEWAYS WITH FIRST DIGIT 'A', 'B', 'C' OR 'D' ARE SAFETY RELATED (QUALITY CLASS Q); 'W' ARE NON-SAFETY RELATED.
  - ALL CABLE TRAY SUPPORT NUMBERS SHOWN ON THIS DWG. ARE PREFIXED BY EZABA.

MATCH LINE - SEE DWG. 13-E-ZAC-006

NUCLEAR SAFETY RELATED

REVISION 3 & SUBSEQUENT REVS BY 7873	10-5-76
--------------------------------------	---------

NO.	DATE	REVISIONS	DR	CHK	DES	ENG	ECG	CHK	PRJ	ENG
1		ISSUED FOR CONSTRUCTION								
2		ISSUED FOR CONSTRUCTION								
3		ISSUED FOR CONSTRUCTION								
4		ISSUED FOR CONSTRUCTION								

<p>DECITEL LOS ANGELES</p>	<p>AUXILIARY BLDG CONDUIT &amp; TRAY PLAN AT EL 70' LEVEL B ZABA</p>	
	<p>SCALE 3/8" = 1'-0"</p>	<p>JOB NO. 10407</p>
<p>ARIZONA NUCLEAR POWER PROJECT PALO VERDE NUCLEAR GENERATING STATION</p>	<p>DRAWING NO. 13-E-ZAC-005</p>	<p>REV. 4</p>