

**Pre-Submittal Meeting Slides for Topical Report WCAP-18240-P,  
“Westinghouse Thermal Design Procedure (WTDP),”  
(Non-Proprietary)**

**July 18, 2018**

---

Westinghouse Electric Company  
1000 Westinghouse Drive  
Cranberry Township, PA 16066

© 2018 Westinghouse Electric Company LLC  
All Rights Reserved

---

This page intentionally left blank.

# Pre-Submittal Meeting on WTDP (Westinghouse Thermal Design Procedure) Topical Report WCAP-18240-P

July 18, 2018

**AP1000** is a trademark or registered trademark of Westinghouse Electric Company LLC, its affiliates and/or its subsidiaries in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.



# AGENDA

- Introductions
- Acronyms
- Problem Statement and Need for Change
- Purpose and Scope
- Technical Overview
- DNBR Limit Calculation – Inputs and Process
- Statistical Rods-in-DNB – Inputs and Process
- Intended Applications
- Sample Results
- Conditions for WTDP Applications
- Topical Report Outline
- Summary



# Technical Acronyms

AO	Axial Offset
ASI	Axial Shape Index (-AO)
CE	Combustion Engineering
CETOP-D	Simplified TORC T/H code in 4-Channel Core Representation
CHF	Critical Heat Flux
COLSS	Core Operating Limit Supervisory System
CPC	Core Protection Calculator
DNB	Departure from Nucleate Boiling
DNBR	Departure from Nucleate Boiling Ratio
$F_{\Delta H}$	Enthalpy Rise Hot Channel Factor
LOCA	Loss of Coolant Accident
NGF	Next Generation Fuel (16x16 CE-NSSS design)
NSSS	Nuclear Steam Supply System
MSCU	Modified SCU (CE-NSSS)
PWR	Pressurized Water Reactor
RTDP	Revised Thermal Design Procedure (Westinghouse-NSSS)
SAL	Safety Analysis Limit
SCU	Statistical Combination of Uncertainties (CE-NSSS)
SER	Safety Evaluation Report
T/H	Thermal-Hydraulic (Design)
THUNC <sub>SD</sub>	Standard deviation of T/H code uncertainties
TORC	T/H Subchannel code used for CE-NSSS
VVER	Water-Water Energetic Reactor (Russian designed PWR)
VIPRE-W	Westinghouse Version of VIPRE-01 T/H Subchannel Code
WTDP	Westinghouse Thermal Design Procedure (Statistical DNB Method)
$\sigma_{GM}$	Standard deviation of DNB probability distribution for $DNBR \geq \text{mean}$
$\sigma_{LM}$	Standard deviation of DNB probability distribution for $DNBR < \text{mean}$



## Problem Statement and Need for Change

- Combustion Engineering (CE) and Westinghouse NSSS plants use different methods for DNBR limit calculations and rods-in-DNB calculations – [ ]<sup>a,c</sup>
- The NRC approval of the CE-NSSS methods is often documented within individual plant licensing bases, rather than in a generic topical report – [ ]<sup>a,c</sup>
- Some plant analysis results are overly conservative and reloads/operations are penalized unnecessarily due to [ ]<sup>a,c</sup>

## Purpose and Scope

- One topical report which consolidates existing approved methods for all PWRs would facilitate future analysis work and review activities
  - DNBR limit for Condition I and II events
  - Statistical rods-in-DNB evaluations for non-LOCA Condition III and IV events in support of radiological consequence analyses
- Applicable to all PWR designs (CE-NSSS, Westinghouse-NSSS, VVER, **AP1000**<sup>®</sup> reactors, APR1400)
- Improved ability to quantify analysis margin:
  - CE-NSSS DNBR limit calculation
  - Westinghouse-NSSS rods-in-DNB for rod ejection and locked rotor



# Technical Overview

- WTDP based on existing CE-PWR statistical methods enhanced with VIPRE-W code:
  - 95/95 DNBR Limit
  - Rods-in-DNB convolution method for Condition III / IV events
- Maintains full compliance with current regulatory requirements and guidelines, including
  - NUREG-0800 Rev. 2 Section 4.4 (T/H Design)
  - NRC Information Notice 2014-01, "Fuel Safety Limit Calculation Inputs Were Inconsistent With NRC-Approved Correlation Limit Values"
- Topical report to be submitted for approval of extended applications of existing NRC-approved methods



# WTDP DNBR Limit Calculation - Input

- DNBR correlation limit as approved by the NRC
- Parameter uncertainties
  - Plant-specific system (fuel-related) parameters
  - Plant-specific state (operating condition and peaking factors) parameters
- Code uncertainty
- Rod bow penalty [ ]<sup>a,c</sup>
- Design parameter ranges
  - Power
  - Pressure
  - Flow
  - T-in
  - [ ]<sup>a,c</sup>
  - [ ]<sup>a,c</sup>



## WTDP DNBR Limit Calculation – Process

- Sample reference condition and calculate DNBR, [ $\text{DNBR}_{a,c}$ ]
- Additional sampling of [ $\text{DNBR}_{a,c}$ ]
- [ $\text{DNBR}_{a,c}$ ]
- DNBR distribution generated with minimum of [ $\text{DNBR}_{a,c}$ ]



# WTDP for Statistical Rods-in-DNB Input and Process

- Based on existing method applied to CE-NSSS plants
  - Credits the fact that there is only 5% probability with 95% confidence that DNB will occur at the 95/95 design DNBR limit
  - No change to conservative assumption of fuel failure when reaching DNB

- DNB probability is determined by integrating the DNBR Limit probability density functions

$$\begin{aligned}
 & - \int_{a,c} \\
 & - \int_{a,c} \\
 & - \int_{a,c} \\
 & - \int_{a,c}
 \end{aligned}$$

- % rods-in-DNB is determined based on probability distribution and following input:

$$\begin{aligned}
 & \bullet \int_{a,c} \\
 & \bullet \int_{a,c} \\
 & \bullet \int_{a,c}
 \end{aligned}$$



# WTDP Intended Applications – Westinghouse-NSSS

- Applications will be on forward-fit basis for plants using RTDP:
  - Monte Carlo sampling for DNBR limit, and/or
  - Rods-in-DNB statistical convolution for Condition IV events
- Implementation requires [  
]a,c including:
  - Approved T/H code and DNB correlations
  - Design interface for reload evaluations
- Flexible input for applications with advanced methods
  - Input of uncertainty in new parameter justified on plant specific basis
  - Can be used with new, approved DNB correlations, transient evaluation methods, etc.
  - *Applicable to new plant designs*

## WTDP Intended Applications – CE-NSSS

- Applications to CE-NSSS currently using SCU/MSCU
  - Simplify DNBR limit calculation process to eliminate response surface as an intermediate step due to TORC code limitations
  - To be implemented with VIPRE-W code
  
- Support CETOP-D replacement with VIPRE-W under currently NRC-approved setpoint methodology and SER conditions
  - WCAP-16500-P-A, CE-NGF fuel topical report
  - WCAP-16500-P-A Supplement 1 Revision 1
  - [ ]<sup>a,c</sup>
  - [ ]<sup>a,c</sup>



# Sample Results: WTDP 95/95 DNBR Limit Westinghouse-NSSS 4-Loop / 17x17 Vantage+ Fuel

Method	DNB Correlation	# of Code Runs	95/95 DNBR Limit	Difference in DNBR Limit
RTDP	WRB-2	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>	
WTDP	WRB-2	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>
		[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>

• [ ]<sup>a,c</sup>



# Sample Results: WTDP 95/95 DNBR Limit CE-NSSS System 80 / 16x16 CE16NGF Fuel

Method	DNB Correlation	# of Code Runs	95/95 DNBR Limit	Difference in DNBR Limit
TORC/SCU	WSSV-T	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>	N/A
VIPRE-W / WTDP	WSSV	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>	[ ] <sup>a,c</sup>

- [ ]<sup>a,c</sup>



# Sample Results

## WTDP Rods-in-DNB Calculations

Event	W-NSSS / Fuel	Rods-in-DNB Deterministic Method	WTDP Rods-in-DNB Statistical Method
Locked Rotor	4-Loop 17x17 V+	[     ] <sup>a,c</sup>	[     ] <sup>a,c</sup>



# Implementation Prerequisites for WTDP Applications

- WTDP application to a plant, as an alternative to either RTDP or SCU, will be based on the following conditions:
  - WTDP shall be used with an approved subchannel code and DNB correlation;
  - Input of parameter uncertainties to the 95/95 DNBR limit calculation shall be justified on a plant specific basis;
  - Input of DNBR limit to the rods-in-DNB evaluation shall be justified on a plant specific basis;
  - The plant application shall reference this report for the statistical DNBR limit method or rods-in-DNB calculation method;
  - For CE-NSSS plants using the VIPRE-W code in replacement of the CETOP-D code, the WTDP application shall be within the limits and conditions of the CE-NSSS setpoint methodology as defined in WCAP-16500-P-A Supplement 1 Revision 1.

# Topical Report Outline

- Report Outline:
  - Introduction & Applicable Regulatory Requirements
  - Method for DNBR Limit Calculation
  - Method for Rods-In-DNB Calculation
  - Intended Applications
    - Westinghouse-NSSS plant DNBR limit
    - CE-NSSS plant DNBR limit
    - Non-LOCA rods-in-DNB events
  - Summary
  - Attachments of sample calculations

# Licensee Implementation

- CE-NSSS
  - License amendment required to revise list of COLR Technical Specification references with respect to CETOP-D and TORC
  - Add reference to VIPRE-W (WCAP-14565-P-A), where applicable
- Westinghouse-NSSS
  - License amendment required to change COLR Technical Specification references, where currently listed, from ITDP (WCAP-8567-P-A) or RTDP (WCAP-11397-P-A) to approved version of WTDP (WCAP-18240-P) following approval
  - Add VIPRE-W (WCAP-14565-P-A) to THINC-IV reference citations (e.g., WCAP-7956-A, WCAP-8054-P-A, WCAP-12330-P-A), where applicable

# Summary

- Executive summary provided prior to the meeting (LTR-NRC-18-41)
- WTDP consolidates existing statistical DNB methods for all PWR applications into one topical report
  - 95/95 DNBR limit
  - Rods-in-DNB for Conditions III and IV events
- Analysis and review efficiencies
  - Improved ability to quantify analysis margin
  - Unnecessary penalties eliminated
- WTDP compatible with current design interfaces and complementary with Westinghouse advanced technologies
- Topical report to be submitted no later than August 30, 2018 for domestic plant applications