



July 19, 2018

NRC 2018-0036  
10 CFR 72.212

ATTN: Document Control Desk  
Director, Spent Fuel Project Office  
Office of Nuclear Material Safety and Safeguards  
U.S Nuclear Regulatory Commission  
Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2  
Dockets 50-026, 50-301 and 72-005  
License Nos. DPR-24 and DPR-27

Registration of NUHOMS®-32PT Casks  
WNHOMS-32-046, WNHOMS-32-048, and WNHOMS-32-050

In accordance with the requirements of 10 CFR 72.212(b)(2), NextEra Energy Point Beach, LLC, is providing the enclosed information to register the use of three approved spent fuel storage casks at the Point Beach Nuclear Plant (PBNP) Independent Spent Fuel Storage Installation (ISFSI).

This letter contains no new commitments and no revisions to existing commitments.

Sincerely,

NextEra Energy Point Beach, LLC

A handwritten signature in blue ink, appearing to read "Eric Schultz".

Eric Schultz  
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC  
Project Manager, Point Beach Nuclear Plant, USNRC  
Resident Inspector, Point Beach Nuclear Plant, USNRC  
PSCW

## ENCLOSURE

### REGISTRATION OF NUHOMS®-32PT CASKS WNHOMS-32-046, WNHOMS-32-048, and WNHOMS-32-050

#### CASK REGISTRATION INFORMATION

Licensee's Name: NextEra Energy Point Beach, LLC

Licensee's Address: 6610 Nuclear Road  
Two Rivers, WI 54241

Reactor License Nos.: DPR-24 and DPR-27

Reactor Docket Nos.: 50-266 and 50-301

ISFSI Docket No.: 72-005

Cask Certificate No.: 1004, Amendment 14

Cask Model No.: NUHOMS®-32PT

Contact: Mr. Brian Smith  
Project Manager  
920/755-7344

Cask Identification Number	Horizontal Storage Module Number	Dry Shielded Canister Number	Dry Shielded Canister Heat Load	Date Placed in Service
WNHOMS-32-046	WHSM-030	WDSC-32-029	13.98 kW	June 21, 2018
WNHOMS-32-048	WHSM-032	WDSC-32-030	14.94 kW	June 28, 2018
WNHOMS-32-050	WHSM-034	WDSC-32-031	15.82 kW	July 12, 2018