


Washington Public Power Supply System
A JOINT OPERATING AGENCY

Central Files

P. O. Box 968 3000 GEO. WASHINGTON WAY RICHLAND, WASHINGTON 99352 PHONE (509) 946-9681

June 29, 1977
G02-77-246

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1900 N. California Boulevard
Walnut Creek, California 94596



Attention: Mr. R. H. Engelken
Director

Subject: WPPSS NUCLEAR PROJECT NO. 2
IE BULLETIN NO. 77-01
DOCKET NUMBER 50-397

Reference: Letter, R.H. Engelken to D.L. Renberger, same subject,
dated April 28, 1977.

Dear Mr. Engelken:

The referenced letter transmitted IE Bulletin 77-01 concerning ITE pneumatic time delay relays which are used on Colt Industries (Fairbanks-Morse) diesel generators.

In response to this IE Bulletin, no ITE pneumatic time delay relays are used in safety related systems.

All pneumatic time delay relays used on safety related systems will have a repeat accuracy range smaller than $\pm 15\%$.

Very truly yours,

D. L. Renberger

D. L. RENBERGER
Assistant Director
Generation & Technology

DLR:GLC:ho

cc: Mr. D. Roe, Bonneville Power Administration
NRC - Office of Inspection & Enforcement (Washington, D.C.)

A02
GD