



Washington Public Power Supply System
A JOINT OPERATING AGENCY

Central Files

P. O. Box 968 3000 GEO. WASHINGTON WAY RICHLAND, WASHINGTON 99352 PHONE (509) 946-1611

November 18, 1976
G02-76-514

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1900 N. California Boulevard
Walnut Creek, California 94596

Attention: Mr. R. H. Engelken
Director

Subject: WPPSS NUCLEAR PROJECT NO. 2
IE CIRCULAR NO. 76-02
DOCKET NUMBER 50-397

Reference: Letter, R.H. Engelken to J.J. Stein, same subject,
dated August 18, 1976

Dear Mr. Engelken:

The referenced letter transmitted the subject circular.

Our A/E was requested to determine if any Westinghouse type BF or BFD type relays are used on Project WNP-2 equipment. Investigation has disclosed that Westinghouse Type BFD relays are used in Westinghouse switchgear presently "on site."

In compliance with IE Circular 76-02, arrangements are being made to visually inspect and functionally check safety related relays during post construction checkout. In addition, these relays will be functionally checked during periodic inspection.

Very truly yours,

D. L. RENBERGER
Assistant Director
Generation and Technology

DLR:GLC:ho

cc: Mr. D. Smithpeter - Bonneville Power Administration.
NRC - Office of Inspection & Enforcement (Washington, D.C.)

