



Central Files

Washington Public Power Supply System
A JOINT OPERATING AGENCY

P. O. Box 968 3000 GEO. WASHINGTON WAY RICHLAND, WASHINGTON 99352 PHONE (509) 946-9681

November 4, 1976
G02-76-496

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1900 N. California Boulevard
Walnut Creek, California 94596

Attention: Mr. R. H. Engelken
Director

Subject: WPPSS NUCLEAR PROJECT NO. 2
IE CIRCULAR NO. 76-04
DOCKET NUMBER 50-397

Reference: Letter, R. H. Engelken to J. J. Stein, same subject,
dated October 1, 1976

Dear Mr. Engelken:

In response to IE Circular 76-04, WPPSS contacted General Electric, who is supplying the Nuclear Steam Supply System (NSSS), to determine if the problem described in IE Circular 76-04 could apply to the WNP-2 Project.

General Electric reported that the switches presently installed on the Reactor Control Bench Board are manufactured by Square D Company rather than by General Electric, as stipulated in IE Circular 76-04, therefore, this response concludes our action relative to the subject circular.

Very truly yours,

D L Renberger

D. L. RENBERGER
Assistant Director
Generation and Technology

DLR:GLC:ho

cc: Mr. D. Smithpeter - Bonneville Power Administration
NRC - Office of Inspection & Enforcement (Washington D.C.)

