

APPENDIX C

ADDITIONAL CONDITIONS

FACILITY OPERATING LICENSE NO. NPF-30

UE shall comply with the following conditions on the schedules noted below:

<u>Amendment Number</u>	<u>Additional Conditions</u>	<u>Implementation Date</u>
133	<p>This amendment authorizes the relocation of certain Technical Specification requirements to licensee-controlled documents. Implementation of this amendment shall include the relocation of these Technical Specification requirements to the appropriate documents, as described in Table LG of Details Relocated from Current Technical Specifications, Table R of Relocated Current Technical Specifications, and Table LS of Less Restrictive Changes to Current Technical Specifications that are attached to the NRC staff's Safety Evaluation enclosed with this amendment.</p>	<p>The amendment shall be implemented by April 30, 2000.</p>
133	<p>The schedule for the performance of new and revised Surveillance Requirements (SRs) shall be as follows:</p> <p>For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval that begins on the date of implementation of this amendment.</p> <p>For SRs that existed prior to this amendment whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of this amendment.</p>	<p>The amendment shall be implemented by April 30, 2000.</p>

Amendment Number	Additional Conditions	Implementation Date
133	<p>For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the first surveillance interval that began on the date the surveillance was last performed prior to the implementation of this amendment.</p> <p>For SRs that existed prior to this amendment whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed prior to implementation of this amendment.</p>	The amendment shall be implemented by April 30, 2000.
180	<p>Technical Specification (TS) 3.6.7 requires the Recirculation Fluid pH Control System to be OPERABLE and Surveillance Requirement (SR) 3.6.7.2 requires verification that the sump pH be \geq 7.1. Trisodium phosphate crystalline (TSP-C) will be used for pH control as described in TS Bases 3.6.7. NRC approval is required prior to using a different chemical for pH control.</p>	Prior to MODE 4 ascending during startup from the Refuel 15 outage.
190	<p>Upon implementation of License Amendment, adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) and control building envelope (CBE) boundary unfiltered air leakage as required by SR 3.7.10.4, in accordance with TS 5.5.17.c.(i), the assessment of CRE habitability as required by Specification 5.5.17.c.(ii), and the measurement of control room pressure as required by Specification 5.5.17.d, shall be considered met. Following implementation:</p> <ol style="list-style-type: none"><li data-bbox="367 1560 1097 1963">a. The first performance of SR 3.7.10.4, in accordance with Specification 5.5.17.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from September 19, 2004, the date of the most recent successful tracer gas test, as stated in the December 15, 2004, letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.	The amendment shall be implemented within 120 days from the date of issuance

Amendment Number	Additional Conditions	Implementation Date
190 (cont'd)	<ul style="list-style-type: none"><li data-bbox="357 325 1104 745">b. The first performance of the periodic assessment of CRE habitability, Specification 5.5.17.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from September 19, 2004, the date of the most recent successful tracer gas test, as stated in the December 15, 2004, letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.<li data-bbox="357 756 1104 1022">c. The first performance of the periodic measurement of control room pressure, Specification 5.5.17.d, shall be within 18 months, plus the 138 days allowed by SR 3.0.2, as measured from March 16, 2007, the date of the most recent successful pressure measurement test.	