

CHAPTER TABLE OF CONTENTS

CHAPTER 3.4

REACTOR COOLANT SYSTEM

<u>Section</u>		<u>Page</u>
3.4.1	RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits	3.4-1
	ACTIONS	3.4-1
	SURVEILLANCE REQUIREMENTS	3.4-2
3.4.2	RCS Minimum Temperature for Criticality	3.4-3
	ACTIONS	3.4-3
	SURVEILLANCE REQUIREMENTS	3.4-3
3.4.3	RCS Pressure and Temperature (P/T) Limits	3.4-4
	ACTIONS	3.4-4
	SURVEILLANCE REQUIREMENTS	3.4-5
3.4.4	RCS Loops - MODES 1 and 2	3.4-6
	ACTIONS	3.4-6
	SURVEILLANCE REQUIREMENTS	3.4-6
3.4.5	RCS Loops - MODE 3	3.4-7
	ACTIONS	3.4-7
	SURVEILLANCE REQUIREMENTS	3.4-9
3.4.6	RCS Loops - MODE 4	3.4-10
	ACTIONS	3.4-10
	SURVEILLANCE REQUIREMENTS	3.4-11
3.4.7	RCS Loops - MODE 5, Loops Filled	3.4-13
	ACTIONS	3.4-14
	SURVEILLANCE REQUIREMENTS	3.4-15
3.4.8	RCS Loops - MODE 5, Loops Not Filled	3.4-16

CHAPTER TABLE OF CONTENTS (Continued)

<u>Section</u>	<u>Page</u>
ACTIONS	3.4-16
SURVEILLANCE REQUIREMENTS	3.4-17
3.4.9 Pressurizer	3.4-18
ACTIONS	3.4-18
SURVEILLANCE REQUIREMENTS	3.4-19
3.4.10 Pressurizer Safety Valves	3.4-20
ACTIONS	3.4-20
SURVEILLANCE REQUIREMENTS	3.4-21
3.4.11 Pressurizer Power Operated Relief Valves (PORVs)	3.4-22
ACTIONS	3.4-22
SURVEILLANCE REQUIREMENTS	3.4-25
3.4.12 Cold Overpressure Mitigation System (COMS)	3.4-26
ACTIONS	3.4-27
SURVEILLANCE REQUIREMENTS	3.4-29
3.4.13 RCS Operational LEAKAGE	3.4-31
ACTIONS	3.4-31
SURVEILLANCE REQUIREMENTS	3.4-32
3.4.14 RCS Pressure Isolation Valve (PIV) Leakage	3.4-33
ACTIONS	3.4-33
SURVEILLANCE REQUIREMENTS	3.4-35
3.4.15 RCS Leakage Detection Instrumentation	3.4-37
ACTIONS	3.4-37
SURVEILLANCE REQUIREMENTS	3.4-40
3.4.16 RCS Specific Activity	3.4-41
ACTIONS	3.4-41
SURVEILLANCE REQUIREMENTS	3.4-42
3.4.17 Steam Generator (SG) Tube Integrity	3.4-44

CHAPTER TABLE OF CONTENTS (Continued)

<u>Section</u>	<u>Page</u>
ACTIONS	3.4-44
SURVEILLANCE REQUIREMENTS	3.4-46

LIST OF FIGURES

Number

Title

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits

LCO 3.4.1 RCS DNB parameters for pressurizer pressure, RCS average temperature, and RCS total flow rate shall be within the limits specified below:

- a. Pressurizer pressure is greater than or equal to the limit specified in the COLR;
- b. RCS average temperature is less than or equal to the limit specified in the COLR; and
- c. RCS total flow rate \geq 382,630 gpm.

APPLICABILITY: MODE 1.

----- NOTE -----
Pressurizer pressure limit does not apply during:

- a. THERMAL POWER ramp > 5% RTP per minute; or
 - b. THERMAL POWER step > 10% RTP.
-

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more RCS DNB parameters not within limits.	A.1 Restore RCS DNB parameter(s) to within limit.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 2.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.1.1	Verify pressurizer pressure is greater than or equal to the limit specified in the COLR.	In accordance with the Surveillance Frequency Control Program
SR 3.4.1.2	Verify RCS average temperature is less than or equal to the limit specified in the COLR.	In accordance with the Surveillance Frequency Control Program
SR 3.4.1.3	Verify RCS total flow rate is $\geq 382,630$ gpm.	In accordance with the Surveillance Frequency Control Program
SR 3.4.1.4	<p>----- NOTE -----</p> <p>Calculated rather than verified by precision heat balance when performed prior to THERMAL POWER exceeding 75% RTP.</p> <p>-----</p> <p>Verify by precision heat balance that RCS total flow rate is $\geq 382,630$ gpm.</p>	<p>Once after each refueling prior to THERMAL POWER exceeding 75% RTP</p> <p><u>AND</u></p> <p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.2 RCS Minimum Temperature for Criticality

LCO 3.4.2 Each operating RCS loop average temperature (T_{avg}) shall be $\geq 551^{\circ}\text{F}$.

APPLICABILITY: MODE 1,
MODE 2 with $k_{eff} \geq 1.0$.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. T_{avg} in one or more operating RCS loops not within limit.	A.1 Be in MODE 2 with $k_{eff} < 1.0$.	30 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.2.1 Verify RCS T_{avg} in each operating loop $\geq 551^{\circ}\text{F}$.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.3 RCS Pressure and Temperature (P/T) Limits

LCO 3.4.3 RCS pressure, RCS temperature, and RCS heatup and cooldown rates shall be maintained within the limits specified in the PTLR.

APPLICABILITY: At all times.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. ----- NOTE ----- Required Action A.2 shall be completed whenever this Condition is entered. ----- Requirements of LCO not met in MODE 1, 2, 3, or 4.</p>	<p>A.1 Restore parameter(s) to within limits.</p>	30 minutes
	<p><u>AND</u></p> <p>A.2 Determine RCS is acceptable for continued operation.</p>	72 hours
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3.</p>	6 hours
	<p><u>AND</u></p> <p>B.2 Be in MODE 5 with RCS pressure < 500 psig.</p>	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. ----- NOTE ----- Required Action C.2 shall be completed whenever this Condition is entered. ----- Requirements of LCO not met any time in other than MODE 1, 2, 3, or 4.</p>	<p>C.1 Initiate action to restore parameter(s) to within limits. <u>AND</u> C.2 Determine RCS is acceptable for continued operation.</p>	<p>Immediately Prior to entering MODE 4</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.3.1 ----- NOTE ----- Only required to be performed during RCS heatup and cooldown operations and RCS inservice leak and hydrostatic testing. ----- Verify RCS pressure, RCS temperature, and RCS heatup and cooldown rates are within the limits specified in the PTLR.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.4 RCS Loops - MODES 1 and 2

LCO 3.4.4 Four RCS loops shall be OPERABLE and in operation.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of LCO not met.	A.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.4.1 Verify each RCS loop is in operation.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.5 RCS Loops - MODE 3

LCO 3.4.5 Two RCS loops shall be OPERABLE, and either:

- a. Two RCS loops shall be in operation when the Rod Control System is capable of rod withdrawal; or
- b. One RCS loop shall be in operation when the Rod Control System is not capable of rod withdrawal.

----- NOTE-----

All reactor coolant pumps may be removed from operation for ≤ 1 hour per 8 hour period provided:

- a. No operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SDM of LCO 3.1.1; and
- b. Core outlet temperature is maintained at least 10°F below saturation temperature.

APPLICABILITY: MODE 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RCS loop inoperable.	A.1 Restore required RCS loop to OPERABLE status.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 4.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. One required RCS loop not in operation with Rod Control System capable of rod withdrawal.</p>	<p>C.1 Restore required RCS loop to operation.</p> <p><u>OR</u></p> <p>C.2 Place the Rod Control System in a condition incapable of rod withdrawal.</p>	<p>1 hour</p> <p>1 hour</p>
<p>D. Required RCS loops inoperable.</p> <p><u>OR</u></p> <p>No RCS loop in operation.</p>	<p>D.1 Place the Rod Control System in a condition incapable of rod withdrawal.</p> <p><u>AND</u></p> <p>D.2 Suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SDM of LCO 3.1.1.</p> <p><u>AND</u></p> <p>D.3 Initiate action to restore one RCS loop to OPERABLE status and operation.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.5.1	Verify required RCS loops are in operation.	In accordance with the Surveillance Frequency Control Program
SR 3.4.5.2	Verify steam generator secondary side narrow range water levels are $\geq 7\%$ for required RCS loops.	In accordance with the Surveillance Frequency Control Program
SR 3.4.5.3	Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.6 RCS Loops - MODE 4

LCO 3.4.6 Two loops consisting of any combination of RCS loops and residual heat removal (RHR) loops shall be OPERABLE, and one loop shall be in operation.

- NOTES -----
1. All reactor coolant pumps (RCPs) and RHR pumps may be removed from operation for ≤ 1 hour per 8 hour period provided:
 - a. No operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SDM of LCO 3.1.1; and
 - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
 2. No RCP shall be started with any RCS cold leg temperature $\leq 275^\circ\text{F}$ unless the secondary side water temperature of each steam generator (SG) is $\leq 50^\circ\text{F}$ above each of the RCS cold leg temperatures.
-

APPLICABILITY: MODE 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required loop inoperable.	A.1 Initiate action to restore a second loop to OPERABLE status.	Immediately
	<p style="text-align: center;"><u>AND</u></p> <p style="text-align: center;">A.2 ----- NOTE ----- Only required if one RHR loop is OPERABLE. -----</p> <p style="text-align: center;">Be in MODE 5.</p>	24 hours

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.6.3	Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	In accordance with the Surveillance Frequency Control Program
SR 3.4.6.4	<p>----- NOTE -----</p> <p>Not required to be performed until 12 hours after entering MODE 4.</p> <p>-----</p> <p>Verify required RHR loop locations susceptible to gas accumulation are sufficiently filled with water.</p>	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 RCS Loops - MODE 5, Loops Filled

LCO 3.4.7 One residual heat removal (RHR) loop shall be OPERABLE and in operation, and either:

- a. One additional RHR loop shall be OPERABLE; or
- b. The secondary side wide range water level of at least two steam generators (SGs) shall be $\geq 86\%$.

----- NOTES -----

1. The RHR pump of the loop in operation may be removed from operation for ≤ 1 hour per 8 hour period provided:
 - a. No operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SDM of LCO 3.1.1; and
 - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
2. One required RHR loop may be inoperable for up to 2 hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.
3. No reactor coolant pump shall be started with any RCS cold leg temperature $\leq 275^\circ\text{F}$ unless the secondary side water temperature of each SG is $\leq 50^\circ\text{F}$ above each of the RCS cold leg temperatures.
4. All RHR loops may be removed from operation during planned heatup to MODE 4 when at least one RCS loop is in operation.

APPLICABILITY: MODE 5 with RCS loops filled.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One RHR loop inoperable.</p> <p><u>AND</u></p> <p>Required SGs secondary side water levels not within limits.</p>	<p>A.1 Initiate action to restore a second RHR loop to OPERABLE status.</p> <p><u>OR</u></p> <p>A.2 Initiate action to restore required SG secondary side water levels to within limits.</p>	<p>Immediately</p> <p>Immediately</p>
<p>B. Required RHR loops inoperable.</p> <p><u>OR</u></p> <p>No RHR loop in operation.</p>	<p>B.1 Suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SDM of LCO 3.1.1.</p> <p><u>AND</u></p> <p>B.2 Initiate action to restore one RHR loop to OPERABLE status and operation.</p>	<p>Immediately</p> <p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.7.1	Verify one RHR loop is in operation.	In accordance with the Surveillance Frequency Control Program
SR 3.4.7.2	Verify SG secondary side wide range water level is $\geq 86\%$ in required SGs.	In accordance with the Surveillance Frequency Control Program
SR 3.4.7.3	Verify correct breaker alignment and indicated power are available to the required RHR pump that is not in operation.	In accordance with the Surveillance Frequency Control Program
SR 3.4.7.4	Verify required RHR loop locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.8 RCS Loops - MODE 5, Loops Not Filled

LCO 3.4.8 Two residual heat removal (RHR) loops shall be OPERABLE and one RHR loop shall be in operation.

- NOTES -----
1. All RHR pumps may be removed from operation for ≤ 1 hour provided:
 - a. The core outlet temperature is maintained at least 10°F below saturation temperature.
 - b. No operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SDM of LCO 3.1.1; and
 - c. No draining operations to further reduce the RCS water volume are permitted.
 2. One RHR loop may be inoperable for ≤ 2 hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.
-

APPLICABILITY: MODE 5 with RCS loops not filled.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR loop inoperable.	A.1 Initiate action to restore RHR loop to OPERABLE status.	Immediately

(continued)

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.9 Pressurizer

LCO 3.4.9 The pressurizer shall be OPERABLE with:

- a. Pressurizer water level $\leq 92\%$; and
- b. Two groups of backup pressurizer heaters OPERABLE with the capacity of each group ≥ 150 kW.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Pressurizer water level not within limit.	A.1 Be in MODE 3.	6 hours
	<u>AND</u>	
	A.2 Fully insert all rods.	6 hours
	<u>AND</u>	
	A.3 Place Rod Control System in a condition incapable of rod withdrawal.	6 hours
	<u>AND</u>	
	A.4 Be in MODE 4.	12 hours
B. One required group of backup pressurizer heaters inoperable.	B.1 Restore required group of backup pressurizer heaters to OPERABLE status.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 3.	6 hours
	C.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.9.1 Verify pressurizer water level is $\leq 92\%$.	In accordance with the Surveillance Frequency Control Program
SR 3.4.9.2 Verify capacity of each required group of backup pressurizer heaters is ≥ 150 kW.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Pressurizer Safety Valves

LCO 3.4.10 Three pressurizer safety valves shall be OPERABLE with lift settings ≥ 2411 psig and ≤ 2509 psig.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 with all RCS cold leg temperatures $> 275^\circ\text{F}$.

----- NOTES -----
The lift settings are not required to be within the LCO limits during MODES 3 and 4 for the purpose of setting the pressurizer safety valves under ambient (hot) conditions. This exception is allowed for 54 hours following entry into MODE 3 provided a preliminary cold setting was made prior to heatup.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One pressurizer safety valve inoperable.	A.1 Restore valve to OPERABLE status.	15 minutes
B. Required Action and associated Completion Time not met. <u>OR</u> Two or more pressurizer safety valves inoperable.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4 with any RCS cold leg temperature $\leq 275^\circ\text{F}$.	6 hours 24 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.10.1	Verify each pressurizer safety valve is OPERABLE in accordance with the Inservice Testing Program. Following testing, lift settings shall be within $\pm 1\%$ of 2460 psig.	In accordance with the Inservice Testing Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.11 Pressurizer Power Operated Relief Valves (PORVs)

LCO 3.4.11 Each PORV and associated block valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each PORV and each block valve.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more PORVs inoperable solely due to excessive seat leakage.	A.1 Close and maintain power to associated block valve.	1 hour
B. One PORV inoperable for reasons other than excessive seat leakage.	B.1 Close associated block valve.	1 hour
	<u>AND</u>	
	B.2 Remove power from associated block valve.	1 hour
	<u>AND</u>	
	B.3 Restore PORV to OPERABLE status.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One block valve inoperable.	<p>----- NOTE ----- Required Actions do not apply when block valve is inoperable solely as a result of complying with Required Actions B.2 or E.2. -----</p> <p>C.1 Place associated PORV in manual control.</p> <p><u>AND</u></p> <p>C.2 Restore block valve to OPERABLE status.</p>	<p>1 hour</p> <p>72 hours</p>
D. Required Action and associated Completion Time of Condition A, B, or C not met.	<p>D.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>D.2 Be in MODE 4.</p>	<p>6 hours</p> <p>12 hours</p>
E. Two PORVs inoperable for reasons other than excessive seat leakage.	<p>E.1 Close associated block valves.</p> <p><u>AND</u></p> <p>E.2 Remove power from associated block valves.</p> <p><u>AND</u></p> <p>E.3 Be in MODE 3.</p> <p><u>AND</u></p> <p>E.4 Be in MODE 4.</p>	<p>1 hour</p> <p>1 hour</p> <p>6 hours</p> <p>12 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. More than one block valve inoperable.</p>	<p>----- NOTE ----- Required Action F.1 does not apply when block valve is inoperable solely as a result of complying with Required Action B.2 or E.2. -----</p>	<p>2 hours</p>
	<p>F.1 Restore one block valve to OPERABLE status.</p>	
<p>G. Required Action and associated Completion Time of Condition F not met.</p>	<p>G.1 Be in MODE 3. <u>AND</u> G.2 Be in MODE 4.</p>	<p>6 hours 12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.11.1 ----- NOTE ----- Not required to be performed with block valve closed in accordance with the Required Actions of this LCO. ----- Perform a complete cycle of each block valve.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.4.11.2 Perform a complete cycle of each PORV.</p>	<p>In accordance with the Inservice Testing Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.12 Cold Overpressure Mitigation System (COMS)

LCO 3.4.12 COMS shall be OPERABLE with a maximum of zero safety injection pumps, one Emergency Core Cooling System (ECCS) centrifugal charging pump, and the normal charging pump capable of injecting into the RCS and the accumulators isolated and one of the following pressure relief capabilities:

- a. Two power operated relief valves (PORVs) with lift settings within the limits specified in the PTLR, or
- b. Two residual heat removal (RHR) suction relief valves with setpoints ≥ 436.5 psig and ≤ 463.5 psig, or
- c. One PORV with a lift setting within the limits specified in the PTLR and one RHR suction relief valve with a setpoint ≥ 436.5 psig and ≤ 463.5 psig, or
- d. The RCS depressurized and an RCS vent of ≥ 2.0 square inches.

----- NOTES -----

1. Two ECCS centrifugal charging pumps may be made capable of injecting for ≤ 1 hour for pump swap operations.
 2. One or more safety injection pumps may be made capable of injecting in MODES 5 and 6 when the RCS water level is below the top of the reactor vessel flange for the purpose of protecting the decay heat removal function.
 3. Accumulator may be unisolated when accumulator pressure is less than the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR.
-

APPLICABILITY: MODE 4 with any RCS cold leg temperature $\leq 275^\circ\text{F}$,
MODE 5,
MODE 6 when the reactor vessel head is on.

ACTIONS

----- NOTE -----
 LCO 3.0.4.b is not applicable when entering MODE 4.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more safety injection pumps capable of injecting into the RCS.	A.1 Initiate action to verify a maximum of zero safety injection pumps are capable of injecting into the RCS.	Immediately
B. Two ECCS centrifugal charging pumps capable of injecting into the RCS.	B.1 Initiate action to verify a maximum of one ECCS centrifugal charging pump and the normal charging pump capable of injecting into the RCS.	Immediately
C. An accumulator not isolated when the accumulator pressure is greater than or equal to the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.	C.1 Isolate affected accumulator.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition C not met.</p>	<p>D.1 Increase all RCS cold leg temperatures to > 275°F.</p> <p><u>OR</u></p> <p>D.2 Depressurize affected accumulator to less than the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.</p>	<p>12 hours</p> <p>12 hours</p>
<p>E. One required RCS relief valve inoperable in MODE 4.</p>	<p>E.1 Restore required RCS relief valve to OPERABLE status.</p>	<p>7 days</p>
<p>F. One required RCS relief valve inoperable in MODE 5 or 6.</p>	<p>F.1 Restore required RCS relief valve to OPERABLE status.</p>	<p>24 hours</p>
<p>G. Two required RCS relief valves inoperable.</p> <p><u>OR</u></p> <p>Required Action and associated Completion Time of Condition A, B, D, E, or F not met.</p> <p><u>OR</u></p> <p>COMS inoperable for any reason other than Condition A, B, C, D, E, or F.</p>	<p>G.1 Depressurize RCS and establish RCS vent of ≥ 2.0 square inches.</p>	<p>12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.12.1	Verify a maximum of zero safety injection pumps are capable of injecting into the RCS.	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.2	Verify a maximum of one ECCS centrifugal charging pump and the normal charging pump capable of injecting into the RCS.	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.3	Verify each accumulator is isolated when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR.	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.4	Verify RHR suction isolation valves are open for each required RHR suction relief valve.	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.5	Verify required RCS vent ≥ 2.0 square inches open.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.12.6	Verify PORV block valve is open for each required PORV.	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.7	Not used.	
SR 3.4.12.8	<p>----- NOTE -----</p> <p>Not required to be performed until 12 hours after decreasing any RCS cold leg temperature to $\leq 275^{\circ}\text{F}$.</p> <p>-----</p> <p>Perform a COT on each required PORV, excluding actuation.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.4.12.9	Perform CHANNEL CALIBRATION for each required PORV actuation channel.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.13 RCS Operational LEAKAGE

LCO 3.4.13 RCS operational LEAKAGE shall be limited to:

- a. No pressure boundary LEAKAGE;
- b. 1 gpm unidentified LEAKAGE;
- c. 10 gpm identified LEAKAGE; and
- d. 150 gallons per day primary to secondary LEAKAGE through any one steam generator (SG).

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCS operational LEAKAGE not within limits for reasons other than pressure boundary LEAKAGE or primary to secondary LEAKAGE.	A.1 Reduce LEAKAGE to within limits.	4 hours
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Pressure boundary LEAKAGE exists. <u>OR</u> Primary to secondary LEAKAGE not within limit.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.13.1 ----- NOTES -----</p> <p>1. Not required to be performed until 12 hours after establishment of steady state operation.</p> <p>2. Not applicable to primary to secondary LEAKAGE</p> <p>-----</p> <p>Verify RCS operational LEAKAGE is within limits by performance of RCS water inventory balance.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.4.13.2 ----- NOTE -----</p> <p>Not required to be performed until 12 hours after establishment of steady state operation.</p> <p>-----</p> <p>Verify primary to secondary LEAKAGE is \leq 150 gallons per day through any one SG.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.14 RCS Pressure Isolation Valve (PIV) Leakage

LCO 3.4.14 Leakage from each RCS PIV shall be within limit.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4, except valves in the residual heat removal (RHR) flow path when in, or during the transition to or from, the RHR mode of operation.

ACTIONS

- NOTES -----
1. Separate Condition entry is allowed for each flow path.
 2. Enter applicable Conditions and Required Actions for systems made inoperable by an inoperable PIV.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more flow paths with leakage from one or more RCS PIVs not within limit.	A.1 ----- NOTE ----- Each valve used to satisfy Required Action A.1 must have been verified to meet SR 3.4.14.1 and be in the reactor coolant pressure boundary. ----- Isolate the high pressure portion of the affected system from the low pressure portion by use of one deactivated remote manual or check valve.	4 hours
	<u>AND</u> A.2 Restore RCS PIV to within limits.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time for Condition A not met.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5.	6 hours 36 hours
C. RHR suction isolation valve interlock function inoperable.	C.1 Isolate the affected penetration by use of one deactivated remote manual valve.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.14.1 ----- NOTES -----</p> <ol style="list-style-type: none"> 1. Not required to be performed in MODES 3 and 4. 2. Not required to be performed on the RCS PIVs located in the RHR flow path when in the shutdown cooling mode of operation. 3. RCS PIVs actuated during the performance of this Surveillance are not required to be tested more than once if a repetitive testing loop cannot be avoided. <p>-----</p> <p>Verify leakage from each RCS PIV is equivalent to ≤ 0.5 gpm per nominal inch of valve size up to a maximum of 5 gpm at an RCS pressure ≥ 2215 psig and ≤ 2255 psig.</p>	<p>In accordance with the Inservice Testing Program,</p> <p><u>AND</u></p> <p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>Prior to entering MODE 2 whenever the unit has been in MODE 5 for 7 days or more and if leakage testing has not been performed in the previous 9 months</p> <p><u>AND</u></p> <p>(continued)</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.14.1 (continued)		Within 24 hours following check valve actuation due to flow through the valve
SR 3.4.14.2	Verify RHR suction isolation valve interlock prevents the valves from being opened with a simulated or actual RCS pressure signal ≥ 425 psig except when the valves are open to satisfy LCO 3.4.12.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.15 RCS Leakage Detection Instrumentation

LCO 3.4.15 The following RCS leakage detection instrumentation shall be OPERABLE:

- a. The containment sump level and flow monitoring system;
- b. One containment atmosphere particulate radioactivity monitor; and
- c. The containment cooler condensate monitoring system.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Required containment sump level and flow monitoring system inoperable.</p>	<p>A.1 ----- NOTE ----- Not required until 12 hours after establishment of steady state operation. ----- Perform SR 3.4.13.1.</p> <p><u>AND</u></p> <p>A.2 Restore required containment sump level and flow monitoring system to OPERABLE status.</p>	<p>Once per 24 hours</p> <p>30 days</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. Required containment atmosphere particulate radioactivity monitor inoperable.</p>	<p>B.1.1 Analyze samples of the containment atmosphere.</p>	<p>Once per 24 hours</p>
	<p><u>OR</u></p>	
	<p>B.1.2 ----- NOTE ----- Not required until 12 hours after establishment of steady state operation. -----</p>	
	<p>Perform SR 3.4.13.1.</p>	<p>Once per 24 hours</p>
	<p><u>AND</u></p>	
	<p>B.2.1 Restore required containment atmosphere particulate radioactivity monitor to OPERABLE status.</p>	<p>30 days</p>
	<p><u>OR</u></p>	
	<p>B.2.2 Verify containment air cooler condensate monitoring system is OPERABLE.</p>	<p>30 days</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.15.1	Perform CHANNEL CHECK of the required containment atmosphere particulate radioactivity monitor.	In accordance with the Surveillance Frequency Control Program
SR 3.4.15.2	Perform COT of the required containment atmosphere particulate radioactivity monitor.	In accordance with the Surveillance Frequency Control Program
SR 3.4.15.3	Perform CHANNEL CALIBRATION of the required containment sump level and flow monitoring system.	In accordance with the Surveillance Frequency Control Program
SR 3.4.15.4	Perform CHANNEL CALIBRATION of the required containment atmosphere particulate radioactivity monitor.	In accordance with the Surveillance Frequency Control Program
SR 3.4.15.5	Perform CHANNEL CALIBRATION of the required containment cooler condensate monitoring system.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.16 RCS Specific Activity

LCO 3.4.16 RCS DOSE EQUIVALENT I-131 and DOSE EQUIVALENT XE-133 specific activity shall be within limits.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. DOSE EQUIVALENT I-131 not within limit.</p>	<p>----- NOTE ----- LCO 3.0.4.c is applicable. -----</p> <p>A.1 Verify DOSE EQUIVALENT I-131 $\leq 60 \mu\text{Ci/gm}$.</p> <p><u>AND</u></p> <p>A.2 Restore DOSE EQUIVALENT I-131 to within limit.</p>	<p>Once per 4 hours</p> <p>48 hours</p>
<p>B. DOSE EQUIVALENT XE-133 not within limit.</p>	<p>----- NOTE ----- LCO 3.0.4.c is applicable. -----</p> <p>B.1 Restore DOSE EQUIVALENT XE-133 to within limit.</p>	<p>48 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition A or B not met. <u>OR</u> DOSE EQUIVALENT I-131 > 60 μ Ci/gm.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.16.1 ----- NOTE ----- Only required to be performed in MODE 1. ----- Verify reactor coolant DOSE EQUIVALENT XE-133 specific activity \leq 225 μ Ci/gm.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.16.2 ----- NOTE ----- Only required to be performed in MODE 1. ----- Verify reactor coolant DOSE EQUIVALENT I-131 specific activity $\leq 1.0 \mu\text{Ci/gm}$.</p>	<p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>Between 2 and 6 hours after a THERMAL POWER change of $\geq 15\%$ RTP within a 1 hour period</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.17 Steam Generator (SG) Tube Integrity

LCO 3.4.17 SG tube integrity shall be maintained.

AND

All SG tubes satisfying the tube plugging criteria shall be plugged in accordance with Steam Generator Program.

APPLICABILITY: MODES 1 2, 3, and 4.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each SG tube.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more SG tubes satisfying the tube plugging criteria and not plugged in accordance with the Steam Generator Program.</p>	<p>A.1 Verify tube integrity of the affected tube(s) is maintained until the next refueling outage or inspection.</p>	<p>7 days</p>
	<p><u>AND</u></p> <p>A.2 Plug the affected tube(s) in accordance with the Steam Generator Program.</p>	<p>Prior to entering MODE 4 following the next refueling outage or SG tube inspection</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. Required Action and associated Completion Time of Condition A not met.</p> <p><u>OR</u></p> <p>SG tube integrity not maintained.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.17.1	Verify SG tube integrity in accordance with the Steam Generator Program.	In accordance with the Steam Generator Program
SR 3.4.17.2	Verify that each inspected SG tube that satisfies the tube plugging criteria is plugged in accordance with the Steam Generator Program.	Prior to entering MODE 4 following a SG tube inspection