APPENDIX A

TO

FACILITY OPERATING LICENSE DPR-64

TECHNICAL SPECIFICATIONS AND BASES

FOR THE

INDIAN POINT 3 NUCLEAR GENERATING STATION UNIT NO. 3

WESTCHESTER COUNTY, NEW YORK

ENTERGY NUCLEAR INDIAN POINT 3, LLC (ENIP3)

AND ENTERGY NUCLEAR OPERATIONS, INC. (ENO)

DOCKET NO. 50-286

Date of Issuance:
April 15, 1976

Amendment No. 203

TABLE OF CONTENTS

1.0 USE AND APPLICATION
1.1 Definitions
1.2 Logical Connectors
1.3 Completion Times
1.4 Frequency

2.0 SAFETY LIMITS (SLs)
2.1 Safety Limits
2.2 Safety Limit Violations

3.0 **LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY**
SURVEILLANCE REQUIREMENT (SR) APPLICABILITY

3.1 REACTIVITY CONTROL SYSTEMS
3.1.1 Shutdown Margin (SDM)
3.1.2 Core Reactivity
3.1.3 Moderator Temperature Coefficient (MTC)
3.1.4 Rod Group Alignment Limits
3.1.5 Shutdown Bank Insertion Limits
3.1.6 Control Bank Insertion Limits
3.1.7 Rod Position Indication
3.1.8 PHYSICS TESTS Exceptions–MODE 2

3.2 POWER DISTRIBUTION LIMITS
3.2.1 Heat Flux Hot Channel Factor (FQ(Z))
3.2.2 Nuclear Enthalpy Rise Hot Channel Factor (F^N_H)
3.2.3 AXIAL FLUX DIFFERENCE (AFD)
3.2.4 QUADRANT POWER TILT RATIO (QPTR)

3.3 INSTRUMENTATION
3.3.1 Reactor Protection System (RPS) Instrumentation
3.3.2 Engineered Safety Feature Actuation System (ESFAS) Instrumentation
3.3.3 Post Accident Monitoring (PAM) Instrumentation
3.3.4 Remote Shutdown
3.3.5 Loss of Power (LOP) Diesel Generator (DG) Start Instrumentation
3.3.6 Containment Purge System and Pressure Relief Line Isolation Instrumentation
3.3.7 Control Room Ventilation (CRVS) Actuation Instrumentation
3.3.8 Fuel Storage Building Emergency Ventilation System (FSBEVS) Actuation Instrumentation

(continued)

TABLE OF CONTENTS

3.4 REACTOR COOLANT SYSTEM (RCS)
3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
3.4.2 RCS Minimum Temperature for Criticality
3.4.3 RCS Pressure and Temperature (P/T) Limits
3.4.4 RCS Loops–MODES 1 and 2
3.4.5 RCS Loops–MODE 3
3.4.6 RCS Loops–MODE 4
3.4.7 RCS Loops–MODE 5, Loops Filled
3.4.8 RCS Loops–MODE 5, Loops Not Filled
3.4.9 Pressurizer
3.4.10 Pressurizer Safety Valves
3.4.11 Pressurizer Power Operated Relief Valves (PORVs)
3.4.12 Low Temperature Overpressure Protection (LTOP)
3.4.13 RCS Operational LEAKAGE
3.4.14 RCS Pressure Isolation Valve (PIV) Leakage
3.4.15 RCS Leakage Detection Instrumentation
3.4.16 RCS Specific Activity
3.4.17 Steam Generator (SG) Tube Integrity

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)
3.5.1 Accumulators
3.5.2 ECCS–Operating
3.5.3 ECCS–Shutdown
3.5.4 Refueling Water Storage Tank (RWST)

3.6 CONTAINMENT SYSTEMS
3.6.1 Containment
3.6.2 Containment Air Locks
3.6.3 Containment Isolation Valves
3.6.4 Containment Pressure
3.6.5 Containment Air Temperature
3.6.6 Containment Spray System and Containment Fan Cooler System
3.6.7 Recirculation pH Control System
3.6.8 Not Used
3.6.9 Isolation Valve Seal Water (IVSW) System
3.6.10 Weld Channel and Penetration Pressurization System (WC & PPS)

(continued)

TABLE OF CONTENTS

3.7 PLANT SYSTEMS
3.7.1 Main Steam Safety Valves (MSSVs)
3.7.2 Main Steam Isolation Valves (MSIVs) and Main Steam Check Valves (MSCVs)
3.7.3 Main Boiler Feedpump Discharge Valves (MBFPDVs), Main Feedwater Regulation Valves (MFRVs), Main Feedwater Inlet Isolation Valves (MFIIVs) and Main Feedwater (MF) Low Flow Bypass Valves
3.7.4 Atmospheric Dump Valves (ADVs)
3.7.5 Auxiliary Feedwater (AFW) System
3.7.6 Condensate Storage Tank (CST)
3.7.7 City Water (CW)
3.7.8 Component Cooling Water (CCW) System
3.7.9 Service Water (SW) System
3.7.10 Ultimate Heat Sink (UHS)
3.7.11 Control Room Ventilation System (CRVS)
3.7.12 Control Room Air Conditioning System (CRACS)
3.7.13 Fuel Storage Building Emergency Ventilation System (FSBEVS)
3.7.14 Spent Fuel Pit Water Level
3.7.15 Spent Fuel Pit Boron Concentration
3.7.16 Spent Fuel Assembly Storage
3.7.17 Secondary Specific Activity

3.8 ELECTRICAL POWER SYSTEMS
3.8.1 AC Sources – Operating
3.8.2 AC Sources – Shutdown
3.8.3 Diesel Fuel Oil and Starting Air
3.8.4 DC Sources – Operating
3.8.5 DC Sources – Shutdown
3.8.6 Battery Cell Parameters
3.8.7 Inverters – Operating
3.8.8 Inverters – Shutdown
3.8.9 Distribution Systems – Operating
3.8.10 Distribution Systems – Shutdown

3.9 REFUELING OPERATIONS
3.9.1 Boron Concentration
3.9.2 Nuclear Instrumentation
3.9.3 Containment Penetrations
3.9.4 Residual Heat Removal (RHR) and Coolant Circulation – High Water Level
3.9.5 Residual Heat Removal (RHR) and Coolant Circulation – Low Water Level
3.9.6 Refueling Cavity Water Level

(continued)

TABLE OF CONTENTS

4.0 DESIGN FEATURES
4.1 Site Location
4.2 Reactor Core
4.3 Fuel Storage

5.0 ADMINISTRATIVE CONTROLS
5.1 Responsibility
5.2 Organization
5.3 Unit Staff Qualifications
5.4 Procedures

5.5 Programs and Manuals
5.5.1 Offsite Dose Calculation Manual (ODCM)
5.5.2 Primary Coolant Sources Outside Containment
5.5.3 NOT USED
5.5.4 Radioactive Effluent Controls Program
5.5.5 Component Cyclic or Transient Limit
5.5.6 Reactor Coolant Pump Flywheel Inspection Program
5.5.7 Inservice Testing Program
5.5.8 Steam Generator (SG) Program
5.5.9 Secondary Water Chemistry Program
5.5.10 Ventilation Filter Testing Program (VFTP)
5.5.11 Explosive Gas and Storage Tank Radioactivity Monitoring Program
5.5.12 Diesel Fuel Oil Testing Program
5.5.13 Technical Specification (TS) Bases Control Program
5.5.14 Safety Function Determination Program (SFDP)
5.5.15 Containment Leakage Rate Testing Program
5.5.16 Control Room Envelope Habitability Program

5.6 Reporting Requirements
5.6.1 NOT USED
5.6.2 Annual Radiological Environmental Operating Report
5.6.3 Radioactive Effluent Release Report
5.6.4 NOT USED
5.6.5 CORE OPERATING LIMITS REPORT (COLR)
5.6.6 NOT USED
5.6.7 Post Accident Monitoring Instrumentation (PAM) Report
5.6.8 Steam Generator Tube Inspection Report

5.7 High Radiation Area

1.0 USE AND APPLICATION

1.1 Definitions

----------NOTE----------
The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications and Bases.

Term	Definition
ACTIONS	ACTIONS shall be that part of a Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times.
ACTUATION LOGIC TEST	An ACTUATION LOGIC TEST shall be the application of various simulated or actual input combinations in conjunction with each possible interlock logic state and the verification of the required logic output. The ACTUATION LOGIC TEST, as a minimum, shall include a continuity check of output devices.
AXIAL FLUX DIFFERENCE (AFD)	AFD shall be the difference in normalized flux signals between the top and bottom halves of a two section excore neutron detector.
CHANNEL CALIBRATION	A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel so that it responds within the required range and accuracy to known input. The CHANNEL CALIBRATION shall encompass the entire channel, including the required sensor, alarm, interlock, display, and trip functions. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an inplace qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. Whenever a sensing element is replaced, the next required CHANNEL CALIBRATION shall include an inplace cross calibration that compares the other sensing elements with the

(continued)

1.1 Definitions

CHANNEL CALIBRATION (continued)	recently installed sensing element. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping calibrations or total channel steps so that the entire channel is calibrated.
CHANNEL CHECK	A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.
CHANNEL OPERATIONAL TEST (COT)	A COT shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify the OPERABILITY of required alarm, interlock, display, and trip functions. The COT shall include adjustments, as necessary, of the required alarm, interlock, and trip setpoints so that the setpoints are within the required range and accuracy.
CORE ALTERATION	CORE ALTERATION shall be the movement of any fuel, sources, or reactivity control components, within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.
CORE OPERATING LIMITS REPORT (COLR)	The COLR is the unit specific document that provides cycle specific parameter limits for the current reload cycle. These cycle specific parameter limits shall be determined for each reload cycle in accordance with Specification 5.6.5. Plant operation within these limits is addressed in individual Specifications.

(continued)

1.1 Definitions (continued)

DOSE EQUIVALENT I-131	DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries per gram) that alone would produce the same dose when inhaled as the combined activities of iodine isotopes I-131, I-132, I-133, I-134, and I-135 actually present. If a specific isotope is not detected, it should be assumed to be present at the minimum detectable activity. The determination of DOSE EQUIVALENT I-131 shall be performed using Committed Effective Dose Equivalent (CEDE) dose conversion factors from Table 2.1 of EPA Federal Guidance Report No. 11, 1988.
DOSE EQUIVALENT XE-133	DOSE EQUIVALENT XE-133 shall be that concentration of Xe-133 (microcuries per gram) that alone would produce the same acute dose to the whole body as the combined activities of noble gas nuclides Kr-85m, Kr-85, Kr-87, Kr-88, Xe-131m, Xe-133m, Xe-133, Xe-135m, Xe-135, and Xe-138 actually present. If a specific noble gas nuclide is not detected, it should be assumed to be present at the minimum detectable activity. The determination of DOSE EQUIVALENT XE-133 shall be performed using effective dose conversion factors for air submersion listed in Table III.1 of EPA Federal Guidance Report No. 12, 1993, "External Exposure to Radionuclides in Air, Water, and Soil".
L_a	The maximum allowable primary containment leakage rate, L_a, shall be 0.1% of primary containment air weight per day at the calculated peak containment pressure (P_a).
LEAKAGE	LEAKAGE shall be: a. <u>Identified LEAKAGE</u> 1. LEAKAGE, such as that from pump seals or valve packing (except for leakage into closed systems and reactor coolant pump (RCP) seal water injection or leakoff), that is captured and conducted to collection systems or a sump or collecting tank; (Leakage into closed systems is leakage that can be accounted for and contained by a

(continued)

1.1 Definitions

LEAKAGE (continued)

system not directly connected to the atmosphere. Leakage past the pressurizer safety valve seats and leakage past the safety injection pressure isolation valves are examples of reactor coolant system leakage into closed systems.)

2. LEAKAGE into the containment atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be pressure boundary LEAKAGE; or

3. Reactor Coolant System (RCS) LEAKAGE through a steam generator to the Secondary System (primary to secondary LEAKAGE);

b. Unidentified LEAKAGE

All LEAKAGE (except for leakage into closed systems and RCP seal water injection or leakoff) that is not identified LEAKAGE;

c. Pressure Boundary LEAKAGE

LEAKAGE (except primary to secondary LEAKAGE) through a nonisolable fault in an RCS component body, pipe wall, or vessel wall.

MASTER RELAY TEST

A MASTER RELAY TEST shall consist of energizing each master relay and verifying the OPERABILITY of each relay. The MASTER RELAY TEST shall include a continuity check of each associated slave relay.

MODE

A MODE shall correspond to any one inclusive combination of core reactivity condition, power level, average reactor coolant loop temperature, and reactor

(continued)

1.1 Definitions

MODE (continued)	vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
OPERABLE-OPERABILITY	A system, subsystem, train, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PHYSICS TESTS	PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation. These tests are: a. Described in FSAR Chapter 13, Initial Tests and Operations; b. Authorized under the provisions of 10 CFR 50.59; or c. Otherwise approved by the Nuclear Regulatory Commission.
QUADRANT POWER TILT RATIO (QPTR)	QPTR shall be the ratio of the maximum upper excore detector calibrated output to the average of the upper excore detector calibrated outputs, or the ratio of the maximum lower excore detector calibrated output to the average of the lower excore detector calibrated outputs, whichever is greater.
RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3216 MWt.

(continued)

1.1 Definitions (continued)

SHUTDOWN MARGIN (SDM)	SDM shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming: a. All rod cluster control assemblies (RCCAs) are fully inserted except for the single RCCA of highest reactivity worth, which is assumed to be fully withdrawn. With any RCCA not capable of being fully inserted, the reactivity worth of the RCCA must be accounted for in the determination of SDM; and b. In MODES 1 and 2, the fuel and moderator temperatures are changed to the hot zero power level.
SLAVE RELAY TEST	A SLAVE RELAY TEST shall consist of energizing each slave relay and verifying the OPERABILITY of each slave relay. The SLAVE RELAY TEST shall include, as a minimum, a continuity check of associated testable actuation devices.
STAGGERED TEST BASIS	A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during n Surveillance Frequency intervals, where n is the total number of systems, subsystems, channels, or other designated components in the associated function.
THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

(continued)

1.1 Definitions (continued)

TRIP ACTUATING DEVICE OPERATIONAL TEST (TADOT)	A TADOT shall consist of operating the trip actuating device and verifying the OPERABILITY of required alarm, interlock, display, and trip functions. The TADOT shall include adjustment, as necessary, of the trip actuating device so that it actuates at the required setpoint within the required accuracy.

Table 1.1-1 (page 1 of 1)
MODES

MODE	TITLE	REACTIVITY CONDITION (k_{eff})	% RATED THERMAL POWER[a]	AVERAGE REACTOR COOLANT TEMPERATURE (°F)
1	Power Operation	≥ 0.99	> 5	NA
2	Startup	≥ 0.99	≤ 5	NA
3	Hot Standby	< 0.99	NA	≥ 350
4	Hot Shutdown[b]	< 0.99	NA	350 > T_{avg} > 200
5	Cold Shutdown[b]	< 0.99	NA	≤ 200
6	Refueling[c]	NA	NA	NA

(a) Excluding decay heat.

(b) All reactor vessel head closure bolts fully tensioned.

(c) One or more reactor vessel head closure bolts less than fully tensioned.

1.0 USE AND APPLICATION

1.2 Logical Connectors

PURPOSE

The purpose of this section is to explain the meaning of logical connectors.

Logical connectors are used in Technical Specifications (TS) to discriminate between, and yet connect, discrete Conditions, Required Actions, Completion Times, Surveillances, and Frequencies. The only logical connectors that appear in TS are AND and OR. The physical arrangement of these connectors constitutes logical conventions with specific meanings.

BACKGROUND

Several levels of logic may be used to state Required Actions. These levels are identified by the placement (or nesting) of the logical connectors and by the number assigned to each Required Action. The first level of logic is identified by the first digit of the number assigned to a Required Action and the placement of the logical connector in the first level of nesting (i.e., left justified with the number of the Required Action). The successive levels of logic are identified by additional digits of the Required Action number and by successive indentations of the logical connectors.

When logical connectors are used to state a Condition, Completion Time, Surveillance, or Frequency, only the first level of logic is used, and the logical connector is left justified with the statement of the Condition, Completion Time, Surveillance, or Frequency.

(continued)

1.2 Logical Connectors (continued)

EXAMPLES

The following examples illustrate the use of logical connectors.

EXAMPLE 1.2-1

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. LCO not met.	A.1 Verify . . . AND A.2 Restore . . .	

In this example the logical connector AND is used to indicate that when in Condition A, both Required Actions A.1 and A.2 must be completed.

(continued)

1.2 Logical Connectors

EXAMPLES
(continued)

EXAMPLE 1.2-2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. LCO not met.	A.1 Trip . . . OR A.2.1 Verify . . . AND A.2.2.1 Reduce . . . OR A.2.2.2 Perform . . . OR A.3 Align . . .	

This example represents a more complicated use of logical connectors. Required Actions A.1, A.2, and A.3 are alternative choices, only one of which must be performed as indicated by the use of the logical connector OR and the left justified placement. Any one of these three Actions may be chosen. If A.2 is chosen, then both A.2.1 and A.2.2 must be performed as indicated by the logical connector AND. Required Action A.2.2 is met by performing A.2.2.1 or A.2.2.2. The indented position of the logical connector OR indicates that A.2.2.1 and A.2.2.2 are alternative choices, only one of which must be performed.

1.0 USE AND APPLICATION

1.3 Completion Times

PURPOSE

The purpose of this section is to establish the Completion Time convention and to provide guidance for its use.

BACKGROUND

Limiting Conditions for Operation (LCOs) specify minimum requirements for ensuring safe operation of the unit. The ACTIONS associated with an LCO state Conditions that typically describe the ways in which the requirements of the LCO can fail to be met. Specified with each stated Condition are Required Action(s) and Completion Time(s).

DESCRIPTION

The Completion Time is the amount of time allowed for completing a Required Action. It is referenced to the time of discovery of a situation (e.g., inoperable equipment or variable not within limits) that requires entering an ACTIONS Condition unless otherwise specified, providing the unit is in a MODE or specified condition stated in the Applicability of the LCO. Required Actions must be completed prior to the expiration of the specified Completion Time. An ACTIONS Condition remains in effect and the Required Actions apply until the Condition no longer exists or the unit is not within the LCO Applicability.

If situations are discovered that require entry into more than one Condition at a time within a single LCO (multiple Conditions), the Required Actions for each Condition must be performed within the associated Completion Time. When in multiple Conditions, separate Completion Times are tracked for each Condition starting from the time of discovery of the situation that required entry into the Condition.

Once a Condition has been entered, subsequent trains, subsystems, components, or variables expressed in the Condition, discovered to be inoperable or not within limits, will not result in separate entry into the Condition, unless specifically stated. The Required Actions of the Condition continue to apply to each

(continued)

1.3 Completion Times

DESCRIPTION (continued)

additional failure, with Completion Times based on initial entry into the Condition.

However, when a subsequent train, subsystem, component, or variable expressed in the Condition is discovered to be inoperable or not within limits, the Completion Time(s) may be extended. To apply this Completion Time extension, two criteria must first be met. The subsequent inoperability:

a. Must exist concurrent with the first inoperability; and

b. Must remain inoperable or not within limits after the first inoperability is resolved.

The total Completion Time allowed for completing a Required Action to address the subsequent inoperability shall be limited to the more restrictive of either:

a. The stated Completion Time, as measured from the initial entry into the Condition, plus an additional 24 hours; or

b. The stated Completion Time as measured from discovery of the subsequent inoperability.

The above Completion Time extensions do not apply to those Specifications that have exceptions that allow completely separate re-entry into the Condition (for each train, subsystem, component, or variable expressed in the Condition) and separate tracking of Completion Times based on this re-entry. These exceptions are stated in individual Specifications.

The above Completion Time extension does not apply to a Completion Time with a modified "time zero." This modified "time zero" may be expressed as a repetitive time (i.e., "once per 8 hours," where the Completion Time is referenced from a previous completion of the Required Action versus the time of Condition entry) or as a time modified by the phrase "from discovery..." Example 1.3-3 illustrates one use of this type of Completion Time. The 10 day Completion Time specified for Conditions A and B in Example 1.3-3 may not be extended.

(continued)

1.3 Completion Times (continued)

EXAMPLES

The following examples illustrate the use of Completion Times with different types of Conditions and changing Conditions.

EXAMPLE 1.3-1

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 5.	6 hours 36 hours

Condition B has two Required Actions. Each Required Action has its own separate Completion Time. Each Completion Time is referenced to the time that Condition B is entered.

The Required Actions of Condition B are to be in MODE 3 within 6 hours AND in MODE 5 within 36 hours. A total of 6 hours is allowed for reaching MODE 3 and a total of 36 hours (not 42 hours) is allowed for reaching MODE 5 from the time that Condition B was entered. If MODE 3 is reached within 3 hours, the time allowed for reaching MODE 5 is the next 33 hours because the total time allowed for reaching MODE 5 is 36 hours.

If Condition B is entered while in MODE 3, the time allowed for reaching MODE 5 is the next 36 hours.

(continued)

1.3 Completion Times

EXAMPLES (continued)

EXAMPLE 1.3-2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One pump inoperable.	A.1 Restore pump to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 5.	6 hours 36 hours

When a pump is declared inoperable, Condition A is entered. If the pump is not restored to OPERABLE status within 7 days, Condition B is also entered and the Completion Time clocks for Required Actions B.1 and B.2 start. If the inoperable pump is restored to OPERABLE status after Condition B is entered, Condition A and B are exited, and therefore, the Required Actions of Condition B may be terminated.

When a second pump is declared inoperable while the first pump is still inoperable, Condition A is not re-entered for the second pump. LCO 3.0.3 is entered, since the ACTIONS do not include a Condition for more than one inoperable pump. The Completion Time clock for Condition A does not stop after LCO 3.0.3 is entered, but continues to be tracked from the time Condition A was initially entered.

While in LCO 3.0.3, if one of the inoperable pumps is restored to OPERABLE status and the Completion Time for Condition A has not expired, LCO 3.0.3 may be exited and operation continued in accordance with Condition A.

(continued)

EXAMPLES

EXAMPLE 1.3-2 (continued)

While in LCO 3.0.3, if one of the inoperable pumps is restored to OPERABLE status and the Completion Time for Condition A has expired, LCO 3.0.3 may be exited and operation continued in accordance with Condition B. The Completion Time for Condition B is tracked from the time the Condition A Completion Time expired.

On restoring one of the pumps to OPERABLE status, the Condition A Completion Time is not reset, but continues from the time the first pump was declared inoperable. This Completion Time may be extended if the pump restored to OPERABLE status was the first inoperable pump. A 24 hour extension to the stated 7 days is allowed, provided this does not result in the second pump being inoperable for > 7 days.

(continued)

1.3 Completion Times

EXAMPLES (continued)

EXAMPLE 1.3-3

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One Function X train inoperable.	A.1 Restore Function X train to OPERABLE status.	7 days AND 10 days from discovery of failure to meet the LCO
B. One Function Y train inoperable.	B.1 Restore Function Y train to OPERABLE status.	72 hours AND 10 days from discovery of failure to meet the LCO
C. One Function X train inoperable. AND One Function Y train inoperable.	C.1 Restore Function X train to OPERABLE status. OR C.2 Restore Function Y train to OPERABLE status.	72 hours 72 hours

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-3 (continued)

When one Function X train and one Function Y train are inoperable, Condition A and Condition B are concurrently applicable. The Completion Times for Condition A and Condition B are tracked separately for each train starting from the time each train was declared inoperable and the Condition was entered. A separate Completion Time is established for Condition C and tracked from the time the second train was declared inoperable (i.e., the time the situation described in Condition C was discovered).

If Required Action C.2 is completed within the specified Completion Time, Conditions B and C are exited. If the Completion Time for Required Action A.1 has not expired, operation may continue in accordance with Condition A. The remaining Completion Time in Condition A is measured from the time the affected train was declared inoperable (i.e., initial entry into Condition A).

The Completion Times of Conditions A and B are modified by a logical connector with a separate 10 day Completion Time measured from the time it was discovered the LCO was not met. In this example, without the separate Completion Time, it would be possible to alternate between Conditions A, B, and C in such a manner that operation could continue indefinitely without ever restoring systems to meet the LCO. The separate Completion Time modified by the phrase "from discovery of failure to meet the LCO" is designed to prevent indefinite continued operation while not meeting the LCO. This Completion Time allows for an exception to the normal "time zero" for beginning the Completion Time "clock". In this instance, the Completion Time "time zero" is specified as commencing at the time the LCO was initially not met, instead of at the time the associated Condition was entered.

(continued)

1.3 Completion Times

EXAMPLES (continued)

EXAMPLE 1.3-4

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more valves inoperable.	A.1 Restore valve(s) to OPERABLE status.	4 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 4.	6 hours 12 hours

A single Completion Time is used for any number of valves inoperable at the same time. The Completion Time associated with Condition A is based on the initial entry into Condition A and is not tracked on a per valve basis. Declaring subsequent valves inoperable, while Condition A is still in effect, does not trigger the tracking of separate Completion Times.

Once one of the valves has been restored to OPERABLE status, the Condition A Completion Time is not reset, but continues from the time the first valve was declared inoperable. The Completion Time may be extended if the valve restored to OPERABLE status was the first inoperable valve. The Condition A Completion Time may be extended for up to 4 hours provided this does not result in any subsequent valve being inoperable for > 4 hours.

If the Completion Time of 4 hours (including the extension) expires while one or more valves are still inoperable, Condition B is entered.

(continued)

1.3 Completion Times

EXAMPLES (continued)

EXAMPLE 1.3-5

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each inoperable valve.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more valves inoperable.	A.1 Restore valve to OPERABLE status.	4 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 4.	6 hours 12 hours

The Note above the ACTIONS Table is a method of modifying how the Completion Time is tracked. If this method of modifying how the Completion Time is tracked was applicable only to a specific Condition, the Note would appear in that Condition rather than at the top of the ACTIONS Table.

The Note allows Condition A to be entered separately for each inoperable valve, and Completion Times tracked on a per valve basis. When a valve is declared inoperable, Condition A is entered and its Completion Time starts. If subsequent valves are declared inoperable, Condition A is entered for each valve and separate Completion Times start and are tracked for each valve.

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-5 (continued)

If the Completion Time associated with a valve in Condition A expires, Condition B is entered for that valve. If the Completion Times associated with subsequent valves in Condition A expire, Condition B is entered separately for each valve and separate Completion Times start and are tracked for each valve. If a valve that caused entry into Condition B is restored to OPERABLE status, Condition B is exited for that valve.

Since the Note in this example allows multiple Condition entry and tracking of separate Completion Times, Completion Time extensions do not apply.

EXAMPLE 1.3-6

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One channel inoperable.	A.1 Perform SR 3.x.x.x. OR A.2 Reduce THERMAL POWER to ≤ 50% RTP.	Once per 8 hours 8 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-6 (continued)

Entry into Condition A offers a choice between Required Action A.1 or A.2. Required Action A.1 has a "once per" Completion Time, which qualifies for the 25% extension, per SR 3.0.2, to each performance after the initial performance. The initial 8 hour interval of Required Action A.1 begins when Condition A is entered and the initial performance of Required Action A.1 must be complete within the first 8 hour interval. If Required Action A.1 is followed, and the Required Action is not met within the Completion Time (plus the extension allowed by SR 3.0.2), Condition B is entered. If Required Action A.2 is followed and the Completion Time of 8 hours is not met, Condition B is entered.

If after entry into Condition B, Required Action A.1 or A.2 is met, Condition B is exited and operation may then continue in Condition A.

(continued)

1.3 Completion Times

EXAMPLES (continued)

EXAMPLE 1.3-7

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One subsystem inoperable.	A.1 Verify affected subsystem isolated. AND A.2 Restore subsystem to OPERABLE status.	1 hour AND Once per 8 hours thereafter 72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 5.	6 hours 36 hours

Required Action A.1 has two Completion Times. The 1 hour Completion Time begins at the time the Condition is entered and each "Once per 8 hours thereafter" interval begins upon performance of Required Action A.1.

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-7 (continued)

If after Condition A is entered, Required Action A.1 is not met within either the initial 1 hour or any subsequent 8 hour interval from the previous performance (plus the extension allowed by SR 3.0.2), Condition B is entered. The Completion Time clock for Condition A does not stop after Condition B is entered, but continues from the time Condition A was initially entered. If Required Action A.1 is met after Condition B is entered, Condition B is exited and operation may continue in accordance with Condition A, provided the Completion Time for Required Action A.2 has not expired.

IMMEDIATE COMPLETION TIME

When "Immediately" is used as a Completion Time, the Required Action should be pursued without delay and in a controlled manner.

1.0 USE AND APPLICATION

1.4 Frequency

PURPOSE

The purpose of this section is to define the proper use and application of Frequency requirements.

DESCRIPTION

Each Surveillance Requirement (SR) has a specified Frequency in which the Surveillance must be met in order to meet the associated LCO. An understanding of the correct application of the specified Frequency is necessary for compliance with the SR.

The "specified Frequency" is referred to throughout this section and each of the Specifications of Section 3.0, Surveillance Requirement (SR) Applicability. The "specified Frequency" consists of the requirements of the Frequency column of each SR as well as certain Notes in the Surveillance column that modify performance requirements.

Situations where a Surveillance could be required (i.e., its Frequency could expire), but where it is not possible or not desired that it be performed until sometime after the associated LCO is within its Applicability, represent potential SR 3.0.4 conflicts. To avoid these conflicts, the SR (i.e., the Surveillance or the Frequency) is stated such that it is only "required" when it can be and should be performed. With an SR satisfied, SR 3.0.4 imposes no restriction.

EXAMPLES

The following examples illustrate the various ways that Frequencies are specified. In these examples, the Applicability of the LCO (LCO not shown) is MODES 1, 2, and 3.

(continued)

EXAMPLES (continued)

EXAMPLE 1.4-1

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
Perform CHANNEL CHECK.	12 hours

Example 1.4-1 contains the type of SR most often encountered in the Technical Specifications (TS). The Frequency specifies an interval (12 hours) during which the associated Surveillance must be performed at least one time. Performance of the Surveillance initiates the subsequent interval. Although the Frequency is stated as 12 hours, an extension of the time interval to 1.25 times the stated Frequency is allowed by SR 3.0.2 for operational flexibility. The measurement of this interval continues at all times, even when the SR is not required to be met per SR 3.0.1 (such as when the equipment is inoperable, a variable is outside specified limits, or the unit is outside the Applicability of the LCO). If the interval specified by SR 3.0.2 is exceeded while the unit is in a MODE or other specified condition in the Applicability of the LCO, and the performance of the Surveillance is not otherwise modified (refer to Example 1.4-3), then SR 3.0.3 becomes applicable.

If the interval as specified by SR 3.0.2 is exceeded while the unit is not in a MODE or other specified condition in the Applicability of the LCO for which performance of the SR is required, then SR 3.0.4 becomes applicable. The Surveillance must be performed within the Frequency requirements of SR 3.0.2, as modified by SR 3.0.3, prior to entry into the MODE or other specified condition or the LCO is considered not met (in accordance with SR 3.0.1) and LCO 3.0.4 becomes applicable.

(continued)

EXAMPLES
(continued)

EXAMPLE 1.4-2

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
Verify flow is within limits.	Once within 12 hours after ≥ 25% RTP AND 24 hours thereafter

Example 1.4-2 has two Frequencies. The first is a one time performance Frequency, and the second is of the type shown in Example 1.4-1. The logical connector "AND" indicates that both Frequency requirements must be met. Each time reactor power is increased from a power level < 25% RTP to ≥ 25% RTP, the Surveillance must be performed within 12 hours.

The use of "once" indicates a single performance will satisfy the specified Frequency (assuming no other Frequencies are connected by "AND"). This type of Frequency does not qualify for the 25% extension allowed by SR 3.0.2. "Thereafter" indicates future performances must be established per SR 3.0.2, but only after a specified condition is first met (i.e., the "once" performance in this example). If reactor power decreases to < 25% RTP, the measurement of both intervals stops. New intervals start upon reactor power reaching 25% RTP.

(continued)

1.4 Frequency

EXAMPLES (continued)

EXAMPLE 1.4-3

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
----------NOTE---------- Not required to be performed until 12 hours after ≥ 25% RTP. ----------	
Perform channel adjustment.	7 days

The interval continues, whether or not the unit operation is < 25% RTP between performances.

As the Note modifies the required performance of the Surveillance, it is construed to be part of the "specified Frequency." Should the 7 day interval be exceeded while operation is < 25% RTP, this Note allows 12 hours after power reaches ≥ 25% RTP to perform the Surveillance. The Surveillance is still considered to be performed within the "specified Frequency." Therefore, if the Surveillance were not performed within the 7 day (plus the extension allowed by SR 3.0.2) interval, but operation was < 25% RTP, it would not constitute a failure of the SR or failure to meet the LCO. Also, no violation of SR 3.0.4 occurs when changing MODES, even with the 7 day Frequency not met, provided operation does not exceed 12 hours with power ≥ 25% RTP.

Once the unit reaches 25% RTP, 12 hours would be allowed for completing the Surveillance. If the Surveillance were not performed within this 12 hour interval, there would then be a failure to perform a Surveillance within the specified Frequency, and the provisions of SR 3.0.3 would apply.

2.1 SLs

2.1.1 Reactor Core SLs

In MODES 1 and 2, the combination of THERMAL POWER, Reactor Vessel inlet temperature, and pressurizer pressure shall not exceed the limits specified in the COLR; and the following SLs shall not be exceeded:

2.1.1.1 The departure from nucleate boiling ratio (DNBR) shall be maintained $\geq$ 1.17 for the WRB-1 DNB correlations.

2.1.1.2 The peak fuel centerline temperature shall be maintained < 5080°F, decreasing by 58°F per 10,000 MWD/MTU of burnup.

2.1.2 RCS Pressure SL

In MODES 1, 2, 3, 4, 5, and in MODE 6 when the reactor vessel head is on, the RCS pressure shall be maintained $\leq$ 2735 psig.

2.2 SL Violations

2.2.1 If SL 2.1.1 is violated, restore compliance and be in MODE 3 within 1 hour.

2.2.2 If SL 2.1.2 is violated:

2.2.2.1 In MODE 1 or 2, restore compliance and be in MODE 3 within 1 hour.

2.2.2.2 In MODE 3, 4, 5, or 6, restore compliance within 5 minutes.

3.0 LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY

LCO 3.0.1 LCOs shall be met during the MODES or other specified conditions in the Applicability, except as provided in LCO 3.0.2, LCO 3.0.7 and LCO 3.0.8.

LCO 3.0.2 Upon discovery of a failure to meet an LCO, the Required Actions of the associated Conditions shall be met, except as provided in LCO 3.0.5 and LCO 3.0.6.

If the LCO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required unless otherwise stated.

LCO 3.0.3 When an LCO is not met and the associated ACTIONS are not met, an associated ACTION is not provided, or if directed by the associated ACTIONS, the unit shall be placed in a MODE or other specified condition in which the LCO is not applicable. Action shall be initiated within 1 hour to place the unit, as applicable, in:

a. MODE 3 within 7 hours;

b. MODE 4 within 13 hours; and

c. MODE 5 within 37 hours.

Exceptions to this Specification are stated in the individual Specifications.

Where corrective measures are completed that permit operation in accordance with the LCO or ACTIONS, completion of the actions required by LCO 3.0.3 is not required.

LCO 3.0.3 is only applicable in MODES 1, 2, 3, and 4.

(continued)

LCO 3.0.4 When an LCO is not met, entry into a MODE or other specified condition in the Applicability shall only be made:

a. When the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time;

b. After performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering the MODE or other specified condition in the Applicability, and establishment of risk management actions, if appropriate; exceptions to this Specification are stated in the individual Specifications, or

c. When an allowance is stated in the individual value, parameter, or other Specification.

This Specification shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

LCO 3.0.5 Equipment removed from service or declared inoperable to comply with ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY or the OPERABILITY of other equipment. This is an exception to LCO 3.0.2 for the system returned to service under administrative control to perform the testing required to demonstrate OPERABILITY.

(continued)

3.0 LCO APPLICABILITY (continued)

LCO 3.0.6

When a supported system LCO is not met solely due to a support system LCO not being met, the Conditions and Required Actions associated with this supported system are not required to be entered. Only the support system LCO ACTIONS are required to be entered. This is an exception to LCO 3.0.2 for the supported system. In this event, an evaluation shall be performed in accordance with Specification 5.5.14, "Safety Function Determination Program (SFDP)." If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered.

When a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with LCO 3.0.2.

LCO 3.0.7

Test Exception LCOs, such as 3.1.8, allow specified Technical Specification (TS) requirements to be changed to permit performance of special tests and operations. Unless otherwise specified, all other TS requirements remain unchanged. Compliance with Test Exception LCOs is optional. When a Test Exception LCO is desired to be met but is not met, the ACTIONS of the Test Exception LCO shall be met. When a Test Exception LCO is not desired to be met, entry into a MODE or other specified condition in the Applicability shall be made in accordance with the other applicable Specifications.

LCO 3.0.8

When one or more required snubbers are unable to perform their associated support function(s), any affected supported LCO(s) are not required to be declared not met solely for this reason if risk is assessed and managed, and:

a. the snubbers not able to perform their associated support function(s) are associated with only one train or subsystem of a multiple train or subsystem supported system or are associated with a single train or subsystem supported system and are able to perform their associated support function within 72 hours; or

b. the snubbers not able to perform their associated support function(s) are associated with more than one train or subsystem of a multiple train or subsystem supported system and are able to perform their associated support function within 12 hours.

At the end of the specified period the required snubbers must be able to perform their associated support function(s), or the affected supported system LCO(s) shall be declared not met.

3.0 SURVEILLANCE REQUIREMENT (SR) APPLICABILITY

SR 3.0.1

SRs shall be met during the MODES or other specified conditions in the Applicability for individual LCOs, unless otherwise stated in the SR. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the LCO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the LCO except as provided in SR 3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

SR 3.0.2

The specified Frequency for each SR is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance.

Exceptions to this Specification are stated in the individual Specifications.

SR 3.0.3

If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. This delay period is permitted to allow performance of the Surveillance. A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed.

If the Surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the LCO must immediately be declared not met, and the applicable Condition(s) must be entered.

(continued)

3.0 SR APPLICABILITY (continued)

SR 3.0.4 Entry into a MODE or other specified condition in the Applicability of an LCO shall only be made when the LCO's Surveillances have been met within their specified Frequency, except as provided by SR 3.0.3. When an LCO is not met due to Surveillances not having been met, entry into a MODE or other specified condition in the Applicability shall only be made in accordance with LCO 3.0.4.

This provision shall not prevent entry into MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

3.1 REACTIVITY CONTROL SYSTEMS

3.1.1 SHUTDOWN MARGIN (SDM)

LCO 3.1.1 SDM shall be within the limits specified in the COLR.

APPLICABILITY: MODE 2 with $k_{eff} < 1.0$,
MODES 3, 4, and 5.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. SDM not within limit.	A.1	Initiate boration to restore SDM to within limit.	15 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.1.1	Verify SDM is within the limits specified in the COLR.	24 hours

3.1 REACTIVITY CONTROL SYSTEMS

3.1.2 Core Reactivity

LCO 3.1.2 The measured core reactivity shall be within ± 1% Δk/k of predicted values.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Measured core reactivity not within limit.	A.1 Re-evaluate core design and safety analysis, and determine that the reactor core is acceptable for continued operation. AND	7 days
	A.2 Establish appropriate operating restrictions and SRs.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.2.1	----------NOTE---------- The predicted reactivity values may be adjusted (normalized) to correspond to the measured core reactivity prior to exceeding a fuel burnup of 60 effective full power days (EFPD) after each fuel loading. ----------	
	Verify measured core reactivity is within ± 1% Δk/k of predicted values.	Once prior to entering MODE 1 after each refueling AND -----NOTE------ Only required after 60 EFPD ---------- 31 EFPD thereafter

3.1 REACTIVITY CONTROL SYSTEMS

3.1.3 Moderator Temperature Coefficient (MTC)

LCO 3.1.3 The MTC shall be maintained within the limits specified in the COLR. The maximum upper limit shall be $\leq$ 0.0 $\Delta k/k°F$ at hot zero power.

APPLICABILITY: MODE 1 and MODE 2 with $k_{eff} \geq 1.0$ for the upper MTC limit, MODES 1, 2, and 3 for the lower MTC limit.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. MTC not within upper limit.	A.1 Establish administrative withdrawal limits for control banks to maintain MTC within limit.	24 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 2 with $k_{eff} < 1.0$.	6 hours
C. MTC not within lower limit.	C.1 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.1.3.1	Verify MTC is within upper limit.	Once prior to entering MODE 1 after each refueling
SR 3.1.3.2	----------NOTES---------- 1. Not required to be performed until 7 effective full power days (EFPD) after reaching the equivalent of an equilibrium RTP all rods out (ARO) boron concentration of 300 ppm. 2. SR 3.1.3.2 is not required to be performed by measurement provided that the benchmark criteria in WCAP-13749-P-A are satisfied and the Revised Predicted MTC satisfies the 300 ppm surveillance limit specified in the COLR. 3. If the MTC is more negative than the 300 ppm Surveillance limit (not LCO limit) specified in the COLR, SR 3.1.3.2 shall be repeated once per 14 EFPD during the remainder of the fuel cycle. 4. SR 3.1.3.2 need not be repeated if the MTC measured at the equivalent of equilibrium RTP-ARO boron concentration of ≤ 60 ppm is less negative than the 60 ppm Surveillance limit specified in the COLR. ---------- Verify MTC is within lower limit.	Once each cycle

3.1 REACTIVITY CONTROL SYSTEMS

3.1.4 Rod Group Alignment Limits

LCO 3.1.4 All shutdown and control rods shall be OPERABLE, with rod group alignment limits as follows:

a. When THERMAL POWER is > 85% RTP, the difference between each individual indicated rod position and its group step counter demand position shall be within the limits specified in Table 3.1.4-1 for the group step counter demand position; and

b. When THERMAL POWER is ≤ 85% RTP, the difference between each individual indicated rod position and its group step counter demand position shall be within 24 steps.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more rod(s) untrippable.	A.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
	OR		
	A.1.2	Initiate boration to restore SDM to within limit.	1 hour
	AND		
	A.2	Be in MODE 3.	6 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
B. One rod not within alignment limits.	B.1	Restore rod to within alignment limits.	1 hour
	OR		
	B.2.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
		OR	
	B.2.1.2	Initiate boration to restore SDM to within limit.	1 hour
		AND	
	B.2.2	Reduce THERMAL POWER to ≤ 75% RTP.	2 hours
		AND	
	B.2.3	Verify SDM is within the limits specified in the COLR.	Once per 12 hours
		AND	
	B.2.4	Perform SR 3.2.1.1.	72 hours
		AND	
	B.2.5	Perform SR 3.2.2.1.	72 hours
		AND	

(continued)

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
B (continued)	B.2.6	Re-evaluate safety analyses and confirm results remain valid for duration of operation under these conditions.	5 days
C. Required Action and associated Completion Time of Condition B not met.	C.1	Be in MODE 3.	6 hours
D. More than one rod not within alignment limit.	D.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
	OR		
	D.1.2	Initiate boration to restore required SDM to within limit.	1 hour
	AND		
	D.2	Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.1.4.1	---------- NOTE ---------- Not required to be met for individual control rods until 1 hour after completion of control rod movement. ---------- Verify individual rod positions within alignment limit.	12 hours
SR 3.1.4.2	Verify rod freedom of movement (trippability) by moving each rod not fully inserted in the core ≥ 10 steps in one direction.	92 days
SR 3.1.4.3	Verify rod drop time of each rod, from the fully withdrawn position, is ≤ 1.8 seconds from the loss of stationary gripper coil voltage to dashpot entry, with: a. T_{avg} ≥ 500°F; and b. All reactor coolant pumps operating.	Prior to reactor criticality after each removal of the reactor head

Table 3.1.4-1

Maximum Permissible Rod Misalignment
(Indicated Rod Position minus Group Step Counter Demand Position)
When > 85 % RTP

Step Counter Demand Position (steps)	Maximum Permissible Deviations (IRPI Position minus Step Counter Demand Position) (steps)
≤ 212	≥ -12 and ≤ +12
213 to 225	≥ -12 and ≤ +17
226	≥ -13 and ≤ +17
227	≥ -14 and ≤ +17
228	≥ -15 and ≤ +17
229	≥ -16 and ≤ +17
≥ 230	≥ -17 and ≤ +17

3.1 REACTIVITY CONTROL SYSTEMS

3.1.5 Shutdown Bank Insertion Limits

LCO 3.1.5 Each shutdown bank shall be within insertion limits specified in the COLR.

APPLICABILITY: MODE 1,
MODE 2 with any control bank not fully inserted.

----------NOTE----------
This LCO is not applicable while performing SR 3.1.4.2.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more shutdown banks not within limits.	A.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
	OR		
	A.1.2	Initiate boration to restore SDM to within limit.	1 hour
	AND		
	A.2	Restore shutdown banks to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1	Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.1.5.1	Verify each shutdown bank is within the limits specified in the COLR.	12 hours

3.1 REACTIVITY CONTROL SYSTEMS

3.1.6 Control Bank Insertion Limits

LCO 3.1.6 Control banks shall be within the insertion, sequence, and overlap limits specified in the COLR.

APPLICABILITY: MODE 1,
MODE 2 with $k_{eff} \geq 1.0$.

----------NOTE----------
This LCO is not applicable while performing SR 3.1.4.2.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Control bank insertion limits not met.	A.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
	OR		
	A.1.2	Initiate boration to restore SDM to within limit.	1 hour
	AND		
	A.2	Restore control bank(s) to within limits.	2 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
B. Control bank sequence or overlap limits not met.	B.1.1	Verify SDM is within the limits specified in the COLR.	1 hour
	OR		
	B.1.2	Initiate boration to restore SDM to within limit.	1 hour
	AND		
	B.2	Restore control bank sequence and overlap to within limits.	2 hours
C. Required Action and associated Completion Time not met.	C.1	Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.6.1	Verify estimated critical control bank position is within the limits specified in the COLR.	Within 4 hours prior to achieving criticality

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.1.6.2	Verify each control bank insertion is within the limits specified in the COLR.	12 hours
SR 3.1.6.3	Verify sequence and overlap limits specified in the COLR are met for control banks not fully withdrawn from the core.	12 hours

3.1 REACTIVITY CONTROL SYSTEMS

3.1.7 Rod Position Indication

LCO 3.1.7 The Individual Rod Position Indication (IRPI) System and the Demand Position Indication System shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each inoperable rod position indicator and each demand position indicator.

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One IRPI per group inoperable for one or more groups.	A.1	Verify the position of the rods with inoperable position indicators indirectly by using movable incore detectors.	Once per 8 hours
	OR		
	A.2	Reduce THERMAL POWER to ≤ 50% RTP.	8 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
B. More than one IRPI per group inoperable.	B.1	Place the control rods under manual control.	Immediately
	AND		
	B.2	Monitor and record RCS Tavg.	Once per 1 hour
	AND		
	B.3	Verify the position of the rods with inoperable position indicators indirectly by using the movable incore detectors.	Once per 8 hours
	AND		
	B.4	Restore inoperable position indicators to OPERABLE status such that a maximum of one IRPI per group is inoperable.	24 hours
C. One or more rods with inoperable position indicators have been moved in excess of 24 steps in one direction since the last determination of the rod's position.	C.1	Verify the position of the rods with inoperable position indicators indirectly by using movable incore detectors.	4 hours
	OR		
	C.2	Reduce THERMAL POWER to ≤ 50% RTP.	8 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. One demand position indicator per bank inoperable for one or more banks.	D.1.1 Verify by administrative means all IRPIs for the affected banks are OPERABLE.	Once per 8 hours
	AND	
	D.1.2 Verify the most withdrawn rod and the least withdrawn rod of the affected banks are ≤ 12 steps apart when > 85% RTP and ≤ 24 steps apart when ≤ 85% RTP.	Once per 8 hours
	OR	
	D.2 Reduce THERMAL POWER to ≤ 50% RTP.	8 hours
E. Required Action and associated Completion Time not met.	E.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.7.1	Verify each IRPI agrees within 12 steps of the group demand position for the full indicated range of rod travel.	Prior to reactor criticality after each removal of the reactor vessel head

3.1 REACTIVITY CONTROL SYSTEMS

3.1.8 PHYSICS TESTS Exceptions – MODE 2

LCO 3.1.8 During the performance of PHYSICS TESTS, the requirements of

LCO 3.1.3, "Moderator Temperature Coefficient (MTC)";
LCO 3.1.4, "Rod Group Alignment Limits";
LCO 3.1.5, "Shutdown Bank Insertion Limits";
LCO 3.1.6, "Control Bank Insertion Limits"; and
LCO 3.4.2, "RCS Minimum Temperature for Criticality"

may be suspended, provided:

a. RCS lowest loop average temperature is ≥ 540°F; and

b. SDM is within the limits specified in the COLR; and

c. THERMAL POWER IS ≤ 5% RTP.

APPLICABILITY: MODE 2 during PHYSICS TESTS.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. SDM not within limit.	A.1	Initiate boration to restore SDM to within limit.	15 minutes
	AND		
	A.2	Suspend PHYSICS TESTS exceptions.	1 hour
B. THERMAL POWER not within limit.	B.1	Open reactor trip breakers.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. RCS lowest loop average temperature not within limit.	C.1 Restore RCS lowest loop average temperature to within limit.	15 minutes
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 3.	15 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.8.1	Perform a CHANNEL OPERATIONAL TEST on power range and intermediate range channels per SR 3.3.1.7, SR 3.3.1.8, and Table 3.3.1-1.	Prior to initiation of PHYSICS TESTS
SR 3.1.8.2	Verify the RCS lowest loop average temperature is $\geq$ 540°F.	30 minutes
SR 3.1.8.3	Verify THERMAL POWER is $\leq$ 5% RTP.	30 minutes
SR 3.1.8.4	Verify SDM is within the limits specified in the COLR.	24 hours

3.2 POWER DISTRIBUTION LIMITS

3.2.1 Heat Flux Hot Channel Factor ($F_Q(Z)$)

LCO 3.2.1 $F_Q(Z)$ shall be within the limits specified in the COLR.

APPLICABILITY: MODE 1.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. $F_Q(Z)$ not within limit.	A.1	Reduce THERMAL POWER ≥ 1% RTP for each 1% $F_Q(Z)$ exceeds limit.	15 minutes after each $F_Q(Z)$ determination
	AND		
	A.2	Reduce Power Range Neutron Flux–High trip setpoints ≥ 1% for each 1% $F_Q(Z)$ exceeds limit.	72 hours after each $F_Q(Z)$ determination
	AND		
	A.3	Reduce Overpower ΔT trip setpoints ≥ 1% for each 1% $F_Q(Z)$ exceeds limit.	72 hours after each $F_Q(Z)$ determination
	AND		
	A.4	Perform SR 3.2.1.1.	Prior to increasing THERMAL POWER above the limit of Required Action A.1

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 2.	6 hours

SURVEILLANCE REQUIREMENTS

----------NOTE----------
During power escalation at the beginning of each cycle, THERMAL POWER may be increased until an equilibrium power level has been achieved, at which a power distribution map is obtained.

SURVEILLANCE		FREQUENCY
SR 3.2.1.1	Verify $F_Q(Z)$ is within limit.	Once after each refueling prior to THERMAL POWER exceeding 75% RTP AND Once within 12 hours after achieving equilibrium conditions after exceeding, by ≥ 10% RTP, the THERMAL POWER at which $F_Q(Z)$ was last verified AND 31 EFPD thereafter

3.2 POWER DISTRIBUTION LIMITS

3.2.2 Nuclear Enthalpy Rise Hot Channel Factor ($F^N_{\Delta H}$)

LCO 3.2.2 $F^N_{\Delta H}$ shall be within the limits specified in the COLR.

APPLICABILITY: MODE 1.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. ---------NOTE--------- Required Actions A.2 and A.3 must be completed whenever Condition A is entered. ---------- $F^N_{\Delta H}$ not within limit.	A.1.1	Restore $F^N_{\Delta H}$ to within limit.	4 hours
	OR		
	A.1.2.1	Reduce THERMAL POWER to < 50% RTP.	4 hours
		AND	
	A.1.2.2	Reduce Power Range Neutron Flux–High trip setpoints to ≤ 55% RTP.	72 hours
	AND		
	A.2	Perform SR 3.2.2.1.	24 hours
	AND		
			(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.3 --------NOTE-------- THERMAL POWER does not have to be reduced to comply with this Required Action. ---------- Perform SR 3.2.2.1.	 Prior to THERMAL POWER exceeding 50% RTP AND Prior to THERMAL POWER exceeding 75% RTP AND 24 hours after THERMAL POWER reaching ≥ 95% RTP
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 2.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.2.2.1	Verify $F^N_{\Delta H}$ is within limits specified in the COLR.	Once after each refueling prior to THERMAL POWER exceeding 75% RTP AND 31 EFPD thereafter

3.2 POWER DISTRIBUTION LIMITS

3.2.3 AXIAL FLUX DIFFERENCE (AFD) (Constant Axial Offset Control (CAOC) Methodology)

LCO 3.2.3 The AFD:

a. Shall be maintained within the target band about the target flux difference. The target band is specified in the COLR.

b. May deviate outside the target band with THERMAL POWER < 90% RTP but ≥ 50% RTP, provided AFD is within the acceptable operation limits and cumulative penalty deviation time is ≤ 1 hour during the previous 24 hours. The acceptable operation limits are specified in the COLR.

c. May deviate outside the target band with THERMAL POWER < 50% RTP.

---------- NOTES----------

1. The AFD shall be considered outside the target band when two or more OPERABLE excore channels indicate AFD to be outside the target band.

2. With Thermal Power ≥ 50% RTP, penalty deviation time shall be accumulated on the basis of a 1 minute penalty deviation for each 1 minute of power operation with AFD outside the target band.

3. With Thermal Power < 50% RTP and > 15% RTP, penalty deviation time shall be accumulated on the basis of a 0.5 minute penalty deviation for each 1 minute of power operation with AFD outside the target band.

4. A total of 16 hours of operation may be accumulated with AFD outside the target band without penalty deviation time during surveillance of power range channels in accordance with SR 3.3.1.6, provided AFD is maintained within acceptable operation limits.

APPLICABILITY: MODE 1 with THERMAL POWER > 15% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. THERMAL POWER ≥ 90% RTP. AND AFD not within the target band.	A.1 Restore AFD to within target band.	15 minutes
B. Required Action and associated Completion Time of Condition A not met.	B.1 Reduce THERMAL POWER to < 90% RTP.	15 minutes
C. ---------NOTE--------- Required Action C.1 must be completed whenever Condition C is entered. ---------- THERMAL POWER < 90% and ≥ 50% RTP with cumulative penalty deviation time > 1 hour during the previous 24 hours. OR THERMAL POWER < 90% and ≥ 50% RTP with AFD not within the acceptable operation limits.	C.1 Reduce THERMAL POWER to < 50% RTP.	30 minutes

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.2.3.1	Verify AFD is within target band for each OPERABLE excore channel.	7 days
SR 3.2.3.2	----------NOTE---------- Assume logged values of AFD exist during the preceding time interval. ----------	
	Verify AFD is within target band and log AFD for each OPERABLE excore channel.	-----NOTE----- Only required to be performed if AFD monitor alarm is inoperable ---------- Once within 15 minutes and every 15 minutes thereafter when THERMAL POWER ≥ 90% RTP AND Once within 1 hour and every 1 hour thereafter when THERMAL POWER < 90% RTP

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.2.3.3	Update target flux difference of each OPERABLE excore channel by: a. Determining the target flux difference in accordance with SR 3.2.3.4, or b. Using linear interpolation between the most recently measured value, and either the predicted value for the end of cycle or 0% AFD.	Once within 31 EFPD after each refueling AND 31 EFPD thereafter
SR 3.2.3.4	----------NOTE---------- The initial target flux difference after each refueling may be determined from design predictions. ---------- Determine, by measurement, the target flux difference of each OPERABLE excore channel.	Once within 31 EFPD after each refueling AND 92 EFPD thereafter

3.2 POWER DISTRIBUTION LIMITS

3.2.4 QUADRANT POWER TILT RATIO (QPTR)

LCO 3.2.4 The QPTR shall be ≤ 1.02.

APPLICABILITY: MODE 1 with THERMAL POWER > 50% RTP.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. QPTR not within limit.	A.1	Reduce THERMAL POWER ≥ 3% from RTP for each 1% of QPTR > 1.00.	2 hours after each QPTR determination
	AND		
	A.2	Determine QPTR after achieving equilibrium conditions from a THERMAL POWER reduction per Required Action A.1.	Once per 12 hours
	AND		
	A.3	Perform SR 3.2.1.1 and SR 3.2.2.1.	24 hours after achieving equilibrium conditions from a Thermal Power reduction per Required Action A.1. AND Once per 7 days thereafter

(continued)

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
	AND		
A. (continued)	A.4	Re-evaluate safety analyses and confirm results remain valid for duration of operation under this condition.	Prior to increasing THERMAL POWER above the limit of Required Action A.1
	AND		
	A.5	--------NOTES-------- 1. Perform Required Action A.5 only after Required Action A.4 is completed. 2. Required Action A.6 shall be completed whenever Required Action A.5 is performed. ----------	
		Normalize excore detectors to restore QPTR to within limits.	Prior to increasing THERMAL POWER above the limit of Required Action A.1
	AND		(continued)

ACTIONS

CONDITION		REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.6	--------NOTE-------- Perform Required Action A.6 only after Required Action A.5 is completed. ---------- Perform SR 3.2.1.1 and SR 3.2.2.1.	Within 24 hours after achieving equilibrium conditions at RTP not to exceed 48 hours after increasing THERMAL POWER above the limit of Required Action A.1
B. Required Action and associated Completion Time not met.	B.1	Reduce THERMAL POWER to ≤ 50% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.2.4.1	----------NOTES---------- 1. With input from one Power Range Neutron Flux channel inoperable and THERMAL POWER ≤ 75% RTP, the remaining three power range channels can be used for calculating QPTR. 2. SR 3.2.4.2 may be performed in lieu of this Surveillance. ---------- Verify QPTR is within limit by calculation.	7 days
SR 3.2.4.2	----------NOTE---------- Not required to be performed until 24 hours after input from one or more Power Range Neutron Flux channels are inoperable with THERMAL POWER > 75% RTP. ---------- Verify QPTR is within limit using the movable incore detectors.	24 hours

3.3 INSTRUMENTATION

3.3.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1 The RPS instrumentation for each Function in Table 3.3.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1-1.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one or more required channels or trains inoperable.	A.1 Enter the Condition referenced in Table 3.3.1-1 for the channel(s) or train (s).	Immediately
B. One Manual Reactor Trip channel inoperable.	B.1 Restore channel to OPERABLE status. OR B.2 Be in MODE 3.	48 hours 54 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One channel or train inoperable.	C.1 Restore channel or train to OPERABLE status. OR C.2.1 Initiate action to fully insert all rods. AND C.2.2 Place the Rod Control System in a condition incapable of rod withdrawal.	48 hours 48 hours 49 hours
D. One Power Range Neutron Flux–High channel inoperable.	----------NOTES---------- 1. The inoperable channel may be bypassed for up to 8 hours for surveillance testing and setpoint adjustment of other channels. 2. Requirements of SR 3.2.4.2 are applicable if the Power Range Neutron Flux input to QPTR is inoperable. ---------- D.1 Place channel in trip. OR D.2 Be in MODE 3.	 6 hours 12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One channel inoperable.	----------NOTE---------- The inoperable channel may be bypassed for up to 8 hours for surveillance testing of other channels. ---------- E.1 Place channel in trip. OR E.2 Be in MODE 3.	 6 hours 12 hours
F. Required Intermediate Range Neutron Flux channel inoperable.	F.1 Suspend operations involving positive reactivity additions. AND F.2 Reduce THERMAL POWER to < P-6.	Immediately 2 hours
G. Required Source Range Neutron Flux channel inoperable.	G.1 Open Reactor Trip Breakers (RTBs).	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
H. One channel inoperable.	----------NOTE---------- The inoperable channel may be bypassed for up to 8 hours for surveillance testing of other channels. ----------	
	H.1 Place channel in trip.	6 hours
	OR	
	H.2 Reduce THERMAL POWER to < P-7.	12 hours
I. One Reactor Coolant Pump Breaker Position channel inoperable.	----------NOTE---------- The inoperable channel may be bypassed for up to 8 hours for surveillance testing of other channels. ----------	
	I.1 Restore channel to OPERABLE status.	6 hours
	OR	
	I.2 Reduce THERMAL POWER to < P-8.	10 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
J. One Turbine Trip channel inoperable.	----------NOTE---------- The inoperable channel may be bypassed for up to 8 hours for surveillance testing of other channels. ---------- J.1 Place channel in trip. OR J.2 Reduce THERMAL POWER to < P-8.	 6 hours 10 hours
K. One train inoperable.	----------NOTE---------- One train may be bypassed for up to 8 hours for surveillance testing provided the other train is OPERABLE. ---------- K.1 Restore train to OPERABLE status. OR K.2 Be in MODE 3.	 6 hours 12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
L. One RTB train inoperable.	----------NOTES---------- 1. One train may be bypassed for up to 2 hours for surveillance testing, provided the other train is OPERABLE. 2. One RTB may be bypassed for up to 2 hours for maintenance on undervoltage or shunt trip mechanisms, provided the other train is OPERABLE. ---------- L.1 Restore train to OPERABLE status. OR L.2 Be in MODE 3.	 1 hour 7 hours
M. One or more channels inoperable.	M.1 Verify interlock is in required state for existing unit conditions. OR M.2 Be in MODE 3.	1 hour 7 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
N. One or more channels inoperable.	N.1	Verify interlock is in required state for existing unit conditions.	1 hour
	OR		
	N.2	Be in MODE 2.	7 hours
O. One trip mechanism inoperable for one RTB.	O.1	Restore inoperable trip mechanism to OPERABLE status.	48 hours
	OR		
	O.2.	Be in MODE 3.	54 hours

SURVEILLANCE REQUIREMENTS

----------NOTE----------
Refer to Table 3.3.1-1 to determine which SRs apply for each RPS Function.

	SURVEILLANCE	FREQUENCY
SR 3.3.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.2	----------NOTES---------- 1. Adjust NIS channel if absolute difference is > 2%. 2. Not required to be performed until 24 hours after THERMAL POWER is ≥ 15% RTP. --- Compare results of calorimetric heat balance calculation to Nuclear Instrumentation System (NIS) channel output.	24 hours
SR 3.3.1.3	----------NOTES---------- 1. Adjust NIS channel if absolute difference is ≥ 3%. 2. Only required to be performed when THERMAL POWER is > 90% RTP. --- Compare results of the incore detector measurements to NIS AFD.	31 effective full power days (EFPD)

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.3.1.4	----------NOTE---------- This Surveillance must be performed on the reactor trip bypass breaker prior to placing the bypass breaker in service. ---------- Perform TADOT.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.5	Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.6	----------NOTE---------- Only required to be performed when THERMAL POWER is > 90% RTP. ---------- Calibrate excore channels to agree with incore detector measurements.	92 EFPD
SR 3.3.1.7	----------NOTE---------- Not required to be performed for source range instrumentation prior to entering MODE 3 from MODE 2 until 4 hours after entry into MODE 3. ---------- Perform COT.	92 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.8	----------NOTE---------- This Surveillance shall include verification that interlocks P-6 and P-10 are in their required state for existing unit conditions. ----------	
	Perform COT.	------NOTE------ Only required when not performed within previous 92 days ---------- Prior to reactor startup AND Four hours after reducing power below P-6 for source range instrumentation AND Twelve hours after reducing power below P-10 for power and intermediate instrumentation AND Every 92 days thereafter

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.9	----------NOTE---------- Verification of setpoint is not required. ---------- Perform TADOT.	92 days
SR 3.3.1.10	----------NOTE---------- This Surveillance shall include verification that the time constants are adjusted to the prescribed values. ---------- Perform CHANNEL CALIBRATION.	24 months AND 18 months for Function 11
SR 3.3.1.11	----------NOTE---------- Neutron detectors are excluded from CHANNEL CALIBRATION. ---------- Perform CHANNEL CALIBRATION.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.12	----------NOTE---------- This Surveillance shall include verification that the electronic dynamic compensation time constants are set at the required values. ---------- Perform CHANNEL CALIBRATION.	24 months
SR 3.3.1.13	Perform COT.	24 months
SR 3.3.1.14	----------NOTE---------- Verification of setpoint is not required. ---------- Perform TADOT.	24 months

Table 3.3.1-1 (page 1 of 8)
Reactor Protection System Instrumentation

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1.	Manual Reactor Trip	1,2	2	B	SR 3.3.1.14	NA
		3[a], 4[a], 5[a]	2	C	SR 3.3.1.14	NA
2.	Power Range Neutron Flux					
	a. High	1,2	4[j]	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11	≤111% RTP
	b. Low	1[b],2	4[j]	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤25% RTP
3.	Intermediate Range Neutron Flux	1[b], 2[c]	1	F	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	NA

(continued)

(a) With Rod Control System capable of rod withdrawal or one or more rods not fully inserted.

(b) Below the P-10 (Power Range Neutron Flux) interlocks.

(c) Above the P-6 (Intermediate Range Neutron Flux) interlocks.

(j) Only 3 channels required during Mode 2 Physics Tests, LCO 3.1.8

Table 3.3.1-1 (page 2 of 8)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
4. Source Range Neutron Flux	2[d]	1	G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	NA
	3[a], 4[a], 5[a]	1	G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11	NA
5. Overtemperature ΔT	1,2	4	E	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.12	Refer to Note 1
6. Overpower ΔT	1,2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.12	Refer to Note 2

(continued)

(a) With Rod Control System capable of rod withdrawal or one or more rods not fully inserted.

(d) Below the P-6 (Intermediate Range Neutron Flux) interlocks.

Table 3.3.1-1 (page 3 of 8)
Reactor Protection System Instrumentation

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7.	Pressurizer Pressure					
	a. Low	1[(e)]	4	H	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥1900 psig
	b. High	1,2	3	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤2400 psig
8.	Pressurizer Water Level - High	1[(e)]	3	H	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤97%
9.	Reactor Coolant Flow - Low	1[(e)]	3 per loop	H	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥90%

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

Table 3.3.1-1 (page 4 of 8)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
10. Reactor Coolant Pump (RCP) Breaker Position					
a. Single Loop	1[(f)]	1 per RCP	I	SR 3.3.1.14	NA
b. Two Loops	1[(g)]	1 per RCP	H	SR 3.3.1.14	NA
11. Undervoltage RCPs (6.9 kV bus)	1[(e)]	1 per bus	H	SR 3.3.1.9 SR 3.3.1.10	NA
12. Underfrequency RCPs (6.9 kV bus)	1[(e)]	1 per bus	H	SR 3.3.1.9 SR 3.3.1.10	≥ 57.22 Hz
13. Steam Generator (SG) Water Level – Low Low	1,2	3 per SG	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 4.0% NR
14. SG Water Level – Low	1,2	2 per SG	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	NA
Coincident with Steam Flow/ Feedwater Flow Mismatch	1,2	2 per SG	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

(f) Above the P-8 (Power Range Neutron Flux) interlock.

(g) Above the P-7 (Low Power Reactor Trips Block) interlock and below the P-8 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 5 of 8)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
15. Turbine Trip-Auto-Stop Oil Pressure	1(h)	3	J	SR 3.3.1.10 SR 3.3.1.14	NA
16. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1,2	2 trains	K	SR 3.3.1.14	NA
17. Reactor Trip System Interlocks					
a. Intermediate Range Neutron Flux, P-6	2(d)	2 trains	M	SR 3.3.1.11 SR 3.3.1.13	NA
b. Low Power Reactor Trips Block, P-7	1	2 trains	N	SR 3.3.1.11 SR 3.3.1.13	NA
c. Power Range Neutron Flux, P-8	1	4	N	SR 3.3.1.11 SR 3.3.1.13	NA
d. Power Range Neutron Flux, P-10	1,2	4	M	SR 3.3.1.11 SR 3.3.1.13	NA
e. Turbine First Stage Pressure, P-7 Input	1	2	N	SR 3.3.1.1 SR 3.3.1.10 SR 3.3.1.13	NA

(continued)

(d) Below the P-6 (Intermediate Range Neutron Flux) interlocks.

(h) Above the P-8 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 6 of 8)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
18. Reactor Trip Breakers(RTBs)(i)	1,2	2 trains	L	SR 3.3.1.4	NA
	3(a), 4(a), 5(a)	2 trains	C	SR 3.3.1.4	NA
19. Reactor Trip Breaker Undervoltage and Shunt Trip Mechanisms	1,2	1 each per RTB	O	SR 3.3.1.4	NA
	3(a), 4(a), 5(a)	1 each per RTB	C	SR 3.3.1.4	NA
20. Automatic Trip Logic	1,2	2 trains	K	SR 3.3.1.5	NA
	3(a), 4(a), 5(a)	2 trains	C	SR 3.3.1.5	NA

(a) With Rod Control System capable of rod withdrawal or one or more rods not fully inserted.

(i) Including any reactor trip bypass breakers that are racked in and closed for bypassing an RTB.

Table 3.3.1-1 (page 7 of 8)
Reactor Protection System Instrumentation

Note 1: Overtemperature ΔT

The Overtemperature ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 2.8% of ΔT span:

$$\Delta T \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1+\tau_1 s)}{(1+\tau_2 s)}\left[T - T'\right] + K_3 (P - P') - f_1(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT, °F.
ΔT_0 is the indicated ΔT at RTP, °F.
s is the Laplace transform operator, sec^{-1}.
T is the measured RCS average temperature, °F.
T′ is the nominal T_{avg} at RTP, ≤ [*]°F.

P is the measured pressurizer pressure, psig
P′ is the nominal RCS operating pressure, ≥ [*] psig

$K_1 \leq$ [*] $K_2 \geq$ [*]/°F $K_3 \geq$ [*]/psig
$\tau_1 \geq$ [*] sec $\tau_2 \leq$ [*] sec

$f_1(\Delta I)$ = [*] {[*] - (q_t - q_b)} when $q_t - q_b \leq$ [*]% RTP
0% of RTP when [*]% RTP < $q_t - q_b \leq$ [*]% RTP
[*] {(q_t - q_b) - [*]} when $q_t - q_b >$ [*]% RTP

Where q_t and q_b are percent RTP in the upper and lower halves of the core, respectively, and $q_t + q_b$ is the total THERMAL POWER in percent RTP.

The values denoted with [*] are specified in the COLR.

Table 3.3.1-1 (page 8 of 8)
Reactor Protection System Instrumentation

Note 2: Overpower ΔT

The Overpower ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 1.8% of ΔT span:

$$\Delta T \leq \Delta T_0 \left\{ K_4 - K_5 \frac{\tau_3 s}{(1+\tau_3 s)} T - K_6 (T - T'') - f_2(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT, °F.
ΔT_0 is the indicated ΔT at RTP, °F.
s is the Laplace transform operator, sec^{-1}.
T is the measured RCS average temperature, °F.
T″ is the nominal T_{avg} at RTP, ≤ [*]°F.

$K_4 \leq$ [*] $K_5 \geq$ [*] /°F for increasing T_{avg}; [*] /°F for decreasing T_{avg} $K_6 \geq$ [*] /°F when T > T″; [*] /°F when T ≤ T″

$\tau_3 \geq$ [*] sec

$f_2(\Delta I)$ = [*]

*The values denoted with [*] are specified in the COLR.

3.3 INSTRUMENTATION

3.3.2 Engineered Safety Feature Actuation System (ESFAS) Instrumentation

LCO 3.3.2 The ESFAS instrumentation for each Function in Table 3.3.2-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.2-1.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one or more required channels or trains inoperable.	A.1 Enter the Condition referenced in Table 3.3.2-1 for the channel(s) or train(s).	Immediately
B. One channel or train inoperable.	B.1 Restore channel or train to OPERABLE status. OR B.2.1 Be in MODE 3. AND ----- NOTE -------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- B.2.2 Be in MODE 4.	48 hours 54 hours 60 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One train inoperable.	C.1 ------NOTE---------- One train may be bypassed for up to 8 hours for surveillance testing provided the other train is OPERABLE. ---------- Restore train to OPERABLE status.	6 hours
	OR	
	C.2.1 Be in MODE 3.	12 hours
	AND ----- NOTE -------- LCO 3.0.4.a is not applicable when entering MODE 4. ----------	
	C.2.2 Be in MODE 4.	18 hours
D. One channel inoperable.	D.1 ---------NOTE---------- The inoperable channel may be bypassed for up to 8 hours for surveillance testing of other channels. ---------- Place channel in trip.	6 hours
	OR	
	D.2.1 Be in MODE 3.	12 hours
	AND	
	D.2.2 Be in MODE 4.	18 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
E. One Containment Pressure channel inoperable in one or both sets of three.	E.1	---------NOTE--------- One additional channel may be bypassed for up to 8 hours for surveillance testing. ----------	
		Place channel in trip.	6 hours
	OR		
	E.2.1	Be in MODE 3.	12 hours
	AND		
	E.2.2	Be in MODE 4.	18 hours
F. One channel or train inoperable.	F.1	Restore channel or train to OPERABLE status.	48 hours
	OR		
	F.2.1	Be in MODE 3.	54 hours
	AND		
	F.2.2	Be in MODE 4.	60 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
G. One train inoperable.	G.1	.....NOTE..... One train may be bypassed for up to 8 hours for surveillance testing provided the other train is OPERABLE. ..... Restore train to OPERABLE status.	6 hours
	OR		
	G.2.1	Be in MODE 3.	12 hours
	AND		
	G.2.2	Be in MODE 4.	18 hours
H. One train inoperable.	H.1	.....NOTE..... One train may be bypassed for up to 8 hours for surveillance testing provided the other train is OPERABLE. ..... Restore train to OPERABLE status.	6 hours
	OR		
	H.2	Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
I. Main Feedwater Pump trip channel(s) inoperable.	I.1	Verify one channel associated with an operating MBFP is OPERABLE.	Immediately
	AND		
	I.2	Restore one channel associated with each operating MBFP to OPERABLE status.	48 hours
J. Required Action and associated Completion Time of Condition I not met.	J.1	Be in MODE 3.	6 hours
K. One or more channels inoperable.	K.1	Verify interlock is in required state for existing unit condition.	1 hour
	OR		
	K.2.1	Be in MODE 3.	7 hours
	AND		
	K.2.2	Be in MODE 4.	13 hours

SURVEILLANCE REQUIREMENTS

----------NOTE----------
Refer to Table 3.3.2-1 to determine which SRs apply for each ESFAS Function.

	SURVEILLANCE	FREQUENCY
SR 3.3.2.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.2.2	Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.2.3	Perform MASTER RELAY TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.2.4	Perform COT.	92 days
SR 3.3.2.5	Perform SLAVE RELAY TEST.	24 months
SR 3.3.2.6	----------NOTE---------- Verification of setpoint not required for manual initiation functions. --- Perform TADOT.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.2.7	----------NOTE---------- This Surveillance shall include verification that the time constants are adjusted to the prescribed values. ---------- Perform CHANNEL CALIBRATION.	 24 months

Table 3.3.2-1 (page 1 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Safety Injection					
a. Manual Initiation	1,2,3,4	2	B	SR 3.3.2.6	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA
c. Containment Pressure-Hi	1,2,3	3	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤4.80 psig
d. Pressurizer Pressure-Low	1,2,3[(b)]	3	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥1710 psig
e. High Differential Pressure Between Steam Lines	1,2,3	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	NA
f. High Steam Flow in Two Steam Lines	1,2[(d)],3[(d)]	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)
Coincident with T_{avg}- Low	1,2[(d)],3[(d)]	1 per loop	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥540.5°F

(continued)

(a) Not used

(b) Above the Pressurizer Pressure interlock.

(c) Less than or equal to turbine first stage pressure corresponding to 54% full steam flow below 20% load, and increasing linearly from 54% full steam flow at 20% load to 120% full steam flow at 100% load, and corresponding to 120% full steam flow above 100% load. Time delay for SI ≤6 seconds.

(d) Except when all MSIVs are closed.

Table 3.3.2-1 (page 2 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Safety Injection (continued)					
g. High Steam Flow in Two Steam Lines	1,2[(d)],3[(d)]	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)
Coincident with Steam Line Pressure-Low	1,2[(d)],3[(d)]	1 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥ 500 psig
2. Containment Spray					
a. Manual Initiation	1,2,3,4	2 per train, 2 trains	B	SR 3.3.2.6	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA
c. Containment Pressure (Hi-Hi)	1,2,3	2 sets of 3	E	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤ 24 psig

(continued)

(c) Less than or equal to turbine first stage pressure corresponding to 54% full steam flow below 20% load, and increasing linearly from 54% full steam flow at 20% load to 120% full steam flow at 100% load, and corresponding to 120% full steam flow above 100% load. Time delay for SI ≤ 6 seconds.

(d) Except when all MSIVs are closed.

Table 3.3.2-1 (page 3 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. Containment Isolation					
a. Phase A Isolation					
(1) Manual Initiation	1,2,3,4	2	B	SR 3.3.2.6	NA
(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA
(3) Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
b. Phase B Isolation					
(1) Manual Initiation	1,2,3,4	2	B	SR 3.3.2.6	NA
(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA
(3) Containment Pressure (Hi- Hi)	1,2,3	2 sets of three	E	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤ 24 psig

(continued)

Table 3.3.2-1 (page 4 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
4. Steam Line Isolation					
a. Manual Initiation	1,2[(d)],3[(d)]	2 per steam line	F	SR 3.3.2.6	NA
b. Automatic Actuation Logic and Actuation Relays	1,2[(d)],3[(d)]	2 trains	G	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA
c. Containment Pressure (Hi-Hi)	1,2[(d)], 3[(d)]	2 sets of 3	E	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤24 psig
d. High Steam Flow in Two Steam Lines	1,2[(d)], 3[(d)]	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)
Coincident with T_{avg}-Low	1,2[(d)], 3[(d)]	1 per loop	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥540.5°F
e. High Steam Flow in Two Steam Lines	1,2[(d)], 3[(d)]	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)
Coincident with Steam Line Pressure-Low	1,2[(d)], 3[(d)]	1 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥500 psig

(c) Less than or equal to turbine first stage pressure corresponding to 54% full steam flow below 20% load, and increasing linearly from 54% full steam flow at 20% load to 120% full steam flow at 100% load, and corresponding to 120% full steam flow above 100% load. Time delay for SI ≤6 seconds.

(d) Except when all MSIVs are closed.

Table 3.3.2-1 (page 5 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Feedwater Isolation					
a. Safety Injection	1,2[(e)]	2 trains	H	SR 3.3.2.2 SR 3.3.2.5	NA
b. SG Water Level-High High	1,2[(e)]	3 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤ 81% NR
6. Auxiliary Feedwater					
a. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	G	SR 3.3.2.2 SR 3.3.2.5	NA
b. SG Water Level-Low Low	1,2,3	3 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥ 4.0% NR
c. Safety Injection [(g)]	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
d. Loss of Offsite Power (Non SI Blackout Sequence Signal)	1,2,3	2	F	SR 3.3.2.6 SR 3.3.2.7	≥ 200 V
e. Trip of Main Boiler Feedwater Pumps	1[(f)], 2[(f)]	1 per MBFP	I	SR 3.3.2.6	NA

(continued)

(e) Except when all MBFPDVs, or MBFRVs and associated bypass valves are closed or isolated by a closed manual valve.

(f) Only required for MBFPs that are in operation.

(g) Not required if AFW pump not required to be OPERABLE.

Table 3.3.2-1 (page 6 of 6)
Engineered Safety Feature Actuation System Instrumentation

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7.	ESFAS Interlocks-Pressurizer Pressure	1,2,3	3	K	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	NA

3.3 INSTRUMENTATION

3.3.3 Post Accident Monitoring (PAM) Instrumentation

LCO 3.3.3 The PAM instrumentation for each Function in Table 3.3.3-1 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

---------- NOTE ----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one required channels inoperable.	A.1 Restore one channel to OPERABLE status.	30 days
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action in accordance with Specification 5.6.7	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with two required channels inoperable. OR One required T_{hot} channel and two required Core Exit Temperature channels inoperable. OR One required T_{cold} channel and two required SG Pressure channels inoperable. OR One required Main Steam Line Radiation channel and two required SG Water Level (Narrow Range) channels inoperable.	C.1 Restore one channel to OPERABLE status.	7 days
D. Required Action and associated Completion Time of Condition C not met.	D.1 Enter the Condition referenced in Table 3.3.3-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.3-1.	E.1 Be in MODE 3. AND E.2 Be in MODE 4.	6 hours 12 hours
F. As required by Required Action D.1 and referenced in Table 3.3.3-1.	F.1 Initiate action in accordance with Specification 5.6.7.	Immediately

SURVEILLANCE REQUIREMENTS

----------NOTE----------
SR 3.3.3.1 and SR 3.3.3.2 apply to each PAM instrumentation Function in Table 3.3.3-1.

	SURVEILLANCE	FREQUENCY
SR 3.3.3.1	Perform CHANNEL CHECK for each required instrumentation channel that is normally energized.	31 days
SR 3.3.3.2	----------NOTE---------- Neutron detectors are excluded from CHANNEL CALIBRATION. --- Perform CHANNEL CALIBRATION.	As specified in Table 3.3.3-1

Table 3.3.3-1 (page 1 of 2)
Post Accident Monitoring Instrumentation

	FUNCTION	REQUIRED CHANNELS	CONDITION REFERENCED FROM REQUIRED ACTION D.1	SR 3.3.3.2 FREQUENCY
1.	Neutron Flux	2	F	24 months
2.	RCS Hot Leg Temperature (Wide Range) (T_{hot})	1 per loop	E	24 months
3.	RCS Cold Leg Temperature (Wide Range) (T_{cold})	1 per loop	E	24 months
4.	RCS Pressure (Wide Range)	2	E	24 months
5.	Reactor Vessel Water Level	2	E	24 months
6.	Containment Water Level (Wide Range)	2	E	24 months
7.	Containment Water Level (Recirculation Sump)	2	E	24 months
8.	Containment Pressure	2	E	18 months
9.	Automatic Containment Isolation Valve Position	2 per penetration flow path[(a)(b)]	F	24 months
10.	Containment Area Radiation (High Range)	2	F	24 months
11.	NOT USED			
12.	Pressurizer Level	2	E	24 months
13.	SG Water Level (Narrow Range)	2 per SG	E	24 months
14.	SG Water Level (Wide Range) and Auxiliary Feedwater Flow	1 each per SG	E	24 months, SGL 18 months, AFF
15.	NOT USED			
16.	Steam Generator Pressure	2 per SG	E	24 months
17.	Condensate Storage Tank Level	2	F	24 months
18.	Core Exit Thermocouples-Quadrant 1	2 (c)	E	24 months
19.	Core Exit Thermocouples-Quadrant 2	2 (c)	E	24 months
20.	Core Exit Thermocouples-Quadrant 3	2 (c)	E	24 months
21.	Core Exit Thermocouples-Quadrant 4	2 (c)	E	24 months
22.	Main Steam Line Radiation	1 per steam line	F	24 months
23.	Gross Failed Fuel Detector	2	F	24 months
24.	RCS Subcooling Margin	2	E	24 months

See NOTES, next page.

TABLE 3.3.3-1 (page 2 of 2)
Post Accident Monitoring Instrumentation

NOTES:

(a) Not required for isolation valves whose associated penetration is isolated by at least one closed and deactivated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.

(b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.

(c) A channel consists of two core exit thermocouples (CETs).

3.3 INSTRUMENTATION

3.3.4 Remote Shutdown

LCO 3.3.4 The Remote Shutdown Functions shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

---------- NOTE ----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required Functions inoperable.	A.1 Restore required Function to OPERABLE status.	30 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.3.4.1	Perform CHANNEL CHECK for each required instrumentation channel that is normally energized.	31 days
SR 3.3.4.2	Verify each required control circuit and transfer switch is capable of performing the intended function.	24 months
SR 3.3.4.3	----------NOTE---------- Neutron detectors are excluded from CHANNEL CALIBRATION. ---------- Perform CHANNEL CALIBRATION for each required instrumentation channel.	24 months

3.3 INSTRUMENTATION

3.3.5 Loss of Power (LOP) Diesel Generator (DG) Start Instrumentation

LCO 3.3.5 One channel per bus of the Undervoltage (480 V bus) Function and two channels per bus of the Degraded Voltage (480 V bus) Function shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4,
When associated DG is required to be OPERABLE by LCO 3.8.2, "AC Sources – Shutdown."

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required channel of Undervoltage Function inoperable in one or more buses.	A.1 Restore channel to OPERABLE status.	1 hour
B. One channel of Degraded Voltage Function inoperable in one or more buses.	B.1 Place channel in trip.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time not met. OR Two channels of Degraded Voltage Function inoperable in one or more buses.	C.1 Enter applicable Condition(s) and Required Action(s) for the associated DG made inoperable by LOP DG start instrumentation.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
	----------NOTE---------- Verification of setpoint not required	31 days
SR 3.3.5.1	Perform TADOT.	
SR 3.3.5.2	Perform CHANNEL CALIBRATION with Allowable Value as follows:	
	a. Undervoltage (480 V bus) Relay Allowable Value ≥ 200 V.	24 months
	b. Degraded Voltage (480 V bus) Relay (Non-SI) Allowable Value ≥ 414 V with a time delay ≤ 45 seconds.	18 months
	c. Degraded Voltage (480 V bus) Relay (Coincident SI) Allowable Value ≥ 414 V with a time delay ≤ 10 seconds.	18 months

3.3 INSTRUMENTATION

3.3.6 Containment Purge System and Pressure Relief Line Isolation Instrumentation

LCO 3.3.6 The Containment Purge System and Pressure Relief Line Isolation instrumentation for each Function in Table 3.3.6-1 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4,
During CORE ALTERATIONS,
During movement of irradiated fuel assemblies within containment.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One radiation monitoring channel inoperable.	A.1 Restore the affected channel to OPERABLE status.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. ---------NOTE--------- Only applicable in MODE 1, 2, 3, or 4. ---------- One or more pressure relief line isolation Functions with one or more automatic actuation trains inoperable. OR Two radiation monitoring channels inoperable. OR Required Action and associated Completion Time of Condition A not met.	B.1 Enter applicable Conditions and Required Actions of LCO 3.6.3, "Containment Isolation Valves," for containment pressure relief line isolation valves made inoperable by isolation instrumentation.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. .....NOTE..... Only applicable during CORE ALTERATIONS or movement of irradiated fuel assemblies within containment. ..... One or more containment purge system isolation Functions with one or more automatic actuation trains inoperable. OR Two radiation monitoring channels inoperable. OR Required Action and associated Completion Time for Condition A not met.	C.1 Place and maintain containment purge system supply and exhaust valves in closed position. OR C.2 Enter applicable Conditions and Required Actions of LCO 3.9.3, "Containment Penetrations," for containment purge system supply and exhaust isolation valves made inoperable by isolation instrumentation.	Immediately Immediately

SURVEILLANCE REQUIREMENTS

----------NOTE----------

Refer to Table 3.3.6-1 to determine which SRs apply for each Containment Purge System and Pressure Relief Line Isolation Function.

	SURVEILLANCE	FREQUENCY
SR 3.3.6.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.6.2	Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.6.3	Perform COT.	92 days
SR 3.3.6.4	----------NOTE---------- Verification of setpoint is not required. ---------- Perform TADOT.	24 months
SR 3.3.6.5	Perform CHANNEL CALIBRATION.	24 months

Table 3.3.6-1 (page 1 of 1)
Containment Purge System and Pressure Relief Line Isolation Instrumentation

	FUNCTION	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	TRIP SETPOINT
1.	Automatic Actuation Logic and Actuation Relays	2 trains	SR 3.3.6.2 SR 3.3.6.4	NA
2.	Gaseous Radiation Monitor (R-12)	1	SR 3.3.6.1 SR 3.3.6.3 SR 3.3.6.5	(b)
3.	Particulate Radiation Monitor (R-11)	1	SR 3.3.6.1 SR 3.3.6.3 SR 3.3.6.5	(b)
4.	ESFAS Function 1, Safety Injection, and ESFAS Function 2, Containment Spray (a)	Refer to LCO 3.3.2, ESFAS Instrumentation, Functions 1 and 2, for all initiation functions and requirements.		

(a) Only required in MODES 1, 2, 3 and 4 as specified in LCO 3.3.2.

(b) As specified in the IP3 Offsite Dose Calculation Manual.

3.3 INSTRUMENTATION

3.3.7 Control Room Ventilation System (CRVS) Actuation Instrumentation

LCO 3.3.7 The CRVS actuation instrumentation for each Function in Table 3.3.7-1 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, 4

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one channel or train inoperable.	A.1 Place CRVS in CRVS Mode 3.	7 days
B. One or more Functions with two channels or two trains inoperable.	B.1.1 Place CRVS in CRVS Mode 3.	72 hours
C. Required Action and associated Completion Time for Condition A or B not met.	C.1 Be in MODE 3. AND ----- NOTE -------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- C.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

----------NOTE----------
Refer to Table 3.3.7-1 to determine which SRs apply for each CRVS Actuation Function.

	SURVEILLANCE	FREQUENCY
SR 3.3.7.1	Perform actuation logic test	31 days staggered test basis
SR 3.3.7.2	----------NOTE---------- Verification of setpoint is not required. --- Perform TADOT.	24 months

Table 3.3.7-1 (page 1 of 1)
CRVS Actuation Instrumentation

	FUNCTION	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	TRIP SETPOINT
1.	Manual Initiation	2	SR 3.3.7.2	NA
2.	Automatic Actuation Logic and Actuation Relays	2 trains	SR 3.3.7.1	NA
3.	Safety Injection	Refer to LCO 3.3.2, "ESFAS Instrumentation," Function 1, for all initiation functions and requirements.		

3.3 INSTRUMENTATION

3.3.8 Fuel Storage Building Emergency Ventilation System (FSBEVS) Actuation Instrumentation

LCO 3.3.8 FSBEVS manual and automatic actuation instrumentation shall be OPERABLE.

APPLICABILITY: During movement of recently irradiated fuel in the fuel storage building.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Manual or automatic FSBEVS actuation instrumentation inoperable.	A.1	Place FSBEVS in operation.	Immediately
	OR		
	A.2	Suspend movement of recently irradiated fuel in the fuel storage building.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.3.8.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.8.2	Perform COT.	92 days
SR 3.3.8.3	Perform CHANNEL CALIBRATION.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits

LCO 3.4.1 RCS DNB parameters for pressurizer pressure, RCS average temperature, and RCS total flow rate shall be within the limits specified below:

a. Pressurizer pressure is greater than or equal to the limit specified in the COLR;

b. RCS average loop temperature is less than or equal to the limit specified in the COLR; and

c. RCS total flow rate ≥ 354,400 gpm and greater than or equal to the limit specified in the COLR.

APPLICABILITY: MODE 1.

----------NOTE----------
Pressurizer pressure limit does not apply during:

a. THERMAL POWER ramp > 5% RTP per minute; or

b. THERMAL POWER step > 10% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more RCS DNB parameters not within limits.	A.1 Restore RCS DNB parameter(s) to within limits.	2 hours
B. Required action and associated Completion Time not met.	B.1 Be in MODE 2.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.1.1	Verify pressurizer pressure is greater than or equal to the limit specified in the COLR.	12 hours
SR 3.4.1.2	Verify RCS average loop temperature is less than or equal to the limit specified in the COLR.	12 hours
SR 3.4.1.3	Verify RCS total flow rate is ≥ 354,400 gpm and greater than or equal to the limit specified in the COLR.	12 hours
SR 3.4.1.4	----------NOTE---------- Not required to be performed until 24 hours after ≥ 90% RTP. ---------- Verify by precision heat balance that RCS total flow rate is ≥ 354,400 gpm and greater than or equal to the limit specified in the COLR.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.2 RCS Minimum Temperature for Criticality

LCO 3.4.2 Each RCS loop average temperature (T_{avg}) shall be ≥ 540°F.

APPLICABILITY: MODE 1,
MODE 2 with k_{eff} ≥ 1.0.

ACTIONS

CONDITION		REQUIRED ACTION		COMPLETION TIME
A.	T_{avg} in one or more RCS loops not within limit.	A.1	Be in MODE 2 with k_{eff} < 1.0.	30 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.2.1	Verify RCS T_{avg} in each loop ≥ 540°F.	-----NOTE------ Only required if T_{avg} - T_{ref} deviation, and low T_{avg} alarm not reset and any RCS loop T_{avg} < 547°F ---------- 30 minutes thereafter

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.3 RCS Pressure and Temperature (P/T) Limits

LCO 3.4.3 RCS pressure, RCS temperature, and RCS heatup and cooldown rates shall be maintained within the limits specified in Figure 3.4.3-1 and Figure 3.4.3-2.

APPLICABILITY: At all times.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. ---------NOTE--------- Required Action A.2 shall be completed whenever this Condition is entered. ---------- Requirements of LCO not met in MODE 1, 2, 3, or 4.	A.1	Restore parameter(s) to within limits.	30 minutes
	AND		
	A.2	Determine RCS is acceptable for continued operation.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1	Be in MODE 3.	6 hours
	AND		
	B.2	Be in MODE 5 with RCS pressure < 500 psig.	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. ---------NOTE---------- Required Action C.2 shall be completed whenever this Condition is entered. ---------- Requirements of LCO not met any time in other than MODE 1, 2, 3, or 4.	C.1 Initiate action to restore parameter(s) to within limits. AND C.2 Determine RCS is acceptable for continued operation.	Immediately Prior to entering MODE 4

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.3.1 ----------NOTE---------- Only required to be performed during RCS heatup, inservice leak testing, and cooldown operations. ---------- Verify RCS pressure, RCS temperature, and RCS heatup and cooldown rates are within the limits specified in the following: a. Figure 3.4.3-1 during RCS heatup and during RCS inservice leak testing; and b. Figure 3.4.3-2 during RCS cooldown.	30 minutes

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: Lower Shell Plate B-2803-3 using credible surveillance data, Position 2.1

LIMITING ART VALUES AT 37 EFPY: 1/4T, 245.0°F (Axial Flaw)
3/4T, 198.2°F (Axial Flaw)



Figure 3.4.3-1:
Heatup and Inservice Leak Test Limitations for Reactor Coolant System
(Without instrument uncertainties)

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: Lower Shell Plate B-2803-3 using credible surveillance data, Position 2.1

LIMITING ART VALUES AT 37 EFPY: 1/4T, 245.0°F (Axial Flaw)
3/4T, 198.2°F (Axial Flaw)



Figure 3.4.3-2:
Cooldown Limitations for Reactor Coolant System
(Without instrument uncertainties)

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.4 RCS Loops – MODES 1 and 2

LCO 3.4.4 Four RCS loops shall be OPERABLE and in operation.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of LCO not met.	A.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.4.1 Verify each RCS loop is in operation.	12 hours

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.5 RCS Loops – MODE 3

LCO 3.4.5 Two RCS loops shall be OPERABLE, and either:

a. Two RCS loops shall be in operation when the Rod Control System is capable of rod withdrawal; or

b. One RCS loop shall be in operation when the Rod Control System is not capable of rod withdrawal.

----------NOTE----------
All reactor coolant pumps may not be in operation for ≤ 1 hour per 8 hour period provided:

a. No operations are permitted that would cause reduction of the RCS boron concentration; and

b. Core outlet temperature is maintained at least 10°F below saturation temperature.

APPLICABILITY: MODE 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RCS loop inoperable.	A.1 Restore required RCS loop to OPERABLE status.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 4.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
C. One required RCS loop not in operation, and reactor trip breakers closed and Rod Control System capable of rod withdrawal.	C.1	Restore required RCS loop to operation.	1 hour
	OR		
	C.2	De-energize all control rod drive mechanisms (CRDMs).	1 hour
D. Two required RCS loops inoperable.	D.1	De-energize all CRDMs.	Immediately
	AND		
OR	D.2	Suspend all operations involving a reduction of RCS boron concentration.	Immediately
No RCS loop in operation.	AND		
	D.3	Initiate action to restore one RCS loop to OPERABLE status and in operation.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.5.1	Verify required RCS loops are in operation.	12 hours
SR 3.4.5.2	Verify steam generator secondary side actual water levels are ≥ 71% wide range for required RCS loops.	12 hours
SR 3.4.5.3	Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.6 RCS Loops – MODE 4

LCO 3.4.6 Two loops consisting of any combination of RCS loops and residual heat removal (RHR) loops shall be OPERABLE, and one loop shall be in operation.

---------- NOTES----------

1. All reactor coolant pumps (RCPs) and RHR pumps may not be in operation for ≤ 1 hour per 8 hour period provided:

   a. No operations are permitted that would cause reduction of the RCS boron concentration; and

   b. Core outlet temperature is maintained at least 10°F below saturation temperature.

2. No RCP shall be started with any RCS cold leg temperature less than the LTOP arming temperature unless the requirements of LCO 3.4.12, "Low Temperature Overpressure Protection (LTOP)," are met.

APPLICABILITY: MODE 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RCS loop inoperable. AND Two RHR loops inoperable.	A.1 Initiate action to restore a second loop to OPERABLE status.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One required RHR loop inoperable. AND Two required RCS loops inoperable.	B.1 Be in MODE 5.	24 hours
C. Required RCS or RHR loops inoperable. OR No RCS or RHR loop in operation.	C.1 Suspend all operations involving a reduction of RCS boron concentration. AND C.2 Initiate action to restore one loop to OPERABLE status and in operation.	Immediately Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.6.1	Verify one RHR or RCS loop is in operation.	12 hours
SR 3.4.6.2	Verify SG secondary side water actual level is ≥ 71% wide range for each required RCS loop.	12 hours
SR 3.4.6.3	Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 RCS Loops-MODE 5, Loops Filled

LCO 3.4.7 One residual heat removal (RHR) loop shall be OPERABLE and in operation, and either:

a. One additional RHR loop shall be OPERABLE; or

b. The secondary side water level of at least two steam generators (SGs) shall be ≥ 71% wide range.

---------- NOTES----------

1. The RHR pump of the loop in operation may not be in operation for ≤ 1 hour per 8 hour period provided:

   a. No operations are permitted that would cause reduction of the RCS boron concentration; and

   b. Core outlet temperature is maintained at least 10°F below saturation temperature.

2. One required RHR loop may be inoperable for up to 2 hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.

3. No reactor coolant pump shall be started with the average of the RCS cold leg temperatures ≤ 330°F unless the requirements of LCO 3.4.12, "Low Temperature Overpressure Protection (LTOP)," are met.

4. All RHR loops may be removed from operation during planned heatup to MODE 4 when at least one RCS loop is in operation.

APPLICABILITY: MODE 5 with RCS loops filled.

ACTIONS

CONDITION		REQUIRED ACTION	COMPLETION TIME
A. One RHR loop inoperable. AND Required SGs secondary side water level not within the limit.	A.1 OR A.2	Initiate action to restore a second RHR loop to OPERABLE status. Initiate action to restore required SG secondary side water level to within the limit.	Immediately Immediately
B. Required RHR loops inoperable. OR No RHR loop in operation.	B.1 AND B.2	Suspend all operations involving a reduction of RCS boron concentration. Initiate action to restore one RHR loop to OPERABLE status and in operation.	Immediately Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.7.1	Verify one RHR loop is in operation.	12 hours
SR 3.4.7.2	Verify SG secondary side water level is ≥ 71% wide range in required SGs.	12 hours
SR 3.4.7.3	Verify correct breaker alignment and indicated power are available to the required RHR pump that is not in operation.	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.8 RCS Loops – MODE 5, Loops Not Filled

LCO 3.4.8 Two residual heat removal (RHR) loops shall be OPERABLE and one RHR loop shall be in operation.

----------NOTES----------

1. All RHR pumps may not be in operation for ≤ 15 minutes provided:

   a. The core outlet temperature is maintained at least 10°F below saturation temperature.

   b. No operations are permitted that would cause a reduction of the RCS boron concentration; and

   c. No draining operations to further reduce the RCS water volume are permitted.

2. One RHR loop may be inoperable for up to 2 hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.

APPLICABILITY: MODE 5 with RCS loops not filled.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR loop inoperable.	A.1 Initiate action to restore RHR loop to OPERABLE status.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required RHR loops inoperable. OR No RHR loop in operation.	B.1 Suspend all operations involving reduction in RCS boron concentration. AND B.2 Initiate action to restore one RHR loop to OPERABLE status and in operation.	Immediately Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.8.1	Verify one RHR loop is in operation.	12 hours
SR 3.4.8.2	Verify correct breaker alignment and indicated power are available to the required RHR pump that is not in operation.	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.9 Pressurizer

LCO 3.4.9 The pressurizer shall be OPERABLE with:

a. Pressurizer water level ≤ 54.3% in MODES 1 and 2 or ≤ 90% in MODE 3; and

b. Two groups of pressurizer heaters OPERABLE with the capacity of each group ≥ 150 kW and capable of being powered from an emergency power supply.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Pressurizer water level not within limit.	A.1	Be in MODE 3 with reactor trip breakers open.	6 hours
	AND		
	A.2	Be in MODE 4.	12 hours
B. One required group of pressurizer heaters inoperable.	B.1	Restore required group of pressurizer heaters to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition B not met.	C.1	Be in MODE 3.	6 hours
	AND		
	C.2	Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.9.1	Verify pressurizer water level is ≤ 54.3% in MODES 1 and 2 OR ≤ 90% in MODE 3.	12 hours
SR 3.4.9.2	Verify capacity of each required group of pressurizer heaters is ≥ 150 kW.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Pressurizer Safety Valves

LCO 3.4.10 Three pressurizer safety valves shall be OPERABLE with lift settings set ≥ 2460 psig and ≤ 2510 psig.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 with all RCS cold leg temperatures > 330°F.

----------NOTE----------
The lift settings are not required to be within the LCO limits during MODES 3 and 4 for the purpose of setting the pressurizer safety valves under ambient (hot) conditions. This exception is allowed for 54 hours following entry into MODE 3 provided a preliminary cold setting was made prior to heatup.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One pressurizer safety valve inoperable.	A.1 Restore valve to OPERABLE status.	15 minutes
B. Required Action and associated Completion Time not met. OR Two or more pressurizer safety valves inoperable.	B.1 Be in MODE 3. AND B.2 Be in MODE 4 with any RCS cold leg temperature ≤ 330°F.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.10.1	Verify each pressurizer safety valve is OPERABLE in accordance with the Inservice Testing Program. Following testing, lift settings shall be ≥ 2460 psig and ≤ 2510 psig.	In accordance with the Inservice Testing Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.11 Pressurizer Power Operated Relief Valves (PORVs)

LCO 3.4.11 Each PORV and associated block valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

---------- NOTE ----------
Separate Condition entry is allowed for each PORV.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more PORVs inoperable and capable of being manually cycled.	A.1 Close and maintain power to associated block valve.	1 hour
B. One PORV inoperable and not capable of being manually cycled.	B.1 Close associated block valve. AND	1 hour
	B.2 Remove power from associated block valve. AND	1 hour
	B.3 Restore PORV to OPERABLE status.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
C. One block valve inoperable.	C.1	Place associated PORV in manual control.	1 hour
	AND		
	C.2	Restore block valve to OPERABLE status.	7 days
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1	Be in MODE 3.	6 hours
	AND		
	D.2	Be in MODE 4.	12 hours
E. Two PORVs inoperable and not capable of being manually cycled.	E.1	Close associated block valves.	1 hour
	AND		
	E.2	Remove power from associated block valves.	1 hour
	AND		
	E.3	Be in MODE 3.	6 hours
	AND		
	E.4	Be in MODE 4.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
F. More than one block valve inoperable.	F.1 Place associated PORVs in manual control. AND F.2 Restore one block valve to OPERABLE status.	1 hour 2 hours
G. Required Action and associated Completion Time of Condition F not met.	G.1 Be in MODE 3. AND G.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.11.1	----------NOTE---------- Not required to be met with block valve closed in accordance with the Required Action of Condition B or E. ---------- Perform a complete cycle of each block valve.	 92 days
SR 3.4.11.2	Perform a complete cycle of each PORV.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.12 Low Temperature Overpressure Protection (LTOP)

LCO 3.4.12 LTOP shall be OPERABLE with no high head safety injection (HHSI) pumps capable of injecting into the RCS and the accumulator discharge isolation valves closed and de-energized, and either of the following:

----------Note----------
LCO 3.4.12.a and LCO 3.4.12.b are not Applicable when all RCS cold leg temperatures are > 330°F.
---

a. The Overpressure Protection System (OPS) OPERABLE with two power operated relief valves (PORVs) with lift settings within the limit specified in Figure 3.4.12-1;

OR

b. The RCS depressurized with an RCS vent of ≥ 2.00 square inches, or one blocked open PORV with its block valve disabled in the open position.

----------NOTES----------
1. Accumulator isolation is only required when accumulator pressure is greater than or equal to the maximum RCS pressure for the coldest existing RCS cold leg temperature allowed by the P/T limit curve in Figure 3.4.12-1.

2. One HHSI pump may be made capable of injecting into the RCS as needed to support emergency boration or to respond to a loss of RHR cooling.

3. One HHSI pump may be made capable of injecting into the RCS for pump testing for a period not to exceed 8 hours.

APPLICABILITY: Whenever the RHR System is not isolated from the RCS,
MODE 4 when any RCS cold leg temperature is ≤ 330°F,
MODE 5,
MODE 6 when the reactor vessel head is on.

ACTIONS

---------- NOTE ----------
LCO 3.0.4.b is not applicable when entering MODE 4.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more HHSI pump(s) capable of injecting into the RCS.	A.1 Initiate action to verify no HHSI pumps are capable of injecting into the RCS. OR	Immediately
	A.2.1 Verify RCS is vented with opening greater than or equal to one pressurizer code safety valve flange. AND	Immediately
	A.2.2 Verify no more than two HHSI pumps are capable of injecting into the RCS	Immediately AND Once per 12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. An accumulator discharge isolation valve not closed and de-energized when the accumulator pressure is greater than or equal to the maximum RCS pressure for the coldest existing cold leg temperature specified in Figure 3.4.12-1.	B.1 Close and de-energize isolation valve for affected accumulator.	1 hour
C. Required Action and associated Completion Time of Condition B not met.	C.1.1 Increase all RCS cold leg temperatures to > 330°F. AND C.1.2 Isolate the RHR System from the RCS. OR C.2 Depressurize affected accumulator to less than the maximum RCS pressure for coldest existing cold leg temperature specified in Figure 3.4.12-1.	12 hours 12 hours 12 hours
D. One required PORV inoperable.	D.1 Restore required PORV to OPERABLE status.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Two required PORVs inoperable. OR Required Action and associated Completion Time of Condition C or D not met.	E.1 Depressurize RCS and establish RCS vent of ≥ 2.00 square inches, or one blocked open PORV with its block valve disabled in the open position. OR	8 hours
	E.2.1 Increase all RCS cold leg temperatures to > 330°F. AND	8 hours
	E.2.2 Isolate the RHR System from the RCS. OR	8 hours
	E.3 Verify pressurizer level, RCS pressure, and RCS injection capability are within limits specified in Figure 3.4.12-2 and Figure 3.4.12-3 for OPS not OPERABLE.	8 hours AND Once per 12 hours thereafter
F. LTOP inoperable for any reason other than Condition A, B, C, D, or E.	F.1 Depressurize RCS and establish RCS vent of ≥ 2.00 square inches, or one blocked open PORV with its block valve disabled in the open position.	8 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.12.1	Verify no HHSI pumps are capable of injecting into the RCS.	12 hours
SR 3.4.12.2	Verify each accumulator discharge isolation valve is closed and de-energized; OR Verify each accumulator pressure is less than the maximum RCS pressure for the coldest existing RCS cold leg temperature allowed by the P/T limit curve in Figure 3.4.12-1.	12 hours 12 hours
SR 3.4.12.3	----------NOTE---------- Only required to be met when complying with LCO 3.4.12.b. ---------- Verify RCS vent ≥ 2.00 square inches, or one blocked open PORV with its block valve disabled in the open position established.	 12 hours for unlocked open vent valve(s) AND 31 days for locked open vent valve(s)

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.4.12.4	----------NOTE---------- Only required to be met when complying with LCO 3.4.12.a. ---------- Perform CHANNEL CHECK of Overpressure Protection (OPS) instrument channels.	24 hours
SR 3.4.12.5	Verify PORV block valve is open for each required PORV.	72 hours
SR 3.4.12.6	----------NOTE---------- Not required to be performed until 12 hours after decreasing any RCS cold leg temperature to $\leq$ 330°F. ---------- Perform a COT on each required PORV, excluding actuation.	24 months
SR 3.4.12.7	Perform CHANNEL CALIBRATION for each required OPS channel as follows: a. OPS actuation channels; and b. RCS pressure and temperature instruments.	 18 months 24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.12.8	----------NOTES---------- 1. Not required to be met when all RCS cold leg temperatures are > 330°F. 2. Not required to be met if SR 3.4.12.9 is met. ---------- Verify each of the following conditions are satisfied prior to starting any RCP: a. Secondary side water temperature of the hottest steam generator (SG) is less than or equal to the coldest RCS cold leg temperature; and b. RCS makeup is less than or equal to RCS losses; and c. Steam generator pressure is not decreasing; and d.1 Overpressure Protection System (OPS) is OPERABLE; OR d.2.1 RCS pressure less than nominal OPS setpoint specified in Figure 3.4.12-1; and d.2.2 Pressurizer level, RCS pressure, and RCS injection capability are within limits specified in Figure 3.4.12-2 and Figure 3.4.12-3 for OPS not OPERABLE.	Within 15 minutes prior to starting any RCP

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.12.9	----------NOTES---------- 1. Not required to be met when all RCS cold leg temperatures are > 330°F. 2. Not required to be met if SR 3.4.12.8 is met. ---------- Verify each of the following conditions are satisfied prior to starting any RCP: a. Secondary side water temperature of the hottest steam generator is ≤ 50°F above the coldest RCS cold leg temperature; and b. RCS makeup is less than or equal to RCS losses; and c. Overpressure Protection System (OPS) is OPERABLE; and d. Pressurizer level is ≤ 73%.	Within 15 minutes prior to starting any RCP



Figure 3.4.12-1: Maximum Allowable PORV Setpoint for LTOP (OPS), 37 EFPY



Figure 3.4.12-2: Maximum Allowable Pressurizer Level for LTOPS Inoperable with 1 Charging Pump Capable of Injecting, 37 EFPY



Figure 3.4.12-3: Maximum Allowable Pressurizer Level for LTOPS Inoperable with 3 Charging Pumps Capable of Injecting, 37 EFPY

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.13 RCS Operational LEAKAGE

LCO 3.4.13 RCS operational LEAKAGE shall be limited to:

a. No pressure boundary LEAKAGE;

b. 1 gpm unidentified LEAKAGE;

c. 10 gpm identified LEAKAGE; and

d. 150 gallons per day primary to secondary LEAKAGE through any one steam generator (SG).

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCS operational LEAKAGE not within limits for reasons other than pressure boundary LEAKAGE or primary to secondary LEAKAGE.	A.1 Reduce LEAKAGE to within limits.	4 hours
B. Required Action and associated Completion Time of Condition A not met. OR Pressure boundary LEAKAGE exists. OR Primary to secondary LEAKAGE not within limit.	B.1 Be in MODE 3. AND ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- B.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.13.1	----------NOTES---------- 1. Not required to be performed in MODE 3 or 4 until 12 hours of steady state operation. 2. Not applicable to primary to secondary LEAKAGE. ----------	-----NOTE---- Only required to be performed during steady state operation ----------
	Verify RCS Operational LEAKAGE is within limits by performance of RCS water inventory balance.	72 hours
SR 3.4.13.2	----------NOTE---------- Not required to be performed until 12 hours after establishment of steady state operation. ----------	
	Verify primary to secondary LEAKAGE is $\leq$ 150 gallons per day through any one SG.	72 hours

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.14 RCS Pressure Isolation Valve (PIV) Leakage

LCO 3.4.14 Leakage from each RCS PIV shall be within limit;

AND

The RHR System autoclosure interlocks (ACI) and open permissive interlocks (OPI) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4, except for leakage limits for valves in the residual heat removal (RHR) flow path when in, or during the transition to or from, the RHR mode of operation.

ACTIONS

---------- NOTES----------

1. Separate Condition entry is allowed for each flow path.

2. Separate Condition entry is allowed for each ACI and OPI.

3. Enter applicable Conditions and Required Actions for systems made inoperable by an inoperable PIV.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more flow paths with leakage from one or more RCS PIVs not within limit.	----------NOTE---------- Each valve used to satisfy Required Action A.1 and Required Action A.2 must have been verified to meet SR 3.4.14.1 and be in the reactor coolant pressure boundary or the high pressure portion of the system. ----------	(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.1 Isolate the high pressure portion of the affected system from the low pressure portion by use of one closed manual, deactivated automatic, or check valve. AND	4 hours
	A.2.1 Isolate the high pressure portion of the affected system from the low-pressure portion by use of a second closed manual, deactivated automatic, or check valve. OR	72 hours
	A.2.2 Restore RCS PIV to within limits.	72 hours
B. Required Action and associated Completion Time for Condition A not met.	B.1 Be in MODE 3. AND	6 hours
	----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ----------	
	B.2 Be in MODE 4.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more RHR System autoclosure interlocks or open permissive interlocks inoperable.	----------NOTE---------- RHR System suction isolation valves with inoperable ACIs or OPIs may be opened for 7 days following entry into MODE 4 from MODE 3. ---------- C.1 Close and de-activate the affected RHR isolation valve. AND C.2 Verify the affected RHR isolation valves are closed and de-activated.	7 days Once per 31 days thereafter

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.14.1	----------NOTES---------- 1. Not required to be performed in MODES 3 and 4. 2. Not required to be performed on the RCS PIVs located in the RHR flow path when in the shutdown cooling mode of operation. 3. RCS PIVs actuated during the performance of this Surveillance are not required to be tested more than once if a repetitive testing loop cannot be avoided. ----------	
	Verify leakage from each RCS PIV is equivalent to ≤ 0.5 gpm per nominal inch of valve size up to a maximum of 5 gpm at an RCS pressure ≥ 2215 psig and ≤ 2255 psig.	24 months AND Prior to entering MODE 2 whenever the unit has been in MODE 5 for 7 days or more, if leakage testing has not been performed in the previous 12 months AND Within 24 hours following valve actuation due to automatic or manual action or flow through the valve

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.4.14.2	Verify RHR System open permissive interlock prevents the valves from being opened with a simulated or actual RCS pressure signal ≥ 450 psig.	24 months
SR 3.4.14.3	Verify RHR System autoclosure interlock causes the valves to close automatically with a simulated or actual RCS pressure signal ≥ 550 psig.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.15 RCS Leakage Detection Instrumentation

LCO 3.4.15 The following RCS leakage detection instrumentation shall be OPERABLE:

a. One containment sump discharge flow monitor;

b. One containment atmosphere radioactivity monitor (gaseous or particulate); and

c. One containment fan cooler unit condensate measuring system.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required containment sump flow monitor inoperable.	A.1 Perform SR 3.4.13.1.	Once per 24 hours
	AND	
	A.2 Restore required containment sump monitor to OPERABLE status.	30 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
B. Required containment atmosphere radioactivity monitor inoperable.	B.1.1	Analyze grab samples of the containment atmosphere.	Once per 24 hours
	OR		
	B.1.2	Perform SR 3.4.13.1.	Once per 24 hours
	AND		
	B.2.1	Restore required containment atmosphere radioactivity monitor to OPERABLE status.	30 days
	OR		
	B.2.2	Verify containment fan cooler unit condensate measuring system is OPERABLE.	30 days
C. Required containment fan cooler unit condensate measuring system inoperable.	C.1	Perform SR 3.4.15.1.	Once per 8 hours
	OR		
	C.2	Perform SR 3.4.13.1.	Once per 24 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required containment atmosphere radioactivity monitor inoperable. AND Required containment fan cooler unit condensate measuring system inoperable.	D.1 Restore required containment atmosphere radioactivity monitor to OPERABLE status. OR D.2 Restore required containment fan cooler unit condensate measuring system to OPERABLE status.	30 days 30 days
E. Required Action and associated Completion Time not met.	E.1 Be in MODE 3. AND ----- NOTE ----- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- E.2 Be in MODE 4.	6 hours 12 hours
F. All required monitors inoperable.	F.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.15.1	Perform CHANNEL CHECK of the required containment atmosphere radioactivity monitor.	12 hours
SR 3.4.15.2	Perform COT of the required containment atmosphere radioactivity monitor.	92 days
SR 3.4.15.3	Perform CHANNEL CALIBRATION of the required containment sump flow monitor.	24 months
SR 3.4.15.4	Perform CHANNEL CALIBRATION of the required containment atmosphere radioactivity monitor.	24 months
SR 3.4.15.5	Perform CHANNEL CALIBRATION of the required containment fan cooler unit condensate measuring system.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.16 RCS Specific Activity

LCO 3.4.16 RCS DOSE EQUIVALENT I-131 and DOSE EQUIVALENT XE-133 specific activity shall be within limits.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. DOSE EQUIVALENT I-131 not within limit.	---------- NOTE -------- LCO 3.0.4.c is applicable ---------- A.1 Verify DOSE EQUIVALENT I-131 $\leq$ 60.0 µCi/gm. AND A.2 Restore DOSE EQUIVALENT I-131 to within limit.	Once per 4 hours 48 hours
B. DOSE EQUIVALENT XE-133 not within limit.	---------- NOTE -------- LCO 3.0.4.c is applicable ---------- B.1 Restore DOSE EQUIVALENT XE-133 within limit.	48 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition A or B not met. OR DOSE EQUIVALENT I-131 > 60.0 µCi/gm.	C.1 Be in MODE 3 with T_{avg} < 500°F. AND C.2 Be in MODE 5	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.16.1 ----------NOTE---------- Only required to be performed in MODE 1. ---------- Verify reactor coolant DOSE EQUIVALENT XE-133 specific activity ≤ 652 µCi/gm.	7 days
SR 3.4.16.2 ----------NOTE---------- Only required to be performed in MODE 1. ---------- Verify reactor coolant DOSE EQUIVALENT I-131 specific activity ≤ 1.0 µCi/gm.	14 days AND Between 2 and 6 hours after a THERMAL POWER change of ≥ 15% RTP within a 1 hour period

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.17 Steam Generator (SG) Tube Integrity

LCO 3.4.17 SG tube integrity shall be maintained.

AND

All SG tubes satisfying the tube plugging criteria shall be plugged in accordance with the Steam Generator Program.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each SG tube.

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more SG tubes satisfying the tube plugging criteria and not plugged in accordance with the Steam Generator Program.	A.1	Verify tube integrity of the affected tube(s) is maintained until the next refueling outage or SG tube inspection.	7 days
	AND		
	A.2	Plug the affected tube(s) in accordance with the Steam Generator Program.	Prior to entering MODE 4 following the next refueling outage or SG tube inspection
B. Required Action and associated Completion Time of Condition A not met.	B.1	Be in MODE 3.	6 hours
	AND		
OR SG tube integrity not maintained.	B.2	Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.17.1	Verify SG tube integrity in accordance with the Steam Generator Program.	In accordance with the Steam Generator Program
SR 3.4.17.2	Verify that each inspected SG tube that satisfies the tube plugging criteria is plugged in accordance with the Steam Generator Program.	Prior to entering MODE 4 following a SG tube inspection

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.1 Accumulators

LCO 3.5.1 Four ECCS accumulators shall be OPERABLE.

APPLICABILITY: MODES 1 and 2,
MODE 3 with reactor coolant system pressure > 1000 psig.

---NOTES---

1. In MODE 3, all accumulator discharge isolation valves may be closed and energized for up to 8 hours during the performance of reactor coolant system hydrostatic testing.

2. In MODE 3, one accumulator discharge isolation valve may be closed and energized for up to 8 hours for accumulator check valve leakage testing.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One accumulator inoperable due to boron concentration not within limits of SR 3.5.1.4.	A.1 Restore boron concentration to within limits of SR 3.5.1.4.	72 hours
B. One accumulator inoperable for reasons other than Condition A.	B.1 Restore accumulator to OPERABLE status.	24 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Be in MODE 3. AND C.2 Reduce reactor coolant system pressure to ≤ 1000 psig.	6 hours 12 hours
D. Two or more accumulators inoperable.	D.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.1.1	Verify each accumulator discharge isolation valve is fully open.	12 hours
SR 3.5.1.2	Verify borated water volume in each accumulator is ≥ 775 cubic feet and ≤ 815 cubic feet.	12 hours
SR 3.5.1.3	Verify nitrogen cover pressure in each accumulator is ≥ 600 psig and ≤ 700 psig.	12 hours

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.1.4	Verify boron concentration in each accumulator is ≥ 2000 ppm and ≤ 2600 ppm.	31 days AND -----NOTE------ Only required to be performed for affected accumulators ---------- Once within 6 hours after each solution volume increase of 10 % of indicated level, that is not the result of addition from the refueling water storage tank
SR 3.5.1.5	Verify power is removed from each accumulator isolation valve operator when reactor coolant system pressure is ≥ 2000 psig.	31 days

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.2 ECCS – Operating

LCO 3.5.2 Three ECCS trains shall be OPERABLE.

----------NOTES----------

1. In MODE 3, both HHSI flow paths may be isolated by closing the isolation valves for up to 2 hours to perform pressure isolation valve testing per SR 3.4.14.1.

2. Operation in MODE 3 with HHSI pumps made incapable of injecting pursuant to LCO 3.4.12, "Low Temperature Overpressure Protection (LTOP)," is allowed for up to 4 hours or until the temperature of all RCS cold legs exceeds 375°F, whichever comes first.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more trains inoperable. AND Two HHSI pumps, one RHR pump and one Containment Recirculation pump are OPERABLE.	A.1 Restore train(s) to OPERABLE status.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.2.1	Verify the following valves are in the listed position with power to the valve operator removed.	12 hours

Number	Position	Function
SI-856B	Closed	HHSI Loop 33 Hot Leg Injection Stop Valve
SI-856G	Closed	HHSI Loop 31 Hot Leg Injection Stop Valve
SI-1810	Open	RWST outlet isolation
AC-744	Open	Common discharge isolation for RHR pumps
SI-882	Open	Common RWST suction isolation for RHR pumps
SI-842	Open	HHSI pump minimum flow line isolation
SI-843	Open	HHSI pump minimum flow line isolation
SI-883	Closed	RHR pump return to RWST isolation
AC-1870	Open	RHR pump minimum flow line isolation
AC-743	Open	RHR pump minimum flow line isolation

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.2.2	Verify that each ECCS manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.5.2.3	Verify each ECCS pump's developed head at the test flow point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.5.2.4	Verify each ECCS automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.5.2.5	Verify each ECCS pump starts automatically on an actual or simulated actuation signal.	24 months
SR 3.5.2.6	Verify, for each ECCS throttle valve listed below, each position stop is in the correct position. Valve Numbers SI-856B SI-856G SI-2165 SI-2170 SI-856C SI-856H SI-2166 SI-2171 SI-856D SI-856J SI-2168 SI-2172 SI-856E SI-856K SI-2169	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.2.7	Verify, by visual inspection, each ECCS train containment sump suction inlet and recirculation sump suction inlet is not restricted by debris and the suction inlet screens show no evidence of structural distress or abnormal corrosion.	24 months

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.3 ECCS-Shutdown

LCO 3.5.3 Two ECCS High Head Safety Injection (HHSI) subsystems and one ECCS Residual Heat Removal (RHR) subsystem shall be OPERABLE.

---NOTE---
An RHR subsystem may be considered OPERABLE during alignment and operation for decay heat removal if capable of being manually realigned to the ECCS mode of operation.

APPLICABILITY: MODE 4.

ACTIONS

---NOTE---
LCO 3.0.4.b is not applicable to the ECCS High Head Safety Injection subsystems.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required ECCS Subsystem inoperable.	A.1 ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- Initiate action to restore required ECCS subsystem to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.3.1	The following SRs are applicable for all equipment required to be OPERABLE: SR 3.5.2.3 SR 3.5.2.7	In accordance with applicable SRs

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.4 Refueling Water Storage Tank (RWST)

LCO 3.5.4 The RWST and two channels of RWST low level alarm shall be OPERABLE.

.....

NOTE 1
The RWST isolation valves connected to non-safety related piping may be opened under administrative controls for up to 14 days per fuel cycle for filtration until the end of refuel outage 18.

.....

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. RWST boron concentration not within limits of SR 3.5.4.3. OR RWST borated water temperature not within limits of SR 3.5.4.1.	A.1	Restore RWST to OPERABLE status.	8 hours
B. One channel of RWST low level alarm inoperable.	B.1	Restore RWST low level alarm to OPERABLE status.	7 days
C. RWST inoperable for reasons other than Condition A or B.	C.1	Restore RWST to OPERABLE status.	1 hour
D. Required Action and associated Completion Time not met.	D.1	Be in MODE 3.	6 hours
	AND		
		----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ----------	
	D.2	Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.5.4.1	----------NOTE---------- Not required to be performed when ambient air temperature is $\geq$ 35°F and $\leq$ 95°F if heating steam supply isolation valves are locked closed. ---------- Verify RWST borated water temperature is $\geq$ 35°F and $\leq$ 105°F.	24 hours
SR 3.5.4.2	Verify RWST borated water level is $\geq$ 35.4 feet.	7 days
SR 3.5.4.3	Verify RWST boron concentration is $\geq$ 2400 ppm and $\leq$ 2600 ppm.	31 days
SR 3.5.4.4	Perform CHANNEL CHECK of RWST level	7 days
SR 3.5.4.5	Perform CHANNEL CALIBRATION of RWST level switch and ensure the low level alarm setpoint is $\geq$10.5 feet and $\leq$12.5 feet.	184 days
SR 3.5.4.6	Perform CHANNEL CALIBRATION of RWST level transmitter and ensure the low level alarm setpoint is $\geq$10.5 feet and $\leq$12.5 feet.	18 months

3.6 CONTAINMENT SYSTEMS

3.6.1 Containment

LCO 3.6.1 Containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Containment inoperable.	A.1 Restore containment to OPERABLE status.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. AND B.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.1	Perform required visual examinations and leakage rate testing except for containment air lock testing, in accordance with the Containment Leakage Rate Testing Program.	In accordance with the Containment Leakage Rate Testing Program

3.6 CONTAINMENT SYSTEMS

3.6.2 Containment Air Locks

LCO 3.6.2 Two containment air locks shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

----------NOTES----------

1. Entry and exit is permissible to perform repairs on the affected air lock components.

2. Separate Condition entry is allowed for each air lock.

3. Enter applicable Conditions and Required Actions of LCO 3.6.1, "Containment," when air lock leakage results in exceeding the overall containment leakage rate.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more containment air locks with one containment air lock door inoperable.	----------NOTES---------- 1. Required Actions A.1, A.2, and A.3 are not applicable if both doors in the same air lock are inoperable and Condition C is entered. 2. Entry and exit is permissible for 7 days under administrative controls if both air locks are inoperable. ----------	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.1 Verify the OPERABLE door is closed in the affected air lock.	1 hour
	AND	
	A.2 Lock the OPERABLE door closed in the affected air lock.	24 hours
	AND	
	A.3 --------NOTE---------- Air lock doors in high radiation areas may be verified locked closed by administrative means. ----------	
	Verify the OPERABLE door is locked closed in the affected air lock.	Once per 31 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more containment air locks with containment air lock interlock mechanism inoperable.	----------NOTES---------- 1. Required Actions B.1, B.2, and B.3 are not applicable if both doors in the same air lock are inoperable and Condition C is entered. 2. Entry and exit of containment is permissible under the control of a dedicated individual. ---------- B.1 Verify an OPERABLE door is closed in the affected air lock. AND B.2 Lock an OPERABLE door closed in the affected air lock. AND B.3 ---------NOTE--------- Air lock doors in high radiation areas may be verified locked closed by administrative means. ---------- Verify an OPERABLE door is locked closed in the affected air lock.	1 hour 24 hours Once per 31 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION		COMPLETION TIME
C. One or more containment air locks inoperable for reasons other than Condition A or B.	C.1	Initiate action to evaluate overall containment leakage rate per LCO 3.6.1.	Immediately
	AND		
	C.2	Verify a door is closed in the affected air lock.	1 hour
	AND		
	C.3	Restore air lock to OPERABLE status.	24 hours
D. Required Action and associated Completion Time not met.	D.1	Be in MODE 3.	6 hours
	AND		
	D.2	Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.1	----------NOTES---------- 1. An inoperable air lock door does not invalidate the previous successful performance of the overall air lock leakage test. 2. Results shall be evaluated against acceptance criteria applicable to SR 3.6.1.1. ---------- Perform required air lock leakage rate testing in accordance with the Containment Leakage Rate Testing Program.	In accordance with the Containment Leakage Rate Testing Program
SR 3.6.2.2	Verify only one door in the air lock can be opened at a time.	24 months

3.6 CONTAINMENT SYSTEMS

3.6.3 Containment Isolation Valves

LCO 3.6.3 Each containment isolation valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

----------NOTES----------

1. Penetration flow path(s) except for 36 inch purge valve flow paths may be unisolated intermittently under administrative controls.

2. Separate Condition entry is allowed for each penetration flow path.

3. Enter applicable Conditions and Required Actions for systems made inoperable by containment isolation valves.

4. Enter applicable Conditions and Required Actions of LCO 3.6.1, "Containment," when isolation valve leakage results in exceeding the overall containment leakage rate acceptance criteria.

5. Enter applicable Conditions and Required Actions of LCO 3.6.9, "Isolation Valve Seal Water (IVSW) System," when required IVSW supply to a penetration flowpath is inoperable.

6. Enter applicable Conditions and Required Actions of LCO 3.6.10, "Weld Channel and Penetration Pressurization System (WC&PPS)," when required WC&PPS supply to a penetration flowpath is inoperable.

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. .....NOTE..... Only applicable to penetration flow paths with two or more containment isolation valves. ..... One or more penetration flow paths with one containment isolation valve inoperable, for reasons other than Condition D.	A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.	4 hours
	AND	
	A.2 .....NOTE..... Isolation devices in high radiation areas may be verified by use of administrative means. ..... Verify the affected penetration flow path is isolated.	Once per 31 days for isolation devices outside containment AND Prior to entering MODE 4 from MODE 5 if not performed within the previous 92 days for isolation devices inside containment

(continued)

ACTIONS (continued)

CONDITION		REQUIRED ACTION	COMPLETION TIME
B. --------NOTE-------- Only applicable to penetration flow paths with two or more containment isolation valves. ---------- One or more penetration flow paths with two or more containment isolation valves inoperable, for reasons other than Condition D.	B.1	Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.	1 hour
C. --------NOTE-------- Only applicable to penetration flow paths with only one containment isolation valve and a closed system. ---------- One or more penetration flow paths with one containment isolation valve inoperable.	C.1 AND C.2	Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange. --------NOTE-------- Isolation devices in high radiation areas may be verified by use of administrative means. ---------- Verify the affected penetration flow path is isolated.	72 hours Once per 31 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Containment bypass leakage or hydrostatically tested valve leakage not within limit.	D.1 Restore leakage within limit.	4 hours for containment bypass leakage AND 72 hours for hydrostatically tested valve leakage
E. Required Action and associated Completion Time not met.	E.1 Be in MODE 3. AND E.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.3.1	Verify each 36 inch purge supply and exhaust isolation valve is sealed closed.	31 days
SR 3.6.3.2	Verify each 10 inch pressure relief isolation valve is closed, except when these valves are open for pressure control, ALARA or air quality considerations for personnel entry, or for Surveillances that require the valves to be open.	31 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.3.3	----------NOTE---------- Valves and blind flanges in high radiation areas may be verified by use of administrative controls. ---------- Verify each containment isolation manual valve and blind flange that is located outside containment and not locked, sealed, or otherwise secured and required to be closed during accident conditions is closed, except for containment isolation valves that are open under administrative controls.	31 days
SR 3.6.3.4	----------NOTE---------- Valves and blind flanges in high radiation areas may be verified by use of administrative means. ---------- Verify each containment isolation manual valve and blind flange that is located inside containment and not locked, sealed or otherwise secured and required to be closed during accident conditions is closed, except for containment isolation valves that are open under administrative controls.	Prior to entering MODE 4 from MODE 5 if not performed within the previous 92 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.6.3.5	Verify the isolation time of each automatic power operated containment isolation valve is within limits.	In accordance with the Inservice Testing Program
SR 3.6.3.6	Verify each automatic containment isolation valve that is not locked, sealed or otherwise secured in position, actuates to the isolation position on an actual or simulated actuation signal.	24 months
SR 3.6.3.7	Verify each 10 inch containment pressure relief line isolation valve is blocked to restrict valve opening to ≤ 60 degrees.	24 months
SR 3.6.3.8	Perform one complete cycle of each manually operated containment isolation valve on essential lines.	24 months
SR 3.6.3.9	Verify leakage rate into containment from isolation valves sealed with service water system is within limits.	In accordance with the Containment Leakage Rate Testing Program

3.6 CONTAINMENT SYSTEMS

3.6.4 Containment Pressure

LCO 3.6.4 Containment pressure shall be maintained as follows:

a. If RWST temperature is > 95^0F or containment temperature is > 125^0F, Containment pressure shall be ≥ -2.0 psig and ≤ +1.5 psig.

b. If RWST temperature is ≤ 95^0F and containment temperature is ≤ 125^0F, Containment pressure shall be ≥ -2.0 psig and ≤ +2.5 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Containment pressure not within limits.	A.1	Restore containment pressure to within limits.	1 hour
B. Required Action and associated Completion Time not met.	B.1	Be in MODE 3.	6 hours
	AND		
	B.2	Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.1	Verify containment pressure is within limits.	12 hours

3.6 CONTAINMENT SYSTEMS

3.6.5 Containment Air Temperature

LCO 3.6.5 Containment average air temperature shall be > 50°F and ≤ 130°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Containment average air temperature ≤50 °F.	A.1 Restore containment average air temperature to >50 °F.	Immediately
B. Containment average air temperature >130 °F.	B.1 Restore containment average air temperature to within ≤130 °F.	8 hours
C. Required Action and associated Completion Time Condition A or B not met.	C.1 Be in MODE 3. AND C.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.5.1	Verify containment average air temperature is within limits.	24 hours

3.6 CONTAINMENT SYSTEMS

3.6.6 Containment Spray System and Containment Fan Cooler System

LCO 3.6.6 Two Containment Spray trains and three Containment Fan Cooler trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One containment spray train inoperable.	A.1 Restore containment spray train to OPERABLE status.	72 hours AND 10 days from discovery of failure to meet the LCO
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3. AND ----- NOTE ----- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- B.2 Be in MODE 4.	6 hours 54 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One containment fan cooler train inoperable.	C.1 Restore containment fan cooler train to OPERABLE status.	7 days AND 10 days from discovery of failure to meet the LCO
D. Two containment fan cooler trains inoperable.	D.1 Restore one containment fan cooler train to OPERABLE status.	72 hours
E. Required Action and associated Completion Time of Condition C or D not met.	E.1 Be in MODE 3. AND ----- NOTE ----- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- E.2 Be in MODE 4.	6 hours 12 hours
F. Two containment spray trains inoperable. OR Any combination of three or more trains inoperable.	F.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.6.6.1	Verify each containment spray manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position.	31 days
SR 3.6.6.2	Operate each containment fan cooler unit fan for ≥ 15 minutes.	92 days
SR 3.6.6.3	Verify each containment fan cooler unit cooling water flow rate is ≥ 1400 gpm.	92 days
SR 3.6.6.4	Verify each containment spray pump's developed head at the flow test point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.6.6.5	Verify each automatic containment spray valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.6.6.6	Verify each containment spray pump starts automatically on an actual or simulated actuation signal.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.6.7	Verify each containment fan cooler unit starts and dampers re-position to the emergency mode automatically on an actual or simulated actuation signal.	24 months
SR 3.6.6.8	Perform required containment fan cooler system filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR 3.6.6.9	Verify each spray nozzle is unobstructed.	10 years

3.6 CONTAINMENT SYSTEMS

3.6.7 Recirculation pH Control System

LCO 3.6.7 The Recirculation pH Control System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Recirculation pH Control System inoperable.	A.1	Restore Recirculation pH Control System to OPERABLE status.	72 hours
B. Required Action and associated Completion Time not met.	B.1 AND	Be in MODE 3. ----- NOTE ----- LCO 3.0.4.a is not applicable when entering MODE 4. ----------	6 hours
	B.2	Be in MODE 4.	54 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.7.1	Perform a visual inspection of eight sodium tetraborate storage baskets to verify each of the following: a. Each storage basket is in place and intact; and, b. Collectively contain $\geq$ 8096 pounds (160 cubic feet) of sodium tetraborate decahydrate, or equivalent.	24 Months

3.6 CONTAINMENT SYSTEMS

3.6.8 **Not Used**

3.6 CONTAINMENT SYSTEMS

3.6.9 Isolation Valve Seal Water (IVSW) System

LCO 3.6.9 The IVSW System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One IVSW system header inoperable. OR One IVSW automatic actuation valve inoperable.	A.1 Restore IVSW system to OPERABLE status.	7 days
B. IVSW system inoperable for reasons other than Condition A.	B.1 Restore IVSW System to OPERABLE Status.	24 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. AND C.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.6.9.1	Verify IVSW tank pressure is ≥ 47 psig.	24 hours
SR 3.6.9.2	Verify IVSW nitrogen supply bank is pressurized with: a. one cylinder with pressure ≥ 1048 psig; or b. two cylinders with pressure ≥ 584 psig; or c. three cylinders with pressure ≥ 430 psig.	24 hours
SR 3.6.9.3	Verify the IVSW tank water volume is ≥ 144 gallons.	24 hours
SR 3.6.9.4	Verify the opening time of each air operated header injection valve is within limits.	24 months
SR 3.6.9.5	Verify each automatic valve in the IVSW System actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.6.9.6	Verify the leakage rate of water from the Isolation Valve Seal Water System is within limits.	In accordance with the Containment Leakage Rate Testing Program.

3.6 CONTAINMENT SYSTEMS

3.6.10 Weld Channel and Penetration Pressurization System (WC&PPS)

LCO 3.6.10 Weld Channel and Penetration Pressurization System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

----------NOTES----------

1. Separate Condition entry is allowed for each component supplied by WC&PPS.

2. Enter applicable Conditions and Required Actions of LCO 3.6.1, "Containment," when the overall containment leakage rate acceptance criteria is exceeded.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more components supplied by WC&PPS not within the pressure limit of SR 3.6.10.1.	A.1 Isolate the WC&PPS supply to the affected components by use of at least one closed and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured. AND	4 hours (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2 --------NOTE-------- Isolation devices in high radiation areas may be verified by use of administrative means. ---------- Verify the WC&PPS supply to the affected component is isolated.	Once per 31 days for isolation devices outside containment not locked, sealed or otherwise secured AND Prior to entering MODE 4 from MODE 5 if not performed within the previous 92 days for isolation devices inside containment
B. WC&PPS air consumption not within the limits of SR 3.6.10.2.	B.1 Enter applicable Conditions and Required Actions of LCO 3.6.3, "Containment Isolation Valves." AND	1 hour from discovery that the WC&PPS air consumption leakage path is depressurized and not isolated from the supported containment isolation valves (continued)

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
B. (continued)	B.2	Enter applicable Conditions and Required Actions of LCO 3.6.2, "Containment Air Locks."	1 hour from discovery that the WC&PPS air consumption leakage path is depressurized and not isolated from the supported air lock
	AND		
	B.3	--------NOTE-------- Enter condition A for components not within the pressure limit of SR 3.6.10.1. ---------- Isolate portions of WC&PPS to restore air consumption to within limits of SR 3.6.10.2.	7 days
C. Required Action and associated Completion Time not met.	C.1	Be in MODE 3.	6 hours
	AND		
	C.2	Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.10.1	Verify all required portions of each WC&PPS zone is pressurized to ≥ 43 psig.	31 days
SR 3.6.10.2	Verify the WC&PPS air consumption is ≤ 0.2% of the containment free volume per day.	31 days
SR 3.6.10.3	Verify the leakage rate for the WC&PPS is ≤ 0.2% of the containment free volume per day when pressurized to ≥ 43 psi above containment pressure.	-----NOTE------ SR 3.0.2 is not applicable ---------- 36 months

3.7 PLANT SYSTEMS

3.7.1 Main Steam Safety Valves (MSSVs)

LCO 3.7.1 The MSSVs shall be OPERABLE as specified in Table 3.7.1-1 and Table 3.7.1-2.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each MSSV.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required MSSVs inoperable.	A.1 Reduce neutron flux trip setpoint to less than or equal to the applicable % RTP listed in Table 3.7.1-1.	4 hours
B. Required Action and associated Completion Time not met. OR One or more steam generators with less than two MSSVs OPERABLE.	B.1 Be in MODE 3. AND B.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.1.1	----------NOTE---------- Only required to be performed in MODES 1 and 2. ----------	
	Verify each required MSSV lift setpoint per Table 3.7.1-2 in accordance with the Inservice Testing Program. Following testing, lift setting shall be within ±1%.	In accordance with the Inservice Testing Program

Table 3.7.1-1 (page 1 of 1)
OPERABLE Main Steam Safety Valves versus
Applicable Neutron Flux Trip Setpoint in Percent of RATED THERMAL POWER

MINIMUM NUMBER OF MSSVs PER STEAM GENERATOR REQUIRED OPERABLE	APPLICABLE Neutron Flux Trip Setpoint (% RTP)
4	≤ 57
3	≤ 38
2	≤ 20

Table 3.7.1-2 (page 1 of 1)
Main Steam Safety Valve Lift Settings

VALVE NUMBER				LIFT SETTING (psig ± 3%)
STEAM GENERATOR				
#31	#32	#33	#34	
MS-45-1	MS-45-2	MS-45-3	MS-45-4	1065
MS-46-1	MS-46-2	MS-46-3	MS-46-4	1080
MS-47-1	MS-47-2	MS-47-3	MS-47-4	1095
MS-48-1	MS-48-2	MS-48-3	MS-48-4	1110
MS-49-1	MS-49-2	MS-49-3	MS-49-4	1120

3.7 PLANT SYSTEMS

3.7.2 Main Steam Isolation Valves (MSIVs) and Main Steam Check Valves (MSCVs)

LCO 3.7.2 Four MSIVs and four MSCVs shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3 except when all MSIVs are closed.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more MSCVs inoperable.	A.1	Restore MSCVs to OPERABLE status.	48 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1	Be in MODE 2.	6 hours
	AND		
	B.2	Close all MSIVs.	14 hours
	AND		
	B.3	Verify all MSIVs closed.	Once per 7 days
C. One MSIV inoperable in MODE 1.	C.1	Restore MSIV to OPERABLE status.	48 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 2.	6 hours
E. --------NOTE---------- Separate Condition entry is allowed for each MSIV. ---------- One or more MSIVs inoperable in MODE 2 or 3.	E.1 Close MSIV. AND E.2 Verify MSIV is closed.	8 hours Once per 7 days
F. One MSIV inoperable. AND One or more MSCVs inoperable.	F.1 Restore all MSCVs to OPERABLE status. OR F.2 Restore all MSIVs to OPERABLE status.	8 hours 8 hours
G. Required Action and associated Completion Time of Condition B, E or F not met.	G.1 Be in MODE 3. AND G.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.2.1	----------NOTE---------- Only required to be performed in MODES 1 and 2. ---------- Verify closure time of each MSIV is ≤ 5.0 seconds on an actual or simulated actuation signal.	In accordance with the Inservice Testing Program
SR 3.7.2.2	Perform visual inspection of each MSCV.	In accordance with the Inservice Testing Program

3.7 PLANT SYSTEMS

3.7.3 Main Boiler Feedpump Discharge Valves (MBFPDVs), Main Feedwater Regulation Valves (MFRVs), Main Feedwater Inlet Isolation Valves (MFIIVs) and Main Feedwater (MF) Low Flow Bypass Valves

LCO 3.7.3 Two MBFPDVs, four MFRVs, four MFIIVs and eight MF low flow bypass valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3 except when each main feedwater and bypass line is isolated by a closed and de-activated motor/air operated valve or isolated by a closed manual valve.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each valve.

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or both MBFPDVs inoperable.	A.1	Close or isolate MBFPDV.	72 hours
	AND		
	A.2	Verify MBFPDV is closed or isolated.	Once per 7 days
B. One or more MFRVs inoperable.	B.1	Close or isolate MFRV.	72 hours
	AND		
	B.2	Verify MFRV is closed or isolated.	Once per 7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more MFIIVs inoperable.	C.1 Close or isolate MFIIV. AND C.2 Verify MFIIV is closed or isolated.	72 hours Once per 7 days
D. One or more MF low flow bypass valves inoperable.	D.1 Close or isolate bypass valve. AND D.2 Verify bypass valve is closed or isolated.	72 hours Once per 7 days
E. Two valves in series in the same flow path inoperable.	E.1 Isolate affected flow path.	8 hours
F. Required Action and associated Completion Time not met.	F.1 Be in MODE 3. AND F.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.3.1	Verify each MBFPDV, MFRV, MFIIV and MF low flow bypass valve closes on an actual or simulated actuation signal within the following limits: a. MBFPDV closure time ≤ 122 seconds; b. MFRV closure time ≤ 10 seconds; and, c. MFIIV closure time ≤ 120 seconds d. MFRV Low Flow Bypass valve closure time 1. primary ≤ 10 seconds 2. backup ≤ 120 seconds.	In accordance with the Inservice Testing Program

3.7 PLANT SYSTEMS

3.7.4 Atmospheric Dump Valves (ADVs)

LCO 3.7.4 Four ADV lines shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required ADV line inoperable.	A.1 Restore required ADV line to OPERABLE status.	7 days
B. Two or more required ADV lines inoperable.	B.1 Restore all but one ADV line to OPERABLE status.	24 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. AND C.2 Be in MODE 4 without reliance upon steam generator for heat removal.	6 hours 18 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.4.1	Verify one complete cycle of each ADV.	24 months
SR 3.7.4.2	Verify one complete cycle of each ADV block valve.	24 months

3.7 PLANT SYSTEMS

3.7.5 Auxiliary Feedwater (AFW) System

LCO 3.7.5 Three AFW trains shall be OPERABLE.

---NOTE---
Only one AFW train, which includes a motor driven pump capable of supporting the credited steam generator(s), is required to be OPERABLE in MODE 4.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

---NOTE---
LCO 3.0.4.b is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One steam supply to turbine driven AFW pump inoperable.	A.1 Restore steam supply to OPERABLE status.	7 days AND 10 days from discovery of failure to meet the LCO
B. One AFW train inoperable in MODE 1, 2 or 3 for reasons other than Condition A.	B.1 Restore AFW train to OPERABLE status.	72 hours AND 10 days from discovery of failure to meet the LCO

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time for Condition A or B not met. OR Two AFW trains inoperable in MODE 1, 2, or 3.	C.1 Be in MODE 3. AND C.2 Be in MODE 4.	6 hours 18 hours
D. Three AFW trains inoperable in MODE 1, 2, or 3.	----------NOTE---------- LCO 3.0.3 and all other LCO Required Actions requiring MODE changes are suspended until one AFW train is restored to OPERABLE status. ---------- D.1 Initiate action to restore one AFW train to OPERABLE status.	Immediately
E. Required AFW train inoperable in MODE 4.	E.1 Initiate action to restore AFW train to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.5.1	----------NOTE---------- Not applicable in MODE 4 when steam generator is relied upon for heat removal. ----------	
	Verify each AFW manual, power operated, and automatic valve in each water flow path, and in both steam supply flow paths to the steam turbine driven pump, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.7.5.2	----------NOTE---------- Not required to be performed for the turbine driven AFW pump until 24 hours after ≥ 600 psig in the steam generator. ----------	
	Verify the developed head of each AFW pump at the flow test point is greater than or equal to the required developed head.	In accordance with Inservice Testing Program
SR 3.7.5.3	----------NOTE---------- Not applicable in MODE 4 when steam generator is relied upon for heat removal. ----------	
	Verify each AFW automatic valve that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.7.5.4	----------NOTES---------- 1. Not required to be performed for the turbine driven AFW pump until 24 hours after ≥ 600 psig in the steam generator. 2. Not applicable in MODE 4 when steam generator is relied upon for heat removal. ---------- Verify each AFW pump starts automatically on an actual or simulated actuation signal.	24 months

3.7 PLANT SYSTEMS

3.7.6 Condensate Storage Tank (CST)

LCO 3.7.6 The CST shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. CST inoperable.	A.1	Verify by administrative means OPERABILITY of City Water.	Immediately AND Once per 12 hours thereafter
	AND		
	A.2	Restore CST to OPERABLE.	7 days
B. Required Action and associated Completion Time not met.	B.1	Be in MODE 3.	6 hours
	AND		
	B.2	Be in MODE 4, without reliance on steam generator for heat removal.	18 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.6.1	Verify the CST level is ≥ 360,000 gal.	12 hours

3.7 PLANT SYSTEMS

3.7.7 City Water (CW)

LCO 3.7.7 CW shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. CW inoperable.	A.1	Verify by administrative means OPERABILITY of Condensate Storage Tank.	Immediately AND Once per 12 hours thereafter
	AND		
	A.2	Restore CW to OPERABLE.	7 days
B. Required Action and associated Completion Time not met.	B.1	Be in MODE 3.	6 hours
	AND		
	B.2	Be in MODE 4, without reliance on steam generators for heat removal.	18 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.7.1	Verify the CW header pressure is ≥ 30 psig.	12 hours
SR 3.7.7.2	Verify the Unit 3 City Water Header Supply Isolation Valves are open.	31 days
SR 3.7.7.3	Perform testing required by Inservice Testing Program for each valve needed to align CW to each AFW pump suction.	In accordance with the Inservice Testing Program

3.7 PLANT SYSTEMS

3.7.8 Component Cooling Water (CCW) System

LCO 3.7.8 Two CCW loops shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CCW loop inoperable.	A.1 -------NOTE------- Enter applicable Conditions and Required Actions of LCO 3.4.6, "RCS Loops□MODE 4," for residual heat removal loops made inoperable by CCW. ---------- Restore CCW loop to OPERABLE status.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3. AND ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- B.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.8.1	----------NOTE---------- Isolation of CCW flow to individual components does not render the CCW System inoperable. ---------- Verify each CCW manual, power operated, and automatic valve in the flow path servicing safety related equipment, that is not locked, sealed, or otherwise secured in position, is in the correct position.	92 days
SR 3.7.8.2	Verify each CCW automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.7.8.3	Verify each CCW pump starts automatically on an actual or simulated actuation signal.	24 months

3.7 PLANT SYSTEMS

3.7.9 Service Water System (SWS)

LCO 3.7.9 Three pumps and required flow path for the essential SWS header shall be Operable;

AND,

Two pumps and required flow path for the nonessential SWS header shall be Operable.

APPLICABILITY: MODES 1, 2, 3, and 4.

----------NOTE----------
If LCO 3.7.9 will be met after the essential and non-essential header are swapped, then LCO 3.0.3 is not applicable for 8 hours while swapping the essential SWS header with the nonessential SWS header.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required SWS pump on essential header inoperable.	A.1 Establish 3 OPERABLE SWS pumps on the essential SWS header.	72 hours
B. One required SWS pump on nonessential header inoperable.	B.1 Establish 2 OPERABLE SWS pumps on the nonessential SWS header.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One EDG ESFAS Service Water valve inoperable.	C.1 Restore both EDG ESFAS Service Water valves to OPERABLE status.	12 hours
D. One FCU ESFAS Service Water valve inoperable.	D.1 Restore both FCU ESFAS Service Water valves to OPERABLE status.	12 hours
E. SWS piping and valves inoperable for reasons other than Conditions A, B, C, or D, with no loss of safety function.	E.1 Restore SWS to OPERABLE Status	12 hours
F. Required Action and associated Completion Time of Condition A, B, C, D or E not met.	F.1 Be in MODE 3 AND ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- F.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.9.1	----------NOTE---------- Isolation of SWS flow to individual components does not render the SWS header inoperable. ---------- Verify each SWS manual, power operated, and automatic valve in the flow path servicing safety related equipment, that is not locked, sealed, or otherwise secured in position, is in the correct position.	92 days
SR 3.7.9.2	Verify each SWS automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.7.9.3	Verify each SWS pump starts automatically on an actual or simulated actuation signal.	24 months

3.7 PLANT SYSTEMS

3.7.10 Ultimate Heat Sink (UHS)

LCO 3.7.10 The UHS shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. UHS temperature > 95°F. OR UHS inoperable for reasons other than temperature > 95°F.	A.1 Be in MODE 3. AND ----- NOTE -------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- A.2 Be in MODE 4.	7 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.10.1 Verify average water temperature of UHS is ≤ 95°F.	24 hours

3.7 PLANT SYSTEMS

3.7.11 Control Room Ventilation System (CRVS)

LCO 3.7.11 Two CRVS trains shall be OPERABLE.

- NOTE -
The control room envelope (CRE) boundary may be opened intermittently under administrative control.

APPLICABILITY: MODES 1, 2, 3 and 4,
During movement of recently irradiated fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One CRVS train inoperable for reasons other than Condition B.	A.1	Restore CRVS train to OPERABLE status.	7 days
B. One or more CRVS trains inoperable due to inoperable CRE boundary in MODE 1, 2, 3, or 4.	B.1	Initiate action to implement mitigating actions.	Immediately
	AND		
	B.2	Verify mitigating actions ensure CRE occupant exposures to radiological, chemical, and smoke hazards will not exceed limits.	24 hours
	AND		
	B.3	Restore CRE boundary to OPERABLE status.	90 days
C. Two CRVS trains inoperable for reasons other than Condition B	C.1	Restore one CRVS train to OPERABLE status.	72 hours

ACTIONS (continued)

D. Required Action and associated Completion Time of Condition A, B or C not met in Mode 1, 2, 3, or 4.	D.1 Be in MODE 3. AND ----- NOTE ------ LCO 3.0.4.a is not applicable when entering MODE 4. ---------- D.2 Be in MODE 4.	6 hours 12 hours
E. One CRVS train inoperable during movement of recently irradiated fuel assemblies.	E.1 Place OPERABLE CRVS train in pressurization mode. OR E.2 Suspend movement of recently irradiated fuel assemblies.	Immediately Immediately
F. Two CRVS trains inoperable during movement of recently irradiated fuel assemblies. OR One or more CRVS trains inoperable due to an inoperable CRE boundary during movement of recently irradiated fuel assemblies.	F.1 Suspend movement of recently irradiated fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.11.1	Operate each CRVS train for ≥ 15 minutes.	31 days
SR 3.7.11.2	Perform required CRVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with VFTP
SR 3.7.11.3	Verify each CRVS train actuates on an actual or simulated actuation signal.	24 months
SR 3.7.11.4	Perform required CRE unfiltered air inleakage testing in accordance with the Control Room Envelope Habitability Program.	In accordance with the Control Room Envelope Habitability Program

3.7 PLANT SYSTEMS

3.7.12 Control Room Air Conditioning System (CRACS)

LCO 3.7.12 Two CRACS trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4,

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CRACS train inoperable.	A.1 Restore CRACS train to OPERABLE status.	30 days
B. Two CRACS trains inoperable.	B.1 Restore one CRACS train to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Be in MODE 3. AND ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- C.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.12.1 Verify each CRACS train has the capability to remove the assumed heat load.	24 months

3.7 PLANT SYSTEMS

3.7.13 Fuel Storage Building Emergency Ventilation System (FSBEVS)

LCO 3.7.13 FSBEVS shall be OPERABLE.

APPLICABILITY: During movement of recently irradiated fuel assemblies in the fuel storage building.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. FSBEVS inoperable.	A.1 Suspend movement of recently irradiated fuel assemblies in the fuel storage building.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.13.1	Verify FSBEVS charcoal filter bypass dampers are installed.	92 days
SR 3.7.13.2	Operate FSBEVS for ≥ 15 minutes.	31 days
SR 3.7.13.3	Perform required FSBEVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR 3.7.13.4	Verify FSBEVS actuates on an actual or simulated actuation signal.	92 days
SR 3.7.13.5	Verify FSBEVS can maintain a pressure ≤ -0.125 inches water gauge with respect to atmospheric pressure during the post accident mode of operation at a flow rate ≤ 20,000 cfm.	24 months

3.7 PLANT SYSTEMS

3.7.14 Spent Fuel Pit Water Level

LCO 3.7.14 The spent fuel pit water level shall be ≥ 23 ft over the top of irradiated fuel assemblies seated in the storage racks.

APPLICABILITY: During movement of irradiated fuel assemblies in the spent fuel pit.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Spent fuel pit water level not within limit.	A.1 .....NOTE..... LCO 3.0.3 is not applicable. ..... Suspend movement of irradiated fuel assemblies in the spent fuel pit.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.14.1	Verify the spent fuel pit water level is ≥ 23 ft above the top of the irradiated fuel assemblies seated in the storage racks.	7 days

3.7 PLANT SYSTEMS

3.7.15 Spent Fuel Pit Boron Concentration

LCO 3.7.15 The Spent Fuel Pit boron concentration shall be ≥ 1000 ppm.

----------NOTE----------
During inter-unit transfer of fuel the spent fuel pit boron concentration must also meet Appendix C LCO 3.1.1, "Boron Concentration".

APPLICABILITY: When fuel assemblies are stored in the spent fuel pit and a spent fuel pit verification has not been performed since the last movement of fuel assemblies in the spent fuel pit.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Spent fuel pit boron concentration not within limit.	----------NOTE---------- LCO 3.0.3 is not applicable. ---		
	A.1	Suspend movement of fuel assemblies in the spent fuel pit.	Immediately
	AND		
	A.2.1	Initiate action to restore spent fuel pit boron concentration to within limit.	Immediately
	OR		
	A.2.2	Initiate action to perform a spent fuel pit verification.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.15.1	Verify the spent fuel pit boron concentration is within limit.	31 days

3.7 PLANT SYSTEMS

3.7.16 Spent Fuel Assembly Storage

LCO 3.7.16 Fuel assemblies stored in the spent fuel pit shall be classified in accordance with Figure 3.7.16-1 based on initial enrichment and burnup; and,

Fuel assembly storage location within the spent fuel pit shall be restricted based on the Figure 3.7.16-1 classification as follows:

a. Fuel assemblies classified as Type 2 may be stored in any location in either Region 1 or Region 2;

b. Fuel assemblies classified as Type 1A, 1B or 1C shall be stored in Region 1;

c. Fuel assembly storage location within Region 1 shall be restricted as follows:

1. Type 1A assemblies may be stored anywhere in Region 1;

2. Type 1B assemblies may be stored anywhere in Region 1, except a Type 1B assembly shall not be stored face-adjacent to a Type 1C assembly;

3. Type 1C assemblies shall not be stored in Row 64 or in Column ZZ; and

4. Type 1C assemblies shall be stored in Region 1 locations where all face-adjacent locations are as follows:

a) occupied by Type 2 or Type 1A assemblies, or

b) occupied by non-fuel components, or

c) empty.

APPLICABILITY: Whenever any fuel assembly is stored in the spent fuel pit.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of the LCO not met.	A.1 .....NOTE..... LCO 3.0.3 is not applicable. ..... Initiate action to move fuel to restore compliance with LCO 3.7.16.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.16.1	Verify by administrative means the initial enrichment and burnup of each fuel assembly and that the storage location meets LCO 3.7.16 requirements.	Prior to storing the fuel assembly in the spent fuel pit



Figure 3.7.16-1 (Page 1 of 1)
Fuel Assembly Classification
for Storage in the Spent Fuel Pit

3.7 PLANT SYSTEMS

3.7.17 Secondary Specific Activity

LCO 3.7.17 The specific activity of the secondary coolant shall be ≤ 0.10 μCi/gm DOSE EQUIVALENT I-131.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Specific activity not within limit.	A.1	Be in MODE 3.	6 hours
	AND		
	A.2	Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.17.1	Verify the specific activity of the secondary coolant is ≤ 0.10 μCi/gm DOSE EQUIVALENT I-131.	31 days

3.8 ELECTRICAL POWER SYSTEMS

3.8.1 AC Sources - Operating

LCO 3.8.1 The following AC electrical sources shall be OPERABLE:

a. Two qualified circuits between the offsite transmission network and the onsite Electrical Power Distribution System; and

b. Three diesel generators (DGs) (31, 32 and 33) capable of supplying the onsite power distribution subsystem(s)

---Note---
The 138 kV circuit is considered inoperable whenever the automatic transfer function for the 6.9 kV buses is disabled.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

---Note---
The LCO 3.0.4.b is not applicable to DGs or the 138kV offsite circuit.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One offsite circuit inoperable.	A.1 Perform SR 3.8.1.1 for OPERABLE offsite circuit. AND	1 hour AND Once per 8 hours thereafter

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	.....NOTE..... Only required if 13.8 kV offsite circuit is supplying 6.9 kV bus 5 or 6 and the Unit Auxiliary Transformer is supplying 6.9 kV bus 1, 2, 3 or 4.	
	A.2 Verify automatic transfer of 6.9 kV buses 1, 2, 3, and 4 to 6.9 kV bus 5 and 6 is disabled.	1 hour AND Once per 8 hours thereafter
	AND	
	A.3 Declare inoperable required feature(s) with no offsite power automatically available when its redundant required feature(s) is inoperable.	24 hours from discovery of no automatically available offsite power to one train concurrent with inoperability of redundant required feature(s)
	AND	
	A.4 Restore offsite circuit to OPERABLE status.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One DG inoperable.	B.1 Perform SR 3.8.1.1 for the offsite circuits.	1 hour AND Once per 8 hours thereafter
	AND	
	B.2 Declare inoperable the required features supported by the inoperable DG when its required redundant feature is inoperable.	4 hours from discovery of Condition B concurrent with inoperability of redundant required feature
	AND	
	B.3.1 Determine OPERABLE DG(s) are not inoperable due to common cause failure. OR	24 hours
	B.3.2 Perform SR 3.8.1.2 for OPERABLE DGs.	24 hours
	AND	
	B.4 Restore DG to OPERABLE status.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Two offsite circuits inoperable.	C.1 Declare required features inoperable when its redundant required feature is inoperable. AND	12 hours from discovery of Condition C concurrent with inoperability of redundant required feature
	C.2 Restore one offsite circuit to OPERABLE status.	24 hours
D. One offsite circuit inoperable. AND One DG inoperable.	----------NOTE---------- Enter applicable Conditions and Required Actions of LCO 3.8.9, "Distribution Systems – Operating," when Condition D is entered with no offsite or DG AC power source automatically available to any train. ---------- D.1 Restore offsite circuit to OPERABLE status. OR D.2 Restore DG to OPERABLE status.	 12 hours 12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Two or more DGs inoperable.	E.1 Restore at least two DGs to OPERABLE status.	2 hours
F. Required Action and associated Completion Time of Condition A, B, C, D, or E not met.	F.1 Be in MODE 3. AND --- NOTE ---- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- F.2 Be in MODE 4.	6 hours 12 hours
G. One or more offsite circuits and two DGs inoperable.	G.1 Enter LCO 3.0.3.	Immediately
H. Two offsite circuits and one or more DGs inoperable.	H.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.1.1	Verify correct breaker alignment and indicated power availability for each offsite circuit.	7 days
SR 3.8.1.2	----------NOTE---------- All DG starts may be preceded by an engine prelube period. ----------	
	Verify each DG starts from standby conditions and achieves: a. in ≤ 10 seconds, voltage ≥ 422 V and frequency ≥ 58.8 Hz; and b. steady state voltage ≥ 422 V and ≤ 500V, and frequency ≥ 58.8 Hz and ≤ 61.2 Hz.	31 days
SR 3.8.1.3	----------NOTES---------- 1. DG loadings may include gradual loading as recommended by the manufacturer. 2. Momentary transients outside the load range do not invalidate this test. 3. This SR shall be conducted on only one DG at a time. 4. This SR shall be preceded by and immediately follow without shutdown a successful performance of SR 3.8.1.2. ----------	
	Verify each DG is synchronized and loaded and operates for ≥ 60 minutes at a load ≥ 1575 kW and ≤ 1750 kW.	31 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.4	Verify each day tank contains ≥ 115 gal of fuel oil.	31 days
SR 3.8.1.5	Check for and remove accumulated water from each day tank.	31 days
SR 3.8.1.6	Verify the fuel oil transfer system operates to automatically transfer fuel oil from DG storage tank to the day tank.	31 days
SR 3.8.1.7	----------NOTE---------- This Surveillance shall not normally be performed in MODE 1 or 2. However this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. ---------- Verify manual transfer of AC power sources from the normal offsite circuit to the alternate offsite circuit.	24 months

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.8	----------NOTES---------- 1. This Surveillance shall not normally be performed in MODE 1 or 2. However this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. 2. Only required to be met if 138 kV offsite circuit is supplying 6.9 kV bus 5 and 6 and the Unit Auxiliary Transformer is supplying 6.9 kV bus 2 or 3. ---------- Verify automatic transfer of AC power for 6.9 kV buses 2 and 3 from the unit auxiliary transformer to 6.9 kV buses 5 and 6.	24 months
SR 3.8.1.9	----------NOTE---------- This Surveillance shall not normally be performed in MODE 1 or 2. However this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. ---------- Verify each DG's automatic trips are bypassed on actual or simulated loss of voltage signal on the emergency bus concurrent with an actual or simulated ESF actuation signal except: a. Engine overspeed; b. Low lube oil pressure; and c. Overcrank relay.	24 months

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.10	----------NOTES---------- 1. Momentary transients outside the load and power factor ranges do not invalidate this test. 2. This Surveillance shall not normally be performed in MODE 1 or 2. However this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. 3. If performed with DG synchronized with offsite power, it shall be performed at a power factor of $\leq$ 0.85 for EDG 31, $\leq$ 0.87 for EDG 32, and $\leq$ 0.84 for EDG 33. However, if grid conditions do not permit, the power factor limit is not required to be met. Under this condition the power factor shall be maintained as close to the limit as practicable. 4. Prior to performing SR 3.8.1.10 while connected to the 13.8 kV offsite power, the grid condition must be evaluated to show that conditions exist to reasonably allow the required power factor limits to be met or perform the SR while connected to the 138 kV offsite power. ---------- Verify each DG operates for $\geq$ 8 hours: a. For $\geq$ 105 minutes loaded $\geq$ 1925kW and $\leq$ 1941 kW; and b. For the remaining hours of the test loaded $\geq$ 1700kW and $\leq$ 1750 kW.	24 months
SR 3.8.1.11	----------NOTE---------- Load timers associated with equipment that has automatic initiation capability disabled are not required to be operable. ---------- Verify each time delay relay functions within the required design interval.	18 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SR 3.8.1.12	----------NOTES---------- 1. All DG starts may be preceded by an engine prelube period. 2. This Surveillance shall not normally be performed in MODE 1, 2, 3, or 4. However portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. 3. This SR may be performed on safeguards power trains one at a time, or simultaneously. Appropriate plant conditions must be established when testing three safeguards power trains simultaneously. ---------- Verify on an actual or simulated loss of offsite power signal in conjunction with an actual or simulated ESF actuation signal: a. De-energization of emergency buses; b. Load shedding from emergency buses; and c. DG auto-starts from standby condition and: 1. energizes permanently connected loads in ≤ 10 seconds, 2. energizes auto-connected emergency loads through individual load timers, 3. achieves steady state voltage ≥ 422 V and ≤ 500 V, 4. achieves steady state frequency ≥ 58.8 Hz and ≤ 61.2 Hz, and 5. supplies permanently connected and auto-connected emergency loads for ≥ 5 minutes.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.13	----------NOTE---------- 1. All DG starts may be preceded by an engine prelube period. 2. Performance of SR 3.8.1.12 may be used to satisfy the requirements of this SR if all three diesel generators are started simultaneously. ---------- Verify when started simultaneously from standby condition, each DG achieves: a. in ≤ 10 seconds, voltage ≥ 422 V and frequency ≥ 58.8 Hz; and b. steady state voltage ≥ 422 V and ≤ 500V, and frequency ≥ 58.8 Hz and ≤ 61.2 Hz.	10 years

3.8 ELECTRICAL POWER SYSTEMS

3.8.2 AC Sources – Shutdown

LCO 3.8.2 The following AC electrical power sources shall be OPERABLE:

a. One qualified circuit between the offsite transmission network and the onsite AC electrical power distribution subsystem(s) required by LCO 3.8.10, "Distribution Systems – Shutdown"; and

b.1 Two diesel generators (DGs) capable of supplying two safeguards power trains of the onsite AC electrical power distribution subsystem(s) required by LCO 3.8.10; or

b.2. One DG capable of supplying necessary portions of the onsite AC electrical power distribution subsytems required by LCO 3.8.10 provided that:

(a) The reactor has been subcritical for at least 5 days, and

(b) The water level in the refueling cavity is $\geq$ 23 feet above the reactor vessel flange, or there is no fuel in the reactor vessel and the refueling cavity.

APPLICABILITY: MODES 5 and 6,
During movement of irradiated fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required offsite circuit inoperable.	----------NOTE---------- Enter applicable Conditions and Required Actions of LCO 3.8.10, with any required bus de-energized as a result of Condition A. ----------	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A.1 (continued)	A.1 Declare affected required feature(s) with no offsite power available inoperable.	Immediately
	OR	
	A.2.1 Suspend CORE ALTERATIONS.	Immediately
	AND	
	A.2.2 Suspend movement of irradiated fuel assemblies.	Immediately
	AND	
	A.2.3 Initiate action to suspend operations involving positive reactivity additions.	Immediately
	AND	
	A.2.4 Initiate action to restore required offsite power circuit to OPERABLE status.	Immediately

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required DG(s) inoperable	B.1 Suspend CORE ALTERATIONS.	Immediately
	AND	
	B.2 Suspend movement of irradiated fuel assemblies.	Immediately
	AND	
	B.3 Initiate action to suspend operations involving positive reactivity additions.	Immediately
	AND	
	B.4 Initiate action to restore required DG(s) to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.2.1	----------NOTES---------- 1. The following SRs are required to be met but are not required to be performed: SR 3.8.1.3, SR 3.8.1.10, SR 3.8.1.11, and SR 3.8.1.12. 2. Portions of SR 3.8.1.12 regarding an actual or simulated ESF actuation signal are not required to be met. ----------	
	For AC sources required to be OPERABLE, the SRs of Specification 3.8.1, "AC Sources – Operating," except SR 3.8.1.8, SR 3.8.1.9, and SR 3.8.1.13, are applicable.	In accordance with applicable SRs

3.8 ELECTRICAL POWER SYSTEMS

3.8.3 Diesel Fuel Oil and Starting Air

LCO 3.8.3 The stored diesel fuel oil and starting air subsystem shall be within limits for each required diesel generator (DG).

APPLICABILITY: When associated DG is required to be OPERABLE.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each DG.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. ----------NOTE---------- Only applicable in MODES 1, 2, 3 and 4. ---------- One or more DGs with usable fuel oil in associated DG fuel oil storage tank < 5365 gal.	A.1 Declare associated DG inoperable.	Immediately
B. ----------NOTE---------- Only applicable in MODES 5 and 6 and during movement of irradiated fuel. ---------- Total combined usable fuel oil in DG fuel oil storage tanks associated with the operable DG(s) < 5365 gal.	B.1 Declare all DGs inoperable.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. ---------NOTE---------- Only applicable in MODES 1, 2, 3 and 4. ---------- Total useable fuel oil in reserve storage tank(s) < 26,826 gal.	C.1 Declare all DGs inoperable.	Immediately
D. One or more DG fuel oil storage tanks or reserve fuel oil storage tanks with fuel oil total particulates not within limits.	D.1 Restore fuel oil total particulates within limit.	7 days for DG fuel oil storage tank AND 30 days for reserve fuel oil storage tank
E. One or more DG fuel oil storage tanks or reserve fuel oil storage tanks with fuel oil properties other than particulates not within limits.	E.1 Restore fuel oil properties to within limits.	30 days for DG fuel oil storage tank AND 60 days for reserve fuel oil storage tank
F. One or more DGs with starting air receiver pressure < 250 psig and ≥ 90 psig.	F.1 Restore starting air receiver pressure to ≥ 250 psig.	48 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
G. Required Action and associated Completion Time not met. OR One or more DGs diesel fuel oil or starting air subsystem not within limits for reasons other than Condition A, B, C, D, E, or F.	G.1 Declare associated DG inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.3.1	----------NOTE---------- Only required in MODES 1, 2, 3 and 4. ---------- Verify reserve storage tank(s) contain ≥ 26,826 gal of fuel oil reserved for IP3 usage only.	24 hours
SR 3.8.3.2	Verify DG fuel oil storage tanks contain: a. Usable fuel oil volume ≥ 5365 gal in each storage tank when in MODES 1, 2, 3 and 4; and b. Total combined usable fuel oil volume ≥ 5365 gal in any DG fuel oil storage tank(s) that are associated with the operable DG(s) when in MODES 5 and 6 and during movement of irradiated fuel assemblies.	31 days
SR 3.8.3.3	Verify that fuel oil properties of new and stored fuel oil in the DG fuel oil storage tanks are tested and maintained in accordance with the Diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.8.3.4	----------NOTE---------- Only required in MODES 1, 2, 3 and 4. ---------- Verify that fuel oil properties in the reserve storage tank(s) are within limits specified in the Diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program
SR 3.8.3.5	Verify each DG air start receiver pressure is ≥ 250 psig.	31 days
SR 3.8.3.6	Check for and remove accumulated water from each DG fuel oil storage tank.	92 days

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

LCO 3.8.4 The following four DC electrical power subsystems shall be OPERABLE:

Battery 31 and associated Battery Charger;
Battery 32 and associated Battery Charger;
Battery 33 and associated Battery Charger; and
Battery 34.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. DC electrical power subsystem 34 Inoperable.	A.1 Declare Inverter 34 inoperable and take Required Actions specified in LCO 3.8.7, Inverters-Operating.	2 hours
B. One DC electrical power subsystem (31 or 32 or 33) inoperable.	B.1 Restore DC electrical power subsystem to OPERABLE status.	2 hours
C. Required Action and Associated Completion Time not met.	C.1 Be in MODE 3. AND --- NOTE ---- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- C.2 Be in MODE 4.	6 hours 12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.4.1	Verify battery terminal voltage on float charge is within the following limits: a. $\geq$ 125.7 V for battery 31; b. $\geq$ 123.5 V for battery 32; and c. $\geq$ 127.8 V for batteries 33 and 34.	31 days
SR 3.8.4.2	----------NOTE---------- This Surveillance shall not normally be performed in MODE 1, 2, 3, or 4. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. ---------- Verify each battery charger supplies its associated battery at the voltage and current adequate to demonstrate battery charger capability requirements are met.	24 months
SR 3.8.4.3	----------NOTES---------- This Surveillance shall not be performed in MODE 1, 2, 3, or 4. ---------- Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test or a modified performance discharge test.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.8.4.4	----------NOTE---------- This Surveillance shall not be performed in MODE 1, 2, 3, or 4. ---------- Verify battery capacity is ≥ 80% of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.	60 months AND 12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating AND 24 months when battery has reached 85% of the expected life with capacity ≥ 100% of manufacturer's rating
SR 3.8.4.5	Verify battery cells, cell plates, and racks show no visual indication of physical damage or abnormal deterioration.	24 months

3.8 ELECTRICAL POWER SYSTEMS

3.8.5 DC Sources – Shutdown

LCO 3.8.5 DC electrical power subsystems shall be OPERABLE to support the DC electrical power distribution subsystems required by LCO 3.8.10, "Distribution Systems – Shutdown."

APPLICABILITY: MODES 5 and 6,
During movement of irradiated fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more required DC electrical power subsystems inoperable.	A.1	Declare affected required feature(s) inoperable.	Immediately
	OR		
	A.2.1	Suspend CORE ALTERATIONS.	Immediately
	AND		
	A.2.2	Suspend movement of irradiated fuel assemblies.	Immediately
	AND		
	A.2.3	Initiate action to suspend operations involving positive reactivity additions.	Immediately
	AND		

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.4 Initiate action to restore required DC electrical power subsystems to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.5.1	----------NOTE---------- The following SRs are not required to be performed: SR 3.8.4.2, SR 3.8.4.3, and SR 3.8.4.4. ---------- For DC sources required to be OPERABLE, the following SRs are applicable: SR 3.8.4.1 SR 3.8.4.3 SR 3.8.4.2 SR 3.8.4.4.	In accordance with applicable SRs

3.8 ELECTRICAL POWER SYSTEMS

3.8.6 Battery Cell Parameters

LCO 3.8.6 Battery cell parameters for batteries 31, 32, 33 and 34 shall be within the limits of Table 3.8.6-1.

APPLICABILITY: When associated DC electrical power subsystems are required to be OPERABLE.

ACTIONS

----------NOTE----------
Separate Condition entry is allowed for each battery.

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One or more batteries with one or more battery cell parameters not within Category A or B limits.	A.1	Verify pilot cells electrolyte level and float voltage meet Table 3.8.6-1 Category C limits.	1 hour
	AND		
	A.2	Verify battery cell parameters meet Table 3.8.6-1 Category C limits.	24 hours AND Once per 7 days thereafter
	AND		
	A.3	Restore battery cell parameters to Category A and B limits of Table 3.8.6-1.	31 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time of Condition A not met. OR One or more batteries with average electrolyte temperature of the representative cells not within limits of SR 3.8.6.3. OR One or more batteries with one or more battery cell parameters not within Category C values.	B.1 Declare associated battery inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.6.1	Verify battery cell parameters meet Table 3.8.6-1 Category A limits.	31 days
SR 3.8.6.2	Verify battery cell parameters meet Table 3.8.6-1 Category B limits.	92 days
SR 3.8.6.3	Verify average electrolyte temperature of representative cells is within the following limits: a. ≥ 60°F for batteries 31, 32 and 34; and b. ≥ 35°F for battery 33.	92 days

Table 3.8.6-1 (page 1 of 1)
Battery Cell Parameters Requirements

PARAMETER	CATEGORY A: LIMITS FOR EACH DESIGNATED PILOT CELL	CATEGORY B: LIMITS FOR EACH CONNECTED CELL	CATEGORY C: ALLOWABLE LIMITS FOR EACH CONNECTED CELL
Electrolyte Level	> Minimum level indication mark, and ≤ ¼ inch above maximum level indication mark(a)	> Minimum level indication mark, and ≤ ¼ inch above maximum level indication mark(a)	Above top of plates, and not overflowing
Float Voltage	≥ 2.13 V	≥ 2.13 V	> 2.07 V
Specific Gravity(b)(c)	≥ 1.205	≥ 1.195 AND Average of all connected cells > 1.205	Not more than 0.020 below average of all connected cells AND Average of all connected cells ≥ 1.195

(a) It is acceptable for the electrolyte level to temporarily increase above the specified maximum during equalizing charges provided it is not overflowing.

(b) Corrected for electrolyte temperature.

(c) A battery charging current of <2 amps when on float charge is acceptable for meeting specific gravity limits following a battery recharge, for a maximum of 7 days. When charging current is used to satisfy specific gravity requirements, specific gravity of each connected cell shall be measured prior to expiration of the 7 day allowance.

3.8 ELECTRICAL POWER SYSTEMS

3.8.7 Inverters – Operating

LCO 3.8.7 Inverters 31, 32, 33 and 34 shall be OPERABLE; and
Two constant voltage transformers (CVTs) capable of supplying 120 V AC vital instrument bus (VIB) 34 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

---------- NOTE ----------
Enter applicable Conditions and Required Actions of LCO 3.8.9, "Distribution Systems - Operating" with any required bus de-energized.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required CVT inoperable.	A.1 Restore CVT to OPERABLE status.	30 days
B. Two required CVTs inoperable.	B.1 Restore one CVT to OPERABLE status.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One inverter inoperable.	C.1 ----NOTE--------- Only applicable to feature(s) that require power to perform the required safety function. ---------- Declare required feature(s) supported by associated inverter inoperable when the required redundant feature(s) is inoperable.	2 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s)
	AND	
	C.2 Restore inverter to OPERABLE status.	7 days
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3.	6 hours
	AND	
	----- NOTE -- LCO 3.0.4.a is not applicable when entering MODE 4. ----------	
	D.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.7.1	Verify correct inverter voltage, frequency, and alignment to required 120V AC vital instrument buses.	7 days
SR 3.8.7.2	Verify manual transfer of the AC power source for VIB 34 from inverter 34 to each required CVT.	24 months

3.8 ELECTRICAL POWER SYSTEMS

3.8.8 Inverters – Shutdown

LCO 3.8.8 Inverters shall be OPERABLE to support the onsite 120 V AC vital instrument bus (VIB) electrical power distribution subsystems required by LCO 3.8.10, "Distribution Systems – Shutdown."

APPLICABILITY: MODES 5 and 6,
During movement of irradiated fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required inverters inoperable.	A.1 Declare affected required feature(s) inoperable.	Immediately
	OR	
	A.2.1 Suspend CORE ALTERATIONS.	Immediately
	AND	
	A.2.2 Suspend movement of irradiated fuel assemblies.	Immediately
	AND	
	A.2.3 Initiate action to suspend operations involving positive reactivity additions.	Immediately
	AND	
		(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.4 Initiate action to restore required inverters to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.8.1	---------- NOTE ---------- Frequency verification not required to be performed for inverter 34. ---------- Verify correct inverter voltage, frequency, and alignments to required 120 V AC vital instrument buses.	7 days

3.8 ELECTRICAL POWER SYSTEMS

3.8.9 Distribution Systems – Operating

LCO 3.8.9 AC, DC, and 120 V AC vital instrument bus VIB electrical power distribution subsystems for safeguards power trains 5A, 6A and 2A/3A shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One AC electrical power distribution subsystem inoperable with no loss of safety function.	A.1 Restore AC electrical power distribution subsystem to OPERABLE status.	8 hours AND 16 hours from discovery of failure to meet LCO
B. One VIB inoperable with no loss of safety function.	B.1 Restore VIB to OPERABLE status.	2 hours AND 16 hours from discovery of failure to meet LCO

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One DC electrical power distribution subsystem inoperable with no loss of safety function.	C.1 Restore DC electrical power distribution subsystem to OPERABLE status.	2 hours AND 16 hours from discovery of failure to meet LCO
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3. AND ----- NOTE ------- LCO 3.0.4.a is not applicable when entering MODE 4. ---------- D.2 Be in MODE 4.	6 hours 12 hours
E. One or more trains with inoperable distribution subsystems that result in a loss of safety function.	E.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.9.1 Verify correct breaker alignments and voltage to required AC, DC, and VIB electrical power distribution subsystems.	7 days

3.8 ELECTRICAL POWER SYSTEMS

3.8.10 Distribution Systems – Shutdown

LCO 3.8.10 The necessary portion of AC, DC, and 120 V AC vital instrument bus (VIB) electrical power distribution subsystems shall be OPERABLE to support equipment required to be OPERABLE.

APPLICABILITY: MODES 5 and 6,
During movement of irradiated fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required AC, DC, or AC vital instrument bus electrical power distribution subsystems inoperable.	A.1 Declare associated supported required feature(s) inoperable. OR	Immediately
	A.2.1 Suspend CORE ALTERATIONS. AND	Immediately
	A.2.2 Suspend movement of irradiated fuel assemblies. AND	Immediately
	A.2.3 Initiate action to suspend operations involving positive reactivity additions. AND	Immediately

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.4 Initiate actions to restore required AC, DC, and AC vital instrument bus electrical power distribution subsystems to OPERABLE status. AND	Immediately
	A.2.5 Declare associated required residual heat removal subsystem(s) inoperable and not in operation.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.10.1	Verify correct breaker alignments and voltage to required AC, DC, and 120 V AC vital instrument bus (VIB) electrical power distribution subsystems.	7 days

3.9 REFUELING OPERATIONS

3.9.1 Boron Concentration

LCO 3.9.1 Boron concentrations of the Reactor Coolant System and the refueling cavity shall be maintained within the limit specified in the COLR.

APPLICABILITY: MODE 6.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Boron concentration not within limit.	A.1 Suspend CORE ALTERATIONS.	Immediately
	AND	
	A.2 Suspend positive reactivity additions.	Immediately
	AND	
	A.3 Initiate action to restore boron concentration to within limit.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.1.1	Verify boron concentration is within the limit specified in COLR.	72 hours

3.9 REFUELING OPERATIONS

3.9.2 Nuclear Instrumentation

LCO 3.9.2 Two source range neutron flux monitors shall be OPERABLE.

APPLICABILITY: MODE 6.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. One required source range neutron flux monitor inoperable.	A.1	Suspend CORE ALTERATIONS.	Immediately
	AND		
	A.2	Suspend positive reactivity additions.	Immediately
B. Two required source range neutron flux monitors inoperable.	B.1	Initiate action to restore one source range neutron flux monitor to OPERABLE status.	Immediately
	AND		
	B.2	Perform SR 3.9.1.1.	Once per 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.2.1	Perform CHANNEL CHECK.	12 hours
SR 3.9.2.2	----------NOTE---------- Neutron detectors are excluded from CHANNEL CALIBRATION. ---------- Perform CHANNEL CALIBRATION.	24 months

3.9 REFUELING OPERATIONS

3.9.3 Containment Penetrations

LCO 3.9.3 The containment penetrations shall be in the following status:

a. The equipment hatch closed and held in place by at least four bolts or the equipment hatch opening is closed using an equipment hatch closure plate that may include a personnel access door that is capable of being closed;

b. One door in each air lock is capable of being closed;

c. Each penetration providing direct access from the containment atmosphere to the outside atmosphere either:

1. closed by a manual or automatic isolation valve, a blind flange, or equivalent, or

2. capable of being closed by OPERABLE Containment Purge Isolation System.

---NOTE---
Penetration flow path(s) providing direct access from the containment atmosphere to the outside atmosphere may be unisolated under administrative controls.

APPLICABILITY: During movement of recently irradiated fuel assemblies within containment.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more containment penetrations not in required status.	A.1 Suspend movement of recently irradiated fuel assemblies within containment	Immediately

MAR 17 2003

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.3.1	Verify each required containment penetration is in the required status.	7 days
SR 3.9.3.2	Verify each required containment purge system valve actuates to the isolation position on an actual or simulated actuation signal.	92 days

3.9 REFUELING OPERATIONS

3.9.4 Residual Heat Removal (RHR) and Coolant Circulation - High Water Level

LCO 3.9.4 One RHR loop shall be OPERABLE and in operation.

---NOTE---
The required RHR loop may not be in operation for ≤ 1 hour per 8 hour period, provided no operations are permitted that would cause reduction of the Reactor Coolant System boron concentration.

APPLICABILITY: MODE 6 with the water level ≥ 23 ft above the top of reactor vessel flange.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. RHR loop requirements not met.	A.1	Suspend operations involving a reduction in reactor coolant boron concentration.	Immediately
	AND		
	A.2	Suspend loading irradiated fuel assemblies in the core.	Immediately
	AND		
	A.3	Initiate action to satisfy RHR loop requirements.	Immediately
	AND		
			(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.4 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.4.1	Verify one RHR loop is in operation and circulating reactor coolant at a flow rate of ≥ 1000 gpm.	12 hours

3.9 REFUELING OPERATIONS

3.9.5 Residual Heat Removal (RHR) and Coolant Circulation - Low Water Level

LCO 3.9.5 Two RHR loops shall be OPERABLE, and one RHR loop shall be in operation.

APPLICABILITY: MODE 6 with the water level < 23 ft above the top of reactor vessel flange.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Less than the required number of RHR loops OPERABLE.	A.1 Initiate action to restore required RHR loops to OPERABLE status. OR A.2 Initiate action to establish ≥ 23 ft of water above the top of reactor vessel flange.	Immediately Immediately
B. No RHR loop in operation.	B.1 Suspend operations involving a reduction in reactor coolant boron concentration. AND	Immediately (continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.2 Initiate action to restore one RHR loop to operation. AND	Immediately
	B.3 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.5.1	Verify one RHR loop is in operation and circulating reactor coolant at a flow rate of ≥ 1000 gpm.	12 hours
SR 3.9.5.2	Verify correct breaker alignment and indicated power available to the required RHR pump that is not in operation.	7 days

3.9 REFUELING OPERATIONS

3.9.6 Refueling Cavity Water Level

LCO 3.9.6 Refueling cavity water level shall be maintained ≥ 23 ft above the top of reactor vessel flange.

APPLICABILITY: During CORE ALTERATIONS, except during latching and unlatching of control rod drive shafts,
During movement of irradiated fuel assemblies within containment.

ACTIONS

CONDITION	REQUIRED ACTION		COMPLETION TIME
A. Refueling cavity water level not within limit.	A.1	Suspend CORE ALTERATIONS.	Immediately
	AND		
	A.2	Suspend movement of irradiated fuel assemblies within containment.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.6.1	Verify refueling cavity water level is ≥ 23 ft above the top of reactor vessel flange.	24 hours

4.0 DESIGN FEATURES

4.1 Site Location

Indian Point 3 is located on the east bank of the Hudson River at Indian Point, Village of Buchanan, in upper Westchester County, New York. The site is approximately 24 miles north of the New York City boundary line. The nearest city is Peekskill which is 2.5 miles northeast of Indian Point.

The minimum distance from the reactor center line to the boundary of the site exclusion area and the outer boundary of the low population zone as defined in 10 CFR 100.3 is 350 meters and 1100 meters, respectively.

4.2 Reactor Core

4.2.1 Fuel Assemblies

The reactor shall contain 193 fuel assemblies. Each assembly shall consist of a matrix of Zircalloy or ZIRLO clad fuel rods with an initial composition of natural or slightly enriched uranium dioxide (UO_2) as fuel material. Reload fuel will have a U-235 enrichment of $\leq$ 5.0 weight percent. Limited substitutions of zirconium alloy or stainless steel filler rods for fuel rods, in accordance with approved applications of fuel rod configurations, may be used. Fuel assemblies shall be limited to those fuel designs that have been analyzed with applicable NRC staff approved codes and methods and shown by tests or analyses to comply with all fuel safety design bases. A limited number of lead test assemblies that have not completed representative testing may be placed in nonlimiting core regions.

4.2.2 Control Rod Assemblies

The reactor core shall contain 53 control rod assemblies. The control material shall be silver indium cadmium, as approved by the NRC.

(continued)

4.0 DESIGN FEATURES (continued)

4.3 Fuel Storage

4.3.1 Criticality

4.3.1.1 The spent fuel storage racks are designed and shall be maintained with:

a. Fuel assemblies having a maximum U-235 enrichment of 5.0 weight percent;

b. $k_{eff} \leq 0.95$ if assemblies are inserted in accordance with Technical Specification 3.7.16, Spent Fuel Assembly Storage.

c. A nominal 9.075 inch center to center distance between fuel assemblies placed in the high density fuel storage racks (Region II);

d. A nominal 10.76 inch center to center distance between fuel assemblies placed in low density fuel storage racks (Region I);

4.3.1.2 The new fuel storage racks are designed and shall be maintained with:

a. Fuel assemblies having a maximum U-235 enrichment of 5.0 weight percent;

b. $k_{eff} \leq 0.95$ under all possible moderation conditions (Credit may be taken for burnable integral neutron absorbers);

c. A nominal 20.5 inch center to center distance between fuel assemblies placed in the storage racks.

4.3.2 Drainage

The spent fuel pit is designed and shall be maintained to prevent inadvertent draining of the pool below a nominal elevation of 88 ft.

(continued)

4.0 DESIGN FEATURES

4.3 Fuel Storage (continued)

4.3.3 Capacity

The spent fuel pit is designed and shall be maintained with a storage capacity limited to no more than 1345 fuel assemblies.

5.0 ADMINISTRATIVE CONTROLS

5.1 Responsibility

5.1.1 The plant manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.

The plant manager or his designee shall approve, prior to implementation, each proposed test, experiment or modification to systems or equipment that affect nuclear safety.

5.1.2 The shift supervisor (SS) shall be responsible for the control room command function. During any absence of the SS from the control room while the unit is in MODE 1, 2, 3, or 4, an individual with an active Senior Reactor Operator (SRO) license shall be designated to assume the control room command function. During any absence of the SS from the control room while the unit is in MODE 5 or 6, an individual with an active SRO license or Reactor Operator license shall be designated to assume the control room command function.

5.0 ADMINISTRATIVE CONTROLS

5.2 Organization

5.2.1 Onsite and Offsite Organizations

Onsite and offsite organizations shall be established for unit operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting safety of the nuclear power plant.

a. Lines of authority, responsibility, and communication shall be defined and established throughout highest management levels, intermediate levels, and all operating organization positions. These relationships shall be documented and updated, as appropriate, in organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements, including the plant specific titles of those personnel fulfilling the responsibilities of the positions delineated in these Technical Specifications, shall be documented in the FSAR and Quality Assurance Plan, as appropriate;

b. The plant manager shall be responsible for overall safe operation of the plant and shall have control over those onsite activities necessary for safe operation and maintenance of the plant;

c. The corporate officer with direct responsibility for the plant shall have corporate responsibility for overall plant nuclear safety and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety; and

d. The individuals who train the operating staff, carry out health physics, or perform quality assurance functions may report to the appropriate onsite manager; however, these individuals shall have sufficient organizational freedom to ensure their independence from operating pressures.

(continued)

5.2 Organization

5.2.2 Unit Staff

The unit staff organization shall include the following:

a. A non-licensed operator shall be assigned to each reactor containing fuel and an additional non-licensed operator shall be assigned for each control room from which a reactor is operating in MODES 1, 2, 3, or 4.

b. Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and 5.2.2.a and 5.2.2.f for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.

c. A radiation protection technician shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.

d. Not Used

(continued)

5.2 Organization

5.2.2 Unit Staff (continued)

e. The operations manager or assistant operations manager shall hold an SRO license.

f. When in MODES 1, 2, 3, or 4 an individual shall provide advisory technical support to the unit operations shift crew in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. This individual shall meet the qualifications specified by ANSI/ANS 3.1-1993 as endorsed by RG 1.8, Rev. 3, 2000.

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS 3.1-1978 for comparable positions with exceptions specified in the Entergy Quality Assurance Program Manual (QAPM).

5.3.2 For the purpose of 10 CFR 55.4, a licensed Senior Reactor Operator (SRO) and a licensed Reactor Operator (RO) are those individuals who, in addition to meeting the requirements of TS 5.3.1, perform the functions described in 10 CFR 50.54(m).

5.0 ADMINISTRATIVE CONTROLS

5.4 Procedures

5.4.1 Written procedures shall be established, implemented, and maintained covering the following activities:

a. The applicable procedures recommended in Regulatory Guide 1.33, Revision 2, Appendix A, February 1978;

b. The emergency operating procedures required to implement the requirements of NUREG-0737 and to NUREG-0737, Supplement 1, as stated in Generic Letter 82-33;

c. Quality assurance for effluent and environmental monitoring;

d. Fire Protection Program implementation; and

e. All programs specified in Specification 5.5.

5.0 ADMINISTRATIVE CONTROLS

5.5 Programs and Manuals

The following programs shall be established, implemented, and maintained.

5.5.1 Offsite Dose Calculation Manual (ODCM)

a. The ODCM shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring alarm and trip setpoints, and in the conduct of the radiological environmental monitoring program; and

b. The ODCM shall also contain the radioactive effluent controls and radiological environmental monitoring activities, and descriptions of the information that should be included in the Annual Radiological Environmental Operating, and Radioactive Effluent Release Reports required by Specification 5.6.2 and Specification 5.6.3.

c. Licensee initiated changes to the ODCM:

1. Shall be documented and records of reviews performed shall be retained. This documentation shall contain:

(a) Sufficient information to support the change(s) together with the appropriate analyses or evaluations justifying the change(s), and

(b) A determination that the change(s) maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50, Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations;

2. Shall become effective after the approval of the plant manager; and

3. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Radioactive Effluent Release Report for the period of the report

(continued)

5.5 Programs and Manuals

5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

in which any change in the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the following:

a. Residual Heat Removal System;

b. Cross Connect Between Low Head Recirculation System and High Head Safety Injection System;

c. High Head Safety Injection system (partial);

d. Reactor Coolant Sampling System;

e. Post Accident Containment Air Sampling System;

f. Volume Control Tank (including Reactor Coolant Pump seal return line);

g. Containment Hydrogen Monitoring system.

The program shall include the following:

a. Preventive maintenance and periodic visual inspection requirements; and

b. Integrated leak test requirements for each system at refueling cycle intervals or less.

(continued)

5.5 Programs and Manuals

5.5.3 NOT USED

5.5.4 Radioactive Effluent Controls Program

This program conforms to 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;

b. Limitations on the concentrations of radioactive material released in liquid effluents to unrestricted areas, conforming to 10 times the concentration values in 10 CFR 20, Appendix B, Table 2, Column 2;

c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents in accordance with 10 CFR 20.1302 and with the methodology and parameters in the ODCM;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;

e. Determination of cumulative dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days. Determination of projected dose contributions from radioactive effluents in accordance with the methodology in the ODCM at least every 31 days;

f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;

g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be limited to the following:

   a. For noble gases: Less than or equal to a dose rate of 500 mrem/yr to the whole body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and

   b. For iodine-131, tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to dose rate of 1500 mrem/yr to any organ.

h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and

j. Limitations on the annual dose or dose commitment to any member of the public, beyond the site boundary due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluents Controls Program surveillance frequency.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the FSAR, Section 4.1.5, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Reactor Coolant Pump Flywheel Inspection Program

This program shall provide for the inspection of each reactor coolant pump flywheel. The program shall include inspection frequencies and acceptance criteria. The inspection frequency will ensure that each reactor coolant pump flywheel is surface and volumetrically inspected at 20-year intervals.

(continued)

5.5 Programs and Manuals

5.5.7 Inservice Testing Program

This program provides controls for inservice testing of ASME Code Class 1, 2, and 3 components including applicable supports. The program shall include the following:

a. Testing frequencies applicable to the ASME Code for Operations and Maintenance of Nuclear Power Plants (ASME OM Code) and applicable Addenda as follows:

ASME OM Code and applicable Addenda terminology for inservice testing activities	Required Frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days
Biennially or every 2 years	At least once per 731 days

b. The provisions of SR 3.0.2 are applicable to the above required Frequencies and to other normal and accelerated Frequencies specified as 2 years or less in the Inservice Testing Program for performing inservice testing activities;

c. The provisions of SR 3.0.3 are applicable to inservice testing activities; and

d. Nothing in the ASME OM Code shall be construed to supersede the requirements of any TS.

(continued)

5.5.8 Steam Generator (SG) Program

A Steam Generator Program shall be established and implemented to ensure that SG tube integrity is maintained. In addition, the Steam Generator Program shall include the following:

a. Provisions for condition monitoring assessments. Condition monitoring assessment means an evaluation of the "as found" condition of the tubing with respect to the performance criteria for structural integrity and accident induced leakage. The "as found" condition refers to the condition of the tubing during an SG inspection outage, as determined from the inservice inspection results or by other means, prior to the plugging of tubes. Condition monitoring assessments shall be conducted during each outage during which the SG tubes are inspected or plugged, to confirm that the performance criteria are being met.

b. Performance criteria for SG tube integrity. SG tube integrity shall be maintained by meeting the performance criteria for tube structural integrity, accident induced leakage, and operational LEAKAGE.

1. Structural integrity performance criterion: All in-service steam generator tubes shall retain structural integrity over the full range of normal operating conditions (including startup, operation in the power range, hot standby, and cool down), all anticipated transients included in the design specification and design basis accidents. This includes retaining a safety factor of 3.0 against burst under normal steady state full power operation primary-to-secondary pressure differential and a safety factor of 1.4 against burst applied to the design basis accident primary-to-secondary pressure differentials. Apart from the above requirements, additional loading conditions associated with the design basis accidents, or combination of accidents in accordance with the design and licensing basis, shall also be evaluated to determine if the associated loads contribute significantly to burst or collapse. In the assessment of tube integrity, those loads that do significantly affect burst or collapse shall be determined and assessed in combination with the loads due to pressure with a safety factor of 1.2 on the combined primary loads and 1.0 on axial secondary loads.

2. Accident induced leakage performance criterion: The primary to secondary accident induced leakage rate for any design basis accident, other than a SG tube rupture, shall not exceed the

(continued)

5.5.8 Steam Generator (SG) Program (continued)

leakage rate assumed in the accident analysis in terms of total leakage rate for all SGs and leakage rate for an individual SG. Leakage is not to exceed 0.3 gpm per SG and 1 gpm through all SGs.

3. The operational LEAKAGE performance criterion is specified in LCO 3.4.13, "RCS Operational LEAKAGE."

c. Provisions for SG tube plugging criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.

d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube plugging criteria. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. A degradation assessment shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.

1. Inspect 100% of the tubes in each SG during the first refueling outage following SG installation.

2. After the first refueling outage following SG installation, inspect each SG at least every 72 effective full power months or at least every third refueling outage (whichever results in more frequent inspections). In addition, the minimum number of tubes inspected at each scheduled inspection shall be the number of tubes in all SGs divided by the number of SG inspection outages scheduled in each inspection period as defined in a, b, c and d below. If a degradation assessment indicates the potential for a type of degradation to occur at a location not previously inspected with a technique capable of detecting this type of degradation at this location and that may satisfy the applicable tube plugging criteria, the minimum number of locations inspected with such a capable inspection technique during the remainder of the inspection period may be prorated. The fraction of locations to be inspected for this potential type of degradation at this location at the end of the inspection period shall be no less than the ratio of the number of times the SG is scheduled to be inspected in the inspection period after the determination that a new

(continued)

5.5.8 Steam Generator (SG) Program (continued)

form of degradation could potentially be occurring at this location divided by the total number of times the SG is scheduled to be inspected in the inspection period. Each inspection period defined below may be extended up to 3 effective full power months to include a SG inspection outage in an inspection period and the subsequent inspection period begins at the conclusion of the included SG inspection outage.

a) After the first refueling outage following SG installation, inspect 100% of the tubes during the next 144 effective full power months. This constitutes the first inspection period;

b) During the next 120 effective full power months, inspect 100% of the tubes. This constitutes the second inspection period;

c) During the next 96 effective full power months, inspect 100% of the tubes. This constitutes the third inspection period; and

d) During the remaining life of the SGs, inspect 100% of the tubes every 72 effective full power months. This constitutes the fourth and subsequent inspection periods.

3. If crack indications are found in any SG tube, then the next inspection for each affected and potentially affected SG for the degradation mechanism that caused the crack indication shall not exceed 24 effective full power months or one refueling outage (whichever results in more frequent inspections). If definitive information, such as from examination of a pulled tube, diagnostic non-destructive testing, or engineering evaluation indicates that a crack-line indication is not associated with a crack(s), then the indication need not be treated as a crack.

e. Provisions for monitoring operational primary to secondary LEAKAGE.

```
----------------------NOTE-------------------
Pages 5.0-16 through 5.0-19 are deleted.
Next page is 5.0-20.
---------------------------------------------
```

(continued)

5.5 Programs and Manuals

5.5.9 Secondary Water Chemistry Program

This program provides controls for monitoring secondary water chemistry to inhibit SG tube degradation. The program shall include:

a. Identification of a sampling schedule for the critical variables and control points for these variables;

b. Identification of the procedures used to measure the values of the critical variables;

c. Identification of process sampling points, which shall include monitoring the condenser hot wells for evidence of condenser in leakage;

d. Procedures for the recording and management of data;

e. Procedures defining corrective actions for all off control point chemistry conditions; and

f. A procedure identifying the authority responsible for the interpretation of the data and the sequence and timing of administrative events, which is required to initiate corrective action.

(continued)

5.5 Programs and Manuals

5.5.10 Ventilation Filter Testing Program (VFTP)

This program provides controls for implementation of required testing of the ventilation filter function for the Control Room Ventilation System and Containment Fan Cooler Units.

Applicable tests described in Specifications 5.5.10.a, 5.5.10.b, 5.5.10.c and 5.5.10.d shall be performed:

1) After 720 hours of charcoal adsorber use since the last test; and,

2) Every 24 months for the Control Room Ventilation System, and Containment Fan Cooler Units; and,

3) After each complete or partial replacement of the HEPA filter train or charcoal adsorber filter; and,

4) After any structural maintenance on the system housing that could alter system integrity; and,

5) After significant painting, fire, or chemical release in any ventilation zone communicating with the system while it is in operation.

SR 3.0.2 is applicable to the Ventilation Filter Testing Program.

(continued)

5.5 Programs and Manuals

5.5.10 Ventilation Filter Testing Program (VFTP) (continued)

a. Demonstrate for each system that an inplace test of the high efficiency particulate air (HEPA) filters shows the specified penetration and system bypass leakage when tested in accordance with the referenced standard at the flowrate specified below.

Ventilation System	Removal Efficiency	Flowrate (cfm)	Reference Standard
Control Room Ventilation System	≥ 99%	80% to 120% of design accident rate	Regulatory Guide 1.52, Rev 2, Sections C.5.a and C.5.c
Containment Fan Cooler Units	≥ 99%	80% to 120% of design accident rate	Regulatory Guide 1.52, Rev 2, Sections C.5.a and C.5.c

(continued)

5.5 Programs and Manuals

5.5.10 Ventilation Filter Testing Program (VFTP) (continued)

b. Demonstrate for each system that an inplace test of the charcoal adsorber shows the specified penetration and system bypass leakage when tested in accordance with the referenced standard at the flowrate specified below.

Ventilation System	Removal Efficiency	Flowrate (cfm)	Reference Standard
Control Room Ventilation System	≥ 99%	80% to 120% of design accident rate	Regulatory Guide 1.52, Rev 2, Sections C.5.a and C.5.d
Containment Fan Cooler Units	≥ 99%	80% to 120% of design accident rate	Regulatory Guide 1.52, Rev 2, Sections C.5.a and C.5.d

(continued)

5.5 Programs and Manuals

5.5.10 Ventilation Filter Testing Program (VFTP) (continued)

c. Demonstrate for each system that a laboratory test of a sample of the charcoal adsorber shows the methyl iodide removal efficiency specified below when tested in accordance with ASTM D3803-1989, subject to clarification below, at a temperature of 86°F and a relative humidity of 95%.

Ventilation System	Methyl iodide removal efficiency (%):	ASTM D3803-1989 Clarification
Control Room Ventilation System	≥ 95.5	78 ft/min face velocity
Containment Fan Cooler Units	≥ 85	59 ft/min face velocity

(continued)

5.5 Programs and Manuals

5.5.10 Ventilation Filter Testing Program (VFTP) (continued)

d. Demonstrate for each system that the pressure drop across the combined HEPA filters, the demisters and prefilters (if installed), and the charcoal adsorbers is less than the value specified below when tested at the flowrate specified below.

Ventilation System	Delta P (inches wg)	Flowrate (cfm):
Control Room Ventilation System	6	≥ 90% of design accident rate
Containment Fan Cooler Units	6	≥ 90% of design accident rate

(continued)

5.5 Programs and Manuals

5.5.11 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Waste Gas Holdup System, the quantity of radioactivity contained in gas storage tanks, and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks. The gaseous radioactivity quantities shall be determined following the methodology in Branch Technical Position (BTP) ETSB 11-5, "Postulated Radioactive Release due to Waste Gas System Leak or Failure." The liquid radwaste quantities shall be determined in accordance with Standard Review Plan, Section 15.7.3, "Postulated Radioactive Release due to Tank Failures."

The program shall include:

a. The limits for concentrations of hydrogen and oxygen in the Waste Gas Holdup System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion);

b. A surveillance program to ensure that the quantity of radioactivity contained in each gas storage tank shall be limited to less than the amount that would result in a whole body exposure of $\geq$ 0.5 rem to any individual in an unrestricted area, in the event of an uncontrolled release of the tanks' contents; and

c. A surveillance program to ensure that the quantity of radioactivity contained in all outdoor liquid radwaste tanks that are not surrounded by liners, dikes, or walls, capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste Treatment System is less than the amount that would result in concentrations less than the limits of 10 CFR 20, Appendix B, Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area, in the event of an uncontrolled release of the tanks' contents.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Explosive Gas and Storage Tank Radioactivity Monitoring Program surveillance frequencies.

(continued)

5.5 Programs and Manuals

5.5.12 Diesel Fuel Oil Testing Program

A diesel fuel oil testing program to implement required testing of both new fuel oil and stored fuel oil shall be established for the DG fuel oil onsite storage tanks and the DG reserve fuel oil storage tanks. The program shall include sampling and testing requirements, and acceptance criteria, all in accordance with applicable ASTM Standards. The purpose of the program is to establish the following:

a. Verification of the acceptability of new fuel oil for use prior to addition to the DG fuel oil onsite storage tanks by determining that the fuel oil has:

   1. Relative density within the limits of 0.83 to 0.89,

   2. kinematic viscosity within the limits of 1.8 to 5.8, and

   3. a clear and bright appearance with proper color

b1. Verification of the acceptability of the fuel oil in the onsite storage tanks and the reserve storage tanks every 92 days by verifying that the properties of the fuel oil in the tanks, other than those addressed in item a., are within limits for ASTM2D fuel oil. The sampling technique for the reserve storage tanks may deviate from ASTM D270-1975 in that only a bottom sample is required.

   or

b2. Verification of the acceptability of each new fuel addition made subsequent to the last verification made in accordance with item b1. by verifying within 31 days following the addition that the properties of the new fuel oil, other than those properties addressed in item a. are within limits for ASTM 2D fuel oil.

c. Verification every 92 days that total particulate concentration of the fuel oil in the onsite and reserve storage tanks is less than or equal to 10 mg/l when tested in accordance with ASTM D-2276, Method A-2 or A-3. The sampling technique for the reserve storage tanks may deviate from ASTM D270-1975 in that only a bottom sample is required.

(continued)

5.5 Programs and Manuals

5.5.12 Diesel Fuel Oil Testing Program (continued)

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Diesel Fuel Oil Testing Program testing frequencies.

5.5.13 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.

b. Licensees may make changes to Bases without prior NRC approval provided the changes do not involve either of the following:

1. a change in the TS incorporated in the license; or

2. a change to the updated FSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.

c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the FSAR.

d. Proposed changes that do not meet the criteria of Specification 5.5.13.b above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

5.5.14 Safety Function Determination Program (SFDP)

This program ensures loss of safety function is detected and appropriate actions taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other appropriate actions may be taken as a result of the support system inoperability and corresponding exception to entering supported system Condition and Required Actions. This program implements the requirements of LCO 3.0.6. The SFDP shall contain the following:

(continued)

5.5 Programs and Manuals

5.5.14 Safety Function Determination Program (SFDP) (continued)

a. Provisions for cross train checks to ensure a loss of the capability to perform the safety function assumed in the accident analysis does not go undetected;

b. Provisions for ensuring the plant is maintained in a safe condition if a loss of function condition exists;

c. Provisions to ensure that an inoperable supported system's Completion Time is not inappropriately extended as a result of multiple support system inoperabilities; and

d. Other appropriate limitations and remedial or compensatory actions.

A loss of safety function exists when, assuming no concurrent single failure, a safety function assumed in the accident analysis cannot be performed. For the purpose of this program, a loss of safety function may exist when a support system is inoperable, and:

a. A required system redundant to the system(s) supported by the inoperable support system is also inoperable; or

b. A required system redundant to the system(s) in turn supported by the inoperable supported system is also inoperable; or

c. A required system redundant to the support system(s) for the supported systems (a) and (b) above is also inoperable.

The SFDP identifies where a loss of safety function exists. If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered.

(continued)

5.5 Programs and Manuals

5.5.15 Containment Leakage Rate Testing Program

A program shall be established to implement the leakage rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with NEI 94-01, Revision 2A, "Industry Guideline for Implementing Performance-Based Option of 10 CFR Part 50, Appendix J," October 2008, as modified by the following exception:

ANS 56.8-2002, Section 3.3.1: WCCPPS isolation valves are not Type C tested.

The maximum allowable primary containment leakage rate, L_a, at a minimum test pressure equal to P_a, shall be 0.1% of primary containment air weight per day. P_a is the peak calculated containment internal pressure related to the design basis accident.

Leakage acceptance criteria are:

a. Containment leakage rate acceptance criterion is $\leq$ 1.0 L_a. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are $\leq$ 0.60 L_a for the Type B and C tests and $\leq$ 0.75 L_a for Type A tests;

b. Air lock testing acceptance criteria are:

   1) Overall air lock leakage rate is $\leq$ 0.05 L_a when tested at $\geq$ P_a,

   2) For each door, leakage rate is $\leq$ 0.01 L_a when pressurized to $\geq$ P_a,

c. Isolation Valve Seal Water System leakage rate acceptance criterion is $\leq$ 14,700 cc/hr at $\geq$ 1.1 P_a.

d. Acceptance criterion for leakage into containment from isolation valves sealed with the service water system is $\leq$ 0.36 gpm per fan

(continued)

5.5 Programs and Manuals

5.5.15 Containment Leakage Rate Testing Program (continued)

cooler unit when pressurized at $\geq$ 1.1 P_a. This limit protects the internal recirculation pumps from flooding during the 12-month period of post accident recirculation.

The provisions of SR 3.0.3 are applicable to the Containment Leakage Rate Testing Program.

Nothing in these Technical Specifications shall be construed to modify the testing Frequencies required by 10CFR50, Appendix J.

The calculated peak containment internal pressure for the design basis loss of coolant accident, P_a, is 42.38 psig. The containment design pressure is 47 psig.

The maximum allowable primary containment leakage rate, L_a, at P_a, shall be 0.1% of primary containment air weight per day.

5.5.16 Control Room Envelope Habitability Program

A Control Room Envelope (CRE) Habitability Program shall be established and implemented to ensure that CRE habitability is maintained such that, with an OPERABLE Control Room Ventilation System (CRVS), CRE occupants can control the reactor safely under normal conditions and maintain it in a safe condition following a radiological event, hazardous chemical release, or a smoke challenge. The program shall ensure that adequate radiation protection is provided to permit access and occupancy of the CRE under design basis accident (DBA) conditions without personnel receiving radiation exposures in excess of 5 rem total effective dose equivalent (TEDE) for the duration of the accident. The program shall include the following elements:

(continued)

5.5.16 Control Room Envelope Habitability Program (continued)

a. The definition of the CRE and the CRE boundary.

b. Requirements for maintaining the CRE boundary in its design condition including configuration control and preventive maintenance.

c. Requirements for (i) determining the unfiltered air inleakage past the CRE boundary into the CRE in accordance with the testing methods and at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, "Demonstrating Control Room Envelope Integrity at Nuclear Power Reactors," Revision 0, May 2003, and (ii) assessing CRE habitability at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, Revision 0.

d. Measurement, at designated locations, of the CRE pressure relative to all external areas adjacent to the CRE boundary during the pressurization mode of operation by one train of the CRVS, operating at the flow rate required by the VFTP, at a Frequency of 24 months on a STAGGERED TEST BASIS. The results shall be trended and used as part of the 24 month assessment of the CRE boundary.

e. The quantitative limits on unfiltered air inleakage into the CRE. These limits shall be stated in a manner to allow direct comparison to the unfiltered air inleakage measured by the testing described in paragraph c. The unfiltered air inleakage limit for radiological challenges is the inleakage flow rate assumed in the licensing basis analysis of DBA consequences. Unfiltered air inleakage limits for hazardous chemicals must ensure that exposure of CRE occupants to these hazards will be within the assumptions in the licensing basis.

f. The provisions of SR 3.0.2 are applicable to the Frequencies for assessing CRE habitability, determining CRE unfiltered inleakage, and measuring CRE pressure and assessing the CRE boundary as required by paragraphs c and d, respectively.

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Not Used

5.6.2 Annual Radiological Environmental Operating Report

----------NOTE----------
A single submittal may be made for a multiple unit station. The submittal should combine sections common to all units at the station.

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the radiological environmental monitoring program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

(continued)

5.6 Reporting Requirements

5.6.2 Annual Radiological Environmental Operating Report (continued)

A full listing of the information to be contained in the Annual Radiological Environmental Operating Report is provided in the ODCM.

5.6.3 Radioactive Effluent Release Report

----------NOTE----------
A single submittal may be made for a multiple unit station. The submittal shall combine sections common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

The Radioactive Effluent Release Report covering the operation of the unit in the previous year shall be submitted prior to May 1 of each year in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and Process Control Program and in conformance with 10 CFR Part 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Not Used

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

1. Specification 2.1, Safety Limits (SL);

2. Specification 3.1.1, Shutdown Margin;

3. Specification 3.1.3, Moderator Temperature Coefficient;

4. Specification 3.1.5, Shutdown Bank Insertion Limits;

5. Specification 3.1.6, Control Bank Insertion Limits;

6. Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z));

7. Specification 3.2.2, Nuclear Enthalpy Rise Hot Channel Factor;

8. Specification 3.2.3, AXIAL FLUX DIFFERENCE (AFD);

9. Specification 3.3.1, Reactor Protection System Instrumentation;

10. Specification 3.4.1, RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits; and

11. Specification 3.9.1, Boron Concentration.

b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

1. WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY," July 1985 (W Proprietary). (Specifications 3.1.5, Shutdown Bank Insertion Limits, 3.1.6, Control Bank Insertion Limits, and 3.2.2, Nuclear Enthalpy Rise Hot Channel Factor);

2a. WCAP-8385, "POWER DISTRIBUTION CONTROL AND LOAD FOLLOWING PROCEDURES, TOPICAL REPORT," September 1974 (W Proprietary). (Specification 3.2.3, Axial Flux Difference (AFD) (Constant Axial Offset Control);

2b. T. M. Anderson to K. Kneil (Chief of Core Performance Branch, NRC) January 31, 1980 -- Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package. (Specification 3.2.3, Axial Flux Difference (AFD) (Constant Axial Offset Control));

2c. NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission,Section 4.3,Nuclear Design,July 1981. Branch

(continued)

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981. (Specification 3.2.3, Axial Flux Difference (AFD) (Constant Axial Offset Control));

3. WCAP-12945-P-A, Volume 1 (Revision 2) and Volumes 2 through 5 (Revision 1), "Code Qualification Document for Best-Estimate Loss-of-Coolant-Accident Analysis," March 1998 (Westinghouse Proprietary);

4. WCAP-11397-P-A, "Revised Thermal Design Procedure," April 1989 (Specification 2.1, Safety Limits (SL)) and Specification 3.4.1, (RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits);

5. WCAP-8745-P-A, "Design Bases for the Thermal Overpower ΔT and Thermal Overtemperature ΔT Trip Functions," September 1986 (Specification 2.1, Safety Limits (SL));

6a. WCAP-10054-P-A, "SMALL BREAK ECCS EVALUATION MODEL USING NOTRUMP CODE," (W Proprietary). (Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z));

6b. WCAP-10054-P-A, Addendum 2, Revision 1, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code; Safety Injection into the Broken Loop and Cosi Condensation Model," July 1997 (Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z)));

6c. WCAP-10079-P-A, "NOTRUMP NODAL TRANSIENT SMALL BREAK AND GENERAL NETWORK CODE," (W Proprietary). (Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z)));

7. WCAP-12610, "VANTAGE+ Fuel Assembly Report," (W Proprietary). (Specification 3.2.1, Heat Flux Hot Channel Factor);

8. WCAP-13749-P-A, "Safety Evaluation Supporting the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement," March 1997. (Specification 3.1.3, Moderator Temperature Coefficient);

9. WCAP-16045-P-A, "Qualification of the Two-Dimensional Transport Code PARAGON," August 2004. (Specification 3.1.1, Shutdown Margin, Specification 3.1.3, Moderator Temperature Coefficient, Specification 3.1.5, Shutdown Bank Insertion Limits, Specification 3.1.6, Control Bank Insertion Limits, Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z)), Specification 3.2.2, Nuclear Enthalpy Rise Hot Channel Factor, Specification 3.2.3, Axial Flux Difference (AFD), Specification 3.9.1, Boron Concentration); and

10. WCAP-10965-P-A, "ANC: A Westinghouse Advanced Nodal Computer Code," September 1986. (Specification 3.1.1, Shutdown Margin, Specification 3.1.3, Moderator Temperature Coefficient, Specification 3.1.5, Shutdown Bank Insertion Limits, Specification 3.1.6, Control Bank Insertion Limits, Specification 3.2.1, Heat Flux Hot Channel Factor (FQ(Z)), Specification 3.2.2, Nuclear Enthalpy Rise Hot

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

Channel Factor, Specification 3.2.3, Axial Flux Difference (AFD), Specification 3.9.1, Boron Concentration).

c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.

d. The COLR, including any midcycle revisions or supplements, shall be provided for each reload cycle to the NRC.

5.6.6 NOT USED

(continued)

5.6.7 Post Accident Monitoring Instrumentation (PAM) Report

When a report is required by LCO 3.3.3, "Post Accident Monitoring (PAM) Instrumentation," a report shall be submitted within the next 14 days. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.

5.6.8 Steam Generator Tube Inspection Report

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 5.5.8 Steam Generator (SG) Program. The report shall include:

a. The scope of inspections performed on each SG,

b. Degradation mechanisms found,

c. Nondestructive examination techniques utilized for each degradation mechanism,

d. Location, orientation (if linear), and measured sizes (if available) of service induced indications,

e. Number of tubes plugged during the inspection outage for each degradation mechanism,

f. The number and percentage of tubes plugged to date, and the effective plugging percentage in each SG, and

g. The results of condition monitoring, including the results of tube pulls and in-situ testing.

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

As provided in paragraph 20.1601(c) of 10 CFR Part 20, the following controls shall be applied to high radiation areas in place of the controls required by paragraph 20.1601(a) and (b) of 10 CFR Part 20:

5.7.1 High Radiation Areas with Dose Rates Not Exceeding 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation

a. Each entryway to such an area shall be barricaded and conspicuously posted as a high radiation area. Such barricades may be opened as necessary to permit entry or exit of personnel or equipment.

b. Access to, and activities in, each such area shall be controlled by means of Radiation Work Permit (RWP) or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.

c. Individuals qualified in radiation protection procedures and personnel continuously escorted by such individuals may be exempted from the requirement for an RWP or equivalent while performing their assigned duties provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.

d. Each individual or group entering such an area shall possess:

1. A radiation monitoring device that continuously displays radiation dose rates in the area; or

2. A radiation monitoring device that continuously integrates the radiation dose rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or

3. A radiation monitoring device that continuously transmits dose rate and cumulative dose information to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area, or

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.1 High Radiation Areas with Dose Rates Not Exceeding 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

4. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,

(i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel exposure within the area, or

(ii) Be under the surveillance as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with individuals in the area who are covered by such surveillance.

e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation

a. Each entryway to such an area shall be conspicuously posted as a high radiation area and shall be provided with a locked or continuously guarded door or gate that prevents unauthorized entry, and, in addition:

1. All such door and gate keys shall be maintained under the administrative control of the shift supervisor, radiation protection manager, or his or her designee.

2. Doors and gates shall remain locked except during periods of personnel or equipment entry or exit.

b. Access to, and activities in, each such area shall be controlled by means of an RWP or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.

c. Individuals qualified in radiation protection procedures may be exempted from the requirement for an RWP or equivalent while performing radiation surveys in such areas provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.

d. Each individual or group entering such an area shall possess:

1. A radiation monitoring device that continuously integrates the radiation rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or

2. A radiation monitoring device that continuously transmits dose rate and cumulative dose information to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area with the means to communicate with and control every individual in the area, or

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

3. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,

(i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel exposure within the area, or

(ii) Be under the surveillance as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with and control every individual in the area.

4. In those cases where options (2) and (3), above, are impractical or determined to be inconsistent with the "As Low As is Reasonably Achievable" principle, a radiation monitoring device that continuously displays radiation dose rates in the area.

e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

f. Such individual areas that are within a larger area where no enclosure exists for the purpose of locking and where no enclosure can reasonably be constructed around the individual area need not be controlled by a locked door or gate, nor continuously guarded, but shall be barricaded, conspicuously posted, and a clearly visible flashing light shall be activated at the area as a warning device.