



Exelon Generation®

4300 Winfield Road  
Warrenville, IL 60555  
630 657 2000 Office

RS-18-092

10 CFR 50.90

August 3, 2018

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

Braidwood Station, Units 1 and 2  
Renewed Facility Operating License Nos. NPF-72 and NPF-77  
NRC Docket Nos. STN 50-456 and STN 50-457

Subject: Supplement to License Amendment Request to Utilize the TORMIS Computer Code Methodology

Reference: 1) Letter from David M. Gullott (Exelon Generation Company, LLC) to U.S. NRC, "License Amendment Request to Utilize the TORMIS Computer Code Methodology," dated February 1, 2018

2) Letter from David M. Gullott (Exelon Generation Company, LLC) to U.S. NRC, "Response to Request for Additional Information Regarding Braidwood TORMIS Amendment Request," dated July 9, 2018

In Reference 1, Exelon Generation Company, LLC (EGC) requested an amendment to Renewed Facility Operating License Nos. NPF-72 and NPF-77 for Braidwood Station, Units 1 and 2. In Reference 2, EGC responded to requested additional information to support the review of the subject License Amendment Request.

Attachment 1A of Reference 1, "Summary of Regulatory Commitments" contains one listed Commitment that "Tornado missile protection will be installed on the Unit 1 and Unit 2 RWST hatches." Following the submittal of Reference 1, tornado missile protection for both Unit 1 and Unit 2 RWST hatches was installed. The associated Engineering Change has been closed as of March 1, 2018. The stated Regulatory Commitment in Reference 1 is complete with no further action remaining.

EGC has reviewed the information supporting the No Significant Hazards Consideration and the Environmental Consideration that was previously provided to the NRC in Reference 1. The additional information provided in this submittal does not affect the conclusion that the proposed license amendment does not involve a significant hazards consideration. This additional information also does not affect the conclusion that neither an environmental impact statement nor an environmental assessment need be prepared in support of the proposed amendment.

August 3, 2018  
U.S. Nuclear Regulatory Commission  
Page 2

In accordance with 10 CFR 50.91, "Notice for public comment; State consultation," paragraph (b), EGC is notifying the State of Illinois of this additional information by transmitting a copy of this letter and its attachment to the designated State Official.

There are no new regulatory commitments contained in this letter. Should you have any questions concerning this letter, please contact Ryan M. Sprengel at (630) 657-2814.

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 3rd day of August 2018.

Respectfully,

A handwritten signature in black ink, appearing to read 'D. M. Gullott', followed by a horizontal line extending to the right.

David M. Gullott  
Manager – Licensing  
Exelon Generation Company, LLC

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Braidwood Station  
Illinois Emergency Management Agency