

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO:

Mr. J. G. Keppler

FROM:

Indiana & Michigan Power Company
Bridgman, Michigan
R. W. Jurgensen

DATE OF DOCUMENT

3/4/77

DATE RECEIVED

3/9/77

☒ LETTER
☐ ORIGINAL
☒ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

One signed copy

DESCRIPTION

Ltr. trans the following:

PLANT NAME:

Cook Unit No. 1

(1-P)

ENCLOSURE

Licensee Event Report (RO 50-315/77-07) on
2/2/77 concerning a violation of tech specs
resulting from the operation of the containment
purge and exhaust system without an auto-trip
feature....

ACKNOWLEDGED

(2-P) DO NOT REMOVE

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION 3/9/77

R.JL

☒ BRANCH CHIEF: Ziemann
☒ W/3 CYS FOR ACTION
☒ LIC. ASST.: Diggs
☒ W/ CYS
☒ ACRS 16 CYS HOLDING/SENT: Cat. B. (3/9/77)

INTERNAL DISTRIBUTION

☒ REG FILE
☒ NRC PDR
☒ I & E (2)
☒ MIPC
☒ SCHROEDER/IPPOLITO
☒ HOUSTON
☒ NOVAK/CHECK
☒ GRIMES
☒ CASE
☒ BUTLER
☒ HANAUER
☒ TEDESCO/MACCARY
☒ EISENHUT
☒ BAER
☒ SHAO
☒ VOLLMER/BUNCH
☒ KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

☒ LPDR: St. Joseph, Mich.
☒ TIC:
☒ NSIC:

CONTROL NUMBER

2521 315
A04
60



1950

1950

1950

1950

1950

1950

1950

1950

1950

1950

1950





INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

Regulatory

File Cyt

March 4, 1977



Mr. J. G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137


Operating License DPR-58
Docket No. 50-315

Dear Mr. Keppler:

Pursuant to the requirements of Appendix A Technical Specifications and the United States Nuclear Regulatory Commission Regulatory Guide 1.16, Revision 4, Section 2.a, the following report is submitted:

RO 50-315/77-07

Sincerely,


R. W. Jurgensen
Plant Manager

RWJ/mj

cc: R. S. Hunter
J. E. Dolan
G. E. Lien
R. Kilburn
R. J. Vollen BPI
R. C. Callen MPSC
K. R. Baker RO: III
R. Walsh, Esq.
P. W. Steketee, Esq.
G. Charnoff, Esq.
G. Olson
J. M. Hennigan
PNSRC
R. S. Keith
Dir., IE (40 copies)
Dir., MIPC (4 copies)

2521



100

SUPPLEMENT TO REPORTABLE OCCURRENCE RO-050-315/77-07

SUPPLEMENT TO EVENT DESCRIPTION

CONTAINMENT PURGE SUPPLY AND EXHAUST FANS WERE RUNNING AND THE VENTILATION ISOLATION VALVES WERE OPEN. THE CONTAINMENT PURGE SYSTEM WAS THEN STOPPED AND THE ISOLATION VALVES SHUT. A VIOLATION OF TECHNICAL SPECIFICATION 3.9.9 RESULTED FROM THE OPERATION OF THE CONTAINMENT PURGE AND EXHAUST SYSTEM WITHOUT AN AUTO-TRIP FEATURE.

SUPPLEMENT TO CAUSE DESCRIPTION

AUTOMATIC SAFETY FEATURES WHILE THE TEST WAS IN PROGRESS. THE OPERATORS FAILED TO RECOGNIZE THE REQUIREMENTS OF TECHNICAL SPECIFICATION 3.9.9.

TO PREVENT RECURRENCE, TWO STEPS WILL BE TAKEN:

- 1) THE SURVEILLANCE TEST PROCEDURE IS BEING REVISED AND WILL NOTE THAT THE CONTAINMENT PURGE AND EXHAUST SYSTEM SHOULD BE ISOLATED IF IN THE MODE 6 CONDITION.
- 2) ACTIONS ARE BEING TAKEN TO REQUEST A CHANGE TO THE APPLICABILITY OF TECHNICAL SPECIFICATION 3.9.9 FROM A MODE 6 REQUIREMENT TO "DURING CORE ALTERATIONS OR MOVEMENT OF IRRADIATED FUEL WITHIN THE CONTAINMENT".



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

March 4, 1977

Mr. J. G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137


Operating License DPR-58
Docket No. 50-315

Dear Mr. Keppler:

Pursuant to the requirements of Appendix A Technical Specifications and the United States Nuclear Regulatory Commission Regulatory Guide 1.16, Revision 4, Section 2.a, the following report is submitted:

RO 50-315/77-07

Sincerely,


R. W. Jurgensen
Plant Manager

RWJ/mj

cc: R. S. Hunter
J. E. Dolan
G. E. Lien
R. Kilburn
R. J. Vollen BPI
R. C. Callen MPSC
K. R. Baker RO: III
R. Walsh, Esq.
P. W. Steketee, Esq.
G. Charnoff, Esq.
G. Olson
J. M. Hennigan
PNSRC
R. S. Keith
Dir., IE (40 copies)
Dir., MIPC (4 copies)

MAR 7 1977

[PLEASE PRINT ALL REQUIRED INFORMATION]

GPO 881-567

SUPPLEMENT TO REPORTABLE OCCURRENCE 'RO-050-315/77-07'

SUPPLEMENT TO EVENT DESCRIPTION

CONTAINMENT PURGE SUPPLY AND EXHAUST FANS WERE RUNNING AND THE VENTILATION ISOLATION VALVES WERE OPEN. THE CONTAINMENT PURGE SYSTEM WAS THEN STOPPED AND THE ISOLATION VALVES SHUT. A VIOLATION OF TECHNICAL SPECIFICATION 3.9.9 RESULTED FROM THE OPERATION OF THE CONTAINMENT PURGE AND EXHAUST SYSTEM WITHOUT AN AUTO-TRIP FEATURE.

SUPPLEMENT TO CAUSE DESCRIPTION

AUTOMATIC SAFETY FEATURES WHILE THE TEST WAS IN PROGRESS. THE OPERATORS FAILED TO RECOGNIZE THE REQUIREMENTS OF TECHNICAL SPECIFICATION 3.9.9.

TO PREVENT RECURRENCE, TWO STEPS WILL BE TAKEN:

- 1) THE SURVEILLANCE TEST PROCEDURE IS BEING REVISED AND WILL NOTE THAT THE CONTAINMENT PURGE AND EXHAUST SYSTEM SHOULD BE ISOLATED IF IN THE MODE 6 CONDITION.
- 2) ACTIONS ARE BEING TAKEN TO REQUEST A CHANGE TO THE APPLICABILITY OF TECHNICAL SPECIFICATION 3.9.9 FROM A MODE 6 REQUIREMENT TO "DURING CORE ALTERATIONS OR MOVEMENT OF IRRADIATED FUEL WITHIN THE CONTAINMENT".