

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:  
Mr. Benard C. Rusche

FROM:  
Indiana & Michigan Power Company  
New York, New York  
Mr. John Tillinghast

DATE OF DOCUMENT  
12/17/76

DATE RECEIVED  
12/22/76

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP INPUT FORM

NUMBER OF COPIES RECEIVED  
One signed

DESCRIPTION

Ltr. notorized 12/17/76....w/attached....  
re their 10/19/76 ltr. and our 8/13/76 ltr.  
concerning reactor vessel overpressurization  
events.

ENCLOSURE

**DO NOT REMOVE**

REACTOR VESSEL OVERPRESSURIZATION  
DISTRIBUTION PER G. ZECH 10-21-76

**ACKNOWLEDGED**

(13-P)

PLANT NAME:  
Cook Unit #1

SAFETY

FOR ACTION/INFORMATION 12/27/76

RJL

|   |          |
|---|----------|
| <input checked="" type="checkbox"/> BRANCH CHIEF: (5) | Ziemann  |
| <input checked="" type="checkbox"/> LIC. ASST:        | Fletcher |
| <input checked="" type="checkbox"/> PROJECT MANAGER:  | Diggs    |
|   |          |
|   |          |

INTERNAL DISTRIBUTION

|  |  |  |  |  |  |
|--|--|--|--|--|--|
| <input checked="" type="checkbox"/> REG FILE           |  |  |  |  |  |
| <input checked="" type="checkbox"/> <del>NRC-PDR</del> |  |  |  |  |  |
| <input checked="" type="checkbox"/> I & E (2)          |  |  |  |  |  |
| <input checked="" type="checkbox"/> OELD               |  |  |  |  |  |
| <input checked="" type="checkbox"/> GOSSICK & STAFF    |  |  |  |  |  |
| <input checked="" type="checkbox"/> KNIGHT             |  |  |  |  |  |
| <input checked="" type="checkbox"/> PAWLICKI           |  |  |  |  |  |
| <input checked="" type="checkbox"/> NOVAK              |  |  |  |  |  |
| <input checked="" type="checkbox"/> EISENHUT           |  |  |  |  |  |
| <input checked="" type="checkbox"/> SHAO               |  |  |  |  |  |
| <input checked="" type="checkbox"/> BAER               |  |  |  |  |  |
| <input checked="" type="checkbox"/> BUTLER             |  |  |  |  |  |
| <input checked="" type="checkbox"/> ZECH               |  |  |  |  |  |
|  |  |  |  |  |  |
|  |  |  |  |  |  |
|  |  |  |  |  |  |

EXTERNAL DISTRIBUTION

CONTROL NUMBER

|  |  |  |  |  |  |
|--|--|--|--|--|--|
| <input checked="" type="checkbox"/> LPDR: St. Joseph, Mich.                                |  |  |  |  |  |
| <input checked="" type="checkbox"/> TIC:   |  |  |  |  |  |
| <input checked="" type="checkbox"/> NSIC:  |  |  |  |  |  |
| <input checked="" type="checkbox"/> ACRS 165 CY5 HOLDING/SENT TO <i>Car. B. (12/27/76)</i> |  |  |  |  |  |
|  |  |  |  |  |  |

12919 Misap4  
GD

20

dan

.....

.....

< >

.....

.....

.....

# INDIANA & MICHIGAN POWER COMPANY

P. O. BOX 18  
BOWLING GREEN STATION  
NEW YORK, N. Y. 10004

## REGULATORY DOCKET FILE COPY

December 17, 1976

Donald C. Cook Nuclear Plant Unit No. 1  
Docket No. 50-315  
DPR No. 58

Mr. Benard C. Rusche, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555



Dear Mr. Rusche:

On October 19, 1976, we responded to your letter of August 13, 1976 addressing reactor vessel overpressurization events. In that response we stated that an analysis had been initiated to evaluate the effectiveness of the pressurizer power operated relief valves in mitigating overpressurization transients. We also noted in our letter the general design criteria for the mitigating system. Preliminary evaluations indicated that the pressurizer power operated relief valves would be adequate to mitigate overpressurization events except for inadvertent opening of the accumulator isolation valve. We stated that adequate administrative controls are available for assuring that certain valves are open during power operation and similar administrative controls would provide the necessary protection for the overpressurization event caused by the accumulator isolation valve opening. This letter is intended to provide additional clarification of our proposed course of action and design criteria for the intended mitigating system. To accomplish this clarification of our course of action and design criteria, a "Reference Mitigating System" is described.

We are proceeding with an analysis of overpressurization transient events by employing the LOFTRAN code. Modifications internal to the code are necessary which will require a development and verification effort. The modified LOFTRAN

12919

V. I. Lenin

... ..

... ..

... ..

... ..

... ..

calculational model, when complete, will provide a technically justifiable and conservative means to determine the adequacy of a relief valve system in mitigating an overpressurization event. Until the calculational model is completed and the bounding analysis is performed, size requirements and setpoints for the relief system cannot be accurately established.

Although specific setpoints and relief capacity requirements of the mitigating system are not known at present, meaningful progress towards resolution of the reactor vessel overpressurization issue is being achieved by defining the design criteria requirements of the mitigating system. When the design criteria requirements are confirmed by the completion of the bounding analysis, plant specific design of modifications in accordance with these specified design criteria can be implemented promptly. The time interval to complete resolution of this issue is minimized by a parallel path of analysis and definition of design criteria and we are following this approach.

In your letter of August 13, formal guidance as to the acceptable design criteria was provided on page three. The letter stated:

"The basic criteria to be applied in determining the adequacy of overpressurization protection are that no single equipment failure or single operator error will result in Appendix G limitations being exceeded."

We embraced this criterion in our letter of October 19, 1976. This criterion is the basis for the "Reference Mitigating System" which incorporates the following specific design features:

- a. An existing wide-range pressure transmitter is proposed as the sensor. Additional bistable(s) will be added to provide an "open" signal to the power-operated relief valve(s). Figure 1 provides a logic diagram of the "Reference Mitigating System." Figure 2 presents an instrumentation loop diagram of the pressure monitoring and relief valve actuating equipment. The present control/protection grading of this instrument loop will be retained.

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

( ) ... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

- b. The power operated relief valves, as previously stated, will be utilized as the pressure relief mechanism. These relief valves are spring loaded closed requiring air to open which is presently supplied by a control air source. To assure operability upon the loss of control air which could initiate an overpressurization event by closure of the letdown isolation valves and disable the pressurizer power-operated relief valves, air accumulator(s) will be utilized. The air accumulator(s) will provide a sufficient air supply to the pressurizer power operated relief valve to allow five cycles of the valve following a loss of normal control air.
- c. The present power supplies for the solenoid valves controlling air flow to the pressurizer power-operated relief valves will be retained. Installation of the "Reference Mitigating System" will not compromise the existing separation between DC power sources.
- d. A keylock switch or an equivalent administratively controlled switch will be used to enable and disable the low setpoint of each relief valve. The enable/disable switches will conform to the separation criteria requirements for the DC buses for the Donald C. Cook Nuclear Plant.
- e. Seismic design of the electronic equipment presently installed in the Donald C. Cook Nuclear Plant will be retained. Additional electronic equipment will be installed so as not to compromise the present seismic qualifications of existing safety systems.
- f. The control air supply from the air accumulators will be seismically designed. The pressurizer power-operated relief valves are designed to withstand seismic loading equivalent to 3.0g in the horizontal direction and 2.0g in the vertical direction and retain their function during such loading. The valves will not be degraded by the system modification.

1. The first part of the document is a letter from the Secretary of the Department of the Interior to the Secretary of the Department of the Army. The letter is dated 1864 and is addressed to the Secretary of the Department of the Army, Washington, D.C. The letter is signed by the Secretary of the Department of the Interior, Washington, D.C.

2. The second part of the document is a letter from the Secretary of the Department of the Interior to the Secretary of the Department of the Army. The letter is dated 1864 and is addressed to the Secretary of the Department of the Army, Washington, D.C. The letter is signed by the Secretary of the Department of the Interior, Washington, D.C.

3. The third part of the document is a letter from the Secretary of the Department of the Interior to the Secretary of the Department of the Army. The letter is dated 1864 and is addressed to the Secretary of the Department of the Army, Washington, D.C. The letter is signed by the Secretary of the Department of the Interior, Washington, D.C.

4. The fourth part of the document is a letter from the Secretary of the Department of the Interior to the Secretary of the Department of the Army. The letter is dated 1864 and is addressed to the Secretary of the Department of the Army, Washington, D.C. The letter is signed by the Secretary of the Department of the Interior, Washington, D.C.

5. The fifth part of the document is a letter from the Secretary of the Department of the Interior to the Secretary of the Department of the Army. The letter is dated 1864 and is addressed to the Secretary of the Department of the Army, Washington, D.C. The letter is signed by the Secretary of the Department of the Interior, Washington, D.C.



- g. Testability will be provided. Verification of operability is possible prior to solid system, low temperature operation by use of the remotely operated isolation valve, enable/disable switch and normal electronics surveillance procedure methodology. Testing requirements will be incorporated in the operating procedures to assure performance prior to existence of plant conditions requiring operability of the mitigating system.
- h. Figure 3 presents a typical electrical schematic diagram which would be used for each pressurizer power operated relief valve. The additional pressure channel's bistable contact or auxiliary relay contact and the enable/disable switch addressed in "d" above are included.
- i. The loss of an instrument power bus will not result in an isolation of letdown flow and disabling of the "Reference Mitigating System."

These design criteria for the "Reference Mitigating System" should be agreed to by completion of the analysis to minimize the time until complete installation of an acceptable system is accomplished. We have inquired as to the availability of electrical and mechanical equipment required for the "Reference Mitigating System." According to vendors' estimates, delivery of additional equipment needed for the "Reference Mitigating System" could be expected within six months of order placement.

It is our desire to resolve this matter by the end of 1977. This goal and the fact that analysis completion is scheduled for the end of March 1977, equipment delivery may require an additional six months, and installation and testing at the Donald C. Cook Nuclear Plant will require more time, makes it imperative that the design criteria include sufficient flexibility to assure accomplishment of desired prevention of overpressurization transients. Two pressurizer relief valves may be necessary to mitigate the worse case overpressurization event to be analyzed in our bounding analysis.



Contingencies of this nature were considered in selection of design criteria. The "Reference Mitigating System" design includes conformance to the guidelines of your August 13, 1976 letter, provides for the maximum pressure relief possible with available mechanical equipment, and could be installed by the end of 1977.

Following the installation of plant modifications and related administrative controls, the probability of ever exceeding Appendix G limits is significantly reduced. In the unlikely event that an overpressurization incident should occur, however, the installation of the subject mitigating system assures that the consequences of such an incident would be significantly reduced. As a result, any adverse consequences with respect to vessel integrity would be negligible. Because large safety margins exist between actual conditions observed during overpressurization incidents and conditions required to assure reactor vessel integrity, exceeding Appendix G limits does not imply loss of vessel integrity.

The impact on the vessel of an overpressurization incident can be best evaluated by performing specific analyses which employ reasonable assumptions in terms of flaw size, integrated neutron fluence, reactor vessel material properties and actual plant data available at the time of the event. This approach relates the stress field developed in the vicinity of the assumed flaw to the applied stress on the structure, material properties, and the size of the defect which would cause failure.

With the installation of the subject mitigating system, it is expected that overpressurization incidents will not occur. However, should such an event occur, we will not resume normal plant operation until we have taken the action required in our current Technical Specification 3/4.4.9. Further, a report of the incident will be filed with the Nuclear Regulatory Commission and an analysis will be available for review.

In our October 19, 1976 letter, we also stated that administrative controls were in force at the Donald C. Cook Nuclear Plant to prevent inadvertent overpressurization of the reactor coolant system by the safety injection accumulators.

... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..


These administrative controls include closing the accumulator injection valves and locking out power to the valve motors during cooldown at Reactor Coolant System Pressure of 1000 psig. Specific procedural verification of valve status and motor breaker status, as now used to verify that the valves are open and power to the motors unavailable, is incorporated in the plant procedures to verify that the valves are closed and power to the motors unavailable.

The steady state flow capacities of typical pressurizer power operated relief valves and the mass injection rates for typical 4 loop Westinghouse plants are provided in Figures 4 and 5, respectively. It is noted that the steady state relief capacity of a single pressurizer power-operated relief valve is of the approximate capacity necessary to compensate for steady state safety injection flow. Although the steady state flow rates appear consistent, transient analyses are necessary to assure capability of the system. Figure 6 presents the typical flow vs. valve plug position relationships which will be incorporated in the analysis.


In summary, the "Reference Mitigating System" design incorporates the guidance of your letter, employs installed plant equipment to avoid equipment procurement delays to the extent possible and provides the maximum pressure relief available. The "Reference Mitigating System," with the ability to verify its functional status prior to establishment of plant conditions where operability of the system is required, coupled with increased administrative control requirements on the accumulator isolation valves, will provide assurance that consequences of an overpressurization event will be mitigated.

Our objective to have a system in operation by the end of 1977 will require NRC review and approval of our design criteria on a timely basis.

Very truly yours,

  
John Tillinghast  
Vice President

Sworn and subscribed to before me  
on this 17th day of December 1976  
in New York County, New York

  
Notary Public

KATHLEEN BARRY,  
NOTARY PUBLIC, State of New York  
No. 41-4605792  
Qualified in Queens County  
Certificate filed in New York County  
Commission expires March 30, 1977

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

101  
102  
103  
104  
105  
106  
107  
108  
109  
110  
111  
112  
113  
114  
115  
116  
117  
118  
119  
120  
121  
122  
123  
124  
125  
126  
127  
128  
129  
130  
131  
132  
133  
134  
135  
136  
137  
138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181  
182  
183  
184  
185  
186  
187  
188  
189  
190  
191  
192  
193  
194  
195  
196  
197  
198  
199  
200

201  
202  
203  
204  
205  
206  
207  
208  
209  
210  
211  
212  
213  
214  
215  
216  
217  
218  
219  
220  
221  
222  
223  
224  
225  
226  
227  
228  
229  
230  
231  
232  
233  
234  
235  
236  
237  
238  
239  
240  
241  
242  
243  
244  
245  
246  
247  
248  
249  
250  
251  
252  
253  
254  
255  
256  
257  
258  
259  
260  
261  
262  
263  
264  
265  
266  
267  
268  
269  
270  
271  
272  
273  
274  
275  
276  
277  
278  
279  
280  
281  
282  
283  
284  
285  
286  
287  
288  
289  
290  
291  
292  
293  
294  
295  
296  
297  
298  
299  
300

301  
302  
303  
304  
305  
306  
307  
308  
309  
310  
311  
312  
313  
314  
315  
316  
317  
318  
319  
320  
321  
322  
323  
324  
325  
326  
327  
328  
329  
330  
331  
332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343  
344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363  
364  
365  
366  
367  
368  
369  
370  
371  
372  
373  
374  
375  
376  
377  
378  
379  
380  
381  
382  
383  
384  
385  
386  
387  
388  
389  
390  
391  
392  
393  
394  
395  
396  
397  
398  
399  
400

401  
402  
403  
404  
405  
406  
407  
408  
409  
410  
411  
412  
413  
414  
415  
416  
417  
418  
419  
420  
421  
422  
423  
424  
425  
426  
427  
428  
429  
430  
431  
432  
433  
434  
435  
436  
437  
438  
439  
440  
441  
442  
443  
444  
445  
446  
447  
448  
449  
450  
451  
452  
453  
454  
455  
456  
457  
458  
459  
460  
461  
462  
463  
464  
465  
466  
467  
468  
469  
470  
471  
472  
473  
474  
475  
476  
477  
478  
479  
480  
481  
482  
483  
484  
485  
486  
487  
488  
489  
490  
491  
492  
493  
494  
495  
496  
497  
498  
499  
500

Mr. Benard C. Rusche

- 7 -

December 17, 1976

cc: G. Charnoff  
R. J. Vollen  
R. C. Callen  
P. W. Steketee  
R. Walsh  
R. S. Hunter  
R. W. Jurgensen - Bridgman




1950



FIGURE 1

LOGIC DIAGRAM  
POWER OPERATED RELIEF VALVE







FIGURE 2

WIDE RANGE PRESSURE SIGNAL







FIGURE 3

TYPICAL POWER OPERATED RELIEF VALVE CIRCUIT





13 2 1222 1222

Water Flow (gpm)

1600  
1400  
1200  
1000  
800  
600  
400  
200  
0




FIGURE 4  
POWER OPERATED RELIEF VALVE  
FLOW CAPACITY PER VALVE  
FULL OPEN  
(Typical)

0 200 400 600 800 1000

Differential Pressure (psi)






FIGURE 5  
SAFETY INJECTION SYSTEM FLOW

4 Loop Plant  
2 SI Pumps  
2 Charging Pumps  
(Typical)

Reactor Coolant Pressure (psi)

2800

2400

2000

1600

1200

800

400

0

0

400


800

1200

1600

2000

Flow Into Reactor Vessel (gpm)







FIGURE 6  
POWER OPERATED RELIEF VALVE  
FLOW CHARACTERISTICS  
(Typical)





1  
2  
3  
4  
5  
6  
7  
8  
9  
10

1