

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactors Safeguards
Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, July 11, 2018

Work Order No.: NRC-3805

Pages 1-335

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

655th MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

WEDNESDAY

JULY 11, 2018

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael L.
Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL L. CORRADINI, Chairman

RONALD G. BALLINGER, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

MARGARET SZE-TAI Y. CHU, Member

VESNA B. DIMITRIJEVIC, Member

1 WALTER L. KIRCHNER, Member
2 JOSE MARCH-LEUBA, Member
3 HAROLD B. RAY, Member
4 JOY L. REMPE, Member
5 PETER RICCARDELLA, Member
6 GORDON R. SKILLMAN, Member
7 MATTHEW SUNSERI, Member

8
9 DESIGNATED FEDERAL OFFICIALS:

10 CHRISTOPHER BROWN
11 WEIDONG WANG
12 KATHY WEAVER

13 ALSO PRESENT:

14 HUDA AKHAVANNIK, NRR
15 ROSSNYEV ALVARADO, NRR
16 STEVEN ARNDT, NRR
17 SURINDER ARORA, NRO
18 AYO AYEGBUSI, NRO
19 ANTONIO BARRETT, NRO
20 LUIS BETANCOURT, NRO
21 SUSHIL BIRLA, RES
22 JOSH BORROMEO, NRR
23 ERIC BOWMAN, OCM
24 ANNA BRADFORD, NRO
25 MIKE BREACH, NRR

1 ALEXANDRA BURJA, NRO
2 LUISSETTE CANDELARIO QUINTANA, NRO
3 HAROLD CHERNOFF, NRR
4 NAN CHIEN, NRO
5 JEFF CIOCCO
6 MICHAEL COOK, GE Hitachi
7 SAMIR DARBALI, NRR
8 MARK DeWIRE, BSEP
9 THINH DINH, NRO
10 BERNARD DITTMAN, RES
11 TIM DRZEWIECKI, NRO
12 ISMAEL GARCIA, NRO
13 JAMES GILMER, NRO
14 RAJ GOEL, NRO
15 BRIAN GREEN, NRO
16 DAN GREEN, TVA
17 RALPH GRUMMER, Farawila, et al.
18 MAURICIO GUTIERREZ, RES
19 SYED HAIDER, NRO
20 NICHOLAS HANSING, NRO
21 MICHELLE HAYES, NRO
22 RAUL HERNANDEZ, NRO
23 SEUNGJU HAN, KHNP
24 ANDY HON, NRR
25 JOHN HONCHARIK, NRO

1 BRIAN HUGHES, NRO
2 SEOKHWAN HUR, KEPCO E&C
3 ATA ISTAR, NRO
4 DIANE JACKSON, NRO/SCVB
5 JAE HOON JEONG, KEPCO
6 SUNGHUAN JUN, KEPCO E&C
7 REBECCA KARAS, NRO
8 MARYAM KHAN, NRO
9 JUNGHO KIM, KHNP
10 TAEHAN KIM, KHNP/KEPCO E&C
11 YUNHO KIM, KHNP
12 RONALD KING, TVA
13 TATSURO KOBAYASHI, TEPCO
14 ROBERT KRSEK, OCM
15 HIEN LE, NRO
16 TUAN LE, NRO
17 KIWON LEE, Doosan
18 YUEH-LI LI, NRO
19 KWANGIL LIM, KEPCO E&C
20 MARK LINTZ, NRO
21 WILL LONG, Duke Energy
22 TIM LUPOLD, NRO
23 GREGORY MAKAR, NRO
24 MICHAEL D. MAZAIKA, NRO
25 MICHAEL McCOPPIN, NRO

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ALAN MEGINNIS, Framatome
2 JILL MONAHAN, Westinghouse
3 WENDELL MORTON, NRR
4 JEFF NOLIN, BSEP
5 CHANG-SOK OH, KNF
6 JONATHAN ORTEGA-LUCIANO, NRO
7 SUNWOO PARK, NRO
8 PRAVIN PATEL, NRO
9 HANH PHAN, NRO
10 DAVID RAHN, NRR
11 SHEILA RAY, NRR
12 FARIDEH SABA, NRR
13 AHSAN SALLMAN, NRR
14 CAYETANO SANTOS, NRO
15 THOMAS SCARBROUGH, NRO
16 MOHAMED SHAMS, Office of Commissioner Wright
17 JOHN SIPHERS, Duke Energy
18 ROB SISK, Westinghouse
19 MATT SMITH, Westinghouse
20 MICHAEL SMITH, NRR
21 RICHARD STATTEL, NRR
22 ED STUTZCAGE, NRO
23 DINESH TANEJA, NRO
24 BRIAN THOMAS, RES
25 ROGER L. THOMAS, JR., Duke Energy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VAUGHN THOMAS, NRO
2 BOYCE TRAVIS, NRO
3 NANETTE VALLIERE, COMM/OCMSB
4 ANDREA D. VEIL, ACRS Executive Director
5 BOOMA VENKATARAMAN, NRR
6 HANRY WAGAGE, NRO
7 WILLIAM WARD, NRO
8 MIKE WATERS, NRR
9 JENNIFER WHITMAN, NRR
10 STEVE WILLIAMS, NRO
11 TOM WILLIAMSON, Duke Energy
12 GEORGE WUNDER, NRO
13 ANDREW YESHNIK, NRO
14 STEPHEN YODERSMITH, BSEP
15 DEANNA ZHANG, NRR
16
17
18
19
20
21
22
23
24
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

C O N T E N T S

Call to Order and Opening 8

Brunswick Steam Electric Plant, Units 1 and . . . 9

2, MELLLA+ Application

Licensee Presentation 10

Staff Presentation 30

Opportunity for Public Comment 39

Digital Instrumentation and Controls 39

Interim Staff Guidance-06, "Licensing
Process" Draft Revision 2, and
Integrated Action Plan for Modernization
of the NRC's Digital I&C Regulatory Structure
Staff Presentation 41

Opportunity for Public Comment 117

APR 1400: Selected Safety Evaluations Associated
with Reactor Design Application 118

Public Comment 184

Adjourn 187

P R O C E E D I N G S

8:29 a.m.

CHAIR CORRADINI: Okay, the meeting will now come to order. This is the first day of the 655th meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: Brunswick Steam Electric Plant, Units 1 and 2, MELLLA+ application; Digital Instrumentation and Controls Interim Staff Guidance 06; APR1400 Safety Evaluations associated with the reactor design application, and preparations of ACRS reports.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act, or FACA. As such, this meeting is being conducted in accordance with the provisions of FACA. That means that the Committee can only speak through its published letter reports. We hold meetings to gather information to support our deliberations.

Interested parties who wish to provide comments can contact our offices requesting time after The Federal Register notice describing a meeting is published. That said, we have set aside 10 minutes for extemporaneous comments from members of the public attending or listening to our meetings. Written

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comments are also welcome.

2 Mr. Weidong Wang is the Designated Federal
3 Official for the initial portion of this meeting.

4 Portions of the sessions of the Brunswick
5 MELLLA+ and APR1400 Safety Evaluations associated with
6 reactor design application may be closed in order to
7 discuss and protect designated information that is
8 proprietary.

9 The ACRS section of the U.S. NRC public
10 website provides our charter, bylaws, letter reports,
11 and full transcripts of all full and subcommittee
12 meetings, including all slides presented to the
13 meeting.

14 We've received no written comments or
15 requests to make oral statements from members of the
16 public regarding today's session.

17 There will be a phone bridgeline open. To
18 preclude interruption, the phone will in a listen-in-
19 only mode during the presentations and Committee
20 discussions.

21 A transcript of a portion of the meeting
22 is being kept, and it is requested that speakers use
23 the microphones, identify themselves, and speak with
24 sufficient clarity and volume, so they may be readily
25 heard.

1 Also, just to remind everybody, could you
2 please silence your cell phones or turn off your
3 devices, so we don't get interrupted by any sort of
4 noises?

5 So, I'll turn this over to Dr. Rempe to
6 lead us through the first portion of the meeting.

7 MEMBER REMPE: Thanks, Mike.

8 So, May 16th, the Power Uprates
9 Subcommittee reviewed the license amendment request
10 and the associated NRC Draft Safety Evaluation for the
11 Brunswick Steam Electric Plant to operate in the
12 expanded Maximum Extended Load Line Limit Analysis
13 plus domain. This is the fifth plant to submit an LAR
14 for operation in the MELLLA+ domain, but the first to
15 rely on GEH methods with Framatome, formerly AREVA,
16 ATRIUM 10XM fuel.

17 On May 15th, the Thermal-Hydraulic
18 Subcommittee reviewed results from confirmatory plant-
19 specific TRACE/PARCS calculations that the staff
20 completed to assist them in their evaluation of this
21 application. At the end of our May 16th meeting, the
22 Subcommittee concluded that this request was ready for
23 consider by the full Committee.

24 And at this point, I would like to ask,
25 Andy, are you the one who is going to start or is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there someone else?

2 MR. HON: No, the licensee is going to
3 start.

4 MEMBER REMPE: Oh, okay. I would like to
5 licensee to please come forward and start our
6 discussion.

7 MR. NOLIN: Good morning. I'm Jeff Nolin.
8 I'm the General Manager of Engineering at Brunswick
9 Nuclear Plant.

10 I would like to thank you for providing us
11 the opportunity to come and discuss the license
12 amendment for Brunswick's implementation of MELLLA+,
13 to answer questions, and talk about our readiness for
14 implementation of the project.

15 The objectives of what we would like to
16 talk about today include why we're pursuing the
17 implementation of MELLLA+; describe some of the key
18 aspects of it; discuss readiness and talk about our
19 intentions for implementation timing.

20 Relative to the timing, Brunswick is
21 looking to implement the MELLLA+ on both Unit 1 and
22 Unit 2 in the fall of 2018. Some of the operating
23 parameters that we're working with: Unit 2 has a
24 planned refueling outage in the spring of 2019.
25 Because of the timing of the Unit 2 fuel cycle, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will be entering a number of deep downpowers for end
2 of cycle and final feedwater temperature reduction in
3 the fall. So, we're looking to implement in the third
4 quarter of 2018 just from an operating preference for
5 the units. We would like to implement both units at
6 the same time to make sure that the operators are
7 working off of a common platform for each unit.

8 A little bit of an overview of Brunswick.
9 Brunswick is a two-unit BWR-4 with a Mark I
10 containment. We are operating, in our license renewal
11 period of extended operation, Brunswick has been
12 operating for 43 and 42 units, respectively. Unit 2
13 is the lead unit.

14 We have been operating with the extended
15 power uprate, 120-percent uprate, since 2004, so 14
16 and 13 years on each unit, which is a little bit
17 different with the MELLLA+ application in that we've
18 been operating with an extended power uprate for more
19 than 13-14 years. And so, this is really an
20 application for MELLLA+ as opposed to a power uprate
21 with MELLLA+. So, it's a little bit different than
22 some of the other license amendments that have been
23 submitted previously.

24 We operate with a 24-month operating
25 cycle. We've transitioned to Framatome fuel in 2008-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2009. So, again, about a decade of operation with
2 Framatome fuel, and we have full-core ATRIUM 10XM fuel
3 right now. We've been on ATRIUM 10XM fuel since the
4 2011-2012 transition.

5 The Brunswick plant, the background of the
6 plant, with the extended power uprate, we dramatically
7 reduced the flow window that the plant operates on
8 from approximately 24 percent to a 6-percent flow
9 window. So, MELLLA+ restores the operating margin for
10 the plant. The primary drivers for that are fuel
11 reactivity manipulations for the operators associated
12 with those downpowers. There are some side benefits
13 relative to recirc pump operation, that the extended
14 operation of that we believe will help recirc pump
15 reliability as well.

16 Finally, relative a project of
17 implementation readiness, we've completed the plant
18 modifications to increase our standby liquid control
19 tanks from enrichment of 47-percent to 92-percent B-10
20 enrichment. Those were completed in 2016 and 2017.
21 We've also implemented the modifications to the e-
22 prompts for the power range monitors. Those were
23 completed in 2016 as well. The operators have
24 performed introduction training and, then, more
25 detailed training on MELLLA+, including simulator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sessions with the MELLLA+ operating domain, and we'll
2 have more discussion on that in subsequent slides.

3 Our phase 2 implementation of the project
4 will include update of procedures and tech specs, the
5 engineering changes. We'll transition our stability
6 solution to the DSS-CD option with the implementation.

7 The implementation will also include a
8 period of special testing to verify thermal-hydraulic
9 stability. That's a series of five points on each
10 unit that we will run through and collect data,
11 including level and pressure perturbations to verify
12 stability. And that will be part of the tech spec
13 implementation.

14 With that, I'll turn it over to Mr.
15 Siphers for the design discussion.

16 MR. SIPHERS: Okay. Good morning. My
17 name is John Siphers. I'm General Manager of Nuclear
18 Fuel Design for Duke Energy, and I would like to
19 describe some of the analyses that went into the LAR
20 that we submitted for MELLLA+.

21 As was previously stated, we have a little
22 bit of a different structure than is typically seen
23 for MELLLA+ applications. We are using the GEH
24 Topical Report for MELLLA+, but we have Framatome
25 fuel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In doing the analysis required by the LAR,
2 we have done all of those analyses, but they required
3 different vendors to do the different piece parts of
4 that analysis to complete the full set. GE provided
5 the overall plant response, specifically ATWS and
6 ATWSI and stability solution work, and Framatome
7 performed the remainder of the analyses, the kind of
8 typical analyses that are done on a reload-by-reload
9 basis to quantify the fuel design attributes each
10 cycle.

11 And as Jeff mentioned earlier, both
12 vendors have had a long history of support for the
13 Brunswick plant. We used GE fuel from initial startup
14 up to and through our power uprate, and we
15 transitioned to Framatome fuel in 2008 and have been
16 using Framatome fuel ever since. So, we've been in a
17 position where both vendors are very familiar with the
18 Brunswick plant.

19 One last note here was on the no impact
20 that was noted in the MELLLA+ Topical Report from ECCS
21 net positive suction head from the implementation of
22 MELLLA+. And therefore, there was no change to the
23 containment accident pressure credit that we
24 originally received in the extended power uprate
25 application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Because of the structure of the project,
2 both vendors doing parts of the analysis, during our
3 pre-submittal meetings there were questions asked
4 about the applicability of GEH methods to Framatome
5 fuel and the applicability of Framatome methods to the
6 MELLLA+ region. Framatome methods have been
7 benchmarked at core conditions at other plants that
8 are equivalent to what we're going to see at Brunswick
9 from a power and flow standpoint. And therefore, the
10 information that we've included in the LAR should
11 allow this SER for Brunswick to be issued without
12 restrictions in those areas. And similarly, the LAR
13 information we presented shows the GEH models were
14 able to accurately represent the Framatome fuel
15 design.

16 One of the ways we did that was that we
17 transferred information directly from Framatome to GE
18 as part of that development. So, GE was allowed to
19 explicitly model the fuel. We also participated in
20 that at Duke Energy by working on the thermal-
21 hydraulic data that went from Framatome to GE, and we
22 had had a history of doing that for many years prior
23 to the MELLLA+ LAR.

24 Following the LAR, during one of the
25 audits, there were some additional questions raised.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in one of the RAIs, we provided some significant
2 comparisons to MELLLA+ predicted core operation and
3 showing the results from GE models and the results
4 from Framatome models, and those were included in one
5 of the RAIs and show excellent agreement between the
6 two models for what would be predicted at Brunswick.

7 One of the more significant areas of focus
8 when operating the MELLLA+ regime, obviously, is the
9 response of the plant when you're on a high power rod
10 line or the high power low-flow conditions. Both the
11 ATWS condition and the potential for ATWS for
12 instability were modeled by GE. And because the
13 analysis, again, was a GE model of a Framatome fuel
14 bundle, GE did a lot of sensitivity cases on fuel
15 parameters that would be important to the outcome of
16 those results. And GE will present a lot more of the
17 information regarding those sensitivity cases later in
18 the GE proprietary session.

19 Also during the MELLLA+ audit, there was
20 a significant amount of discussion with the NRC
21 reviewers on the Tmin model that's used for the
22 results of the ATWSI analysis. And as a result of
23 that discussion, we ran several cases, and had GE run
24 several cases, that compared the results of that
25 model. And that's also going to be presented later in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the proprietary session as well. We believe that
2 those sensitivity cases show that the model
3 effectively analyzes the MELLLA+ operating regime from
4 the standpoint of completely protecting the fuel
5 parameters of concern.

6 A couple of decisions that we made in our
7 implementation of MELLLA+. One decision that we made
8 was that we would transition to the DSS-CD system for
9 thermal-hydraulic instability monitoring during the
10 development. The additional protection that that
11 system offers is the confirmation density algorithm
12 for detection of thermal-hydraulic instability. And
13 in this new software/hardware configuration, that
14 algorithm is really layered on top of all the
15 algorithms that were previously present in the option
16 3 system. So, we believe that that offers us
17 additional confirmation or additional protection
18 against thermal-hydraulic instability. And that will
19 be the licensing basis method that we use going
20 forward.

21 The second decision that we made early on
22 in the project was to ensure the MELLLA+ operating
23 region would not adversely impact the ATWS analysis
24 and to ensure that we elected to significantly
25 increase our Boron-10 enrichment in our standby liquid

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control system from 47 to 92 percent out of the
2 Boron-10. The outcome of that is it accelerates the
3 shutdown of the core during an ATWS condition and,
4 effectively, by doing that, limits the heat transfer
5 to the suppression pool that occurs during that
6 situation. And if you look at the information in the
7 box there, one of the interesting outcomes of that is
8 that the amount of additional shutdown that we've
9 gotten from the increased Boron is that the peak pool
10 temperature from our EPU MELLLA+ plus conditions is
11 actually less than the peak pool temperature was when
12 we originally licensed the core under the lowest core
13 flow we could get under the original power. So, we
14 believe this is actually a quantifiable increase in
15 safety that we've made as part of the project.

16 MEMBER SKILLMAN: John, how much is the
17 delta, please? Approximately, what is the delta
18 between what the original was and what the negative
19 effect of the Boron --

20 MR. SIPHERS: In terms of?

21 MEMBER SKILLMAN: Delta degrees
22 Fahrenheit.

23 MR. SIPHERS: Yes, it's the 189 to 174.

24 MEMBER SKILLMAN: Okay.

25 MR. SIPHERS: So, you're looking at 25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 degrees.

2 MEMBER SKILLMAN: Oh, thank you. Thank
3 you.

4 MR. SIPHERS: Yes, sir.

5 MEMBER MARCH-LEUBA: John, out of
6 curiosity, how much money has this Boron modification
7 cost? Because it is a really good modification. It
8 improves the safety of the reactor significantly.

9 MR. SIPHERS: I have to ask Stephen to
10 comment on that.

11 MR. YODERSMITH: This is Stephen
12 Yodersmith from the Brunswick plant.

13 It was about a million dollars for each
14 unit. So, it was a significant investment in --

15 MEMBER MARCH-LEUBA: It's not
16 insignificant.

17 MR. YODERSMITH: The Boron, the enriched
18 B-10 powder itself is very expensive. So, just the
19 powder itself was, say, 750 grand, and then, the labor
20 and the time to do the modification and the
21 engineering work.

22 MEMBER MARCH-LEUBA: I can just say from
23 other licensees that the most expensive part, the most
24 difficult part was to get rid of the old Boron.
25 Nobody wanted it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. YODERSMITH: Yes, nobody did want it.
3 Yes, we tried to stash in the FLEX dome, thinking that
4 might be a good option, and the feedback was it's not
5 enough water. Even though it's got Boron in it, it's
6 just not enough water. So, yes. No, we couldn't sell
7 it to anybody. Nobody wanted it.

8 MEMBER MARCH-LEUBA: So, just keeping it
9 in a 50-gallon tank somewhere?

10 MR. YODERSMITH: There's a stability pond
11 that we have onsite. And so, it was analyzed by our
12 Chemistry Department and by our RP Department.
13 There's no radioactivity in it. And since it is just
14 Boron, we were able to put it in the stability pond.
15 So, it was properly evaluated for the environmental
16 impacts, which were none, and we are able to store it
17 there.

18 MEMBER MARCH-LEUBA: Thank you.

19 MR. YODERSMITH: Yes, sir.

20 MEMBER BALLINGER: You could start up your
21 own shielding company?

22 (Laughter.)

23 MR. YODERSMITH: Something, yes.

24 MEMBER BALLINGER: Make concrete.

25 MR. YODERSMITH: Yes, no kidding. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Yes. Yes, the 47 percent was still very enriched, and
2 we were surprised nobody wanted it.

3 MR. SIPHERS: All right. If there are no
4 further questions, I'll turn it over to Mark DeWire,
5 who will describe the validity of the operator actions
6 required under MELLLA+ and the training that Brunswick
7 operators received.

8 MR. DeWIRE: Hi. Good morning. I am Mark
9 DeWire. I'm Assistant Ops Manager Shift at the
10 Brunswick station.

11 As has been mentioned by Mr. Siphers and
12 Mr. Nolin, we did conduct operator training. We
13 started off in the year 2017, in the spring, with a
14 high-level classroom overview of MELLLA+ and what was
15 going to be coming forward with that.

16 We came back, followed back around in the
17 fall, October-November timeframe, with some more
18 classrooms and tech spec workbook exercises; going in
19 the simulator, doing some demonstrations and looking
20 at some equipment changes that had happened in there.

21 A lot of the operator training happened
22 around the time-critical operator action of 120
23 seconds for initiating reactor water level reduction.
24 That was a lot of the simulator time spent, doing
25 that. And we also looked at the procedure updates

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we did.

2 With regards to the time-critical operator
3 action, we did receive training on that. We are
4 trained from ATWS conditions, from initial training,
5 and then, through continuing training. So, this is
6 really just kind of a refresher on the time-critical
7 operator action that would be established.

8 We ran three high power ATWS simulator
9 scenarios per crew. And then, in February of this
10 year, the NRC came down and did an audit of the time-
11 critical operator actions associated with those ATWS
12 actions.

13 As stated, we did three simulator
14 scenarios per crew. With 12 crews, that gave us 36
15 scenarios. We did do timing on the time-critical
16 operator action. That was the average time was 85
17 seconds with a deviation of 16 seconds. And then,
18 that proved that the operating crews were able to
19 effectively get the time-critical operator action
20 within the required timeframe with margin.

21 MEMBER MARCH-LEUBA: Hey, just out of
22 curiosity, how many time-critical operator actions do
23 you have in the plant? Is it two or is it 200?

24 MR. DeWIRE: It's not 200.

25 MEMBER MARCH-LEUBA: A dozen?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DeWIRE: It may be 25 to 30, somewhere
2 in that area. We have them broken down into an hour
3 or less, you know, and then, you've got specific ones,
4 like 120 seconds associated with reactor water level.
5 You get 20 minutes with control building HVAC. So,
6 there's various actions that are out there. This is
7 one of the more limiting ones by far.

8 MEMBER MARCH-LEUBA: And how often do they
9 get tested? Will you repeat this test every five
10 years or every --

11 MR. DeWIRE: It becomes part of the LOCT
12 scenarios and initial scenarios to have that time-
13 critical operator action to meet that, whenever you do
14 that evaluated scenario.

15 MEMBER MARCH-LEUBA: Was the example
16 operators that we didn't have to re-license?

17 MR. DeWIRE: That's correct. And then,
18 the actual time-critical operator actions are
19 contained with their own procedures against their own
20 validations on a periodic basis. And if you don't
21 meet those bases, you start off with putting in the
22 corrective action process and figure out what happened
23 via that way.

24 MEMBER MARCH-LEUBA: Thank you.

25 MEMBER REMPE: Since we're running a

1 little behind schedule, or ahead of schedule, we've
2 got time. Talk about time-sensitive actions. The
3 operator action to inject the SLC is a time-sensitive
4 action. How many of those do you have and what type
5 of validation is done with that?

6 MR. DeWIRE: It's in the same program as
7 the time-critical operator action. Containment is in
8 the same procedures, so they would be validated the
9 same way --

10 MEMBER REMPE: Oh, really?

11 MR. DeWIRE: -- on a periodic basis.

12 MEMBER REMPE: Okay. And is there about
13 30 of them also?

14 MR. DeWIRE: Somewhere around that area,
15 yes. I don't have the exact number in my head. It's
16 been a while since I did that audit.

17 MEMBER REMPE: Okay. Thank you.

18 MR. DeWIRE: Yes.

19 MEMBER SKILLMAN: Mark, may I ask this,
20 please?

21 MR. DeWIRE: Yes, sir.

22 MEMBER SKILLMAN: Of your 12 operating
23 crews, can you speak to how many did not know an ATWS
24 scenario was going to be presented to them? And
25 hence, they were not prepared and waiting for ATWS.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They were actually focused on something else when the
2 ATWS event was introduced.

3 MR. DeWIRE: You're talking about for
4 the --

5 MEMBER SKILLMAN: Crew training.

6 MR. DeWIRE: For the quarterly, for the
7 training?

8 MEMBER SKILLMAN: Yes.

9 MR. DeWIRE: They knew they were getting
10 trained on ATWS. Now the scenarios, you don't walk in
11 and put a countdown time and say, okay, now the ATWS
12 is going to begin. You start them off with some
13 event, and then, it progresses into an ATWS. So, they
14 know they're in there for ATWS training certainly, but
15 they're not on station ready to go with prescribed
16 actions or anything like that.

17 MEMBER SKILLMAN: Are there any scenarios
18 where they're not aware there's going to be an ATWS,
19 but you know that is what you're going to subject them
20 to, so it truly is a surprise?

21 MR. DeWIRE: Absolutely. When we do
22 quarterly -- or testing, cyclical training testing in
23 the simulator, one of the scenarios that we can give
24 them is an ATWS, and that will be in there. So, they
25 have no idea it's coming then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay. Thank you.

2 MR. DeWIRE: Yes, sir. Any other
3 questions on that?

4 (No response.)

5 MR. DeWIRE: All right. In conclusion,
6 then, I would just like to wrap it up with the
7 implementation of the MELLLA+ significant benefits
8 that we talked about. One of the ones near and dear
9 to my heart is the greater flexibility in using core
10 flow to control reactivity. It's a lot less shots on
11 goal for the number of downpowers and reactivity
12 manipulations that the station and the operators have
13 to perform, and it increases the station's capacity
14 factor during the operating cycle.

15 We'll be ready to implement the MELLLA+
16 license amendment, the DSS-CD firmware, and SLC.
17 We've already completed those, as we've discussed.
18 The training, we've completed the training on the
19 MELLLA+ equipment, procedures, and the required
20 actions. The final power and future minor setpoint
21 engineering change is approved, and implementation and
22 a test plan has been established. And as Mr. Nolin
23 alluded to, we're requesting approval to support the
24 third quarter of 2018 implementation.

25 MEMBER MARCH-LEUBA: So, I assume that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DSS-CD has already been implemented and is running?
2 You just have jumped it out today, correct?

3 MR. DeWIRE: That's correct.

4 MEMBER MARCH-LEUBA: So, does it look good
5 with respect to noise?

6 MR. DeWIRE: Yes, I haven't seen any
7 issues with it.

8 MEMBER MARCH-LEUBA: How long has it been
9 running? A year?

10 MR. SIPHERS: Since 2016.

11 MR. DeWIRE: 2016, is that right?

12 MEMBER MARCH-LEUBA: A couple of years?

13 MEMBER RICCARDELLA: Why does it increase
14 capacity factor? What's the mechanism for that?

15 MR. SIPHERS: Less downpowers.

16 MEMBER MARCH-LEUBA: Control those --

17 MR. DeWIRE: So, we're coming into the
18 fall where I start to die off pretty rapidly with my
19 k-effectives. So, I'm having to do a lot more
20 downpowers and a lot more watt adjustments in order to
21 maintain 100 percent. If I can extend this flow
22 window out, I can just run the flow up and maintain
23 the power on that rod line. So, there's less
24 downpowers, less time down, and increased production
25 factor.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIPHERS: One of the things in a BWR,
2 when we adjust control rods, we typically like to do
3 that at a lower core power.

4 MEMBER RICCARDELLA: Oh, I see.

5 MR. SIPHERS: So, any type of rod
6 adjustment that we do involves reducing flow to a very
7 low power, adjusting the rods, and then, kind of
8 ramping back up to higher power.

9 MEMBER RICCARDELLA: I got you. Okay. I
10 understand. Thank you.

11 MR. NOLIN: So, from an operator burden
12 standpoint, you have less downpowers. But, from a
13 safety standpoint, you have less rod manipulations as
14 well.

15 MEMBER MARCH-LEUBA: I have one more
16 question.

17 MEMBER REMPE: One more question? Okay.

18 MEMBER MARCH-LEUBA: Can you skip up to
19 slide 21? That serves you well for having backup
20 slides.

21 (Laughter.)

22 MEMBER MARCH-LEUBA: So, those are the
23 test points, A, B, C, D, and E, right where you are
24 going to do the stability tests?

25 MR. YODERSMITH: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Are those results
2 going to be -- I assume they are not going to be
3 public, but are they going to be shared with Framatome
4 and/or GE? Or are you going to keep them by
5 yourselves or? What type of benchmark do you plan to
6 do, especially analytical analysis?

7 MR. YODERSMITH: Yes, we plan on sharing
8 the results with GE and Framatome, absolutely, and
9 then, sharing, one, our stability results are in line
10 with what GE would expect and what we would expect, as
11 the site, and from the TIP standpoint, that are
12 uncertainties are in line with --

13 MEMBER MARCH-LEUBA: You collect TIPs now?

14 MR. YODERSMITH: Yes, sir, we'll collect
15 TIP data at test condition alpha and at test condition
16 echo for the point of verifying that our belief that
17 there is no problem with uncertainty in this region --
18 we verify that and validate that.

19 MEMBER MARCH-LEUBA: Can you do me a
20 favor, as a personal favor, and ask GE and Framatome
21 to analyze the points ahead of time, to calculate what
22 the decay ratio is before you run the tests?

23 MR. YODERSMITH: Oh, yes.

24 MEMBER MARCH-LEUBA: Before and after?

25 MR. YODERSMITH: Yes, yes, right, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Do a blind test.

2 MR. YODERSMITH: Right. That is in the GE
3 task report for our testing. And so, it kind of
4 outlines what sort of tests we should do and that it's
5 okay to do them.

6 MEMBER MARCH-LEUBA: Similar to what Dave
7 was commenting on the simulator testing, if you know
8 what the answer is, it's very easy to reproduce. It's
9 best to do a blind test ahead of time.

10 MR. YODERSMITH: Right, right. Yes, we'll
11 have acceptance criteria all laid out in the special
12 procedures. So, we'll know what good looks like.

13 Thank you.

14 MEMBER REMPE: Okay. So, if there aren't
15 any more questions, let's have the staff come forward.
16 Unlike at the Subcommittee meeting, we are going to
17 let the staff have more time. We ran over with the
18 licensee last Subcommittee meeting.

19 MR. HON: Good morning, Chairman Corradini
20 and Chairman Rempe. I'm Andy Hon. I'm the Project
21 Manager at NRR for this project.

22 Our team is going to share with you the
23 results of our review and the SE. Our SE, the draft
24 has been provided to you. It's very similar to other
25 plants' SE. It addresses each section of the M+ that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the licensee shared earlier, the SAR, and then, all
2 the applicable Ls and Cs, I should say limitations and
3 conditions, from the Topical Report referenced.

4 Our team conducted two audits on five
5 focus areas that we will be sharing with you. The
6 first audit is the detailed Safety Analyses that was
7 done in July last year here in Rockville. And then,
8 we actually went to the site in February this year to
9 audit the simulator of their operator actions.

10 Our SE also included a summary of our
11 colleagues at Research using the TRACE computer
12 modeling to model the application. And that's also
13 included in our SE for Brunswick plant-specific
14 modeling.

15 Our plan is to finalize our SE next month,
16 make a final decision after today's briefing, and
17 incorporate any comments the Committee wishes to
18 incorporate.

19 I would like to recognize that a number of
20 people contributed to this project from both NRR,
21 different branches, and also our colleagues at
22 Research, as well as our consultants from Oak Ridge.

23 In today's presentation, we have two parts
24 because of the proprietary information. We have the
25 open session that we'll be sharing with you in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 next 10 minutes. And then, after that, we would like
2 to close the session to share more proprietary
3 information.

4 The plan right now is only including GEH
5 information sharing. If there are any questions
6 related to the AREVA or Framatome, we may have to
7 excuse people who do not have access to that
8 information in a later part of the meeting. And at
9 the end, our management would like to share some
10 closing remarks.

11 With that, I'll turn it over to our lead,
12 Josh.

13 MR. BORROMEO: Good morning. My name is
14 Josh Borromeo. I'm in the Reactor Systems Branch in
15 NRR. And I'll be discussing the NRC focus areas of
16 the application, why we focused on them, and provide
17 an overview of the review of each of these areas.

18 So, as the licensee mentioned, the LAR
19 will allow Brunswick to operate at flows as low as 85-
20 percent core flow and at 100-percent power. And they
21 followed the GE MELLLA+ Licensing Topical Report,
22 which is essentially the MELLLA+ roadmap for licensing
23 MELLLA+.

24 Now this isn't the first time that the
25 staff has seen a MELLLA+ application. It's not the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 first time that we've seen MELLLA+ with GE methods or
2 the first time we've seen MELLLA+ with Framatome
3 methods. However, it's the first time that we've seen
4 a combination of GE methods and Framatome fuel, and
5 that's really in the stability and the ATWS analyses
6 that the licensee provided. Now I'm going to touch on
7 them in my presentation, but Aaron is going to go into
8 much more detail in the closed session.

9 So, the areas -- next slide.

10 CHAIR CORRADINI: Just a clarification,
11 because you nicely went through all that, have you
12 guys reviewed the reverse, which is GE fuel with
13 Framatome analysis methodology, the extent of flow in
14 there? I don't remember that.

15 MR. BORROMEO: I don't think we did for --

16 CHAIR CORRADINI: I didn't think so.
17 Okay.

18 MR. BORROMEO: I don't think there was a
19 transition for there, was there?

20 CHAIR CORRADINI: Okay. Thank you. Thank
21 you.

22 MR. BORROMEO: Okay. So, the areas where
23 the staff reviewed are areas that have been
24 historically challenging or have been new to the
25 staff. The first is the applicability of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Framatome methods to MELLLA+. It's important to note
2 that, like the licensee said, they already have
3 Framatome fuel and the methods are already approved
4 for EPU. What the licensee is really requesting is
5 just approval for the Framatome methods and the
6 MELLLA+ operating domain.

7 The next focus area is a safety limit MCPR
8 penalty removal. Historically, a safety limit MCPR
9 penalty has been applied to all the MELLLA+
10 applications. This time the licensee was able to
11 gather more data and justify the removal of this
12 penalty.

13 The next focus area was DSS-CD. The
14 application of DSS-CD isn't new. However, the
15 licensee is requesting a change to the methodology and
16 it will reduce the range that the algorithm searches
17 for thermal-hydraulic instabilities. And they changed
18 that due to plant-specific noise that they had to
19 avoid spurious scrams.

20 And finally, ATWSI and ATWS, like I said,
21 the combination of the GE methods and the AREVA fuel
22 was a challenge for us. Tmin has been historically
23 challenging. So, we focused on that, as we have done
24 for previous reviews. And the licensee was able to
25 gain margin in the ATWSI analyses by fine-tuning their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 feedwater temperature reduction rate.

2 So, for the Framatome methods, we recently
3 approved methods for MELLLA+ for Monticello. So, we
4 have a very recent precedent that we were able to
5 start from. What the staff did was take a look to
6 make sure that there wasn't anything new or different
7 between the plants and the reviews that would cause us
8 to have to question or dig in any further to what the
9 licensee provided.

10 And the staff determined that we could
11 apply similar SE justifications and conclusions as we
12 did for Monticello, except for the MICROBURN-B2, which
13 is the core simulator, which is related to the safety
14 limit .03 penalty.

15 Now the safety limit MCPR penalty, like I
16 said, this is a penalty that has been applied to other
17 MELLLA+ applications, and it's a limitation and
18 condition in the GE MELLLA+ roadmap methodology. Now,
19 for Monticello, we continued to apply this .03 safety
20 limit MCPR penalty at high-power-to-flow ratios
21 because the staff didn't think there was enough data
22 to justify the removal of this penal.

23 So, since the Monticello application, the
24 staff has reviewed an AURORA-B Topical Report that
25 requested MICROBURN-B2 be approved in the MELLLA+

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating domain without a penalty. In that review,
2 the staff determined that there was no adverse
3 uncertainty trend at high-power-to-flow ratios. So,
4 what the licensee did for Brunswick was follow a
5 similar approach to AURORA-B. So, the licensee was
6 able to provide additional data and justification.
7 The staff reviewed that and took a similar review
8 approach to AURORA-B and determined that we were able
9 to remove the penalty for this review.

10 For DSS-CD, the staff has reviewed the
11 DSS-CD implementation several times, including fuel
12 type changes and setpoint changes. These are allowed
13 within the DSS-CD methodology. The big change for us,
14 though, was that the licensee is shrinking the
15 oscillation period range that the algorithm searches
16 for to determine if these are truly thermal-hydraulic
17 instabilities of the plant or if they aren't. And the
18 licensee, like I mentioned, is doing this because of
19 plant-specific noise that they have to avoid spurious
20 scrams.

21 CHAIR CORRADINI: When you say "reduce in
22 time"?

23 MR. BORROMEO: Reduce in period. So, they
24 take a look at the oscillating period, and that period
25 that they search for is slightly reduced.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: During the Subcommittee
2 meeting -- I'm not sure whether it was the closed or
3 open part -- but you just said, "Oh, the licensee is
4 doing this because of their particular situation."

5 MR. BORROMEEO: Correct.

6 MEMBER REMPE: I thought it was presented
7 to us that this may not be the only one to expect to
8 occur.

9 MR. BORROMEEO: It might not be the only
10 one to expect, but this is the first time the staff
11 has seen it.

12 MEMBER REMPE: Right. Okay. Thank you.

13 MR. BORROMEEO: Aaron is going to get into
14 more detail on this, but the licensee provided us
15 TRACG sensitivity studies to demonstrate that the
16 spirit of the DSS-CD methodology was still maintained,
17 and the staff found that this was acceptable.

18 And then, for ATWSI, the licensee
19 mentioned the challenges with Tmin. Aaron is going to
20 discuss that, the Tmin sensitivity studies that we
21 requested from the licensee, which is similar to what
22 we've done before for Peach Bottom and several other
23 plants.

24 However, the big, new item that has been
25 mentioned over and over again the GE methods and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Framatome fuel, the combination there. So, the
2 licensee did a series of sensitivity studies to bound
3 the ATRIUM 10XM fuel, and the staff reviewed this and
4 determined that what the licensee did was
5 conservative.

6 In order to also support this, the NRR
7 staff requested Research perform TRACE confirmatory
8 studies, and PERC is going to give a presentation on
9 that later. Those results supported the NRR's
10 conclusion that the ATRIUM 10XM fuel was
11 conservatively modeled and that the ATWS results meet
12 the ATWS acceptance criteria. And Aaron is going to
13 get into more details in this in the closed session.

14 So, in conclusion, for these focus areas,
15 the Framatome methods we found were valid for the
16 conditions of the Brunswick MELLLA+ operating domain.
17 The .03 safety limit MCPR penalty is not necessary for
18 this Brunswick MELLLA+ application. The change in the
19 DSS-CD methodology was acceptable, and the ATWSI
20 analysis bounded the ATRIUM 10XM fuel and continues to
21 meet the ATWS acceptance criteria. And ultimately,
22 the staff found that the proposed Brunswick MELLLA+
23 operating domain license amendment request was
24 acceptable.

25 MEMBER REMPE: So, do any of the members

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have any comments or questions?

2 (No response.)

3 MEMBER REMPE: We are going to go to a
4 closed session. But, before we do that, we need to
5 allow for public comments and open up the lines.

6 I guess, Weidong, you'll take care of
7 getting the lines open. While we're waiting, does
8 anyone in the room want to make a comment?

9 (No response.)

10 MEMBER REMPE: Okay. So, the lines are
11 open. Does anyone on the line wish to make a comment
12 today?

13 (No response.)

14 MEMBER REMPE: Hearing no one, I guess
15 we'll close the line, and we'll switch to the closed
16 session.

17 (Whereupon, the above-entitled matter went
18 off the record at 9:09 a.m. and resumed at 10:15 a.m.)

19 CHAIR CORRADINI: Okay. Let's come back
20 into session. So, our next topic will be talking
21 about the Digital I&C Interim Staff Guidance-06, and
22 I'll turn it over to Member Brown.

23 MEMBER MARCH-LEUBA: And this is open
24 session?

25 CHAIR CORRADINI: Open?

1 MEMBER BROWN: The whole session is open.
2 This morning the staff will be presenting
3 to us the Draft of Revision 2 to the Digital I&C
4 ISG-06, the licensing process, outlining what needs to
5 be done in order to get through the licensing process
6 for operating plants upgrading their analog
7 instrumentation to digital instrumentation and control
8 systems.

9 Our full Committee reviewed Revision 1 of
10 ISG-06 in October of 2010, and the initial Revision 1
11 of this ISG was issued later in 2011, if I believe
12 correctly. Our Subcommittee reviewed this latest
13 draft of Revision 2 on May 17th and June 20th.

14 We will also hear an overview and updated
15 progress of the Staff's Integrated Action Plan for the
16 modernization of the NRC's digital I&C regulatory
17 infrastructure.

18 Before I turn it over to the presenters,
19 Brian, would you like to say a few words?

20 MR. B. THOMAS: Sure. Good morning.
21 Brian Thomas with the Office of Research and, also, a
22 member of the Steering Committee, on behalf of the
23 Steering Committee, and there are a few members who
24 are not there, Bob Caldwell, we're expecting him to
25 join us; also, Eric Benner, who is the Chair of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Steering Committee who is out on leave at this time.

2 But, on behalf of the members of the
3 Steering Committee and on behalf of the staff, I want
4 to express our appreciation and our thanks for having
5 us here. We look forward to the exchange with you.
6 As Member Brown said, our exchanges with the
7 Subcommittee back on the 17th of May as well as June
8 20th were very informative. The staff will address
9 some of those comments that we received then and go
10 through the ISG-06 as well as the IAP as a whole.

11 So, thank you.

12 MEMBER BROWN: Okay. Thank you.

13 Mike, would you like to take over and get
14 us moving?

15 MR. WATERS: Yes. Good morning, Chairman
16 and fellow members of the ACRS. My name is Mike
17 Waters. I'm currently serving as the Acting Deputy
18 Director, Division of Engineering in NRR. Our
19 Division Director Eric Benner is also out this week.
20 So, I'm acting for him as well.

21 I want to re-echo Brian's opening remarks
22 on behalf of the Steering Committee. Thank you for
23 taking the time to meet with us.

24 I also would like to acknowledge the staff
25 out there in the audience. We have multiple people

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from multiple Divisions who share responsibility for
2 digital I&C who are here in the audience, who will
3 participate and help us on this.

4 As noted by Charlie, this follows two
5 Subcommittee meetings this May and June on both Draft
6 ISG-06 and the Integrated Action Plan. These were
7 very viable interactions already, and we've already
8 updated the ISG to reflect some of the comments we
9 heard from the Subcommittee in both of those
10 Subcommittee meetings. We appreciate that.

11 We look forward to productive dialog this
12 morning, and we're specifically seeking feedback and
13 endorsement on our Draft ISG-06, which we intend to
14 publish for formal public comment later this month.

15 And before going on, I would like to
16 acknowledge the people at the table. We have Mr. Dave
17 Rahn, a Senior Electrical Engineer who will talk about
18 the Integrated Action Plan; Samir Darbali; Richard
19 Stattel from NRR, and Deanna Zhang from NRO, who will
20 discuss the scope and content of ISG-06.

21 Next slide, please.

22 And as Charlie noted, this is the agenda.
23 We're first going to talk about the Draft ISG-06,
24 which will be a substantial portion of the meeting
25 today, followed by Dave's discussion on the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 activities that are ongoing, the Integrated Action
2 Plan.

3 With that, we're ready to start. If
4 there's any questions? Otherwise, I'll turn it over
5 to Samir.

6 MR. DARBALI: Thank you, Mike. Next
7 slide, please. So, I would like to mention --

8 MEMBER BLEY: Is your mic on?

9 MR. DARBALI: Thank you. Thank you. As
10 has been said, we briefed the ACRS Digital I&C
11 Subcommittee back on May 17th and June 20th on
12 Revision 2 of ISG-06. We received some verbal
13 comments from the ACRS Subcommittee which mainly
14 focused on how the system architecture and fundamental
15 design principles are addressed in what we call a Tier
16 1, 2, and 3 review process.

17 The next slide. And later on, we'll talk
18 about how we addressed those comments.

19 So, the purpose and scope of ISG-06 has
20 remained the same from Revision 1 to Revision 2. the
21 ISG-06 defines the licensing process used to support
22 the review of license amendment request associated
23 with safety-related digital I&C equipment
24 modifications in operating plants and in new plants
25 once they become operational. This guidance is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistent with the NRC's policy on digital I&C
2 equipment and is not intended to substitute NRC
3 regulations.

4 This ISG provides guidance for activities
5 performed before license amendment requests and during
6 license amendment requests review. The staff uses the
7 process described in the ISG to evaluate compliance
8 with NRC regulations, and the ISG makes reference to
9 SRP Chapter 7. It's not meant to replace Chapter 7.

10 Next slide.

11 So, the Revision 1 of ISG-06 introduces
12 the concept of tiers, and we're keeping that concept
13 in Revision 2. And it provides a graded approach for
14 how we perform our digital I&C modification reviews.
15 In a Tier 1 review, a licensee is proposing to use a
16 NRC preapproved digital platform Topical Report. In
17 a Tier 2, the licensee is referencing a Topical Report
18 that has been preapproved, but with some
19 modifications. And on a Tier 3 type of review, the
20 licensee is using a new platform that has not been
21 previously reviewed.

22 MEMBER MARCH-LEUBA: I see you're focusing
23 on hardware. How about software? If I have a
24 platform that has been approved with some software,
25 and I make any change to the software, does it become

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a Tier 2?

2 MR. DARBALI: When we talk about the
3 tiers, we're talking about both hardware and software.
4 So, when we perform our Topical Report evaluations of
5 the platform we're looking at, we're looking at the
6 RACs, we're looking at the modules, we're looking at
7 different components and the software that performs
8 the function.

9 MEMBER MARCH-LEUBA: My specific question
10 is, at which point -- obviously, you are allowed to
11 change the setpoints, right?

12 MR. DARBALI: Right, right.

13 MEMBER MARCH-LEUBA: There's not a change.
14 At which point does it become a Tier 2 for a change?

15 MR. DARBALI: And Rich can talk more about
16 this.

17 There isn't really one Tier 1 specific or
18 one Tier 2 type. There's always something in the
19 middle. I think Diablo Canyon is a good example where
20 the licensee used the latest Topical Report that was
21 approved months before the license amendment request.
22 And yet, there were some changes in between.

23 So, the staff uses the tiers as guidance
24 on how to review it, but there's some flexibility
25 allowed to the staff on how we evaluate it. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensee will identify the changes, and we'll decide
2 which aspects need to be reviewed.

3 MR. STATTEL: This is Rich Stattel.

4 With regard to software, your specific
5 question, there are many platforms. So, there's a lot
6 of things that are unique to each platform. However,
7 a typical platform involves two types of software.
8 So, it's very easy to partition this. There is
9 platform-level software. Think of that as operating
10 system software. And then, there's application-
11 specific software, which, basically, that's the
12 software that's written to perform certain safety
13 functions. So, to perform the reactor scram function,
14 to perform ESF functions.

15 When we're talking about application
16 software, plant-specific software, there is no change
17 involved with that because that will not be developed
18 until the application is -- until that effort is
19 underway.

20 MEMBER MARCH-LEUBA: So, that is the Tier
21 1?

22 MR. STATTEL: When you go over to the
23 other side, when you talk about the operating system,
24 the platform-level software, really, that does not
25 change very frequently.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Yes.

2 MR. STATTEL: And any changes to that,
3 even if they're minor changes, change -- now we're
4 talking, also, a lot about PLCs, programmable logic
5 controllers. In those applications, we're talking
6 about function block diagrams which use a preapproved
7 library. So, essentially, there's a library of
8 functions, and a developer can choose from that
9 library implementation of those functions. That
10 library itself is considered platform software or
11 operating-system-type software. It can change, but it
12 doesn't change very often. Basically, that's the
13 library from which the developer chooses and builds
14 his application. But changes to those software
15 basically place that into a Tier 2 review. Okay?

16 MEMBER MARCH-LEUBA: Okay. Thank you.

17 MR. DARBALI: Okay. Next slide.

18 The ISG, Revision 1, also introduces the
19 concept of phases. And this allows the staff and the
20 licensee to understand the different stages of license
21 amendment review. So, we call the pre-application
22 meeting or before a license amendment is issued a
23 Phase 0. So, that's when we have discussions with the
24 licensee on what they propose to provide in the
25 license amendment request.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Phase 1 is the license amendment request
2 submittal or initial application, and that covers
3 system description, compliance with IEEE standards,
4 design requirements, design specification, and
5 planning and processing information. Then, a Phase 2
6 is a continued review, an audit process where the
7 licensee provides supplemental information.

8 So, you can think of Phase 1 and Phase 2
9 as the licensee has a design, but it's not complete.
10 So, they are allowed, under what we call the Tier 1,
11 2, and 3 review process, to provide that Phase 1
12 information first. The staff starts their review.
13 And as the licensee completes their implementation and
14 testing activities, they provide that Phase 2
15 information, and the staff can go and review and audit
16 that information.

17 MEMBER MARCH-LEUBA: So, in the example
18 that Rich was giving us, say PLCs, they would provide
19 a PLC hardware or we will use this type of machine?

20 MR. DARBALI: Right.

21 MEMBER MARCH-LEUBA: We will provide the
22 library functions --

23 MR. DARBALI: Right.

24 MEMBER MARCH-LEUBA: -- under Phase 1,
25 correct, likely?

1 MR. DARBALI: Right. Yes.

2 MEMBER MARCH-LEUBA: And then, as you are
3 reviewing that, they will do the application software
4 on top of it?

5 MR. DARBALI: Right. Yes. So, you'll see
6 we'll see design requirements, design specifications,
7 but how that gets implemented, we won't see that until
8 Phase 2.

9 MR. STATTEL: One of the challenges I'll
10 just mention, one of the challenges we faced with
11 digital I&C equipment that's kind of unique to this
12 technology is that the development processes span
13 years. So, a lot of times the development of these
14 types of systems can three, four years to occur. So,
15 when we originally developed the ISG in 2010, we
16 recognized this and we wanted to provide a way of
17 essentially performing our evaluation in parallel with
18 that development process. Because when you put our
19 two-year evaluation in series with it, it makes it
20 very difficult for plants to implement these types of
21 modifications.

22 MEMBER MARCH-LEUBA: And what makes it so
23 long, testing? Because, obviously, it's not a
24 problem. I mean, the problems are not that
25 complicated.

1 MR. STATTEL: I guess there are many
2 reasons for that. Because they go through the process
3 of selecting a platform. The designs are typically
4 not identical to the systems they are replacing
5 oftentimes. So, for instance, with Diablo Canyon,
6 they're trying to eliminate manual operator actions.
7 So, there's changes associated with that. And there
8 are also challenges that relate to diversity, defense
9 in depth.

10 The other hazard that these digital
11 systems have a potential for is common-cause failures.
12 So, there's not a one-for-one easy replacement
13 digital-to-analog for that without having to
14 additionally address diversity. So, oftentimes, these
15 systems involve installation of automatic diverse
16 actuation systems or in certain technologies they are
17 able to implement diverse measures within the system
18 in order to address the potential for common-cause
19 failures.

20 Those are just a couple of examples of why
21 the development processes span this. There are other
22 factors that we've seen in evaluations. The Diablo
23 Canyon development process took about four years to
24 complete. That had more to do with vendor performance
25 issues and contract administration. It was things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that were not really associated with the regulatory or
2 licensing process. But it basically extended the
3 development time for that.

4 Previous to that the Oconee application,
5 there was an original submittal, and the staff had
6 deemed that they had not adequately addressed
7 diversity and defense in depth. It was withdrawn and,
8 then, resubmitted, and a redesign was performed.

9 So, it's really just been our experience
10 that these projects tend to take an extensive period
11 of time for development.

12 MR. DARBALI: And then, we have what we
13 call a Phase 3, which is really, once the license
14 amendment has been issued, then the licensee installs
15 it. And then, we have regional and site inspections.

16 Next slide.

17 So, we have used Revision 1 of ISG-06 for
18 several license amendment requests, most notably,
19 Diablo Canyon Plant Protection System and the Hope
20 Creek Power Range Neutron Monitoring System. We've
21 also used it for various digital I&C Topical Report
22 reviews. That really allows us to, since the Topical
23 Report has been reviewed using the ISG, the licensee
24 wants to use that platform. Most of the criteria in
25 the ISG has been covered. So, it facilitates the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff's review.

2 We've found that the concept of the Tiers
3 1, 2, and 3 and the Phase 1 and 2 review process have
4 been useful. One thing to note is that, originally,
5 the ISG was meant to be a one-stop shop that included
6 all of the digital NRC guidance, and this became
7 problematic because we ended up duplicating a lot of
8 the Chapter 7 guidance as well as IEEE Standards 603
9 and 7-4.3.2. Because the ISG originally issued in
10 2011, we've revised several Regulatory Guides since
11 then. So, those became outdated.

12 And Revision 1 of the ISG focused more on
13 specific documents by title instead of the information
14 needed to make the review. So, we saw an opportunity
15 to improve on those.

16 Next slide.

17 Right, so we found that we could improve
18 on streamlining the ISG and the Tier 1, 2, and 3
19 review process. Also, we've been having several
20 public meetings with industry, and they've expressed
21 concerns that they need to expand significant
22 resources for procuring, developing, and testing the
23 system before they get the license amendment. So,
24 right now, under the Tier 1, 2, and 3 review process,
25 the licensee has to procure the system, design it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 develop the modification, implement it, and do
2 testing, and finally, factory acceptance tests before
3 we issue the license amendment. And they've expressed
4 concerns with that saying they would like to see that
5 license amendment issued earlier. So, the staff took
6 our internal lessons learned and comments from
7 industry, and we tried to improve on Draft Revision 2
8 of the ISG.

9 Next slide.

10 So, here's a comparison of both Revision
11 1 and Draft Revision 2. Both Revision 1 and 2 include
12 the Tier 1, 2, and 3 review process which uses a
13 preapproved platform Topical Report. Again, this is
14 for Tiers 1 and 2. For Tier 3, the platform review
15 would be part of a license amendment review.

16 The system description and system
17 architecture are included as part of this review. We
18 understand that, when we first presented the ISG
19 Revision 2 to the ACRS Subcommittee, they pointed out
20 it wasn't clear that we did that system architectural
21 review for the tier process. So, we improved the
22 language on that.

23 So, we do review software design,
24 implementation, and test plan and processes. And we
25 also review implementation and test results

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information. So, we've maintained that tiered process
2 in Revision 2.

3 We've also added a new review process that
4 we call the alternate review process. It also uses a
5 preapproved Topical Report platform. It covers system
6 description and system architecture, and the review
7 covers the software design, implementation, test plans
8 and processes.

9 However, the main difference between the
10 alternate process and the tier process is that
11 implementation of the design and the test results will
12 be subject to inspection because those will occur
13 after the license amendment has been issued.

14 MEMBER MARCH-LEUBA: What's the likelihood
15 that the inspection will remove a license? Once
16 somebody has a license, it's very difficult to get rid
17 of it.

18 MR. DARBALI: Well, right. The process is
19 not intended to remove the license, but a violation
20 might be issued if it's found that the licensee has
21 made -- either they did not comply with any of the
22 conditions in the license amendment or they've made
23 some sort of design that required a new license
24 amendment request.

25 MEMBER MARCH-LEUBA: I'm not saying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there's nothing wrong. I mean, I see a lot of balance
2 here with Part 52 --

3 MR. DARBALI: Right.

4 MEMBER MARCH-LEUBA: -- where you approve
5 a paper design --

6 MR. DARBALI: Right.

7 MEMBER MARCH-LEUBA: -- and then, you
8 build it.

9 MR. DARBALI: Right.

10 MR. WATERS: Yes, this is something
11 similar, but it's very different. We will issue the
12 license and they have the authority to build,
13 instruct, and operate the system. As you said, any
14 issues of implementation and testing will be in
15 oversight space. And if our inspection records find
16 an issue in the oversight process, as Samir has noted,
17 like anything else, there's remedies to any adverse
18 things. We hope we don't have any. But that is the
19 difference. Both on the vendor side and site
20 inspections, we will look at the development and the
21 testing.

22 MEMBER MARCH-LEUBA: I see this very
23 positive. Yes, the staff needs to keep the stick.
24 So, you should be able to enforce decisions
25 afterwards.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WATERS: Yes, and part of the fabric
2 of this is we are actively working with what the
3 inspection programmatically, little "p,"
4 programmatically, will look like with this new process
5 both in vendor inspection, what we believe will
6 involve vendor inspections more so than the changes to
7 the site inspection.

8 MEMBER MARCH-LEUBA: Okay. Thank you.

9 CHAIR CORRADINI: I'm not an expert in any
10 of this. So, let me ask a broader question. How many
11 have used the top approach and successfully installed
12 a digital I&C system? Not Revision 2, which has the
13 alternate approach, but the --

14 MR. DARBALI: Right. So, for Revision 1,
15 the tier process, we've successfully used it for
16 Diablo Canyon. They have not installed the system
17 because they're going to be shutting down. So, they
18 decided not to install it. But it was a successful
19 review. And it was the pilot for the ISG. We've
20 successfully used it for Hope Creek, for the Neutron
21 Monitoring System --

22 CHAIR CORRADINI: Okay.

23 MR. DARBALI: -- and several Topical
24 Reports. So, we've had some use from that. And then,
25 Revision 1 came from lessons learned from previous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reviews. And industry has had positive feedback on
2 the tier process.

3 MR. STATTEL: I think the answer is about
4 a half dozen.

5 (Laughter.)

6 CHAIR CORRADINI: Okay. And then, with
7 this alternate review process, my sense is industry
8 will probably use it more -- feel that that could be
9 more effective?

10 MR. DARBALI: Yes. So, during our public
11 interactions with the industry, they do prefer
12 alternate review process. They understand they are
13 taking a risk post-license amendment and subject to
14 inspections and any violations. Whereas, now, during
15 the Phase 2, if they want to do a change to the
16 design, then we're still reviewing it. So, the tier
17 process allows that flexibility.

18 CHAIR CORRADINI: Okay. Thank you.

19 MEMBER BROWN: Correct me if I'm wrong,
20 but the alternate review process that you've
21 incorporated -- let me back up just a minute. If you
22 go back eight years, when we first did the first
23 version of this, the way I've viewed this was taking
24 all of the various documents, the Reg Guides and
25 everything else that are applicable to the I&C world

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which somebody would try to design to, and it kind of
2 coalesced them in and said, "Here's the things you
3 have to look at and the stuff we expect you to present
4 to us, so we can perform our review."

5 So, it took some of the surprise of, all
6 of a sudden, "Hey, you didn't give us this and we
7 really want that." It's now kind of put together in
8 terms of this ISG.

9 The alternate review process, in my mind
10 -- that's why I asked them to correct me if I'm wrong
11 -- is similar to what we do on the design
12 certification side. We approve a Chapter 7 based on
13 an I&C Safety System Technical Report or Topical
14 Report, which are more than platforms. They might
15 identify a platform, but they identify a system
16 architecture. The license is issued and they build,
17 and it gets inspected and tested subsequent to that
18 license. That's the way I view the alternate review
19 process now being applied to the individual
20 replacement of systems. That's just a calibration.
21 If you can fix that a little bit --

22 MR. STATTEL: I would also mention, the
23 next slide will show a timeline, right, that explains
24 that.

25 CHAIR CORRADINI: I figured something like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 MR. STATTEL: And before Samir leads into
3 this, our experience, essentially, we're issuing the
4 license amendment at an earlier stage, at completion
5 of design, before the design is implemented or tested,
6 right? So, that's the point in time that we're now
7 issuing the license amendment.

8 Our experience, that window of time can
9 typically take from a year to two years or even
10 longer, right? And in our experience, design changes
11 do occur during implementation and during testing. We
12 expect that those design changes would now occur, if
13 the alternate review process is used, those design
14 changes are occurring after we issue the license
15 amendment. Therefore, they would be using either
16 their 50.59 process or they would submit additional
17 license amendments to accomplish those changes.

18 MR. DARBALI: Thank you, Rich. So, the
19 top portion of this slide describes the staff
20 activities related to Tier 1, 2, and 3 review, and
21 this is for Revision 1 and Revision 2 of the ISG.
22 Whereas, the bottom portion describes the NRC staff
23 activities related to the alternate review process.
24 The middle portion describes the licensee activities
25 in procuring and developing testing, the modification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, you can see that, for the tier
2 process, the license amendment request gets submitted
3 earlier because they are allowed that Phase 2
4 information supplemental submittal later on. So, they
5 can start their license amendment request submittal
6 earlier. For the alternate review process, they need
7 to get more design information because they only get
8 one submittal. This is one of the main differences.
9 For the alternate review process, you don't have a
10 Phase 2 submittal. So, all of the information
11 necessary for the staff to make a safety determination
12 has to be provided in the license amendment request.
13 So, it will take longer for the licensee to submit
14 that. We'll perform our review and audits, and you
15 can see at the bottom the license amendment gets
16 issued earlier.

17 MEMBER KIRCHNER: But, yes, Samir, let me
18 ask a question. One of your earlier slides expressed
19 the industry concern about the resources that are
20 required before the amendment is issued. So, when I
21 look at your diagram, it strikes me that there's still
22 significant resources invested before you get the LA
23 issued.

24 MR. DARBALI: Under the alternate review
25 process.

1 MEMBER KIRCHNER: Under both.

2 MR. DARBALI: Well, yes. Yes.

3 MEMBER KIRCHNER: So, what substantially
4 is different, then, in the alternate process in terms
5 of saving resources?

6 MR. DARBALI: Well, what we've received,
7 the feedback we've received from industry regarding
8 the tiered process is plant management doesn't want to
9 commit a large budget for a digital modification
10 without seeing that license amendment. So, the
11 alternate review process would allow them to say,
12 well, plant management is going to commit not the
13 whole cost of developing, implementing, and testing a
14 system, but enough to get that design information and
15 get a license amendment. It gives licensees that
16 flexibility. They can get that funding for the design
17 to be approved. After that, they can go back to their
18 management and say, "We have our license amendment,"
19 and request funding to complete the design. Industry
20 feels that would enable them to perform more
21 modifications.

22 MEMBER MARCH-LEUBA: I know you don't know
23 the answer to this, but it would be helpful if you
24 could give us a ballpark one-year money for each of
25 those blue boxes in the middle.

1 MR. DARBALI: Yes, it would be helpful.

2 (Laughter.)

3 MEMBER MARCH-LEUBA: I know you don't know
4 it.

5 MR. STATTEL: In a later slide, I will
6 talk a little bit about the efficiency, because we do
7 aim to improve the efficiency of our evaluation
8 activities, and I will speak to that separately.

9 MEMBER KIRCHNER: But that's a different
10 matter than investment by the Applicant to actually
11 get a design mature enough that you can issue the LA
12 under the alternate review process. It strikes me the
13 bulk of the investment has been struck roughly where
14 the red line is on the bottom.

15 MEMBER BROWN: No, no, that's not the
16 case.

17 MEMBER KIRCHNER: So, the testing has --

18 MEMBER BROWN: I've built so much of this
19 stuff.

20 MEMBER KIRCHNER: Yes.

21 MEMBER BROWN: And if you get a system
22 design and an architecture, and it's laid out and you
23 understand it, you haven't committed to a vendor to
24 design, build, manufacture, test. All that money has
25 not been spent. In the tiered process, that money has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 been spent while you're getting the license amendment.

2 MEMBER KIRCHNER: Right.

3 MEMBER BROWN: That is a huge investment
4 in cost. The earlier part is cheaper.

5 MR. STATTEL: Yes, that's what the
6 licensees are telling us.

7 MEMBER KIRCHNER: Okay.

8 MR. STATTEL: We're the lower --

9 MEMBER BROWN: I did that for 22 years.

10 MR. STATTEL: Think about it this way:
11 where the lower red line on this chart here, they
12 haven't bought any equipment; they haven't built
13 anything; they haven't wired up anything; they haven't
14 built anything. Everything is on paper at that point.

15 MEMBER KIRCHNER: Oh, I was going from
16 your review above in the blue; it says "fabrication".

17 MEMBER BLEY: That's the top.

18 MR. DARBALI: Well, you know, the line is
19 flexible.

20 (Laughter.)

21 MEMBER KIRCHNER: Okay. I'm with Charlie.
22 I kind of said, well, if you are designing and
23 fabricating, that means you're procuring, then your
24 investment is huge.

25 MEMBER BROWN: If you look at the ISG,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there's a figure for the alternate review process.
2 I'm forgetting what the figure number is. And it is
3 more clear than this particular diagram --

4 MEMBER KIRCHNER: Okay. Thank you.

5 MEMBER BROWN: -- because all this other
6 dollars are not expended before that license amendment
7 is requested. Yes, that adds a little bit of
8 confusion, I agree with you on that.

9 MEMBER KIRCHNER: Yes.

10 MEMBER BROWN: I see your blue line in
11 there.

12 MEMBER MARCH-LEUBA: But is it true that,
13 if you're using an approved Topical, basically, you're
14 copying what some other plant did before, you get to
15 red real fast, the bottom red?

16 MR. DARBALI: Right.

17 MEMBER MARCH-LEUBA: I mean, if you just
18 copy what somebody else did, you just have to change
19 the name of the plant and you submit it?

20 MR. DARBALI: Right. Unfortunately, we
21 haven't seen so many digital modifications --

22 MEMBER MARCH-LEUBA: But, hopefully, we
23 will.

24 MR. DARBALI: Hopefully, yes.

25 So, that's one of the differences.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Another major --

2 MEMBER BROWN: Well, let me --

3 MR. DARBALI: Go ahead.

4 MEMBER BROWN: Let me comment on the
5 Topical Report. We've had three, I think it's two or
6 three design certifications where a particular
7 platform has been utilized, and that eliminated a
8 whole pile of work that the Applicant had to do. He
9 was just using that and using that as the main
10 framework for developing each of his designs. So,
11 that is a powerful incentive to not reinvent something
12 new, but to use something somebody's already got in
13 place and has applied before. That significantly
14 reduces the staff's needs, if there are minimal, if
15 any, changes to the platform software, the operating
16 system, and all you have to deal with is application
17 software and how it interfaces.

18 So, I think the use of existing components
19 that have been approved is a big incentive. That's
20 personal opinion. But, anyway, you can go on now.

21 MR. WATERS: I think staff agrees. We
22 have really positive experience with the new digital
23 neutron monitoring system. They've installed many
24 plants using them over Topical. And as we get more
25 and more a little more frequently, we've become more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 efficient and they use the same thing. Obviously, if
2 the fleet operators want to do things for major
3 upgrades, we would hope to have the same efficiencies
4 after we get a standardized process going, and if they
5 use the same Topical, the same configuration, we hope
6 to have the same savings.

7 MR. DARBALI: So, the other change between
8 the two processes is that orange box at the bottom,
9 which identifies that, for those activities that the
10 staff would not be performing a review on, mainly
11 implementation and testing, including factory
12 acceptance testing, results, those would be covered by
13 optional vendor inspections. And the staff would be
14 engaging the vendor inspection and site inspection
15 team from the very beginning. Actually, the staff
16 expects to be part of those inspection activities.
17 So, those would be covered.

18 Next slide.

19 This slide summarizes some of the
20 characteristics of a license amendment request that
21 uses this new alternate review process. As we said,
22 the LAR has to provide the necessary and sufficient
23 design information to demonstrate regulatory
24 compliance. They don't have that Phase 2 option.

25 The licensee's vendor oversight plan is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 described, and this plan ensures that the vendor
2 executes the project consistently with the license
3 amendment request and consistent with requirements of
4 the 2015 version of ASME NQA 1.

5 Appropriate commitments to complete
6 Topical Report plant-specific action items will be
7 included. So, every Topical Report, because it's
8 generic, includes specific action items that need to
9 be performed that are plant-specific. So, the
10 licensee needs to provide that information.

11 For those activities that would occur
12 after the license amendment is issued, the LAR should
13 include commitments to complete those activities. And
14 some of those, as we'll talk later, may be converted
15 to conditions. The license amendment request also
16 should include commitments to complete those life-
17 cycle activities under the licensee's QA program.

18 Next.

19 As I said, the alternate review process
20 relies on those additional regulatory commitments, and
21 the staff may translate some of those regulatory
22 significant commitments into license conditions; for
23 example, factory acceptance test results.

24 Next.

25 This slide describes those activities that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the staff would be performing with the licensee during
2 the Phase 0 pre-application coordination meetings.
3 So, one of the topics that we would be discussing with
4 the licensee is which review process should be used
5 for the LAR. We expect the licensee to come in and
6 say, "I want to use the tiered process" or "I want to
7 use the alternate review process." And so, we'll have
8 a discussion with the licensee, and the staff will,
9 then, internally make a determination whether they can
10 actually do that. So, the staff has the final say as
11 to what review process will be used.

12 We will also discuss the use of a
13 preapproved Topical Report and any significant
14 changes. So, that would help us determine if it's a
15 Tier 1/Tier 2 review.

16 We'll talk about the portion of the plant
17 system to be replaced; key design concepts, including
18 the four fundamental design principles; any variances
19 from the current I&C guidance, and we'll also cover
20 the applicability of Enclosure B, and we'll show you
21 that Enclosure B soon.

22 Next slide.

23 When we briefed the Subcommittee back on
24 May 17th, one of the main comments was the tiered
25 process does not seem to cover the system architecture

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as part of its review. The staff took that comment
2 and went back and looked at the ISG, and realized
3 that, yes, for the alternate review process, we do
4 emphasize a lot of that system architecture review.
5 We didn't do that, even though it is our intention to
6 review it for the tiered process. So, we went back
7 and we decided to make Section D.2, which would only
8 apply to the alternate review process, it will now
9 apply to both processes. So, it will be clear now
10 that system architecture is covered, regardless of the
11 review process used.

12 Another comment was regarding the four
13 fundamental --

14 MEMBER BLEY: And you've built that into
15 the Draft now?

16 MR. DARBALI: Yes, yes.

17 MEMBER BLEY: So, the one that says "Out
18 for comment" would include that?

19 MR. DARBALI: Yes. That change has been
20 made, and we'll show you that in the Enclosure B
21 table.

22 Another comment was the four fundamental
23 design principles are emphasized for the alternate
24 review process and not the tier process. Because that
25 section is still part of Section D.2., by making

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Section D.2 applicable to the tier process, we solve
2 that issue as well. So now, the four fundamental
3 design principles are covered in both processes.

4 And then, hardware configuration control.
5 This slide, it's not up-to-date as to how the ISG
6 looks right now. So, the comment on hardware
7 configuration control was that the ISG was silent. We
8 keep emphasizing software configuration management,
9 software configuration control, but we make no mention
10 of hardware.

11 So, what we've done since that meeting,
12 and since we submitted this slide, is we scrubbed the
13 ISG. We looked when we talk about configuration
14 management, and we had a section D.4.2.5. It used to
15 be titled, "Software Configuration Management
16 Process". We looked at it. We realized we don't need
17 to exclude hardware. So, right now, it's just
18 "Configuration Management Process". Whenever we've
19 talked about configuration management, and we've
20 focused on software, we realized that there's no need
21 to just exclude it. So, one of the fixes was to
22 remove the word "software"; just make it generic.

23 One of the things to understand is, the
24 reason we tend to focus on software configuration
25 management is because hardware configuration

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 management has always existed. And licensees, under
2 their QA programs, and vendors under the QA program,
3 typically handle that.

4 When the digital I&C software
5 configuration management guidance has been put out,
6 it's to kind of explain or re-emphasize to licensees,
7 hey, software is different; you should be doing
8 configuration management of software. It may have
9 given the impression that we don't care about
10 hardware, which is not true. A lot of times, when we
11 look at our configuration management reviews, vendors
12 use what they call a configuration status accounting-
13 type document, and that includes not only the software
14 version and software changes, but also hardware
15 versions. And so, they identify the modules. They
16 identify the components. So, it is covered.

17 We tried to change the language in the ISG
18 so hardware wasn't excluded. We did not create or add
19 or reference any other hardware-specific configuration
20 management documents because I don't think we use any.
21 So, that's how we tried to address that particular
22 comment.

23 MEMBER SKILLMAN: Samir, I understand, I
24 think I understand what you're trying to communicate.
25 The basis of my comment is that, at least in my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experience, where plants have really gotten into
2 trouble, they've been so eager to implement a change,
3 a license amendment, a hardware change, a widget
4 change, they get so caught in the ether of what
5 they're going to get when they have this new thing,
6 that they are often not as rigorous and disciplined as
7 they need to be to make sure that the "i's" are dotted
8 and the "t's" are crossed in the documentation and
9 that they've gone back into the bowels of their plant
10 and made certain that the whatever it is they're
11 changing has not created an unintended consequence.

12 MR. DARBALI: Right.

13 MEMBER SKILLMAN: That was what I was
14 thinking when I made the comment.

15 MR. DARBALI: Okay.

16 MEMBER SKILLMAN: I think you've said, by
17 extracting the word "hardware," you're using
18 "Configuration Management," capital "C", capital "M",
19 and that ought to take care of it. With all due
20 respect, I'm not sure you've gone far enough.

21 It seems to me that there should be a
22 bunch of exclamation points where your document says,
23 "We've been through this a couple of times, and those
24 who have succeeded have succeeded because they've
25 really paid a lot of attention to these fine details.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And where we've found problems is where the integrity
2 of the configuration management/configuration control
3 program has not been as rigorous as it needs to be.

4 And there's one more piece. The
5 configuration management discussion needs to be hooked
6 to a rigorous Appendix 16, xvi, of your Appendix B
7 program for reporting issues, whether you call it
8 "condition reports," or whatever the utility uses.
9 But there needs to be a way to make sure that what you
10 find in the exploring of the configuration control
11 issues gets caught by your corrective action program
12 and it gets vetted by the station staff, so that they
13 understand what the extended condition might be.

14 MR. DARBALI: Right.

15 MEMBER SKILLMAN: Because in so many
16 cases, an I&C change really has extended condition
17 issues that are not obvious.

18 MR. DARBALI: Right.

19 MEMBER SKILLMAN: That's a long sermon.
20 I apologize, but that was the heart of what I was
21 trying to communicate.

22 MR. DARBALI: Okay.

23 MEMBER SKILLMAN: And I know from
24 experience, if you look at the 95-003 plants, the
25 95-002 plants, the 0350 plants, the fingerprint on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 each of those plants is a breakdown in configuration
2 control, a breakdown in corrective action. And the
3 price is so high for those people who have fallen
4 under that situation.

5 Here you might be doing a frontal lobotomy
6 on a plant. This is the place to catch it right on
7 the front end where your ISG says, "Caution, caution,
8 caution"; when you're getting into this, understand
9 what you're dealing with.

10 MR. DARBALI: Okay.

11 MEMBER SKILLMAN: So, I thank you.

12 MR. DARBALI: No, I appreciate that
13 feedback.

14 MEMBER BROWN: I'm going to amplify Dick's
15 comment a little bit. In thinking about how we
16 address this, it was, as he phrased it in the
17 Subcommittee meeting on the 17th, it was relative to
18 the licensee having ownership of what the design looks
19 like when they get it, so that they can ensure that
20 their procedures, practices, and actual management
21 configuration, management systems that are in place,
22 are now consistent with the new technology and don't
23 still rely on the practices that existed for the old
24 technology. I'm squishing his comments from the May
25 17th thing down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. STATTEL: I would just say that the
3 staff agrees. The staff agrees that configuration
4 management is an important characteristic for
5 hardware, software, anything involved with these plant
6 modifications.

7 We're just really trying to explain that
8 the emphasis was placed on software because this is
9 guidance that's basically above and beyond, unique to
10 digital systems. So, what's unique about digital
11 systems? Primarily, it's the software, the HDL
12 implementation. That's why it was that way.

13 When we received your comment, we do agree
14 that, when you emphasize software, you're
15 inadvertently also de-emphasizing the hardware aspects
16 of it, and we didn't intend to do that. So, we're
17 willing to make changes to basically put it on equal
18 footing. We're kind of struggling with exactly where
19 to do that.

20 MEMBER MARCH-LEUBA: But I'm thinking on
21 hardware configuration control, the fact that there's
22 a very limited number of vendors that can supply the
23 system -- it's not you can, almost like at home, buy
24 a power range monitor. You're already from GE. You
25 install it from GE, and if you need a spare part,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you're going to buy it from GE.

2 MR. STATTEL: Correct.

3 MEMBER MARCH-LEUBA: There is no way you
4 are going to put something else. So, maybe if that is
5 the issue, say that the vendor must keep how the
6 configuration control is. Probably the plant doesn't
7 have any option to change it.

8 MR. STATTEL: Right.

9 MR. DARBALI: Okay. Appreciate that.
10 Thank you.

11 MR. WATERS: So, we'll be happy to take a
12 look at the ISG again to see if there's any clarifying
13 language to add the emphasis there before we issue for
14 public comments. And it sounds like some of this
15 conversation also helps us when we converse with the
16 Inspection Program because this is also an issue we
17 want to ensure is appropriately inspected with the
18 right rigor as well. So, we'll see what we can do in
19 the Draft ISG before we feed it back to you and before
20 we issue for public comment.

21 MR. DARBALI: So, this slide covers some
22 of the changes we've made to the ISG since we last
23 presented it.

24 Like we said, Section D.2, System
25 Architectures, now applies to the Tier 1, 2, and 3

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review process.

2 Also, Section D.3, Hardware Equipment
3 Qualification, now also applies to Tier 1, 2, and 3.
4 What happened was we had that Section D.9.9, which
5 basically covered that same information specifically
6 to the Tier 1, 2, and 3 review process. We realized
7 there was no need to have that guidance separate. So,
8 we eliminated D.9.9 and we made sure that guidance is
9 covered by D.3.

10 We've made general editorial changes for
11 clarification. So, we made the changes regarding
12 configuration management, and we'll go back and look
13 at those.

14 We had language for pre-application
15 coordination meetings and post-license-amendment
16 activities, and we had that separate for each process.
17 We realized those activities are actually common. So,
18 we kind of changed how Section C looks. So now, that
19 information is more consolidated.

20 Next slide.

21 And now, I'll turn it over to Rich to talk
22 about the structure of the ISG.

23 MR. STATTEL: The diagram you see here is
24 illustrating the new structure of ISG-06. It
25 basically is a chapter breakdown of the new document,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and we did restructure it significantly from the
2 original version.

3 The ISG will now provide guidance for two
4 different regulatory evaluation processes. So, it
5 contains sections that are common to both processes as
6 well as sections that are unique to each.

7 As an example, Section D.1 provides
8 guidance for evaluating and describing the system
9 that's being modified. Since the evaluation is the
10 same for this area, regardless of the type of review
11 being performed, the team saw no need to duplicate
12 this guidance. So, therefore, D.1 is now applicable
13 to both the Tier 1, 2, 3 process and for the alternate
14 review process. Section D.4, on the other hand,
15 provides guidance for development planning processes
16 that is unique to the alternate review process. And
17 thus, it is only referenced in the alternate review
18 process tables of the enclosure.

19 Conversely, Section D.9 provides guidance
20 for evaluating design products that would not be
21 available for an alternate review prior to issuance of
22 the license amendment. Therefore, D.9 is only
23 referenced in the Tier 1, 2, 3 sections/tables of the
24 enclosure.

25 We can also look at the Enclosure B

1 itself, which I kind of prefer to do. This is
2 actually right out of the ISG. Here are two tables
3 that are provided in Enclosure B of the new Revision
4 2. The first table identifies the information to be
5 provided with the license amendment request. This
6 table is applicable to both the alternate review
7 process, as you can see by the columns, and the Tier
8 1, 2, 3 review processes. The second table
9 corresponds to the Phase 2 supplemental information.
10 Now that table is unique to the Tier 1, 2, and 3
11 review processes.

12 So now, also note that the X's in this
13 table, their guidance and assessment will still need
14 to be done for each application to determine the
15 appropriate information that would be needed for a
16 particular license amendment request.

17 Revision 1 of the ISG also included a
18 Phase 3 table which identified documents that would be
19 made available for inspection after the issuance of
20 the license amendment. This table was removed because
21 we did not intend to provide inspection guidance in
22 this ISG.

23 I mentioned before I was going to talk a
24 little bit about efficiency. So, this is where this
25 comes in. One of the things you will notice is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the planning and process review guidance is now only
2 applicable to the alternate review process. The
3 reason for that is because, without having final
4 design products in hand or being able to look at
5 those, you kind of put more emphasis on the planning
6 and the quality processes that go into building that
7 system. So, there is more of an emphasis placed on
8 the processes.

9 Whereas, with a Tier 1 review, we have
10 final design products in hand, so we're able to de-
11 emphasize the process. So, it's not as important that
12 you had good planning. I mean, it's important. We're
13 not trying to say it's not important. But, if you
14 have the final product and you have test results and
15 you have evidence that it meets the regulatory
16 requirements, the planning processes aren't quite as
17 important.

18 So, we're able to gain some efficiencies
19 here by spending more of our time on reviewing those
20 design outputs as opposed to spending time reviewing
21 planning processes, which, even if you find problems
22 with the planning, they are not going to affect the
23 design outputs when they're already in --

24 MEMBER MARCH-LEUBA: Yes, I understand
25 what you're saying.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STATTEL: Yes.

2 MEMBER MARCH-LEUBA: You need to educate
3 me a little bit, and I apologize, I was not here for
4 the May Subcommittee meeting, and that's why I need to
5 ask, for personal reasons.

6 1.15 triggered just a thought here. I
7 mean, if you are designing and replacing a flood
8 protection system, you don't have enough boxes here.
9 You have to go through all this. But now, if I'm
10 replacing a relay, an analog relay, with one that has
11 some better digital components, does it trigger
12 everything, or can I get out of it before I start? I
13 mean, I'm just replacing a one-to-one relay, but this
14 one has some microprocessor inside. At what point do
15 I go to jail? You know what I mean, get out of jail
16 on the Monopoly.

17 MR. STATTEL: Well, I would say that the
18 ISG is really developed with -- we're replacing a
19 reactor protection system.

20 MEMBER MARCH-LEUBA: But help me
21 personally relate.

22 MR. STATTEL: That's really the scope of
23 this. And it gets a little awkward when you try to
24 apply it to Topical Reports when you don't even know
25 what they're going to build with it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And also, like your example, if we're just
2 doing a relay-type replacement, it's really hard to
3 fit it into this mold.

4 MEMBER MARCH-LEUBA: But is it clear that
5 it doesn't apply?

6 MR. STATTEL: Correct, yes.

7 MEMBER MARCH-LEUBA: It is clear? I'm not
8 sure. I'm asking you.

9 MEMBER BLEY: You could turn it around and
10 say, is it clear what applies, what are the
11 requirements if you do a simple thing like that?

12 MR. STATTEL: And it's a challenge for us
13 because, when we have our Phase 0 meetings, these
14 types of aspects come up during those meetings and we
15 have these discussions, right? And where there is no
16 clear guidance, essentially, at that stage we're
17 developing a review plan, a unique, specific review
18 plan for that type of operation.

19 MEMBER MARCH-LEUBA: But a relay would
20 probably come into --

21 MR. STATTEL: In your example, relay
22 replacements, actually, I've never seen one actually
23 come in as a license amendment, because, typically,
24 those would be brought --

25 MEMBER MARCH-LEUBA: But I'm saying relay

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because that's the one that caused a problem in the
2 past --

3 MR. STATTEL: Right.

4 MEMBER MARCH-LEUBA: -- where you guys
5 know the example.

6 MR. WATERS: Right, and we would expect
7 these to be done in 50.59, so that inspection -- but,
8 if for some reason, someone had to come and get a
9 license amendment to approve this, we do have the
10 broader Chapter 7. And the key there is having a
11 complication meeting and having the discussion of what
12 would we look at and what not. We may not even go
13 into ISG-06. We'll just say, you know, Section 1.-
14 whatever of the SRP covers it. The key is to have
15 that conversation.

16 MS. ZHANG: This is Deanna.

17 That was actually discussed, about
18 replacement of certain components instead of replacing
19 a whole system, whether we should revise this ISG to
20 include guidance for that. We had to prioritize what
21 guidance we want to focus on for this revision, and we
22 decided to defer that to later.

23 MEMBER MARCH-LEUBA: I'm not complaining.
24 I'm just asking you, the guys that wrote it, are we
25 falling into a trap that, if I want to change a relay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I have to go through all of this?

2 MEMBER BLEY: Or do we confuse the
3 licensee who doesn't know what the heck to do with
4 replacing a component? Does this apply to me? Does
5 it not apply? Can I just do it under 50.59? What do
6 I do?

7 MR. WATERS: My belief is, no, just given
8 the amount of dialog we've had in the last several
9 years, both on this and the 50.59 process. You're
10 probably going to understand what they plan to do
11 under 50.59, what they have to do to address those
12 questions. This is for major upgrades. As Deanna
13 said, we deferred having it for every type of possible
14 upgrade. If we get one for a LAR, we'll just have to
15 make a game-day adjustment and tell them what we need
16 to --

17 MEMBER BLEY: I assumed that was what it
18 was, but, until Jose brought it up, I never really
19 thought about what do I do if I a small change.

20 MR. STATTEL: We do get questioned about
21 this often. What I tell licensees is, don't assume
22 that it does not apply. If you have a question, have
23 a Phase 0 meeting.

24 And we have had Phase 0 meetings where,
25 after we discuss it and talk about what's entailed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here, we all agree that a license amendment is not
2 required and they don't have to apply all of this
3 guidance to those types of modifications.

4 MEMBER MARCH-LEUBA: I know it's a little
5 late, but --

6 MR. STATTEL: So, we have had several.
7 And I encourage licensees to come in and have those
8 meetings, even if they don't necessarily lead to an
9 actual license amendment.

10 MEMBER MARCH-LEUBA: I know it's a little
11 late, but I would have put a 1.01 step. Let's say
12 it's applicability.

13 MR. STATTEL: Right.

14 MEMBER MARCH-LEUBA: Very simple. Put it
15 in the guidance that this doesn't necessarily apply to
16 everything or something. I mean, review
17 applicability, or something like that.

18 MR. STATTEL: There has been a lot of
19 criticism in recent months over the onerous criteria
20 that exists around digital I&C equipment. And it is
21 onerous, and part of the reason for that, Chapter 7 is
22 a pretty encompassing review guidance and it covers
23 everything from planning aspects to design, to
24 implementation, to testing. So, it covers all
25 aspects. It is basically an all-things-to-all-people,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 everything soup to nuts involved with the development
2 process of digital I&C systems.

3 What we're trying to do is, we can't just
4 remove that because it is, actually, very good
5 guidance, depending on what aspect of the development
6 process you're looking at, you're evaluating. But
7 what we can do is we can emphasize and de-emphasize
8 certain things, depending on exactly what it is you're
9 looking at.

10 So, in a Phase 1 -- or I'm sorry -- in a
11 Tier 1 review where we're looking at design outputs
12 and we see test results, we can de-emphasize those
13 planning parts. In an alternate tier where all we see
14 is the planning and development activities, we can put
15 additional emphasis on that and, of course, we can de-
16 emphasize the test results in those cases.

17 MEMBER BROWN: We need to keep moving.
18 So, I want to just make the Committee aware there are
19 other thrusts of their evaluations. RIS 2002-22 has
20 to deal with these types, the 50.59 type, what falls
21 under that to some extent, as well as another set of
22 documents relative to embedded digital devices, which
23 inflames other emotions when you get involved with
24 them.

25 Before you shift off of this, you made a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comment relative to Phase 2, and there is no Phase 3.
2 Yet, there is a post, in your figure C.1, there is
3 what you call a post-license-amendment issuance, which
4 is, in my view, kind of a Phase 3, but it's not part
5 of the actual -- it's after license amendment has been
6 applied. So, I agree, you've deleted the old Phase 3,
7 but there's still, in a tiered system, there is still
8 a post-license. I don't think it's --

9 MR. STATTEL: That's true. The process is
10 still there.

11 MEMBER BROWN: And it's in both. It's in
12 both, as the alternate review process and the other
13 one.

14 MR. STATTEL: But we removed the table
15 from the enclosure.

16 MEMBER BROWN: Yes, I got that part, but
17 it doesn't need it. It's just that it's not like
18 everything stops --

19 MR. STATTEL: Right.

20 MEMBER BROWN: -- after Phase 2. That's
21 the point.

22 MR. STATTEL: That's true. Right.

23 MEMBER BROWN: Okay?

24 MR. STATTEL: Yes.

25 MEMBER BROWN: All right. Go ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DARBALI: One more point I would like
2 to bring on the relay. The industry members --

3 MEMBER BROWN: You don't know when to
4 stop, do you?

5 (Laughter.)

6 MR. DARBALI: The industry members that
7 have participated in the public meetings regarding
8 ISG-06 are also involved in an industry effort to
9 create a digital design or engineering design guide
10 document. So, it's meant to be an industry guide
11 document, and we'll tell them how to apply the ISG.
12 We haven't seen the document, but we would expect that
13 that guidance document would tell licensees for what
14 type of notifications they should use the ISG.

15 MEMBER BROWN: Okay. Keep rolling. Next
16 slide.

17 MS. ZHANG: I might --

18 MEMBER BROWN: Oh, you're on it?

19 MS. ZHANG: Again, my name is Deanna. I'm
20 here to discuss the system architecture section, and
21 specifically on the four fundamental design
22 principles.

23 As Samir and Rich both stated, this
24 section has now been expanded to apply to both the
25 Tier 1, 2, and 3 process as well as the alternate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review process. So, this fundamental design
2 principles and the system architecture was in that
3 system architecture section, has been emphasized in
4 this Revision 2, ISG-06.

5 Just to reiterate, the four fundamental
6 design principles include redundancy, independence,
7 deterministic behavior, diversity, and defense in
8 depth. And these are the same fundamental I&C design
9 principles used in support of the staff's ongoing
10 NuScale Chapter 7 review, which the staff uses, the
11 Design Review Standard, DSRS.

12 So, it is expected that the licensee
13 provides the information that supports the Safety
14 Evaluation, including demonstrating how the proposed
15 design and architecture meet the four fundamental I&C
16 design principles and how applicable regulations are
17 met.

18 For the fundamental design principle of
19 redundancy, the system architecture section specifies
20 that the NRC staff should verify that the licensee has
21 demonstrated there is sufficient redundancy in the new
22 architecture. This includes verifying that the single
23 failure criterion reliability and requirements for
24 maintenance bypass have been addressed by the design.

25 For the fundament design principle of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independence, the system architecture section
2 specifies that the NRC staff should verify that the
3 licensee has demonstrated that the design applies
4 physical, electrical, data communications independence
5 as well as functional independence in the new
6 architecture. The staff should review whether
7 connections internal to the safety system, including
8 cross-divisional interfaces, connections to human
9 systems interfaces, connections between safety-related
10 and non-safety systems have been adequately
11 identified.

12 For the fundamental design principle of
13 determinism, the system architecture section specifies
14 that the NRC staff should verify that the licensee has
15 demonstrated that the design exhibits deterministic
16 behavior. So, the reviewers should evaluate whether
17 deterministic behavior of the new architecture ensures
18 input signals and system characteristics result in
19 output signals through known relationships among the
20 different system states and responses to those states,
21 and the system produces the same outputs for a given
22 set of input signals within a well-defined response
23 time limit. In other words, the design exhibits
24 predictable and repeatable behavior.

25 Information should also be provided on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design to demonstrate that software failures, whether
2 they affect the watchdog timer functions, including
3 when the watchdog timer times out. This information
4 should address hardware and software malfunction
5 coverages for the watchdog timer, including a
6 description of the enunciation and the effects on the
7 plant during and after any reset of the functions
8 initiated by an expiring watchdog timer.

9 For the fundamental design principle of
10 diversity and defense in depth, the system
11 architecture section specifies that the NRC staff
12 should verify that the licensee has demonstrated, via
13 diversity and defense-in-depth evaluation, that the
14 use and application of D.3 in the new architecture
15 ensures that safety is maintained in the event of a
16 postulated software common-cause failure.

17 Next, I'll pass it on to Samir for the
18 license and oversight --

19 MEMBER BROWN: But, before you do that,
20 I'll just bring up, as we discuss in all the new
21 certifications and other aspects, even when we did
22 Diablo Canyon, there was an emphasis, also, on --
23 although nobody likes to admit it -- control of
24 access. And that is not directly addressed in the ISG
25 as a principle, although you probably recognize that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as long as I'm on the Committee will be resolving
2 control of access, and not relative to a cybersecurity
3 issue, but relative to just blocking off access from
4 external to the plant. I mean, it's literally
5 applying the same thing to the new architectures that
6 we apply to how you manage access to the hardware and
7 the cabinets inside the plant that we've always done.
8 So, I haven't figured out how to get you guys to admit
9 to that yet.

10 CHAIR CORRADINI: If you hadn't said this,
11 I would have been shocked.

12 (Laughter.)

13 MEMBER BROWN: Yes, I just wanted to get
14 it on the record that that is an aspect that is
15 missing from the ISG.

16 MR. DARBALI: Okay. So, I think I'll --

17 CHAIR CORRADINI: Just let it go.

18 (Laughter.)

19 MEMBER BROWN: I don't want you to take
20 any issue with my comments. They're simply meant to
21 be put on the record and to put everybody on notice
22 that --

23 MS. ZHANG: We understand.

24 MEMBER BROWN: It's a very important
25 issue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DARBALI: I will only say secure
2 development and operational environment is covered --

3 MEMBER BROWN: That has nothing to do with
4 control of access.

5 Okay. Have at it now.

6 MR. DARBALI: All right.

7 MEMBER BROWN: You can work on your little
8 chart here.

9 MR. DARBALI: This is just a summary of
10 the two different processes. The Tier 1, 2, and 3
11 review process has two submittals, one with the LAR
12 and, then, the supplemental Phase 2. Whereas, the
13 alternate review process just has one submittal, which
14 is the LAR.

15 If there are design changes made after the
16 license amendment request has been submitted, under
17 the tier review process, those can be incorporated as
18 part of the Phase 2 review. Whereas, if those occur
19 during the use of the alternate review process, it may
20 not be possible to review those. So, those would have
21 to be performed with a new license amendment request,
22 if needed, or through the 50.59 process.

23 We typically don't have license conditions
24 for the Tier 1, 2, and 3 review process. And when I
25 say "license conditions," I mean specific to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 digital I&C platform design. Whereas, with the
2 alternate review process, we envision we will have
3 license conditions regarding those implementation and
4 testing activities.

5 And then, the inspection scope, both the
6 tier process and the alternate review process will
7 make use of our regional and site inspection process,
8 but the alternate review process will make use of the
9 vendor inspection process to look at those
10 implementation and testing activities.

11 Next slide.

12 So, the next steps in the ISG-06 revision
13 project is to issue Revision 2, Draft Revision 2, for
14 public comments at the end of July; if not, early
15 August. We are going to be conducting an inspection
16 workshop with industry in September to go over these
17 additional inspection activities related to the
18 alternate review process. We expect to issue the
19 final ISG at the end of the year, and then, engage
20 utilities in the use of the ISG Revision 2 through
21 pre-application meetings. And eventually, we do know
22 this is an Interim Staff Guidance, so we do know that
23 we will be incorporating this into the standard review
24 plan or our Reg Guide.

25 MEMBER MARCH-LEUBA: Samir, do you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 envision any additional ACRS involvement after the
2 public comments are addressed?

3 MEMBER BROWN: Our letter will address
4 that.

5 MR. DARBALI: Okay.

6 MEMBER MARCH-LEUBA: Well, I'm asking
7 them.

8 (Laughter.)

9 MR. DARBALI: We will be happy to
10 accommodate that, if the Committee feels they would
11 like to be briefed again. We're trying to follow an
12 NRR Office instruction. I forgot -- like 508, I think
13 it is. It's the ISG development process. It only
14 calls for one briefing to the ACRS, but I'm sure we --

15 MR. WATERS: Yes, let us circle back to
16 that. We want to make this summer date, and we're
17 happy to engage the ACRS. I don't think we had
18 planned to resubmit the final version review or
19 meetings. But we do plan for, when we get an
20 application in, to engage on an actual application
21 that would be used in this Draft ISG, whenever that
22 comes in.

23 MEMBER BROWN: But we will address that in
24 our letter. I can only comment that we've done a
25 complete review of the ISG as it presently stands.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Depending on the nature of public comments and how
2 they're incorporated, if they do something -- so, we
3 will have to evaluate what we do with that subsequent
4 to this particular letter. So, I'm not counting it
5 out, but I'm not saying you'll have to.

6 Is that an appropriate -- I think that's
7 an appropriate way of phrasing it.

8 MR. DARBALI: Yes. Appreciate it.

9 MEMBER BROWN: I'm done. Yes, I would
10 just emphasize we've got a hard stop at 12:15. We've
11 got about nine slides left for the IAP discussion.

12 CHAIR CORRADINI: And then, we still have
13 to reserve time for public comment.

14 MEMBER BROWN: Public comments. So, if
15 you could finish in about 30 minutes or so, that would
16 be useful. Or earlier. That's fine, also.

17 CHAIR CORRADINI: I can't control the
18 members in terms of their interactions. I can't even
19 control myself. That's also the truth.

20 So, have at it.

21 MR. RAHN: Yes, sir. So, thank you. I
22 will lead you through this discussion on the
23 Integrated Action Plan.

24 We did have an early introduction of this
25 plan back in 2016, before it actually became a formal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 document. We briefed the Digital I&C Subcommittee.
2 And then, last year, we also briefed them on the
3 status of the Integrated Action Plan in May of last
4 year, also, the Digital I&C Subcommittee. I think
5 this might be the first time we're presenting it to
6 the full Committee.

7 What we would like to talk about today is
8 just an overview, and then, perhaps be ready to answer
9 questions that you may have.

10 The key items that we would like to
11 emphasize are that, once we've embarked upon the
12 Integrated Action Plan, we work closely with
13 stakeholders, typically through a series of public
14 meetings, to identify what kinds of regulatory
15 products would be most beneficial for them. And then,
16 we work to develop those products, have some kind of
17 comment process on those products, especially if it's
18 the regulatory process, it requires it. And then, in
19 addition, we have now started to release the first of
20 our products.

21 We have been focusing on those products
22 that only answer the near-term needs. So, we've
23 essentially prioritized everything into what we call
24 tactical and strategic planning efforts. We have been
25 focusing on the products that are part of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 technical effort right now.

2 And so, recently, we released a document
3 that Charlie recently just mentioned. We issued a RIS
4 supplement to RIS 2002-22. That document endorses an
5 NEI implementing guide which is called NEI-0101. In
6 that document, there has been maybe some uncertainty
7 regarding the appropriate use of that. We have some
8 inspection items where it appeared that the licensees
9 didn't all fully understand what the guide was telling
10 them to do.

11 But, most importantly, they were having
12 difficulty implementing the upgrades under a 10 CFR
13 505.59 process. So, RIS 2002-22, Supplement 1,
14 provided a more clarified way of approaching how to
15 prepare for doing 50.59 evaluations using what we call
16 a qualitative assessment process. We had, actually,
17 a briefing of the Subcommittee on that specific topic
18 last month.

19 Also, we are planning on considering the
20 long-term needs yet for what should our digital I&C
21 infrastructure look like. And so, we've started the
22 ball rolling as far as identifying topics to be worked
23 on. But, most importantly, we're at the point now
24 where we've overcome the hurdle of what we need for
25 the short term. We would like to now have a better

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 informing of what our long-term process should look
2 like. So, at the end of this month, we've scheduled
3 a public meeting to help that process.

4 Yes?

5 MEMBER BLEY: Can I interrupt?

6 MR. RAHN: Yes.

7 MEMBER BLEY: And this is more a
8 Committee/Subcommittee question, a Committee question,
9 Charlie. But my impression was in our letter we're
10 only addressing the ISG.

11 MEMBER BROWN: Just the ISG-06.

12 MEMBER BLEY: Were we intending to ever
13 address the RIS or is that on our calendar or not?

14 MEMBER BROWN: Right now, it's been
15 issued.

16 MEMBER BLEY: Oh, it's just out there?
17 Okay.

18 MEMBER BROWN: Yes. There was an earlier
19 version that was issued, I've forgotten when.

20 MR. RAHN: Yes, there was a version issued
21 in July for public comments, last July.

22 MEMBER BLEY: Right.

23 MR. RAHN: And then, we issued it again
24 for public comments in March of this year.

25 MEMBER BROWN: Is that Supplement 1?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAHN: Yes, it's still Supplement 1.

2 And then, we've incorporated public
3 comments received during that March time period.

4 MEMBER BLEY: Okay.

5 MR. RAHN: And now, it's been formally
6 issued.

7 MEMBER BLEY: Okay. Thank you.

8 MR. RAHN: So, what we're embarking on is,
9 there are directions we got from the Commission that
10 were identified in two SRM documents, 15-0106 and
11 16-0070. Those documents were initiated because we
12 were attempting to perform an incorporation by
13 reference of the 2009 version of IEEE 603. And when
14 the proposed language for rulemaking went up with that
15 info paper -- I'm sorry, it was a SECY paper -- it was
16 also submitted with not only incorporating by
17 reference IEEE 603, but also includes some additional
18 requirements regarding things like digital
19 communications and independence, and there was some
20 additional phrases that were being proposed.

21 And the Commission decided that, rather
22 than to take it upon ourselves to change the rule by
23 inserting these additional clauses -- and some of
24 these clauses were not -- they would be good for new
25 reactor applications, but not ideal for operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactors because their design basis and their
2 licensing basis was based on the previous versions of
3 IEEE 603. So, they were suggesting that, rather than
4 propose new rules, a better approach would be to
5 identify what should be the really important
6 requirements, and put those in the rule, and then,
7 identify other enhancements of that as guidance, and
8 keep that in the guidance level.

9 So, they provided us an SRM that basically
10 had these bullets included in there, which was let's
11 not only address this rulemaking for 603, but look at
12 the whole broad picture of how do we do digital I&C
13 regulatory reviews, and provide some kind of a
14 strategy that has some kind of a cohesive effort that
15 addresses all the needs for the agency as well as
16 stakeholders, but primarily making sure that we have
17 good representation of the NRR, NRO, and Research
18 needs in mind.

19 And then, along the way, in doing that, we
20 were to identify the best ways of engaging all our
21 stakeholders to provide input for our consideration
22 and help to identify regulatory problems and solutions
23 for them. Basically, all new requirements should be
24 performance-based. We had a little discussion last
25 month of what does performance-based mean. But we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 aiming towards keeping that in mind. And so far, we
2 haven't identified new requirements at this point,
3 but, if we do, that's the approach we're going to
4 take.

5 We're going to focus on what kinds of
6 approaches would be acceptable and to comply with the
7 current requirements. And if we come up with new
8 requirements, it's the same thing; come up with
9 guidance for that.

10 Any new requirements should be technology-
11 neutral. And I think we talked about technology-
12 inclusive. I think that was something another
13 licensee brought to our attention. And then, in
14 addition, a guidance for any specific technology types
15 could be tailored, if necessary.

16 The same requirements should apply to new
17 reactors and operating reactors. And we also need to
18 evaluate any policy issues that could arise while
19 we're going to through this process and bring it to
20 the attention of the Commission as early as possible.

21 So, the approach we have taken, as I
22 described a little earlier, is that we looked to see
23 what all inputs we had from stakeholders, and we tried
24 to work with them to prioritize what are their needs
25 and what's their relative priority. And so, we broke

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our approach into two pieces, a tactical, for address
2 all our short-term needs, and a strategic, which will
3 identify where should we go with this regulatory
4 infrastructure for the long term.

5 The long-term need is to also identify not
6 only the types of lightwater reactors that we're
7 currently licensing, but also any new small modular
8 reactors or advanced reactors that could be proposed.
9 So, the regulatory infrastructure needs to be
10 accommodating to all those different types of
11 technologies.

12 The plans that we have --

13 MEMBER BROWN: Let me make an
14 observation --

15 MR. RAHN: Yes, sir. Yes.

16 MEMBER BROWN: -- if I could. Going back
17 to the comment about the same requirements for
18 operating versus new reactors --

19 MR. RAHN: Yes.

20 MEMBER BROWN: -- which I totally agree
21 with, just for the Committee members who have not been
22 on the Committee for a long time -- Dennis will
23 remember this, and so will Mike, probably Dick to some
24 extent. I think that might be about it. Since we
25 started dealing with the digital stuff back in 2008

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and '09 on -- I've forgotten what the plant was, ESBWR
2 -- the Committee, us, our viewpoint has been applied
3 in exactly the same way, whether it has been a new
4 design reactor or upgrades for the operating reactors.
5 And I've always wondered how in the world can we get
6 that thought process applied relative to how you all
7 do your infrastructure. I haven't come up with a good
8 way to do that yet. But the fundamental principles
9 approach to evaluating it, and then, having everything
10 else waterfall under that, is a very consistent way of
11 applying it to both new and operating reactors in
12 terms of new reactor protection and safeguard systems,
13 whole system replacements. I'm not talking about a
14 relay here or a relay there, or what have you. So,
15 that's an important point. I just wanted to emphasize
16 that; having both march to the same drummer is a very
17 valid point to deal with it.

18 The other discussion we had in the
19 Subcommittee meeting -- and it was very, very, very
20 animated for a couple of us with this what do we mean
21 by performance-based, which is about as ambiguous as
22 you can get, in my own mind. But, I mean, we can
23 continue to struggle with that. But using the
24 fundamentals is a performance-based approach to doing
25 things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so, if a regulatory framework,
2 overarching one, is structured around that framework,
3 let everything else waterfall out from under it, that
4 establishes a performance-based, rather than
5 prescriptive, general way of approaching things. So,
6 anyway, I just had to throw that one in for the
7 record.

8 MR. RAHN: Currently, in our plan, we're
9 on what we call Revision 2 of our plan. Some of you
10 may have already seen this version which we published
11 in January. But it covers the topics I have on this
12 slide.

13 The first one is what we call our
14 protection against common-cause failure. We refer to
15 these as MPs, for modernization plans. MP 1 has three
16 aspects to it. The first one has to do with
17 development of this RIS 2002-2022, Supplement 1, which
18 I mentioned earlier.

19 A second part of it is a document that we
20 were planning to review, and potentially endorse,
21 having to do with identifying design attributes that
22 could be used for supporting a qualitative assessment
23 that you could refer to when you're performing digital
24 upgrades under 10 CFR 50.59.

25 It's a document that's being prepared by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NEI called 16-16. That document got started, and
2 then, it got placed on hold pending an update of a
3 portion of it that is being prepared by EPRI. So,
4 it's going to refer to, it's going to have an appendix
5 at the end of it which talks about different types of
6 digital hazards such as software hazards or
7 communications or intercommunication links, and then,
8 what potential design attributes could you include in
9 a design to address those hazards. That document is
10 still being prepared, and it's not expected to be
11 completed until later this year. Mid-November I think
12 is the timeframe they were giving us. So, we'll
13 resume work on that review after NEI provides us the
14 next version.

15 MEMBER SKILLMAN: David --

16 MR. RAHN: Yes?

17 MEMBER SKILLMAN: -- before you change
18 this slide, let me ask this question. And it's
19 relating to the second bullet. The words that you
20 used were "upgrades under 50.59".

21 MR. RAHN: Yes.

22 MEMBER SKILLMAN: And I would ask you to
23 clarify what you mean by that. I ask the question
24 because there was at one time in the industry the
25 notion 50.59 is a change process. It's not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAHN: Yes.

2 MEMBER SKILLMAN: It's a screening process
3 to determine whether or not the change rises to the
4 level of requiring a license amendment. So, let me
5 ask you, please, to clarify what you meant.

6 MR. RAHN: Yes, that's exactly what we
7 mean. Before making a determination that a
8 modification to the plant could be made, the important
9 first step is to verify that that particular
10 modification is consistent with the current licensing
11 basis for a plant. Typically, that's as documented in
12 the Safety Analysis of record. So, typically, the
13 first step is to see, are they introducing some new
14 mode of failure or some type of error that could
15 introduce or increase the frequency of accidents. And
16 so, they have to embark on a process that says, if
17 they trigger one of these eight criteria, such as
18 accident frequency or new malfunction types, then they
19 wouldn't be consistent with their current licensing
20 basis, and a prior staff review would be needed. And
21 that's what it is aimed at, is helping licensees
22 response to the eight criteria that are in the
23 10 CFR 50.59 process.

24 MEMBER SKILLMAN: Thank you, David.

25 MR. RAHN: Yes. The Part 1.C is an

1 evaluation of where are we with regard to the existing
2 policy for addressing CCF. So, we've embarked upon a
3 review of where are we currently with regard to our
4 guidance that responds to SRM SECY-93-087, which
5 currently describes what would be a suitable approach
6 for addressing potential for common-cause failure,
7 primarily aimed at software introducing.

8 So, that evaluation was done, and we're
9 preparing an info SECY paper that would outline what
10 we consider to be our recommendations for maintaining
11 status quo with that and perhaps enhancing the way we
12 adopt that policy in our existing guidance documents.
13 So, that paper is a draft right now. We've gone up
14 through our channels, but we haven't submitted it.
15 We're planning to submit that thing next month.

16 Yes?

17 MEMBER BROWN: When you say "submit," you
18 mean submit --

19 MR. RAHN: To the Commission.

20 MEMBER BROWN: No, I'm just thinking about
21 we get a copy of it; that's all.

22 MR. RAHN: Oh, okay. Yes.

23 MEMBER BROWN: An outrageous thought
24 process.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAHN: Yes, right. Well, I would
2 think the one we've done already, I don't see a
3 problem with that, sharing it. But what do you think?

4 MEMBER BROWN: It's an open document. It
5 will be publicly accessible, correct?

6 MR. WATERS: Yes, actually, it's an
7 information paper to the Commission explaining how we
8 are moving forward in applying common-cause failure.

9 At our briefing two months, what you saw
10 was essentially a comment in the paper. It will be a
11 more narrative format, but applying the guiding
12 principles and, again, addressing scope, as well as we
13 believe our next step will be updating Branch
14 Technical Position BTP 7-19 to the Staff Guidance for
15 addressing D.3 for an entire scope of systems. And
16 we'll be happy to engage the ACRS on that document as
17 we begin updates. But, yes, we'll make the
18 information paper available to the ACRS when it's
19 complete.

20 MEMBER BROWN: Yes, that would be useful.
21 We had an interesting discussion on this during the
22 6/20 Subcommittee meeting, where I guess the Committee
23 expressed that BTP 7-19 and the addition of diverse
24 actuating systems, or whatever you want to call them,
25 diverse systems based on an analysis of where you need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 them, if operators can't take care of stuff -- we've
2 got plants operating under those right now, and it
3 seems to work.

4 And how complicated do we need to make
5 this? That's my only big concern, is you're never
6 going to be able to test software; you're never going
7 to be able to find software errors. You don't have
8 the resources, and the vendors don't have the
9 resources, to test it and a manner to do that, either.
10 Software errors are largely designed items. So, I
11 mean, the software does what it's going to do.

12 The diverse approach to doing business
13 looks like we're not going to tell plants to stop
14 operating because of some new metrics that you come up
15 with. So, I just wanted to get that back out, that we
16 had that discussion in the last meeting, and quite
17 frankly, we've done a lot of design certifications
18 where we've accepted the BTP 7-19 approach was the
19 diverse protection systems being the solution to the
20 common-cause failures in the I&C systems.

21 MR. WATERS: I think staff agrees with
22 that, and that was one of the four fundamental
23 principles we talk about in ISG-06.

24 MEMBER BROWN: Exactly.

25 MR. WATERS: We're focused on having that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at an appropriate level of defense in depth and
2 diversity to the extent practical commensurate with
3 the risk associated with the system. One of the
4 questions we faced is the "What if?" What if we get
5 a smaller upgrade that's not a full-blown RPS or SFAS
6 or for a LAR review? What's the scoop with that?
7 What flexibilities do we have in using best estimates
8 and operator diversity, to create operator
9 intervention? And this is some of the things we
10 wanted to clarify in the BTP.

11 MEMBER BROWN: Okay. I just wanted to get
12 it that it's been discussed.

13 MR. WATERS: Sure.

14 MEMBER BROWN: And I certainly am looking
15 that we do what we need to do, but don't do stuff that
16 prevents moving forward with these systems which are
17 vast improvements on the reliability and the operation
18 of the plants. Those are real concerns.

19 We've got about 10 minutes here for you to
20 finish up four slides.

21 MR. RAHN: Yes. So, I'll get through the
22 rest of this slide, and then, I can zip through the
23 remainder. The next item on here is what we call our
24 Modernization Plan No. 2. In this plan, we are more
25 formally developing a product which will become

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably an endorsable guide.

2 Currently, the guidance for addressing the
3 10 CFR 50.59 process is covered in a Reg Guide, 1.187.
4 That Reg Guide endorses NEI document 96-07. 96-07
5 goes into great detail about how do you do this
6 evaluation to determine whether prior staff approval
7 is needed before you can make a change. But that
8 guidance, even though it's very detailed, it didn't
9 address some of the criteria that a mod engineer at a
10 plan would need to consider when he does digital
11 upgrades.

12 So, it was decided that a new appendix be
13 developed. So, we refer to it as 96-07, Appendix D.
14 It's going to have some specific criteria in it that
15 would aid a modification engineer at the plant to
16 perform the evaluations that are needed to ensure that
17 he doesn't have to have prior staff approval.

18 We would plan to have that endorsable.
19 That particular product is still in development.
20 We've had many months of dealings with the developers,
21 and we think we see light at the end of the tunnel.

22 MR. WATERS: Let me just clarify --

23 MEMBER BROWN: That's an NEI?

24 MR. WATERS: Yes. This is a document that
25 they are revising, a lot based on the lessons from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 RIS we talked about. And we're expecting to submit
2 that for endorsement and review.

3 MEMBER BROWN: Thank you.

4 MR. RAHN: The next Modernization Plan is
5 one that we have that is called "Acceptance of Digital
6 Equipment". What it's really about is, is there a way
7 that we could enhance the process by which we address
8 the critical characteristic of dependability for a
9 particular new digital platform or a component that
10 would be used in a safety-related application that's
11 been procured under a commercial grade dedication
12 process?

13 That is also being started, and it's being
14 done with the assistance of work by EPRI. What we're
15 looking at is the possibility of leveraging some of
16 the work that's already been done for the oil and gas
17 industry through their use of ISA Standard 84 and IEC
18 Standards 61508 and 61511.

19 In those processes, they determine what
20 they call a safety integrity level, and then, a third-
21 party certifier does some evaluations and testing to
22 determine whether or not a particular vendor's product
23 could meet a certain certification level.

24 And so, what we're considering is coming
25 up with a process by which we could also recognize

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that certification level. In order to do that, we
2 would have to certify the certifiers first. And then,
3 we would have some kind of avenue by which a licensee
4 may be able to procure a device that's been certified
5 under that process as part of the input to our
6 commercial grade dedication process. Basically, that
7 would help leverage the issue about dependability of
8 a hardware/software platform for safely performing it
9 safety integrity actions.

10 The last item we have is our long-term
11 regulatory approach. Samir talked to us today about
12 the first item, which we call Modernization Plan 4A,
13 which is a better description of a more efficient
14 licensing process. But, beyond that, we're just now
15 coming to terms with what else are we going to include
16 in this modernization effort. We have a number of
17 suggestions that have been given to us through
18 stakeholders and NEI and other organizations, but they
19 haven't been revisited in a couple of years. So, what
20 we're next going to do is evaluate that current list
21 and, also, listen to stakeholders for any new items
22 that might arise because of the fact that we're now
23 including advanced reactors in our upfront potential
24 for new license applications.

25 So, we have scheduled a meeting for later

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this month to gather more information and to help
2 prioritize the needs for that. Mostly important to us
3 is helping us organize for what kind of regulatory
4 research activities need to go on before we can do
5 that modernization.

6 Okay. So, here's where we are at with the
7 IAP. We've originally sent a draft of this to the
8 Commission, and they responded in October of 2016. We
9 have already issued Revisions 0 and 1, and Revision 2
10 is now on the street. Revision 2 came out in January.
11 Right now, we're identifying all the things that need
12 to be changed for Revision 3. We plan to issue
13 Revision 3 in September of this year.

14 Along with that, in October, we provide an
15 annual report to the Commission telling them where we
16 are on the IAP performance, the status of where we are
17 at.

18 So, Rev. 2 identified some of these
19 changes that we've covered actually today. And Rev.
20 3, we're going to talk further about work that's
21 already been completed, but, also, we're going to try
22 to inform where we're going with the MPs that we've
23 already embarked upon and, hopefully, also identify
24 what should the longer-term activities include.

25 Right now, we're planning a stakeholder

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meeting at the end of this month. We actually have,
2 with the various MPs, we have a meeting tomorrow, for
3 example, on the commercial grade dedication issue. We
4 will have continued meetings throughout this year. We
5 are also planning on preparing a Commission meeting in
6 October of this year. So, that is something that is
7 on our table along with everything else that we are
8 doing.

9 So, that's what we have for today, but I'm
10 happy to entertain any further questions.

11 MEMBER BROWN: Are you happy now, Mike?

12 Okay. You're complete.

13 If there's no more questions from the
14 table right now, should I go to the audience first?

15 Is there anybody in the audience for the
16 meeting today that would like to make any comments,
17 public comments? I don't see anybody standing up to
18 be recognized.

19 Kathy, is the phone line open?

20 MR. T. BROWN: The phone line is open.

21 MEMBER BROWN: Okay. Is there anybody out
22 there that would like to make a comment?

23 Thank you for telling me it's open. I
24 appreciate that.

25 (No response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Hearing none, Mike, I will
2 turn it back over to you.

3 CHAIR CORRADINI: Okay. I wanted to thank
4 the staff. I know we kind of constrained you into
5 this, unfortunately, but I appreciate both the
6 discussion for the ISG as well as your plans for the
7 IAP. I'll get it wrong if I try to say the words. I
8 remember the IAP.

9 So, at this point, we're going to take a
10 break. We have to be back here, the Committee members
11 have to be back here at 15 after precisely because
12 we're going to have a security discussion in closed
13 session. So, I'll let you go, as long as you come
14 back in 17 minutes.

15 MEMBER BROWN: When do we eat lunch?
16 After the security session?

17 CHAIR CORRADINI: At 12:15, be back here.
18 What you choose to do with your 17 minutes is your
19 choice. Okay. See you back here shortly.

20 (Whereupon, the above-entitled matter went
21 off the record at 11:57 a.m. and resumed at 1:45 p.m.)

22 CHAIR CORRADINI: Okay, we'll come back
23 into the session. Our topic for this afternoon is the
24 APR1400 design evaluation review and I'll turn it over
25 Professor Ballinger.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BALLINGER: Thank you, Mr.
2 Chairman. This meeting represents, I hope, and I hope
3 they hope as well, the last meeting on the APR1400.

4 I could list the meetings that we had over
5 the past year and a half or more but it would take too
6 much time. I could list the people that have
7 contributed to all of this, staff and members of the
8 Committee, and that would also take too much time.

9 So, I'll just thank everybody ahead of
10 time that we got this far and hopefully, we'll have a
11 great conclusion today and going forward. And is
12 Bill...Yes, he's not in the next room.

13 MR. WARD: Thank you.

14 MEMBER BALLINGER: Do you want to say a
15 few words?

16 MR. WARD: Yes, this is the last meeting,
17 we hope, I definitely agree with that and we, too,
18 would like to thank all the people that have been
19 involved, those currently involved, those in the room,
20 and all the prior Members of the Committee, at least
21 one of whom I've seen walking around the floor
22 already, and even prior Members of our staff who are
23 also attending as members of the public.

24 Anyway, we are happy that we've reached
25 this point and we look forward to a productive meeting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with hopefully the outcome we need.

2 Thank you.

3 MR. SISK: This is Rob Sisk, Westinghouse.
4 I'll just very briefly echo the comments already made.

5 I'm very appreciative of everybody that
6 got us to the point where we are now, coming to the
7 end of Phase 5 as we get to this milestone for
8 APR1400. And it's been quite a journey.

9 So without further ado, I would like to
10 introduce Mr. Yunho Kim, the APR1400 Project Manager.

11 MR. KIM: I am Yunho Kim from KHNP, I am
12 actually APR 1400 Project Manager. I'm very honored
13 to have the scheduled time at the ACRS Committee
14 meeting.

15 So looking back at our bigger process, at
16 Page 3 we have more than 300 open items. So we needed
17 closer communication with the staff. We resolved all
18 the open items, and based on that, we have ACRS
19 meeting October 2017 to last month, June 2018. We
20 presented how we resolved those open items.

21 It was a very tremendous work but there
22 was a very good benefit for APR1400 application. So
23 from now on, I want to have a good productive meeting
24 today and I wanted to just thank you for APR1400.
25 Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KIM: Good afternoon, ladies and
2 gentlemen. My name is Taehan Kim from KEPCO E&C. I'm
3 honored to be here today to present this material,
4 this section
5 on APR1400 design future and design comparison and
6 summary of review at this final ACRS meeting for
7 APR1400 review.

8 This slide shows the contents of my
9 presentation. First, the lead design feature of the
10 APR1400, design comparison of APR1400 and the System
11 80+, and enhancements addressed during the review
12 process, and ITAAC items addressed during the review
13 and summary of topical report and RAIs. Then I will
14 summarize this presentation.

15 Let me start by presentation by
16 introducing the design feature of APR1400. As you
17 know, APR1400 is an evolutionary pressurized water
18 reactor which I improved from the operating stage of
19 APR1000 and conventional shipment and System 80+.

20 Major improvements include 4-train safety
21 injection system, I mean mechanically and
22 electrically, and in-containment refueling water
23 storage tank, a full digital instrument and control
24 system, and also severe accident mitigation system
25 with the incorporation of new requirements for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hydrogen, gas control, and containment of over-
2 pressure protection.

3 This slide shows the different design
4 features of APR1400 from System 80+. The first item
5 is pre-stressed concrete cylindrical containment
6 compared with spherical steel containment of System
7 80+.

8 The second and distinctive new design
9 feature is fluidic device in safety injection tank to
10 enhance safety injection system performance. The next
11 item is fully digitalized, improved I&C system and the
12 computer-based main control room design.

13 And the rest, PLUS 7 fuel with enhanced
14 thermal margins, high burnup, and improved fuel
15 economy. And APR1400 incorporates the passive
16 autocatalytic recombiner and igniter for hydrogen
17 mitigation.

18 Also design enhancement to better execute
19 severe accident mitigation strategies such as
20 emergency containment spray backup system with the
21 external water tank and mobile generator to control
22 long-term containment pressure.

23 This slide shows the major parameters of
24 APR 1400, design lifetime of 60 years for Class 1
25 major equipment, 4000 megawatt thermal and a 1400

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 megawatt electrical power.

2 Operation condition of primary and
3 secondary site is listed as follows. This slide shows
4 the safety injection system configuration and brief
5 description.

6 As shown in the left figure, it is a very
7 simply design with four independent trains. Each of
8 them have one safety injection pump, one safety
9 injection tank, and related affairs.

10 Each pump takes borated water from the
11 IRWST and the IRWST is located at the lower level of
12 containment. By reducing the IRWST, the operational
13 reliability is enhanced due to no operator action for
14 continued long-term cooling.

15 The right-side figure shows the full-scale
16 test facility for fluid device development. A number
17 of full-scale tests for performance verification and
18 sensitivity of manufacturing tolerance of fluid device
19 were performed with this full-scale test facility.

20 This slide shows the internal
21 configuration of the vortex chamber in the fluid
22 device. The idea of passive flow control comes from
23 the application of vortex flow. Vortex flow is formed
24 in the vortex chamber and provides high-flow
25 resistance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The entire configuration of the Vortex
2 chamber is precisely designed to make strong flow when
3 water is supplied from the control nozzle only, as is
4 shown in the right figure. Because of high resistance
5 due to vortex, low inside flow is damaged.

6 However, if the water is supplied from the
7 both the supply port and supply nozzle and control
8 nozzle, as shown in left-side figure, low-flow vortex
9 is formed and high inside flow is damaged.

10 So when the water level in the tank is
11 high, we get high flow rate and when the water level
12 is low in the top of standpipe, we have low flow rate.

13 This slide shows the design feature of
14 instrumentation and control system with diverse
15 platforms. Safety system is implemented by
16 programmable logic controllers. Non-safety system is
17 implemented by distributed control system.

18 However, diverse protection system is
19 implemented by FPGA-based logic controller. Data
20 communication system maintains independence between
21 safety system and non-safety system. Remote shutdown
22 is also available when MCR is uninhabitable.

23 APR1400 has performed probabilistic risk
24 assessment evaluation for the following area based on
25 the basic element and approach given in ASME/ANS code.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 At power operation mode, Level 1 and 2
2 internal events include fire, internal flooding,
3 seismic risk evaluation based on the seismic margin
4 methodology and other external events performed.

5 For the low-power and shutdown operation
6 mode, APR1400 has also performed evaluation for Level
7 1 and 2 internal events, fire, flooding, and seismic
8 risk evaluation.

9 With this PRA, KHNP investigated design
10 improvements to reduce or eliminate weakness in
11 APR1400 design and as a consequence, increase the
12 number of emergency diesel generators from 224 and the
13 extended 125 volt DC battery life from 8 hours to 16
14 hours.

15 This following slide shows other design
16 features like GSI-191, Reg-Guide-4.21-related, AIA,
17 and more.

18 Regarding the GSI-191 issue, APR1400
19 design does not use fibrous insulation in the zone of
20 influence. And I&C sump strainer performance tests
21 were performed in accordance with the Reg Guide 1.83,
22 82, and ANS47.

23 Also, in-vessel downstream effects tests
24 were performed in accordance with document 16793.
25 APR1400 design includes features to conform with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 10 CFR 20.1406 and Reg Guide 4.21 to minimize
2 contamination of the facility and embodiment
3 throughout the life cycle.

4 APR1400 has minimized embedded and/or
5 buried piping, prepared a provision for early leak
6 detection and introduced trench and double-walled
7 piping. Aircraft impact assessment of APR1400 was
8 performed in accordance with 10 CFR 50.158 and Reg
9 Guide 1.217 and ANS7-13.

10 The structural analysis demonstrates that
11 the integrity of the containment is maintained as part
12 of meeting the sufficiency criteria for maintaining
13 core cooling and the integrity of the spent fuel pool
14 is maintained for all strikes to meet the AIA
15 requirement.

16 The heat removal assessment demonstrates
17 at least one division of core cooling is available for
18 all strikes. For the provision of loss of power
19 event, APR1400 has four EDGs, emergency diesel
20 generators, for emergency power and AAC gas turbine
21 generator for SBO.

22 And for FLEX design for the extended loss
23 of AC power, we provide with a FLEX pump RCS makeup,
24 spent fuel makeup, and spray mobile generator, and
25 also spent fuel level instrumentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This following slide shows the summarized
2 design difference with the System 80+. Firstly, the
3 containment shape is much different. System 80+ has
4 a spherical steel containment but the APR1400 has a
5 cylindrical-shaped, pre-stressed concrete containment.

6 The thermal power of the core is slightly
7 different, the hot leg temperature is down from 621 to
8 615 to minimize deviation in the steam generator too.
9 The RCS overpressure protection system of the APR1400
10 consists of four high-level operated spring release
11 valves.

12 CHAIR CORRADINI: Can I ask a question
13 about those? What is the experience in Shin Kori
14 about the pilot operated safety relief valves. It's
15 my understanding there was some leakage there.

16 MR. KIM: We do have a POSRV in Shin Kori
17 3 and 4. we have some leaking problem.

18 CHAIR CORRADINI: Is it the same design as
19 what we're looking at here or has there been
20 modifications?

21 MR. KIM: In the design but to my
22 knowledge, as I heard, they manage to handle their
23 problem.

24 CHAIR CORRADINI: Say that again, please?

25 MR. KIM: They managed their problem.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: How did they manage the
2 problem?

3 MR. KIM: I don't really exactly know how
4 they did but it's what I've heard is the latest news.

5 CHAIR CORRADINI: When you started showing
6 these comparisons, I was looking for lessons learned
7 from either prior System 80 operation or current close
8 enough design.

9 So that's why I asked the question.

10 MR. KIM: This is a big difference and we
11 have the kind of things because I know they managed it
12 is the latest news.

13 CHAIR CORRADINI: So let me ask my
14 question a little bit differently. Has this, what
15 I'll call, leak issue in the pilot system been solved
16 for Shin Kori?

17 MR. KIM: That's what I heard.

18 MR. KIM: Actually, let me add some
19 explanation. actually, we had the same issue in the
20 Shin Kori 3 and the PNPP. So the HMPs are approaching
21 Kori 3, we are looking for what is the root cause and
22 that's still going on.

23 But we have found a way to solve the
24 leakage problems so Shin Kori 3 is now working on the
25 power operation. For the root cause of the leakage,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we are still working on. So, probably within a year
2 we will find what is the main cause of leakage.

3 But I think the vendor --

4 CHAIR CORRADINI: Say that again, please?

5 MR. KIM: The vendor, vendor of POSRV,
6 says that usually, the minor leakage is acceptable but
7 the regular leakage I do not think is different today
8 so we tried to meet the core body, no leakage.

9 So we are trying to solve that issue.
10 Currently, we are working on it so probably it will be
11 somewhere within a year.

12 MEMBER KIRCHNER: A related question,
13 you're contrasting the design features that are
14 different from the CE System 80.

15 Of those major items you listed, how many
16 of them have been demonstrated in your modern plant
17 section in Kori? Have you pretty much done all these
18 similar improvements with your newer plants?

19 MR. KIM: In Kori 3 and 4, we applied all
20 these things, cylindrical concrete containment, the
21 power's the same, the holding temporary's the same.
22 And four-train safety injection system with the DBR
23 fluid device.

24 MEMBER KIRCHNER: POSRV? Is the Shin Kori
25 plant digital, I&C?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KIM: Yes.

2 MEMBER KIRCHNER: Thank you.

3 MR. KIM: Let me continue. APR1400
4 adopted the interior head assembly for the reactor
5 vessel head and its upper structure, and
6 considerations for strategy cabinet flooding system
7 and pile ignite and fluid device in safety injection
8 tank.

9 This slide shows the summarized table of
10 design differences with System 80+, almost the same
11 items. 4000 megawatt thermal and 1400 megawatt
12 electric and 1400 megawatt electric and 4PS POSRV and
13 IHA, and fluid device in safety injection tank.

14 And we applied the large display panel
15 with a compared work station with a computerized
16 procedure system for maintaining control of APR1400
17 network and data link for data communications for
18 APR1400.

19 This section in the required containment
20 and pile ignite apply for hydrogen gas mitigation and
21 a gas turbine generator and an additional backup
22 supply of spray water.

23 From this slide, the major enhancement
24 addressed during the required process will be
25 presented. Unlike the other Applicant, APR1400 has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 adopted graded approach on the piping design area, I
2 meant design acceptance criteria, through
3 communication with the NRC staff by utilizing detailed
4 reference design information.

5 And for the structure of the design, the
6 effects of the construction sequence and the post-
7 construction analyses of the NI building have been
8 considered in the structure of the design based on the
9 construction practice of APR1400, I mean Shin Kori 3
10 and 4.

11 This slide shows the major design
12 enhancement items in instrument and control systems.
13 For plant protection system, switch panel is added for
14 trip channel bypass, setpoint reset, and operating
15 bypass. And cross-channel communications are deleted
16 except 14 signals for reactor trip.

17 For diverse protection system, we adopted
18 FPGA-based logic controller instead of PLC.

19 And TPS channel, TPS2 channel is increased
20 to four channels to be two out of four trip and motor-
21 generator set breaker trip is changed to reactor trip,
22 switchgear breaker trip and also reactor trip.
23 Switchgear is changed once they go from one set of
24 four break to two diverse sets of eight breaks.

25 This slides shows the category and number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of ITAAC items. We have a total 1202 ITAAC items and
2 key changed items are summarized in the next slide.

3 This slide shows the list of key change
4 items in ITAAC during the review process.

5 ITAAC wording change based on NRC
6 guidelines and incorporation of standardized ITAAC
7 guidelines and technical-related item like CPU load
8 restrictions prior to logic within the SF,
9 structure-related ITAAC items, and things like that is
10 incorporated, I mean addressed during the review
11 process.

12 KHNP provided five topical reports to
13 support the APR1400 application, such as KHNP-QAPD for
14 the APR1400 DC, KCE-1 critical heat flux correlation
15 for PLUS7 thermal design. The third one is the fluid
16 device design for APR1400.

17 The first one is realistic evaluation
18 methodology for large break LOCA of the APR1400 based
19 on PLUS7 fuel design for the APR1400. All five
20 topical reports have been reviewed and approved by the
21 NRC staff.

22 KCE-1 CHF correlation topical report
23 described a CHF test of PLUS7 fuel, correlation
24 development, verification and validation, and each
25 application to the APR1400.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 KCE-1 CHF correlation topical report
2 supports DCD Chapter 4 and 15 by issuing the design
3 acceptance criteria under full compliance with
4 conditions and limitation of FSER.

5 Fluid device topical reports contain the
6 design requirements, detailed design of the SIT-FD and
7 the result of full-scale performance verification
8 tests, fluidic device topical reports about DCD
9 Chapter 6 and Chapter 15 by issuing the design and the
10 performance of SIT-FD.

11 479 topical report contains evaluation
12 result for fuel assembly and rod supporting, DCD
13 Chapter 4. Main contents of 479 topical reports are
14 fuel rod design, fuel assembly design, and the
15 evaluation results of poolside examination, hot cells
16 examination, and the commercial operating experience.

17 Consideration of the thermal conductivity
18 degradation is included, and evaluation results show
19 the performance integrity of PLUS7.

20 Large break LOCA coolant extends to
21 topical report to describe a realistic evaluation
22 methodology, CAREM for the analysis of LBO APR1400.
23 CAREM follows NUREG/CR-5249, CSAU, in the Reg Guide
24 1.20703.

25 CAREM supports DCD Chapter 15, evaluation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 result of CAREM for APR1400 shows sufficient safety
2 margin of ECCS performance.

3 This table summarizes the RAI issue and
4 resolve for each chapter. More than 2000 RAIs were
5 issued and resolved.

6 CHAIR CORRADINI: You're way ahead of me,
7 but I wanted to ask, the RAI issues will be resolved
8 by revisions to DCD Rev. 3, is that correct?

9 MR. KIM: All confirmatory items we've
10 included in Rev. 3.

11 CHAIR CORRADINI: Okay, thank you.

12 MR. KIM: Finally, I will summarize this
13 presentation. APR1400 DCD is completed, all AIAs have
14 been resolved with adequate and sufficient discretion.
15 Confirmatory items have been incorporated into DCD
16 Rev. 3.

17 And with this opportunity, I would like to
18 express out team's deep gratitude to all of NRC staff
19 and ACRS Members for the excellent review, discussion,
20 and feedback for APR1400 DCD.

21 All those efforts result in the enhanced
22 design and made it possible to complete the review
23 process with in the schedule of 42 months.

24 Thank you again.

25 MEMBER BALLINGER: Thank you. At the risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of being in denial, we're ahead of schedule. We
2 probably should just pick it up with the staff now.
3 So, are you guys ready to roll?

4 MR. WARD: Yes, we are. Good afternoon,
5 my name is Bill Ward, I'm the Lead Project Manager for
6 the APR1400 review for NRC and I'm going to start our
7 presentation today with an overview. You can go to
8 the next slide.

9 First of all, I want to say again thank
10 you for all the meetings and all the help and the
11 logistics and everything that we've had to organize
12 over the last 27 months.

13 As you know, there have been two rounds of
14 ACRS meetings, Phase 3 and then Phase 5, and of
15 course, EFROWN had Subcommittee and then full
16 Committee. The Subcommittees were monthly and then we
17 grouped them in the full Committee meetings.

18 We've maintained an aggressive schedule
19 over the last four years at this point, almost four
20 years, three and a half, in order to meet the
21 milestones we have for our review.

22 Part of that was because of the effort
23 required to issue revisions and DCDs, we were trying
24 to avoid having multiple rounds of DCD revisions.

25 And so one of the things we did when KHNP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was going to issue Rev. 2 at the end of year last
2 year, we were talking about how we were going to
3 organize the last revision and make sure we presented
4 everything to ACRS, and then in terms of being able to
5 do the review and then finish the final SER and still
6 meet our schedule.

7 So, we let the deadline for Rev. 2 slide
8 a little bit to get everything we could into Rev. 2.
9 Rev. 2 was issued in March and now Rev. 3 is the one
10 coming up.

11 So, since we issued Rev. 2, we've been
12 focusing on controlling any changes and making sure we
13 know exactly what changes there are coming and that we
14 document on them.

15 So, we've been trying to make sure we are
16 aware of that and we provided feedback to the
17 Committee so you knew what changes were coming in for
18 any RAI responses that came in after the
19 representative Subcommittee.

20 So, going to my slide on ACRS review,
21 we've had 31 meetings in 27 months.

22 CHAIR CORRADINI: I thought you were going
23 to hand off with something.

24 MR. WARD: I'm going to lead onto it in a
25 second, I'm sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: You're way ahead of me.

2 MR. WARD: I'm leading into it.

3 CHAIR CORRADINI: Okay, fine. Sorry,
4 excuse me.

5 MR. WARD: So we've had 31 meetings and I
6 just wanted to say the RAI count in our case would be
7 at 2201 for the DCD and the 24 for the environmental
8 report.

9 We also had 69 RAI questions on topical
10 report and way back in pre-application space, we had
11 21 RAI questions on the quality assurance program.

12 So, as I was saying, we began providing
13 information on changes that were coming ever since we
14 started planning Phase 5 Subcommittee meetings. So
15 the first Subcommittee meeting was in October so we
16 submitted our ASER in September.

17 So ever since September, we've had to make
18 sure that we kept you up to date on anything that came
19 through.

20 So we went through and we verified any of
21 the RAI responses that came through, and most of the
22 responses are just corrections of typographic errors
23 and things like that. But we wanted to make sure we
24 kept you informed so we've been providing you that
25 update.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We reviewed all the responses since then
2 and made sure that there was nothing significant in
3 them. We kept you up to date, as I said, and there's
4 a total of 52 revised responses that have been
5 received since the Subcommittee for each chapter. So,
6 for example, the last Subcommittee we had was for
7 Chapters 6, 13, and 14.3.

8 And actually, there were some responses
9 that came in after the SC but before we presented them
10 in the Subcommittee meetings so we were able to
11 address them directly in the meeting.

12 So, in general, we've tried to make sure
13 that everything is out there that's coming. And now
14 that we've reached this point, there are no more
15 changes that are going to occur. I'm tracking
16 everything.

17 Of those revised responses and some
18 earlier revised responses that came in, we have a
19 total of 50 questions that are confirmatory actions.
20 And we're waiting for Rev. 3 of the DCD to come in to
21 make sure they're in there.

22 We've seen the revised response, we know
23 exactly what is coming in, and when it comes in, we're
24 going to verify that it's what we thought was going to
25 be there. If it's different then that's an issue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And we'll be able to finalize the FSER.

2 We're already writing the FSER under the
3 assumption that we will have exactly what is promised
4 in the responses.

5 At the same time, we've also been talking
6 with KHMP and they have an electronic reading room so
7 as they put their Rev. 3 version together, they're
8 going to make it available for us to see that so we
9 can have confidence in it. And then when they issue
10 Rev. 3, we'll verify that it's exactly what we
11 thought.

12 So, we're taking all the steps we can to
13 make sure that there are no more changes at this point
14 and anything else that really needed to be considered
15 would have to be postponed until after we get through
16 this process and through the final safety evaluation.

17 And there is a process for that, NRC has
18 something called interim staff guidance, Number 11,
19 which is where you get to a certain point where you
20 have to cut off any changes and they get postponed and
21 put off to a parking lot until later when they deal
22 with them.

23 So, we're at the point now where this is
24 the design that's being approved and what we are
25 seeing as we're going to Rev. 3 is what will be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 record design for your approval.

2 MEMBER SUNSERI: Hey, Bill, just a quick
3 question. I understand what you're doing with the 50
4 or so confirmatory items. Do you do any checking of
5 the rest of the Rev. 3 to make sure nothing else
6 changed besides those 50?

7 MR. WARD: We spot check it. We're going
8 to do a sensory review and we're going to spot check
9 it. But because the total DCD is between 11,000 and
10 12,000 pages, it's really hard for us to check every
11 single thing.

12 MEMBER SUNSERI: I just wondering how the
13 configuration, if you will, is maintained at the base
14 document.

15 MR. WARD: One of the things I think, I
16 can't necessarily speak for everybody but I tell
17 people what you do is you pull up the previous Rev.
18 and you pull up the current Rev..

19 Where there's a change bar, you can look
20 and see if the pages are looking the same. And if
21 there's a radical difference, there should be a change
22 bar and then we can go in and figure out what the
23 change is about.

24 And one of the things KHNP has done is
25 provide tables that show us why the changes occurred.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They aren't necessarily marked in the DCD, it's just
2 a change bar, but there are RAI tracking reports and
3 there's a change list that if you know how to go
4 through and read them, you can figure out why each
5 change was made and trace it back to the individual
6 RAIs.

7 So even if you weren't involved in the
8 review, eventually, you could figure out exactly why
9 that change was made in each revision.

10 MEMBER BALLINGER: But just for the
11 record, any letter that we would write would be on
12 Revision 2 with confirmatory items. We have not seen
13 Revision 3 so we can't write a letter on Revision 3.

14 CHAIR CORRADINI: That's where I thought
15 you were going.

16 MR. WARD: That's what I wanted to verify
17 because what appears in Rev. 3 should be just Rev. 2
18 with the confirmatory items.

19 MEMBER BALLINGER: The operative word is
20 should be.

21 MEMBER REMPE: Before you go on, today we
22 got an email about Subpart E versus Subpart B. So
23 we're doing a standard design approval here, not a
24 standard design certification, correct?

25 MR. WARD: It's both. I have that in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 final slide but, yes, initially when KHNP applied, the
2 initial application, Rev. 0 of the DCD, they asked for
3 a standard design certification in Subpart B.

4 A few months ago, they began discussing
5 coming in for a standard design approval and when they
6 submitted Revision 2 in March, they included in the
7 submission the request for what they call the final
8 design approval.

9 And it's a little bit of I don't want to
10 say semantics, but we originally had regulations that
11 called it a final design approval. And that was
12 changed in 2007 and so now it's called a standard
13 design approval, so that's what they want.

14 The idea is that when we issue the FSER,
15 we'll be able to issue a standard design approval.
16 But when you look through Subpart E and I get a
17 comparison of what's required for the technical
18 information between Subpart D and Subpart E, they're
19 essentially the same.

20 There's a couple minor differences but we
21 felt like they provided everything you're supposed to
22 provide for either subpart. And both subparts have a
23 statement regulation in there that there needs to be
24 review for safety issues by the ACRS.

25 And so part of the request today, and I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 state it in the last slide, is that we're asking for
2 the letter to state that's been performed for both
3 Subpart B and Subpart E.

4 MEMBER REMPE: So for my education and on
5 the record, has anyone ever done this standard design
6 approval?

7 MR. WARD: Yes.

8 MEMBER REMPE: I know you changed the word
9 and maybe it was a final design approval. Who else --

10 MR. WARD: Most recently, the ESBWR design
11 did it. When they applied, they asked for final
12 design approval, but by the time it was issued it was
13 after 2007.

14 But the letter that went out did call it
15 a final design approval.

16 MEMBER REMPE: Not in the standard design
17 certification. So is the AP1000 the only --

18 MR. WARD: No, ESBWR, the General
19 Electric.

20 MEMBER REMPE: How many certified designs
21 do we have in the U.S. if the ESBWR is only a standard
22 design?

23 MR. WARD: It's also certified.

24 MEMBER REMPE: It's both, okay.

25 MR. WARD: So there are five certified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 designs, three of which expired.

2 MEMBER BLEY: And a rule is issued whether
3 it's design approval or design certification.

4 MR. WARD: The design certification goes
5 to rule-making so that doesn't happen until we go
6 through the rule-making process.

7 And we're going through a direct final
8 rule because we feel like this is based on existing
9 plants and it's been operating in Korea so we're
10 thinking it's going to be few, if any, adverse
11 comments.

12 MEMBER BLEY: But the appendix to the rule
13 will be for the design certification?

14 MR. WARD: That's correct.

15 This is just an approval which a COL
16 Applicant could reference but then it puts a lot of
17 the burden on the COL Applicant to follow through on
18 certain things, which if they reference the design
19 cert, certain steps are taken.

20 MEMBER REMPE: Say that more clearly. I
21 thought you were not going to go through a rule but
22 you said, oh, we're going to go through a rule on this
23 too?

24 MR. WARD: We're going through a rule,
25 yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Okay, I guess I
2 misunderstood the formal discussion.

3 MR. WARD: We're asking for both, both for
4 the Subpart B, which eventually will go to rule-making
5 and the rule-making process officially for us began at
6 the beginning July and we're asking for a direct final
7 rule where we don't go through two steps.

8 We think we can do it in one step, and
9 we're hoping to complete the rule in May.

10 MEMBER BALLINGER: May?

11 MR. WARD: 2019. The standard design
12 approval, once we issue the final safety evaluation,
13 we would be able to send the letter saying that they
14 had the standard design approval.

15 But like I said, the difference between
16 the two, we tend to issue both, the difference between
17 the two is the amount of work that the COL would have
18 to do with referencing it.

19 MEMBER REMPE: A little off topic, has
20 anyone just done a standard design approval and not
21 gone for the certified design?

22 MR. WARD: Not that I'm aware of.

23 MEMBER REMPE: Thank you.

24 MR. WARD: So, we are going to present
25 each chapter, we have a slide per chapter. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 chapter PMs are going to present each slide as their
2 chapter. We have one chapter PM who's not here today
3 and Mark is going to cover her slide.

4 But we have a roomful of experts from the
5 tech staff here to help answer any questions or come
6 up. So, I'm going to turn it over now. Well, Chapter
7 1 is mine.

8 Chapter 1, it's the design, the APR1400
9 design, the objectives, the information regarding how
10 the DCD was developed and structured in comparison
11 with other facilities.

12 There's some charts in there similar to
13 what KHNP just provided. Later sections provide lists
14 and tables of reference material and other items.

15 All of these are for the purpose of being
16 referenced by the other 18 chapters. There are no
17 specific design commitments in Chapter 1, everything
18 is referenced from other chapters.

19 So there was no specific review done,
20 safety review done, on Chapter 1 and there are no
21 confirmatory items, we didn't ask any RAIs.

22 There are a couple of COL items but
23 they're very high-level. They state for example that
24 a COL would have to name who their architect and
25 engineering firm is that's going to build it and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 things like that.

2 And that's not really design-related so
3 there's nothing there to review.

4 So the conclusion, the Applicant provided
5 adequate general description of the design objectives
6 in DCD construction and they provided accurate
7 information in the list and tables as confirmed by the
8 evaluations of the individual chapters.

9 So any questions on Chapter 1? Chapter 2
10 is going to be Mark presenting for Carolyn.

11 MR. LINTZ: Chapter 2 covers site
12 characteristics. The scope of review included site-
13 related design characteristics for the APR1400 design,
14 including geography, demography, nearby facilities,
15 meteorology, hydraulic engineering, geology,
16 seismology, and geotechnical engineering.

17 The postulated site parameters related to
18 climatology, atmospheric dispersion, ground and
19 surface water, precipitation, geology, seismology, and
20 geotechnical engineering. There are two minor
21 confirmatory items that remain pending submission of
22 DCD Rev. 3.

23 In conclusion, the Applicant has provided
24 an adequate description of the site-specific
25 information to ensure that potential COL Applicants

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 referencing the APR1400 design can meet the relevant
2 requirements.

3 And Applicants seeking a combined license
4 must address the site-specific information.

5 MR. WARD: Any questions on Chapter 2?

6 MR. LINTZ: Chapter 3, design of
7 structures, systems, components, and equipment.

8 The scope includes classification of
9 structures, systems, and components, wind and tornado
10 loadings, water level design, missile protection,
11 protection against dynamic effects associated with
12 postulated rupture of piping, seismic design, design
13 of Category 1 structures, mechanical systems and
14 components, seismic, dynamic, and environmental
15 qualification of mechanical and electrical equipment,
16 piping design review, and threaded fasteners.

17 The Applicant applied a new approach to
18 defying the ITAAC for the critical sections. That
19 would be the steel and reinforced concrete for the
20 design of the safety-related structures, the reactor
21 building and auxiliary building, and the EDG building.

22 There are nine confirmatory items that
23 remain pending submission of the DCD Rev. 3. In
24 conclusion, the Applicant has demonstrated that
25 structures, systems, and components and equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comply with NRC regulations and conform to NRC
2 guidance.

3 MEMBER BLEY: Mark, I have a question. We
4 had some internal conversations about it. We have a
5 large set of ITAAC and we have a fairly large set of
6 confirmatory items.

7 I'm pretty familiar with the requirements
8 on the licensee to clear the ITAAC items. How does
9 that compare with what they have to do to clear a
10 confirmatory item?

11 MR. LINTZ: Will you clarify that?

12 MEMBER BLEY: No, I'm expecting somebody
13 over here to clarify that for me.

14 MR. HUGHES: Is the question not for the
15 Applicant but for KHNP for the confirmatory --

16 MEMBER BLEY: No, KHNP has to clear the
17 confirmatory items. At what point in time does that
18 happen?

19 MR. LINTZ: It can happen today, there
20 could be an email in my --

21 MEMBER BLEY: But when does it have to
22 happen?

23 MR. LINTZ: It has to happen by the time
24 we get Rev. 3.

25 MEMBER BLEY: So before the rule, before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we get to the rule?

2 MR. WARD: Yes.

3 MEMBER BLEY: So all the confirmatory
4 items have to be met by the Applicant before you can
5 complete the rule?

6 MR. WARD: A confirmatory item, when we
7 ask an RAI and they provide a response, we always ask
8 for projects to provide a markup of the DCD or the
9 technical report showing where they're going to make
10 the changes so we know exactly what changes. Because
11 sometimes the wording is very critical.

12 MEMBER BLEY: So all of these should be
13 answered in Rev. 3?

14 MR. WARD: They're already in the revised
15 response or RAI response, or sometimes they revise it
16 if we find an error in the response. But we've
17 already gotten a response that says this is what the
18 revised document is going to look like.

19 So all we're waiting for to close the
20 confirmatory item is to see that revised document
21 actually issued. So it's really up to the staff to
22 close a confirmatory item.

23 The Applicant has already provided us the
24 proposed change, now we just need to see the revised
25 document and we close the confirmatory item.

1 MEMBER BLEY: I haven't followed
2 everything during this process, I wasn't really on the
3 Subcommittee. But most of the ITAAC are aimed at
4 things that you clear towards the end of construction.

5 MR. WARD: Correct.

6 MEMBER BLEY: That's generally right.

7 MR. LINTZ: Or doing construction.

8 MEMBER BLEY: Along the way, they can't
9 really be clear until they start building the plant.
10 That's what I thought.

11 MR. LINTZ: You said there's a large
12 number of ITAACs and that might look like it, but as
13 Bill intimated, most of these, in fact, all of these,
14 have been agreed upon and the only thing we're waiting
15 for is to see Rev. 3 with all these in it.

16 MEMBER BLEY: I've been thinking about
17 those a little and thinking back to Part 50, where you
18 had startup requirements which are kind of like ITAAC.

19 And I don't really have a feel or a memory
20 that helps me -- for the most part, there ought to be
21 a wash between what you'd have for startup items under
22 Part 50 and what you have as ITAAC here, I would
23 think, but I don't know that.

24 MR. HUGHES: The difference with the ITAAC
25 is the paperwork has to be submitted as a package and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it gets reviewed by the staff.

2 MEMBER BLEY: For the startup tests and
3 that sort of thing, they just do them?

4 (Simultaneous speaking.)

5 MR. HUGHES: -- basically did, and then
6 they had an internal Test Review Board that would
7 review it.

8 MEMBER BLEY: And staff could audit it?

9 MR. HUGHES: And staff would audit it.

10 MEMBER BLEY: Okay.

11 MR. WARD: And the timing is very
12 different. All the ITAAC are going to be done before
13 we approve fuel loading, and some of the startup
14 tests, a lot of those are in 14.2.

15 MEMBER BLEY: Those we still have?

16 MR. WARD: Yes, and we still have 14.2.

17 MEMBER REMPE: So in this application,
18 though, there's something, at least the moment --
19 because I was more focused on Chapter 19, it's a bit
20 different in that the COL Applicant will select an
21 option whether they go for in-vessel retention to
22 external reactor vessel cooling or not, which is a
23 little bit different than just an ITAAC that you put
24 a valve in at a certain place or whatever. And that's
25 a bit different.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And are there other things that maybe I
2 missed because I wasn't so focused on the COL items,
3 which are a bit different with this application at a
4 high level?

5 MR. HUGHES: Are you talking about the
6 ITAAC itself?

7 MEMBER REMPE: No, this is not an ITAAC,
8 it's a COL item, which is a little different than an
9 ITAAC, right?

10 MR. WARD: Correct.

11 MEMBER REMPE: And I was just wondering
12 are there other COL items that are a little different
13 with this application?

14 MR. WARD: Offhand I don't know of any.

15 MEMBER MARCH-LEUBA: Going back to the
16 ITAAC issue, I'm just talking off the top of my head,
17 but there were 2000, roughly, RAIs and now that you
18 just finished with them, you know how much work it
19 took to resolve all those.

20 There are 1200 items. I'm wondering if
21 it's too many. The amount of paperwork that the COL
22 would have to produce and the amount of work on this
23 building to get them reviewed, it's not insignificant.

24 MR. HUGHES: We would not do 100 percent
25 review, we would do a sampling review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: The number I've seen
2 in my reviews previously is roughly 40 percent of
3 them, about half. It's still a large number.

4 MEMBER BLEY: We haven't been through the
5 process yet at any plant and Region II runs that kind
6 of inspection.

7 MR. HUGHES: They would be assisted by --

8 MEMBER MARCH-LEUBA: We did this at Vogtle
9 and I remember the licensing manager complaining,
10 saying, I still have 200 ITAACs to go through. They
11 take a week a piece, we'll never get this plan
12 constructed. That's what he said.

13 MS. BRADFORD: Can I make one comment? My
14 name is Anna Bradford, I'm the Deputy Division
15 Director in the Division of Licensing, Site Safety and
16 Environmental Analysis, and the Office of New
17 Reactors.

18 I just want to make clear that the COL
19 items, the ITAAC, the confirmatory items, this is all
20 the same process and approach we've used for previous
21 design certifications and review. So I just don't
22 want to get too off track.

23 I'm hoping that no one thinks that this is
24 something new and unusual or this is just for KHNP.
25 This is our Office of New Reactor's standard approach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the way that we've done that. I just want to make
2 that clear.

3 Thank you.

4 CHAIR CORRADINI: I just think some of the
5 Members weren't around when we had the joy of AP1000
6 and ESBWR. So that's part of it but I also think the
7 sheer number sometimes gives people surprise.

8 MEMBER MARCH-LEUBA: As a lesson learned,
9 I would hate if we pushed something to an ITAAC
10 because we don't want to make a decision now. It's
11 not something you can make a decision now what the
12 limit is. You say, well, we'll look at it later.

13 I have one practical example which is the
14 main steam isolation valves, the last one we saw.

15 MR. HUGHES: This is Brian Hughes.

16 If I may, the ITAAC is very similar to the
17 startup tests so you would not do an ITAAC until the
18 equipment is installed, it's ready to go, and you have
19 to test that equipment or that structural member.

20 So, the only thing is the paperwork, which
21 they choose to do on Part 52, seems to be a little
22 more than actual startup but that is the process on
23 Part 52, the rule. So that's what we're required to
24 do if they do a Part 52 application.

25 MEMBER MARCH-LEUBA: I'm not saying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything about the APR1400 for KHNP. If this is the
2 way they decide to do it, good for them.

3 MR. WARD: I'd like to add that we are
4 applying lessons learned. It may be somewhat
5 transparent in the way we present it to ACRS but there
6 are steps we've taken as we've gone through. There
7 were several rounds of the ITAAC review, including one
8 that took about a year.

9 We went through with the Division of
10 Construction and Instruction Programs and with the
11 Office of the General Counsel to make sure the wording
12 was clear legally, et cetera, and also for inspectors
13 to be able to make sure that they could actually
14 inspect what was being written.

15 There was a lot of times where an ITAAC
16 might make a statement that an inspector looks at and
17 says, well, how am I supposed to verify that? So,
18 there have been several rounds in the process to make
19 sure those were corrected to the best that we could.

20 And then most recently, right in the last
21 few months, we had one in particular in Chapter 3
22 which we're talking about now. So, in terms of
23 construction dimensions and things like that, which
24 was a big problem for the Vogtle construction, there
25 was a lot of back and forth and discussing how to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 And eventually, the staff came up with a
3 new approach versus using actual physical dimensions
4 like length, and came up with ratios for load versus
5 load capacity.

6 And that was all applied in the ITAAC and
7 that was a new approach. The Applicant liked it and
8 I think the industry is pleased that we took that
9 approach, and we're looking to see how it works out.

10 MEMBER MARCH-LEUBA: I'm glad you thought
11 of that. I'm just concerned that we are building this
12 plant and this building will be overwhelmed with
13 paperwork.

14 MR. WARD: So, there's an interest on both
15 sides, the industry and the NRC, to improve as we go
16 along.

17 MEMBER MARCH-LEUBA: I would like to
18 minimize the number.

19 MEMBER REMPE: I had the same thought
20 originally and so I asked how many were there for
21 AP1000 and ESBWR? And AP1000 had like 800.

22 You can correct me because I just looked
23 on the Internet, and I had 815 and this says 1202.
24 But ESBWR had 1614 so they actually doubled what
25 AP1000 had.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Not all ITAACs are
2 equal.

3 MEMBER REMPE: I guess, I don't know. You
4 can say this one's kind of --

5 MR. WARD: And a final statement, NEI and
6 the industry have come up with some standard ITAACs,
7 but they came out kind of late for this review.

8 And we presented them to KHNP and we
9 discussed it, but it looked like it might cause a
10 delay in the schedule and we wanted to maintain that.
11 So, KHNP made the decision to stay with the ITAACs
12 that were proposed and we worked with those.

13 MEMBER REMPE: But there was a schedule
14 pressure that offset that you might have been able to
15 --

16 MR. WARD: Shifting over to a whole new
17 approach on the ITAAC and not knowing exactly where
18 that would lead, they made the decision to stick with
19 what they had.

20 MEMBER REMPE: That's a good decision,
21 thank you.

22 MR. WARD: So, Chapter 4?

23 MR. WUNDER: Thank you. Good afternoon,
24 Mr. Chairman, ladies and gentlemen of the Committee.
25 I'm George Wunder, I'm the Project Manager assigned to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Chapter 4, Reactor, as well as a few other chapters of
2 the APR1400 DCD review.

3 The staff review of the application
4 covered the areas of fuel system design, nuclear
5 design, thermal and hydraulic design, reactor
6 materials, and the functional design of the reactivity
7 control system.

8 As of today, there is a confirmatory item
9 to be resolved when we receive Revision 3 to the DCD.
10 We have received all necessary markups to give us
11 confidence that this item will be resolved on receipt
12 of the next revision.

13 The Applicant has provided sufficient
14 information to allow the staff to conclude the proper
15 methodologies were used, proper codes and standards
16 apply, and applicable design and other regulatory
17 criteria were met.

18 The staff has concluded that the Applicant
19 has allowed for proper testing and inspection. The
20 staff has also performed its own confirmatory analysis
21 with its first cycle core design. Any questions?
22 Thank you.

23 MEMBER BALLINGER: I probably should
24 interject here. Each one of these chapters, there's
25 a statement about Revision 2 to Revision 3 and what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happening. The rest of the Committee should know that
2 Matt and I, and other Members of the Subcommittee,
3 didn't trust but verify.

4 The staff constructed an Excel spreadsheet
5 with every item on it with a ranking of whether it was
6 minor, less than minor, important and everything, and
7 we went through that and we have been going through
8 that so that we made sure that there were no real
9 showstoppers between Revision 2 and Revision 3 that we
10 would be tripped up on.

11 MR. HUGHES: Chairman, Members, my name is
12 Brian Hughes, I'm going to present Chapter 5, Reactor
13 Coolant System and Connecting Systems. The scope of
14 the review included thermal and hydraulic design
15 review, reactor materials review, code requirements.

16 We have two minor confirmatory items that
17 remain, pending submission of DCD Rev. 3. The
18 conclusions were that the Applicant provided an
19 adequate description of all aspects of the reactor
20 cooling system, its connecting systems, thereby
21 allowing the staff to conclude that proper
22 methodologies were used, the proper codes were
23 applied, all appropriate design criteria and other
24 applicable regulatory criteria were met, and the staff
25 concluded that the Applicant has allowed for proper

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 testing and inspection.

2 Let's move on to Chapter 6. Chapter 6 is
3 Engineered Safety Features. In Chapter 6 the scope of
4 design was thermal and hydraulic design, material
5 qualifications, heat removal adequacy, code and QA
6 requirements, and containment functional design.

7 For confirmatory items, we have seven
8 confirmatory items that remain pending submission of
9 the DCD Revision 3.

10 The conclusion of the staff is that the
11 Applicant provided an adequate description of all
12 aspects of the engineered safety features, thereby
13 allowing the staff to conclude that proper
14 methodologies were used, that proper codes were
15 applied, and that all appropriate design criteria and
16 other applicable regulatory criteria were met. The
17 staff concluded that the Applicant has allowed for
18 proper testing and inspection. Questions?

19 MR. LINTZ: Mark Lintz, Chapter 7,
20 Instrumentation and Controls.

21 The scope includes safety-related and non-
22 safety-related I&C systems, data communication
23 systems, quality and qualification, integrity,
24 reliability, diversity, defense and depth and single
25 failure criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There are four confirmatory items that
2 remain pending submission of the DCD Rev. 3.
3 Conclusion, the Applicant has demonstrated that the
4 I&C systems and the overall I&C architecture meet the
5 fundamental safety design principles of independence,
6 diversity, defense and depth, determinism, and
7 redundancy.

8 The Applicant has provided sufficient
9 information to demonstrate isolation of I&C systems
10 from external interfaces. The staff concludes that
11 the I&C design complies with NRC regulations and
12 conforms to NRC guidance.

13 Any questions?

14 MR. HUGHES: Okay, Chapter 8. Chapter 8
15 discusses the electric power system. The staff's
16 review covered the offsite power system, onsite AC and
17 DC power systems, and station blackout.

18 There are, I believe, three open items
19 that need to be resolved with the next revision of the
20 DCD. The staff has markups of the relevant material
21 and is confident that these items will be resolved
22 upon receipt of the revision.

23 MEMBER BLEY: Can you add a little detail
24 to that? From what you've seen, I take it you would
25 consider them resolved, you just need to see them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 documented?

2 MR. HUGHES: Right, actually what we've
3 got is a markup of the DCD page and they say this is
4 what the DCD page will look like --

5 MEMBER BLEY: That you find acceptable if,
6 in fact, acceptable --

7 MR. HUGHES: Find acceptable and all we
8 have to do is sign.

9 MEMBER BLEY: That's what I said. But it
10 didn't sound that way.

11 MR. HUGHES: Sorry if I wasn't clear. The
12 staff has concluded that the offsite and onsite
13 electrical systems comply with all applicable design
14 criteria and standards and that the Applicant provided
15 sufficient information and identified necessary
16 analysis to support a future COL application.

17 The staff further concluded that the
18 APR1400 design is capable with standing and recovering
19 from a station blackout of the stated coping period.

20 Okay, Chapter 9 covers the auxiliary
21 systems. We reviewed the fuel handling and storage
22 system, water systems, process of auxiliaries, HVAC,
23 and other systems.

24 All confirmatory actions were addressed in
25 the second revision to the DCD. The staff has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concluded that all auxiliary systems comply with the
2 applicable design and other regulatory criteria, and
3 that the Applicant has allowed for adequate pre-
4 operational testing.

5 The staff has concluded that the Applicant
6 has provided sufficient information and identified
7 necessary analysis to support a future COL
8 application.

9 And as long as I'm on a roll, I'll do
10 Chapter 10, Steam and Power Conversion System. The
11 staff has reviewed the turbine generator, main steam
12 system, condensate and feed and associated systems,
13 and the auxiliary feed and steam systems.

14 All confirmatory actions were addressed in
15 the second revision to the DCD. The staff has
16 concluded that the steam and power conversion systems
17 comply with the applicable design and other regulatory
18 criteria.

19 The staff has concluded that the Applicant
20 has provided sufficient information to support a
21 future COL application.

22 MR. WARD: And for Chapter 11, I'll turn
23 it over to whoever's doing it.

24 MR. LINTZ: Mark Lintz again, Chapter 11,
25 Radioactive Waste Management.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The scope includes liquid waste management
2 systems, the gaseous waste management system, solid
3 waste management system, and the process in the
4 effluent radiological monitoring and sampling system,
5 including the instrumentation used to monitor and
6 control releases of radioactive effluents and waste.
7 All confirmatory items were closed with DCD Revision
8 2.

9 In conclusion, the Applicant has
10 demonstrated that the systems comply with NRC
11 regulations and conform with NRC guidance to avoid
12 unmonitored and uncontrolled radioactive releases to
13 the environment. Are there any questions on Chapter
14 11?

15 Chapter 12, Radioactive Protection. The
16 scope includes information on facility and equipment
17 design and programs used to meet the radiation
18 protection standards in 10 CFR Parts 20, 50, 70.
19 There's one confirmatory item that remains pending
20 submission of the DCD Revision 3.

21 In conclusion, the Applicant has
22 demonstrated that the APR1400 design includes adequate
23 design features to maintain the radiation does
24 resulting from exposure to radioactive sources to
25 within the limits required by 10 CFR 120 and as low as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is reasonably achievable if operated with an
2 appropriate radiation protection program.

3 An Applicant seeking a combined license
4 must address the radiation protection program as well
5 as other identified radiation protection information
6 items.

7 Are there any questions on Chapter 12?

8 Chapter 13 is Conduct of Operations,
9 Chapter 13 describes a required organizational
10 structure, programs, and procedures required of a COL
11 to safely operate the plant.

12 There were 33 COL information items in the
13 five areas of concern for ACRS safety review,
14 including organizational structure training, emergency
15 planning, operational programs, and plant procedures.

16 Six areas of physical security had no
17 COLs, seventh area, fitness for duty, had one but we
18 do not present those to ACRS. There are two minor
19 confirmatory items remaining pending submission of DCD
20 Revision 3.

21 We concluded that the Applicant provided
22 adequate guidance and information including
23 establishing the training programs in accordance with
24 NEI0613A, emergency planning facility design
25 requirements, operational programs developed in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accordance with SECY-05-0197.

2 The GTGs and EDGs, there is an acronym
3 list at the back, those are guidelines used to develop
4 site-specific procedures that are prepared by KHNP,
5 which, when implemented by a COL, provides adequate
6 assurance the COL will operate the plant safely.

7 Any questions on Chapter 13?

8 MR. SANTOS: Good afternoon, my name is
9 Cayetano Santos, I'm the Chapter 14 Project Manager.
10 Chapter 14 is verification programs and there's two
11 major parts of it in the scope.

12 One is the initial test program which
13 includes pre-operational tests, initial fuel loading,
14 initial criticality tests, low-power tests and power
15 ascension tests. These are sections 14.1 and 14.2 of
16 the SER.

17 There are currently no confirmatory items
18 pending for these two sections so DCD Rev. 2 should be
19 the latest and greatest. Regarding the ITP, the
20 staff's conclusion is that the Applicant has fully
21 addressed all the information related to this and has
22 demonstrated compliance with the applicable
23 regulations.

24 The second aspect of the verification
25 programs, as was described earlier, ITAAC and other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Tier 1 information including definition of terms,
2 general provisions for the design descriptions. This
3 is discussed in Section 14.3 or the SER.

4 There are two confirmatory items in this
5 section that are pending DCD Rev. 3 and the staff's
6 conclusions regarding ITAAC are that it basically
7 meets the 5247B1 finding, that the ITAAC are necessary
8 and sufficient to provide reasonable assurance that if
9 the ITAAC are met, the facility that incorporates the
10 design has been designed and will be operated in
11 conformity with the NRC's regulations.

12 Any discussion, more about ITAAC?

13 MR. LINTZ: Chapter 15, Transient and
14 Accident Analyses.

15 The scope includes analyses of the APR1400
16 responses to postulated equipment failures or
17 malfunctions to determine the limiting conditions for
18 operation, limiting safety system settings, and design
19 specifications for safety-related structures, systems,
20 and components, the design basis accident
21 radiological consequence analysis.

22 All confirmatory items were closed with
23 DCDRevision2.

24 In conclusion, the Applicant has
25 demonstrated in its analysis of the APR1400 nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam supply system to anticipated operational
2 occurrences and postulated accidents and in its
3 analyses of the radiological consequences of design
4 besides accidents, that the APR1400 design complies
5 with NRC regulations and conforms with NRC guidance.

6 MR. HUGHES: Questions? We'll move on to
7 Chapter 16.

8 The scope of review -- the analysis of the
9 APR1400 defined terms limiting conditions for
10 operations, limiting safety system settings, and
11 design specifications for safety-related structures,
12 systems, and components, a review of the reactor trip
13 and the Engineering Safety Features Actuation System
14 known as ESFAS, setpoint, and service methodologies.

15 The status of the confirmatory items, all
16 confirmatory items are closed with DCD Revision 2.
17 The conclusion of the staff is that Applicant has
18 provided the APR1400 technical specifications that
19 comply with applicable regulations and conform with
20 the NRC guidance.

21 Questions?

22 Chapter 17, Quality Assurance and
23 Reliability Assurance. The scope included quality
24 assurance, including a quality assurance program
25 inspection, the maintenance rule, and a reliability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assurance program, including the reliability assurance
2 program list of structures, systems, and components.
3 There is one confirmatory item that remains pending
4 submission of DCD Revision 3.

5 To conclude, the Applicant added 3 COL
6 information items, making the reliability assurance
7 program acceptable to use for use to identify risk-
8 significant SSCs.

9 The Applicant has demonstrated that the
10 quality assurance maintenance rule and reliability
11 assurance programs comply with NRC regulations and
12 conform to NRC guidance.

13 Questions?

14 MR. SANTOS: Chapter 18, the scope of this
15 chapter's review was the Human Factors Engineering
16 portion of the APR1400 DCD. This also included 12
17 implementation plans that are documented in technical
18 reports that are incorporated by reference into the
19 DCD as Tier II information.

20 These technical reports described the
21 proposed methods that a COL Applicant would use to
22 develop the APR1400 control room design.

23 There are currently six minor confirmatory
24 items that remain pending submission of DCD Revision
25 3 and Revision 3 of some of these technical reports,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these implementation plan technical reports.

2 And the staff's conclusion is that the
3 Applicant's HFE design conforms with the guidance
4 described in NUREG 0711 and therefore provides
5 reasonable assurance that the HFE-related requirements
6 are satisfied.

7 Any questions?

8 MR. LINTZ: Chapter 19, Probabilistic Risk
9 Assessment and Severe Accident Evaluation. The scope
10 includes the probabilistic risk assessment and its
11 uses and the severe accident evaluation.

12 There remains seven confirmatory items
13 pending submission of DCD Revision 3.

14 The Applicant provided PRA revisions to
15 the at-power internal events Level 1 and 2 PRA, the
16 at-power internal fire Level 1 and 2 PRA, the at-power
17 internal flooding Level 1 and 2 PRA, the low-power
18 shutdown internal events, Level 2 PRA, the low-power
19 shutdown internal fire Level 1 and 2 PRA, and the low-
20 power shutdown internal flooding Level 1 and 2 PRA.

21 These updates were in response to an RAI
22 and represent significant improvements. The Applicant
23 has demonstrated that the probabilistic risk
24 assessment and severe accident programs comply with
25 NRC regulations and conform to NRC guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 19.3, Design Basis, Beyond Design Basis
2 External Event. The scope includes conformance of the
3 APR1400 design with SECY 1225, NRC orders EA-12-049
4 and EA-12-51 and the details addressing the
5 recommendations of the Near-Term Taskforce with
6 respect to managing and mitigating external events
7 that are beyond the design basis of the plant.

8 Two confirmatory items remain pending
9 submission of DCD Revision 3. The Applicant has
10 addressed in the APR1400 application the Commission-
11 approved Fukushima actions described in SECY 1225 and
12 in NRC orders EA-12-049 and EA-12-51 to the fullest
13 extent practicable.

14 19.4, Loss of Large Area. The scope
15 includes guidance and strategies provided to a COL to
16 address the loss of large areas of the APR1400 plant
17 due to explosions or fires from a beyond design basis
18 event, using readily available resources and
19 identifying potential practicable areas for the use of
20 beyond readily available resources.

21 This is provided to aid the COL in meeting
22 the requirements of 10 CFR 50.54(hh)(2). One
23 confirmatory item remains pending submission of DCD
24 Revision 3.

25 CHAIR CORRADINI: Can you tell me what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that one was? Some of these I remember, some I don't.
2 This one, I have no...I know you have a master list.

3 MR. WARD: Did one of the reviews speak to
4 this item?

5 CHAIR CORRADINI: Also, since we have all
6 these people in the audience dying to talk to us, I
7 wanted to go back to the two confirmatory in 19.3 but
8 let's do 19.4 first.

9 MR. WARD: Actually, they're all three
10 related. There was a realization, I guess, on the part
11 of KHNP that there was references to available mobile
12 generators.

13 And KHNP on site will provide a 480 volt
14 generator and it's a gas turbine generator, a GTG.
15 The remote or offsite mobile generators that would be
16 available to support in both of the situations in 19.3
17 and 19.4, KHNP cannot necessarily define what type
18 they're going to be.

19 They had said they were GTGs, now they're
20 just saying the 4.16 kV is a mobile generator, not
21 defining what type it is.

22 So, they've had to make that change in a
23 number of different places so both the confirmatory
24 items in 19.3 and 19.4 are trying to fix that.

25 CHAIR CORRADINI: So it's being, sorry for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the wording, but a bit more vague as to what it is
2 that will provide the necessary --

3 MR. WARD: It's going to 4.16 kV mobile
4 generator. I'm not necessarily exactly sure if
5 they're going to be diesel or something else.

6 So there's a number of places, in Chapter
7 8, 19.3 and 19.4, where they're trying to make the
8 same fix.

9 CHAIR CORRADINI: Thank you. I couldn't
10 remember.

11 MR. LINTZ: I think I've concluded 19.4.
12 19.5, Aircraft Impact Assessment. The scope includes
13 features considered in the APR1400 design to minimize
14 or mitigate the impact of a large, commercial
15 aircraft.

16 The APR1400 is designed to maintain the
17 reactor core cooled and the integrity of the spent
18 fuel pool. This section is provided to demonstrate
19 compliance with 10 CFR 50.150(a). All confirmatory
20 items were closed with DCD Revision 2.

21 The application performed a design-
22 specific assessment of the effects of the impact of a
23 large commercial aircraft on the APR1400 design.

24 The Applicant used the assessment to
25 identify and to incorporate into the design those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design features and functional capabilities to show
2 that with the reduced use of operator actions, the
3 reactor core remains cooled or the containment remains
4 intact, and the spent fuel cooling or spent fuel
5 integrity is maintained.

6 Any questions on Chapter 19?

7 MEMBER DIMITRIJEVIC: Yes, I have a quick
8 question.

9 I'm sort of curious, in some chapters you
10 opted to talk about future COLA application but in the
11 Chapter 19, you didn't mention anything about what are
12 the expectation of the Chapter 19 for the future COLA
13 applications?

14 You know, maybe this application would be
15 reviewed, be required, for example, to complete it,
16 human factors, what update needs to be done and things
17 like that.

18 MR. WARD: Well, there are site-specific
19 aspects to all the chapters that need to be done,
20 including COL Applicant would have to do a site-
21 specific PRA addendum to add on to what was provided
22 for the design of the plant.

23 MEMBER BLEY: Especially for the cooling
24 systems and maybe seismic.

25 MR. WARD: Earlier there was a question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about I believe ITAAC or something, about decisions
2 that have to be made. And obviously, one of the
3 bigger ones is the ultimate heat sink for a COL.
4 There's no decision made at all.

5 There's interface requirements that are
6 provided by the design, and it's up to the COL to
7 define and design how they're going to provide an
8 ultimate heat sink. And of course, that's going to be
9 a major factor.

10 MEMBER DIMITRIJEVIC: And how about the
11 peer review requirements for the risk-informed
12 applications? You didn't really measure anything on
13 COLA in this summary, COL applications, so I'm sort of
14 curious why did you decide not to?

15 MR. WARD: Hanh or Michelle, you want to
16 add anything?

17 MR. PHAN: Good afternoon, this is Hanh
18 Phan and I'm the Lead Reviewer for APR1400 PRA and
19 Severe Accident Evaluation. When the Applicant
20 submits their PRA, they inform the staff that they
21 have the peer reviews affirmed for their PRA.

22 There are COL information items asking the
23 COLs Applicants to conduct another peer review if they
24 plan to use their PRA for any risk-informed decision
25 method.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER DIMITRIJEVIC: Thank you.

2 MR. PHAN: Thank you.

3 MR. WARD: Any other questions related to
4 19 or any of the chapters at this point? Onto the
5 conclusions and next steps. I went through some of
6 this at the beginning.

7 In the original application, KHNP
8 requested the certification of the APR1400 design
9 under 10 CFR Part 52, Subpart B, which is the design
10 certification, which will include a rulemaking, which
11 has started and we hope to conclude by May of 2019.

12 Earlier this year on March 8th, the
13 Applicant submitted Revision 2 of the DCD and
14 requested a final design approval.

15 As I said, the FTA was superseded by the
16 standard design approval under Subpart E, and that is
17 what the Applicant would like to request, a standard
18 design approval.

19 In both cases, there are requirement for
20 ACRS to do a review of the safety of the design and we
21 are asking that ACRS provide that report to the
22 Commission to meet the requirements there.

23 MEMBER BLEY: Bill? This application came
24 to you in a different way than usual and we don't know
25 if there will ever be a COL here. The SER, or at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 least the drafts we looked at, are proprietary.

2 Will that be true with the final SER?

3 MR. WARD: No, there are parts of the SER
4 that might be redacted. We've tried to --

5 MEMBER BLEY: Pick out the limited?

6 MR. WARD: It's very limited. That's not
7 necessarily the case sometimes with the topical
8 reports because they tend to provide more information.

9 MEMBER BLEY: So if somebody decides to
10 build one of these not in the United States, it would
11 be a COL, they would still have access to most of the
12 review information as public information here?

13 MR. WARD: If it's publicly available it
14 will be on the website and they would have access to
15 that. But we wouldn't have any oversight on that, we
16 wouldn't be --

17 MEMBER BLEY: I think the drafts we had,
18 everything was marked which I understand.

19 MR. WARD: Our process, actually, when we
20 issue the SEs, when we finish an SE we issue it as
21 proprietary and we ask that the Applicant do a
22 proprietary review and a technical check to make sure
23 we didn't misstate something.

24 And they respond about ten days later and
25 that's the request, and I can send you examples of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 MEMBER BLEY: You don't have to, I was
3 just curious because I've never gone back after the
4 fact to see how that looks. It's never been on my
5 plate.

6 MR. WARD: Many of the SEs come back and
7 they say there's nothing proprietary in them, in which
8 case we go back, we remove the proprietary headings.

9 And some of them come back and there's
10 areas that there's a number that's marked or a
11 sentence that's marked, and we'll either redact that
12 or attempt to rewrite it without providing the
13 proprietary information.

14 MEMBER BLEY: So it's reasonably limited
15 in the final draft?

16 MR. WARD: Yes.

17 MEMBER BLEY: I was curious, it's never
18 come up before but I've never been thinking about
19 building these elsewhere before.

20 MR. WARD: Yes, it's a precautionary step
21 that we take where we provide them initially as
22 proprietary.

23 MEMBER BLEY: Thanks.

24 MEMBER BALLINGER: Yes, I wanted to make
25 sure I'm very clear, the original submittal was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Subpart B and then the letter that I thought I saw
2 said that they wanted to shift to Subpart E.

3 MR. WARD: They don't want to shift.

4 MEMBER BALLINGER: So now you're saying
5 they want both?

6 MR. WARD: They want both. So we're
7 asking for the report to confirm that required was
8 done for both, which is Section 52.53 and 52.141.

9 MEMBER BALLINGER: Which are identical
10 statements.

11 MR. WARD: Right, and pretty much most of
12 the requirements in those two subparts are identical.

13 CHAIR CORRADINI: Folks, we have a few
14 minutes. So what's the benefit of that? I don't
15 appreciate this.

16 MR. WARD: I can speculate.

17 MEMBER BLEY: Is that something that was
18 not for these people, but when Part 52 was written,
19 was it written with both A and B in it originally?

20 MR. WARD: It was originally written and
21 I couldn't find an old version but I was doing the
22 research on this and I think there was an Appendix O
23 that talked about some details on the final design
24 approval because I've seen that referenced.

25 But there were a number of reasons. There

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was a major re-write of Part 52 in 2007 and it's very
2 extensive if you look at the Federal Register. And
3 one of those rewrites was to shift the FTA through
4 this SDA and put it in the subpart.

5 CHAIR CORRADINI: Say that again, please?

6 MR. WARD: It was to shift some of the
7 requirements from the Appendix into Subpart E. Some
8 of it was already in E because I see references to the
9 same items, regulation numbers, but they were
10 rewritten.

11 The revision was pretty extensive, I don't
12 remember the exact reason why they did that but the
13 difference is really on what the COL would want to do.

14 If they want to be able to take the
15 standard design approval and run with it, they have a
16 lot more work they have to do but maybe that allows
17 them more freedom.

18 On the other hand, if they go with the
19 design cert, a lot of things are already decided for
20 them. But you might want to make changes in case they
21 have exemptions to the rule.

22 So providing both gives an option, and I'm
23 still working with the General Counsel's Office to
24 find out.

25 It's our understanding that when we issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the design cert, if no COL has chosen to ask for the
2 standard design approval, we will withdraw it and they
3 will only have the certification option.

4 MEMBER BLEY: Say that part again?

5 MR. WARD: I'm working with the general
6 Counsel's Office. It's my understanding, what he
7 understands, is that when the certification is
8 complete, if no COL has asked to use the standard
9 design approval we will withdraw it.

10 (Simultaneous speaking.)

11 MR. WARD: For a certain period of time,
12 but if nobody invokes it --

13 MEMBER BLEY: During that period of time?

14 MR. WARD: Between when we issue it and
15 when we certify the design in May next year that we
16 will withdraw it.

17 MEMBER BLEY: So it's that short of time?

18 MR. WARD: It will just be a
19 certification.

20 MEMBER BLEY: I'm not sure I understand
21 the difference much.

22 MEMBER BALLINGER: But then the standard
23 design approval is moot.

24 MR. WARD: Right, at that point, unless
25 somebody invokes it. They can continue with it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's what I'm being told now.

2 CHAIR CORRADINI: Okay, I got it.

3 MEMBER BALLINGER: But with the design
4 certification, that other is moot.

5 MR. WARD: The design approval is moot at
6 that point, yes.

7 MEMBER BLEY: Everybody responsible for
8 this is probably gone now.

9 MEMBER BALLINGER: Interesting, thank you.

10 MR. WARD: So it just allows you, if
11 somebody's anxious schedule-wise I guess or for other
12 reasons, they have the option. But that's my
13 understanding and I've been waiting for the General
14 Counsel to confirm.

15 MEMBER BALLINGER: Thank you.

16 MR. WARD: So, in conclusion we are asking
17 that the report reflect both the request for Subpart
18 B and Subpart E.

19 And the next step is assuming that the
20 staff has provided sufficient information and you're
21 able to provide the report that supports both
22 subparts, KHNP will issue Rev. 3 of the DCD and any
23 referenced technical quotes that have also been
24 revised.

25 We will review Revision 3, and I said here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that it'll be the revision of record but you corrected
2 me saying it's really Revision 2 in the confirmatory
3 actions.

4 So we will verify the revisions are in DCD
5 Revision 3 in the technical reports and we will issue
6 our final safety evaluation by the end of September.

7 Lastly, I just wanted to thank again the
8 Committee, Committee members, the support staff for
9 all the help and support, all the logistics, all the
10 scheduling that went into this, the back and forth of
11 providing information.

12 It's been a pleasure working with you and
13 we all are glad that we were able to do this and hope
14 that you didn't have any problem with what we did. We
15 appreciate your help and your findings.

16 MEMBER BALLINGER: Thank you very much.
17 We have enough time for Chapters 25 through 40 but I
18 couldn't find them anywhere.

19 MEMBER BLEY: Excuse me, Ron.

20 MEMBER BALLINGER: So we probably ought to
21 think about asking the public if there are any --

22 MEMBER BLEY: No, before that, I have a
23 process question for you, Mr. Chairman.

24 I'm remembering back and I don't remember
25 if it was the ESBWR or something after that where we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 wrote our letter on a situation like this, but when
2 the final DCD came out, it had some substantive
3 changes.

4 CHAIR CORRADINI: It wasn't ESBWR.

5 MEMBER BLEY: And the staff gave us a
6 chance to review that. We looked at it, looked
7 through it, and decided that those changes weren't
8 sufficient.

9 We actually wrote a letter saying we don't
10 need to have anymore meetings or something like that.

11 CHAIR CORRADINI: I don't know if we want
12 to -- your answer is correct but it was for a
13 different reason. It was ESBWR because they modified
14 their steam dryer design.

15 MEMBER BLEY: That was it.

16 CHAIR CORRADINI: So this is not relevant.

17 MEMBER BLEY: But it was a change later?

18 CHAIR CORRADINI: It was a change.

19 MEMBER BLEY: We didn't have further
20 meetings but we wrote a letter say it doesn't change
21 our opinion as I recall.

22 CHAIR CORRADINI: And since you're into
23 process land, when they start writing the rule, we are
24 allowed comment on that if we choose.

25 We have chosen with AP1000 and ESBWR not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to write any comments or a letter of report on the
2 rule because for all intents and purposes the rule is
3 this.

4 MEMBER BALLINGER: Now, should we go and
5 ask for comment? Or I'll turn it back over to you if
6 you want to do the asking. I'm in the other room.

7 Are there any comments from anybody in the
8 room? And I don't know whether the phone line is
9 open.

10 CHAIR CORRADINI: Just wait until it
11 crackles.

12 MEMBER BALLINGER: I didn't hear it.

13 CHAIR CORRADINI: Chris will check. We're
14 open. Are there any members of the public that would
15 like to make a comment? Please state your name and
16 make your comment. Five-second rule. Hearing none,
17 back to you, Mr. Chairman.

18 MEMBER BALLINGER: Okay, thank you very
19 much. Let me thank KHNP and their associated
20 consultants for all these wonderful months and years
21 of discussion. I thank the staff.

22 At this point, we're going to go off the
23 record, we'll take a break until 3:35 p.m. -- let's be
24 generous, 3:40 p.m. and then we'll come back on the
25 record and start dealing with our draft letters.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, you're welcome to stay, the fun only
2 begins now. 3:40 p.m. We'll discuss that after we're
3 off the record.

4 (Whereupon, the above-entitled matter went
5 off the record at 3:18 p.m.)

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



Brunswick Steam Electric Plant Units 1 and 2 MELLLA+ (Maximum Extended Load Line Limit Analysis Plus)

Advisory Committee on Reactor Safeguards Meeting



BSEP Station Overview and MELLLA+ Project Overview

Jeff Nolin – BSEP GM Nuclear Engineering

Objectives

Show Need for MELLLA+

Describe Key Aspects and Answer Questions

Demonstrate Readiness

Requested Approval supporting 3Q 2018 Implementation

BSEP Station Overview

- General Electric BWR-4, Mark I Containment
- Began commercial operation in 1975 (Unit 2) and 1976 (Unit 1), OLTP 2436 MWt
- EPU (120% OLTP) 2923 MWt fully implemented in 2004 (Unit 1) and 2005 (Unit 2)
- 24 month operating cycle
- Transitioned to Framatome Fuel in 2008 (U1) and 2009 (U2)
- Full Core Framatome ATRIUM 10XM Fuel
- Licensed for Increased Core Flow (ICF) (110% at reduced power, 104.5% at CLTP 2923 MWt)


MELLLA+ Project Overview – Background and Benefits

Background

- EPU reduced the licensed flow window at rated power from approximately 24% to 6% Total Core Flow. MELLLA+ will expand the licensed flow window at 100% power from 99-104.5% to 85-104.5% Total Core Flow.

Benefits

- Fewer reactivity manipulations
- Reduction in down-powers
- Increase station capacity factor
- Lower Reactor Recirculation Pump (RRP) speeds:
 - increase RRP seal lifetime
 - increase net electric generation due to lower pump power usage



MELLLA+ Project Overview – Implementation Progress and Plans

- Phase 1 (Pre-MELLLA+ Approval) – Plant Modifications and Training
 - Standby Liquid Control (SLC) Boron-10 (B10) enrichment upgrade (Completed in 2016 & 2017)
 - APRM EPROM modifications (Completed Mid 2016 on both Units)
 - Plant Operators Introduced to MELLLA+ (2017 Cycle 3 Training)
 - Operators provided with overview of hardware and procedure changes including revised Power/Flow maps along with simulator exercises on new time critical operator action. (2017 Cycle 6 Training)
- Phase 2 (Post MELLLA+ Approval) – Online Updates and Testing
 - Implement new Technical Specifications, Engineering Changes (ECs), Procedures
 - Special Testing in MELLLA+ Domain including Level Control, Pressure Control, APRM / LPRM / TIP / OPRM data evaluations, Fuel Thermal Margins, and Moisture Carryover
 - Transition to Detect & Suppress Solution – Confirmation Density (DSS-CD) Stability Option from Option III

MELLLA+ Design and Analyses

John Siphers – GM Nuclear Fuel Design

MELLLA+ Design and Analyses

- The M+ SAR follows the guidelines contained in the generic MELLLA+ Licensing Topical Report (M+LTR), NEDC-33006P-A.
 - Although the M+LTR is a product of GEH, BSEP utilizes Framatome A10XM fuel. As such, the safety evaluations provided in the M+SAR are the results from both GEH and Framatome.
 - GEH evaluated the overall plant response with M+, ATWS, ATWSI and long term stability solution DSS-CD. GEH has a long experience of modeling BSEP from startup through EPU operation.
 - Framatome performed the remaining typical reload specific fuels analyses. Framatome has been modeling BSEP at EPU conditions since the original ATRIUM 10 transition in 2008 and ATRIUM 10XM since 2011.
- Consistent with the M+LTR, the evaluation of BSEP Emergency Core Cooling System Net Positive Suction Head demonstrated there is no adverse impact and therefore no change to Containment Accident Pressure credit is warranted with MELLLA+.

MELLLA+ Design and Analysis – Vendor Methodology Applicability

- ANP-3108P, Applicability of Framatome BWR Methods to Brunswick Extended Power Flow Operating Domain (EPFOD)
 - No SER restrictions on Framatome methodology that are impacted by EPFOD
 - BSEP core and assembly conditions in MELLLA+ are equivalent to core and assembly conditions of other plants for which the methodology was benchmarked
- GEH methods are applicable to MELLLA+ and are capable of modeling Framatome fuel
 - Transfer of information from Framatome to GEH allowed explicit modeling of the fuel
 - Duke developed and provided a GEH thermal hydraulic model (ISCOR) for ATRIUM 10XM
 - NRC RAI SRXB-RAI-11 response provided steady-state core simulator comparisons for BSEP MELLLA+ cycle using GEH and Framatome methods
 - Shows GEH methods modeled the A10XM fuel and core characteristics in a satisfactory manner

MELLLA+ Design and Analysis – Key GEH Analyses

- GEH analyzed Anticipated Transient Without Scram (ATWS) and ATWS with Instability (ATWSI) scenarios.
- To address the effect of any uncertainty in GEH modeling A10XM, fuel parameter sensitivities were performed.
- For ATWSI, additional sensitivities were executed utilizing the homogenous nucleation plus contact temperature model for T_{\min} and plant data was utilized to determine an appropriate feedwater temperature reduction rate.

MELLLA+ Design and Analysis – Key MELLLA+ Mitigating Actions

- BSEP will transition from Option III to Detect and Suppress Solution – Confirmation Density (DSS-CD) for thermal hydraulic stability (THI) protection. To set the DSS-CD amplitude discriminator, GEH analyzed BSEP limiting events to demonstrate adequate margins.
- BSEP increased the Standby Liquid Control System (SLCS) B-10 enrichment (47 to 92% B-10) such that the ATWS heat load to the suppression pool was reduced at 2923 MW_{th}/85% flow when compared to original power 2436 MW_{th}/75% flow conditions (19.8% B-10).
 - 2436 MW_{th}/75% Flow peak pool temperature was 189.4 F while EPU/MELLLA+ is 174.0 F.

Operator Actions and Training

Mark DeWire – BSEP Assistant OPS Manager - Shift

Operator Actions and Training – Overview

Operator Training was Conducted During Two Cycles of 2017

- Cycle 3 (May/June 2017)
 - MELLLA+ Introduction (Classroom Only)
- Cycle 6 (Oct/Nov 2017)
 - MELLLA+ Procedure and Equipment Changes (Classroom)
 - MELLLA+ Tech Spec Workbook (Classroom)
 - Equipment Demonstrations (Simulator)
 - ATWS Proficiency Training (Simulator)
- Operator training included training on:
 - MELLLA+ Operating Restrictions, Technical Specification changes, and procedure updates
 - Time Critical Operator Action (TCOA) to initiate reactor water level reduction during ATWS within 120 seconds

Operator Actions and Training – ATWS Time Critical Operator Actions

ATWS TCOA Training

- Operating crews were trained on MELLLA+ ATWS time critical actions
- Three high power ATWS simulator scenarios performed per crew
- February 2018 NRC Audit observed performance of high power ATWS time critical actions

Operator Actions and Training – ATWS Time Critical Operator Actions

ATWS TCOA timing results:

- 12 operating crews were timed initiating ATWS reactor water level reduction (36 scenarios)
- Average time to initiate reactor water level reduction was 85 seconds
- Standard deviation was 16 seconds
- Operating crews have demonstrated ability to perform TCOA within required times with margin

Conclusions

Implementation of MELLLA+ will provide significant benefits:

- Operators will have greater flexibility in using core flow to control reactivity
- Reduces the number of plant downpowers and reactivity manipulations
- Increases the station's capacity factor during the operating cycle

Brunswick will be ready to implement the MELLLA+ License Amendment

- Installation of the DSS-CD firmware and SLC enrichment change complete
- Training on MELLLA+ equipment, procedures and required operator actions is complete
- Final PRNM setpoint Engineering Change is approved
- Implementation test plan established

Requested Approval supporting 3Q 2018 Implementation

Questions

Backup Slides


Power Density Comparison for MELLLA+ Submittals

Plant	GGNS	PB	BFN	BSEP	NMP2	MNGP
EPU Thermal Power (MWth)	4408	3951	3952	2923	3988	2004
Licensed Core Flow (Mlb/hr)	112.5	102.5	102.5	77	108.5	57.6
MELLLA+ knee % power	80.6	78.8	77.6	77.6	77.6	82.5
MELLLA+ knee % flow	55	55	55	55	55	57.4
power/flow ratio at MELLLA+ knee	57.42	55.23	54.40	53.56	51.86	50.01
power density (kW/ft)	5.5	4.8	4.8	4.9	4.9	4
power density (kW/L)	62.3	58.4	58.4	59	59	48.3

BSEP Station Overview

Key Milestones	Year	MWt
Full Power Operation (Original Licensed Thermal Power - OLTP)	1976 (Unit 1) / 1975 (Unit 2)	2436
MELLLA Operating Domain	1990 (Unit 1) / 1989 (Unit 2)	
Stretch Power Uprate Operation (105% OLTP)	1996 (Unit 1) / 1997 (Unit 2)	2558
Option III Stability Solution	2002 (Unit 1) / 2003 (Unit 2)	
Extended Power Uprate Operation (120% OLTP)	2004 (Unit 1) / 2005 (Unit 2)	2923
Renewed Operating License 2036 (Unit 1) / 2034 (Unit 2)	2006 (Unit 1) / 2006 (Unit 2)	
Framatome A10 Fuel Introduction	2008 (Unit 1) / 2009 (Unit 2)	
Framatome A10XM Fuel Introduction	2012 (Unit 1) / 2011 (Unit 2)	

Special Testing in MELLLA+ Domain



MELLLA+ Design and Analysis – SLMCPR

- BSEP does not have any SLMCPR penalties for operation in EPU. No additional SLMCPR penalty is warranted for MELLLA+.
- The primary concern prompting a penalty is increased void fractions due to operation at higher power/flow ratios and lack of operating data to justify current licensing uncertainties.
- Framatome operating experience includes data that validates use of existing uncertainties with Framatome methods at the BSEP MELLLA+ high power/flow ratios.
- Therefore, operation in the MELLLA+ region is within the analysis capabilities of Framatome methods and uncertainties and no SLMCPR penalty is warranted.

MELLLA+ Design and Analysis – DSS-CD

- BSEP will transition from Option III to Detect and Suppress Solution – Confirmation Density (DSS-CD) for thermal hydraulic stability (THI) protection.
 - DSS-CD adds a fourth algorithm (confirmation density) to the three available with Option III (period based, growth based, amplitude based). All four of these algorithms detect instability and protect the reactor from THI. The confirmation density algorithm will become the licensing basis method.
 - DSS-CD implementation includes Manual Backup Stability Protection (BSP) and Automated Backup Stability Protection (ABSP).
 - BSP is utilized when OPRM system is inoperable and relies on manual operator action. For BSEP, operation in MELLLA+ regime is not allowed with BSP.
 - ABSP provides an automatic trip if operating in a region with high potential for thermal hydraulic instability
 - To set the DSS-CD amplitude discriminator BSEP limiting events were performed to demonstrate adequate margins.

MELLLA+ Design and Analysis – ATWS

- GEH performed Anticipated Transient Without Scram (ATWS) scenarios.

Parameter	Result	Design Limit
Suppression Pool Temperature (F)	174.0	207.7
Peak Cladding Temperature (F)	1215	2200
Peak Containment Pressure (psig)	8.4	62

- To address the effect of any uncertainty in GEH modeling A10XM, fuel parameter sensitivities were performed.
- BSEP increased the Standby Liquid Control System (SLCS) B-10 enrichment (47 to 92% B-10) such that the heat load to the suppression pool was reduced at 2923 MW_{th}/85% flow when compared to original power 2436 MW_{th}/75% flow conditions (19.8% B-10).
 - 2436 MW_{th}/75% Flow peak pool temperature was 189.4 F while EPU/MELLLA+ is 174.0 F.

MELLLA+ Design and Analysis – ATWSI

- Limiting ATWSI event is the turbine trip with bypass (TTWBP) initiated from 100%P/85% F.
- Key operator action credited: Reactor water level reduction within 120s following indication of no scram.
- To address the effect of any uncertainty in GEH modeling A10XM, fuel parameter sensitivities were performed to show the operator actions credited are appropriate.

MELLLA+ Design and Analysis – ATWSI

- Additional sensitivities were executed utilizing the homogenous nucleation plus contact temperature model for T_{\min} .
 - More conservative compared to the Modified Shumway T_{\min} model used in the SAR.
 - Plant data was utilized to determine an appropriate feedwater temperature reduction rate.
- ATWSI results will be presented during proprietary session.

MELLLA+ Design and Analysis – RSAR MELLLA+ Impacts

- MELLLA+ Reload Safety Analysis Report (RSAR) was submitted to NRC as a supplemental information to MELLLA+ LAR
 - Documents Single Loop Operation (SLO) and Feedwater Temperature Reduction are not allowed within the MELLLA+ operating domain
 - Documents additional SLMCPR calculations that are required to encompass MELLLA+ domain
 - New MELLLA+ plant specific LOCA analysis
 - No impact to ASME overpressurization. ATWS overpressurization slightly higher when initiated from MELLLA+ conditions
 - No impact on OLMCPR
 - No impact on LHGR limits
 - No impact on MAPLHGR Limits
 - Documents cycle specific DSS-CD Stability acceptability

Operator Actions and Training – License Restrictions

Operation in the MELLLA+ domain is prohibited when operating with the following plant conditions:

- Reactor Recirculation System Single Loop Operation (SLO)
- Feedwater Temperature Reduction (currently defined as more than 10°F below design)
- Guidance on restrictions will be incorporated into Abnormal Operating Procedures (AOPs), Annunciator Panel Procedures (APPs), Operating Procedures (GPs and OPs), and engineering procedures (ENPs).

Operator training has been conducted on these restrictions and the corresponding procedure updates.

Operator Actions and Training – Technical Specification Changes

- New Operating License Condition – Operation in MELLLA+ domain not allowed with Feedwater Temperature Reductions (FWTR)
- TS 3.1.7 SLC - B10 enrichment increase (92%)
- TS 3.3.1.1 RPS Instrumentation
 - DSS-CD – Confirmation Density Algorithm (CDA) Replaces Period Based Detection Algorithm (PBDA) as the required Thermal Hydraulic Instability (THI) detection algorithm
 - OPRM Upscale and Out of Service actions - ABSP (Automatic Backup Stability Protection)
 - APRM Simulated Thermal Power (STP) trip setpoint change

Operator Actions and Training – Technical Specification Changes (Continued)

- TS 3.4.1 Recirculation Loops - No operation in MELLLA+ domain during SLO
- TS 5.6.5 COLR requirements for MELLLA+ - BSP regions and boundaries, and ABSP setpoints
- TS 5.6.7 Reporting requirements for OPRM upscale function inoperability
- TRM 3.3 Rod block setpoint, TRM nominal trip setpoints,
- TS/TRM bases

Operator training has been conducted on the MELLLA+ Technical Specifications

Operator Actions and Training – ATWS Time Critical Operator Actions (TCOA)

Time Critical Operator Action (TCOA): Initiate reactor water level reduction during ATWS within 120 seconds

- ATWS Emergency Operating Procedures (EOPs) revised to reflect TCOA
- Terminate/Prevent Injection hard card revised to improve efficiency
- Control Room Supervisor (CRS) retains Command and Control of TCOA

Operator training conducted on 120s Terminate and Prevent TCOA



**655th ACRS Full Committee Meeting
July 11, 2018**

**Brunswick Steam Electric Plant Units 1 & 2
Maximum Extended Load Line Limit Analysis Plus (MELLLA+)**

**Josh Borromeo (Lead Reviewer, DSS/SRXB)
Andy Hon (Project Manager, DORL)
Aaron Wysocki (Consultant, ORNL)
Office of Nuclear Reactor Regulation**

- Similar to other plants' MELLLA+ SE
- Addressed each section of the BSEP SAR and applicable LTRs' L&Cs
- Conducted two audits on 5 focused areas
 - Safety analyses – July 2017 in Rockville
 - Simulator – February 2018 on site
- Included a summary of RES confirmatory study using TRACE computer modelling of Brunswick plant specific MELLLA+ conditions.
- Finalizing the SE for August decision date after the ACRS briefing.



NRC Staff Review Team

Office of Nuclear Reaction Regulation		
J. Borromeo (Lead)	M. Biro	M. Breach
M. Chernoff	J. Dozier	A. Hon
J. Hughey	D. Ki	M. Panicker
A. Sallman	R. Stattel	A. Smith
M. Smith	A. Wysocki (ORNL)	
Office of Nuclear Regulatory Research		
A. Bielen	K. Gibson	C. Gingrich
N. Hudson	J. Staudenmeier	P. Yarsky (Lead)

Agenda

Open Session to the Public

Duration	Presenter(s)	Topic
	ACRS	Opening introduction
25 min	Licensee	License Amendment Request overview
10 min	NRC staff / ORNL	Review highlights
5 min	ACRS	Public comments

Closed Sessions Below

15 min	Licensee/GEH	LAR - ATWSi details (GEH proprietary)
25 min	NRC staff / ORNL	Review details and TRACE (GEH proprietary)
1 min	NRC SES	Management closing remark
	ACRS	Discussions and meeting adjourned



U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

Brunswick MELLLA+ Application

Application Overview

- MELLLA+ expands the operating domain by allowing operation at 85% core flow at 100% power
- Followed the GEH MELLLA+ licensing topical report
 - Fifth MELLLA+ review with GEH methods
 - Second MELLLA+ review with Framatome methods and fuel
 - First analysis with the combination of GE methods, Framatome methods, and Framatome fuel



- Applicability of Framatome methods to BSEP MELLLA+
 - Framatome methods not generically approved for MELLLA+
- SLMCPR 0.03 penalty removal
 - A SLMCPR penalty has been applied to other MELLLA+ applications
- Application of DSS-CD
 - t_{\min} - time period lower limit change (in the DSS-CD LTR, the time period lower limit is identified as T_{\min})
- ATWS-I and ATWS
 - First time application of GEH methods with Framatome fuel
 - T_{\min} (minimum film boiling temperature) uncertainty (ATWS-I)
 - Feedwater temperature reduction rate (ATWS-I)



Review Summary – Framatome Methods in MELLLA+

- Framatome approved (for EPU) methods have been used by BSEP. In addition, the licensee evaluated GEH topical reports limitations and conditions for generic applicability
- Framatome methods extended to MELLLA+ for recent Monticello MELLLA+ (EFW) LAR
- All the methods are the same as Brunswick except for stability and ATWS (GEH methods)
- Staff determined that the Framatome methods were valid for BSEP MELLLA+ conditions
 - Same conclusion as Monticello (except for MICROBURN-B2 for SLMCPR 0.03 penalty)



Review Summary – SLMCPR

0.03 Penalty

- The 0.03 SLMCPR penalty was applied for Monticello MELLLA+ (EFW) above a power-to-flow ratio of 42 MWt/Mlbm/hr
- AURORA-B AOO topical report review identified no adverse uncertainty trend in MELLLA+ at high power-to-flow ratios
- AURORA-B and Brunswick both use MICROBURN-B2
- Licensee took a similar approach as AURORA-B
- Staff determined that licensee provided sufficient data and justification such that this penalty was not necessary for Brunswick MELLLA+



- DSS-CD implemented in other MELLLA+ applications which included adjustments to amplitude discriminator and extension of DSS-CD applicability for the fuel type
- Brunswick is adjusting amplitude discriminator and extended DSS-CD applicability for ATRIUM-10XM fuel which is similar to other applications
- The new item is t_{\min} , time period lower limit to 1.0s
- Staff requested sensitivity studies to justify this change and determined that the change would maintain the as-approved performance of DSS-CD



- Staff requested ATWS-I calculations using homogenous nucleation temperature for minimum film boiling temperature (T_{\min}) following a similar approach as Peach Bottom
- Both Brunswick and Peach Bottom gained margin in ATWS-I by reducing the feedwater temperature reduction rate
- The new item is the use of TRACG for ATWS-I with ATRIUM 10XM fuel
- Staff reviewed the approach to bound the ATRIUM 10XM fuel and determined that it was conservative and the results met the ATWS acceptance criteria
- For ATWS-I, staff used a TRACE confirmatory study to support conclusions



Conclusions

- The BSEP safety analysis report discusses the acceptability of the focus areas of the review
 - Framatome methods were valid for the conditions for BSEP MELLLA+
 - The 0.03 SLMCPR penalty is not necessary for BSEP
 - DSS-CD t_{\min} increased to 1.0 sec would maintain the as-approved performance of DSS-CD
 - The ATWS-I analysis of ATRIUM 10XM was conservative and the ATWS-I results meet the ATWS acceptance criteria
- The staff concludes that the nuclear design of the fuel assemblies, control systems, and reactor core will continue to meet the GDC regulatory requirements
- The staff finds the proposed BSEP MELLLA+ operating domain extension acceptable



Additional Backup Slides



Containment Accident Pressure (CAP) Credit for NPSH

Currently Licensed CAP Credit – EPU LAR Approved in 2002

- CAP Credit of 5 psi for Long Term (after 10 min) LOCA Pump NPSH
- No CAP Credit for Short Term (up to 10 min) LOCA Pump NPSH
- No CAP Credit for Special Events (SBO, ATWS, and Appendix R Fire) NPSH

MELLLA+ CAP

- No Additional CAP Credit Requested - SECY-11-0014 is not Applicable
- RHR & CS Pump LOCA Short & Long term NPSH Analysis is Bounded by Current Analysis,
- Currently Licensed CAP Credit of 5 psi for LOCA Long Term As-Is
- ATWS NPSH Margin Increased Due to Increased Boron Concentration from 47-Atom Percent to 92-Atom percent
- No Impact on NFPA-805 Fire and SBO NPSH
- No Impact on SBO Event NPSH



U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

CAP Credit Commission Documents

- **SECY 11-0014, “USE OF CONTAINMENT ACCIDENT PRESSURE IN ANALYZING EMERGENCY CORE COOLING SYSTEM AND CONTAINMENT HEAT REMOVAL SYSTEM PUMP PERFORMANCE IN POSTULATED ACCIDENTS” (ML102590196)**
- **SRM 11-0014, “STAFF REQUIREMENTS – SECY-11-0014 – USE OF CONTAINMENT ACCIDENT PRESSURE IN ANALYZING EMERGENCY CORE COOLING SYSTEM AND CONTAINMENT HEAT REMOVAL SYSTEM PUMP PERFORMANCE IN POSTULATED ACCIDENTS” (ML110740254)**




SRM-SECY-11-0014 - Commission Direction on Use of CAP

- In SECY 11-0014 the staff recommended and in SRM 11-0014 the commission approved Option 1
- “The staff should evaluate current extended power uprate (EPU) applications, as well as future applications for new or increased credit for containment accident pressure, consistent with staff practice in implementing the current risk review guidance (Standard Review Plan Section 19.2), including the review of nonrisk-informed applications such as EPUs and the recently-developed deterministic guidance based on recommendations of the Advisory Committee on Reactor Safeguards (ACRS) to include uncertain and margins in CAP calculations.”




Brunswick MELLLA+ Power/Flow Map

Core Flow (Mlb/hr)





P/F Map Plant Comparison





Conclusions - Operational

- The BSEP safety analysis report proposes solutions to maintain margins under MELLLA+ that are acceptable to satisfy the regulatory criteria
 - FWHOOS not allowed in MELLLA+
 - SLO not allowed in MELLLA+
 - DSS-CD T_{\min} increased from to 1.0 sec
 - SLC boron enrichment increased
 - 120 sec operation action time for reactor level reduction
- The staff concludes that the nuclear design of the fuel assemblies, control systems, and reactor core will continue to meet the GDC regulatory requirements
- The staff finds the proposed BSEP MELLLA+ operating domain extension acceptable

**Proposed Revision 2 of DI&C-ISG-06
“Licensing Process”
&
Status Update: Integrated Action Plan
for Modernizing the NRC Digital I&C
Regulatory Infrastructure**

USNRC Staff Briefing to the ACRS Full Committee
“Digital Instrumentation and Controls”

July 11, 2018

Discussion Topics

- I. Draft Revision 2 to DI&C-ISG-06, “Licensing Process”

- II. Integrated Action Plan (IAP) Strategy for Digital I&C Modernization—Update on Status of Activities

I. Draft Rev. 2 to DI&C-ISG-06 “Licensing Process”

Samir Darbali, NRR/DE/EICB

Richard Stattel, NRR/DE/EICB

Deanna Zhang, NRO/DEI/ICE

Advisory Committee on Reactor Safeguards

Full Committee Briefing

July 11, 2018

ACRS Subcommittee Briefing

(May 17, 2018)

- The staff briefed the ACRS DI&C Subcommittee on the proposed changes to be made to DI&C interim staff guidance (ISG) 06, draft Revision 2.
- The ACRS Subcommittee provided verbal comments to the staff. The main comments focused on how the “System Architecture” and “Fundamental Design Principles” are addressed within the Tier 1, 2, 3 Review Process.

DI&C-ISG-06 Purpose and Scope

- Defines the licensing process used to support license amendment request (LAR) reviews associated with safety-related DI&C equipment modifications in operating plants and in new plants once they become operational
- Provides guidance for activities performed before LAR submittal and during LAR review. The NRC staff uses the process described in ISG-06 to evaluate compliance with NRC regulations
- ISG-06 makes reference to, and is to be used in conjunction with SRP Chapter 7 (NUREG-0800)

ISG-06 Rev. 1 – Key Concepts: Tiers

Tiers – a general guide for defining the scope or complexity of a review:

- Tier 1 – license amendments proposing to reference a previously approved topical report.
- Tier 2 – license amendments proposing to reference a previously approved topical report with deviations tailored to the plant specific application.
- Tier 3 – license amendments proposing to use a new DI&C platform or component(s) not previously approved by an NRC topical report review.

ISG-06 Rev. 1 – Key Concepts: Phases

Phases – a general guide for defining the NRC staff activities to be performed during the review.

- Phase 0 – Pre-Application Meetings with the NRC Staff
- Phase 1 – Initial Application (LAR)
System Description, Compliance with IEEE Stds, Design Requirements, Design Specifications, Planning and Process Information
- Phase 2 – Continued Review and Audit (Supplemental Information)
System Architecture, Software/Hardware Design Specifications, Test Results
- Phase 3 – Implementation and Inspection

ISG-06 Rev. 1 – Lessons Learned and Industry Feedback

- ISG-06, Rev. 1 was used to review the Diablo Canyon Plant Protection System DI&C LAR (ADAMS Accession No. ML16139A008), the Hope Creek Power Range Neutron Monitoring System LAR (ADAMS Accession No. ML17216A022), and DI&C topical report reviews
- The concepts of tier labels and review phases are useful
- The “one-stop shop” approach of Revision 1 created challenges:
 - Duplication of SRP Chapter 7, IEEE Std 603 and IEEE Std 7-4.3.2 guidance
 - References to Regulatory Guides and other documents became outdated
 - Revision 1 focused more on specific documents, instead of the information needed to make the required regulatory findings

ISG-06 Rev. 1 – Lessons Learned and Industry Feedback (cont.)

- The Tier 1, 2, and 3 Review Process could be further improved/streamlined
- Industry has expressed concerns with ISG-06, Rev. 1:
 - Significant resources are required for procuring, developing, and testing a full DI&C design before the license amendment is issued
 - Several review criteria topical areas were repetitive
- Staff's lessons learned and industry feedback on Rev. 1 informed the development of ISG-06, Rev. 2

ISG-06 Revision 1 vs. Draft Revision 2

- Both ISG-06 **Revision 1** and **Revision 2** include a Tier 1, 2, 3 Review Process:
 - Use of a Pre-Approved Platform Topical Report
 - System Description and System Architecture
 - Review of Software Design, Implementation & Test Plans and Processes
 - Review of Implementation and Test Results Information
- ISG-06 **Revision 2** also introduces an Alternate Review Process:
 - Use of a Pre-Approved Platform Topical Report
 - System Description and System Architecture
 - Review of Software Design, Implementation, & Test Plans and Processes
 - ***The Implementation and Test Results Information will be subject to inspection***

Comparison of Licensing and Oversight Activities

Timeline →

Tier 1, 2, and 3 Review Process (Rev. 1 and 2)

LAR Submitted →
Phase 1 Information Available

NRC: LAR (Phase 1) and Phase 2 Review, and Regulatory Audit(s)

← LA Issued

NRC: Optional Regional Inspections of Site Activities

Licensee Activities

Tier 1, 2, and 3 Licensee Activity:
Producing and Submitting Phase 2 Supplement Info
(Not applicable to the Alternate Review Process)

Modification Concept and Phase 0 Meeting(s)

High Level System Design, Planning

Detailed HW & SW Design and Fabrication

Implementation and Test Activities, including FAT Report

Post FAT Licensee Activities, SAT

Alternate Review Process (Rev. 2)

LAR Submitted →
All Information to meet Regulatory Requirements Available

NRC: LAR Review and Regulatory Audit(s)

← LA Issued

NRC: Optional Vendor Inspections of Implementation & Test Activities per License Conditions

NRC: Optional Regional Inspections of Site Activities

Timeline →

Characteristics of a License Amendment Request (LAR) using the Alternate Review Process

- The LAR provides the necessary and sufficient design information to demonstrate regulatory compliance
 - The LAR describes the licensee's Vendor Oversight Plan that ensures the vendor executes the project consistent with the LAR and the requirements of the 2015 version of ASME NQA 1, Part II Subpart 2.7 on Quality Assurance Requirements for Computer Software for Nuclear Facility Applications
 - The LAR includes appropriate commitments to complete plant-specific actions that are included in the referenced topical report
 - The LAR includes appropriate commitments to complete lifecycle activities under the licensee's QA program
-

Alternate Review Process: Licensee Commitments and License Conditions

- The Alternate Review Process relies on the LAR containing licensing information and additional regulatory commitments to implement remaining development phases by the licensee's QA program, after the license amendment is issued
- The NRC staff may likely translate some of the regulatory-significant commitments into license conditions, as part of the approval (e.g., factory acceptance testing)

Phase 0 Activities and Review Process Selection

- Phase 0, Pre-Application meeting(s) will be used to discuss with licensees how the proposed DI&C modification LAR will address:
 - Licensee-identified Review Process for the LAR
 - Use of a pre-approved topical report, and any significant variances
 - Portion of the plant system to be replaced and its impact on the plant, calibration, surveillance testing (and associated impacts on plant staff), and FSAR impacts
 - Key design concepts, including the four fundamental design principles
 - Significant variances from current guidance
 - Enclosure B table applicability
- The Pre-Application meeting summary will include a preliminary assessment that the licensee-identified Review Process is applicable for the proposed modification

ACRS Subcommittee Comments

(May 17, 2018 Briefing)

- System Architecture – the ISG doesn't show how System Architecture is covered/reviewed under the Tier 1, 2 and 3 Review Process.
 - Section D.2, “System Architecture,” will now be applicable to both processes, and Enclosure B, “LAR Submittal Information” has been updated accordingly.
- Four Fundamental Design Principles – it is not clear how the four fundamental design principles are applied to a Tier 1, 2 and 3 Review
 - Section D.2, which contains the sections on the fundamental design principles, is now applicable to both Processes.

ACRS Subcommittee Comments


(May 17, 2018 Briefing) (continued)

- Hardware Configuration Control – the ISG is silent in regards to configuration control and configuration management of hardware.
 - The staff is evaluating how to address this concern in the ISG

ISG-06 Changes Made since the May 17, 2018 ACRS DI&C Subcommittee Meeting

- Section D.2, “*System Architecture*” is now applicable to the Tier 1, 2, 3 Review Process
- Section D.3, “*Hardware Equipment Qualification*” is now applicable to the Tier 1, 2, 3 Review Process
 - Section D.9.9, “*Equipment Environmental Qualification*” deleted since it is now covered under Section D.3
- General Changes
 - Clarification added
 - Editorial changes

DI&C-ISG-06 Rev. 2 Structure



DI&C-ISG-06, Rev 2, Enclosure B Tables

	AR	Tier			Plant-Specific Information Submitted with License Amendment Request (Phase 1 for Tier 1, Tier 2, Tier 3)
		1	2	3	
1.1	X				(Summary of) Application Software Planning and Processes (D.4)
1.2	X	X	X		Approved Topical Report Safety Evaluation (D.5)
1.3	X	X	X	X	System Description (D.1)
1.4	X	X	X	X	System Architecture (D.2)
1.5	X	X	X	X	(Summary of) Hardware Equipment Qualification (D.3)
1.6	X	X	X	X	(Unified Compliance Matrix for) IEEE Stds 603 and 7-4.3.2 (D.6)
1.7	X	X	X	X	(Changes to) Technical Specifications (D.7)
1.8	X	X	X	X	Setpoint Methodology and Calculations (D.7)
1.9	X	X	X	X	Secure Development and Operational Environment (D.8)
1.10		X	X	X	Software Requirements Specification (D.9.1)
1.11		X	X	X	Software Design Specification (D.9.2)
1.12		X	X	X	Design Analysis Reports for Platform Changes (D.9.3)
1.13		X	X	X	System Response Time Analysis Report (D.9.7)
1.14			X	X	Design Report on Computer Integrity, Test and Calibration, and Fault Detection (D.9.7)
1.15				X	Commercial-Grade Dedication Plan (D.9.10) (D.9.9)
1.16				X	Quality Assurance Plan for Hardware (D.9.11) (D.9.10)
1.17				X	Equipment Qualification Testing Plans (Including EMI, Temp., Humidity, and Seismic) (D.9.9) (D.3)
1.18				X	(Summary of) Hardware Development Process (D.9.14) (D.9.10)

	Tier			Phase 2 – Submitted before Requested Approval (Tier 1, Tier 2, Tier 3 only) Note: This table does not apply to Alternate Review Process applications.
	1	2	3	
2.1	X	X	X	Safety Analysis (D.9.4)
2.2	X	X	X	As-Manufactured, System Configuration Documentation (D.9.5)
2.3	X	X	X	Summary Test Reports (Including Test Results up to FAT) (D.9.6)
2.4	X	X	X	System Response Time Confirmation Report (D.9.7)
2.5	X	X	X	Reliability Analysis (D.9.7)
2.6	X	X	X	System-Level Failure Modes and Effects Analysis (D.9.8)
2.7	X	X	X	Qualification Test Methodologies (D.9.9) (D.3)
2.8		X	X	Platform-Level Failure Modes and Effects Analysis (D.9.8)
2.9		X	X	(Summary of) EMI, Temp., Humidity, and Seismic Testing Results (D.9.9) (D.3)
2.10			X	Commercial-Grade Dedication Report(s) (D.9.10) (D.9.9)

System Architecture – Fundamental Design Principles

- Four fundamental design principles are integrated into Alternate Review Process:
 - Verify the design applies sufficient **redundancy** in the new architecture (ISG-06 Rev. 2, Section D.2.6.2.1).
 - Verify the design demonstrate physical, electrical, data communications, and functional **independence** in the new architecture (D.2.2, D.2.5, D.2.6.2.2).
 - Verify design exhibits **deterministic behavior** (D.2.2.1, D.2.6.2.3)
 - Verify the design has sufficient **diversity and defense-in-depth** in the new architecture to ensure safety is maintained in the event of a postulated common cause failure (D.2.6.2.4)

Licensing and Oversight Comparison Summary

	Tier 1, 2, and 3 Review Process	Alternate Review Process
<i>Document Submittals</i>	2 Submittals (LAR – Phase 1) (Supplement – Phase 2)	1 Submittal (LAR)
<i>Design Changes After LAR Submittal</i>	Design changes submitted during the Phase 2 review (before FAT) can be reviewed as part of the LAR review	Design changes during Implementation and Testing phases will need to be performed under 10 CFR 50.59, or new LAR approval
<i>License Conditions</i>	None (Typically)	Potentially: <ul style="list-style-type: none"> • Implementation of high quality software development process (e.g., NQA-1-2015) • Vendor oversight • Resolution of plant specific action items identified in the topical report • Implementation and Test activities (e.g., FAT)
<i>Inspection Scope</i>	<ul style="list-style-type: none"> • <u>Regional Inspection</u> of Post FAT Licensee Activities (e.g., Installation, Maintenance, Training, Operations, Plans, SAT) 	<ul style="list-style-type: none"> • <u>Vendor Inspection</u> of Implementation, Integration, and Test Activities (e.g. FAT) • <u>Regional Inspection</u> of Post FAT Licensee Activities (e.g., Installation, Maintenance, Training, Operations, Plans, SAT)

Next Steps

- Issue draft Rev. 2 of the ISG for formal public comments at the end of July, 2018
- Conduct an ISG-06 Inspection Workshop – Sept., 2018
- Issue the final ISG, addressing public comments by the end of 2018
- Engage utilities in pre-application meetings
- Exercise ISG and incorporate into Standard Review Plan

II. Status Update: Integrated Action Plan to Modernize the DI&C Regulatory Infrastructure

Eric Benner, NRR/DE

David Rahn, NRR/DE/EICB

Advisory Committee on Reactor Safeguards

Full Committee Briefing

July 11, 2018

Key Messages

- Making progress on Integrated Action Plan (IAP) activities
- Focused on developing regulatory products that support near-term upgrade needs identified by industry stakeholders
- First implementable results target safety-related upgrades under 10 CFR 50.59 (i.e., RIS supplement)
- Next priority – revise licensing process (ISG-06, Rev. 2)
- Staff will continue to pursue broader modernization efforts (initiated in October 2017)

Commission Direction on Digital I&C

(SRM-SECY-15-0106 & SRM-SECY-16-0070)

- Develop an integrated strategy under the oversight of a senior management steering committee to modernize the DI&C regulatory infrastructure
- Engage stakeholders to identify common priorities, problems, and potential solutions to address them
- New or revised requirements should be performance-based, rather than prescriptive
- Focus on acceptable approaches to comply with the requirements
- Requirements should be technology-neutral; Guidance for specific technologies should be tailored if necessary
- Same requirements should apply for operating and new reactors
- Evaluate potential policy issues; present any issues that are ripe for consideration to Commission prior to any rulemaking

IAP Strategy for DI&C Modernization

- Objective: Modernize the digital I&C regulatory infrastructure to enhance the NRC's capability to be more timely, efficient and effective in ensuring safety, and provide a consistent and predictable regulatory process
 - Tactical - Continue to prioritize and implement the regulatory activities needed to provide regulatory clarity and support industry confidence to perform digital I&C upgrades (MPs# 1-3 and MP# 4A)---(High-Priority, Shorter-term Regulatory Products)
 - Strategic - Assess and implement broader modernization of regulatory infrastructure (MP# 4B) (Long-term horizon activities)

Modernization Plans

- **Modernization Plan (MP) #1 – Protection against Common Cause Failure**
 - MP #1A – Regulatory Issue Summary (RIS) 2002-22, Supplement 1
 - MP #1B – Review of NEI 16-16
 - MP #1C – Implementing Commission Policy on Protection against CCF in DI&C Systems
- **MP #2 – Considering Digital Instrumentation & Controls in Accordance with 10 CFR 50.59**
- **MP #3 – Acceptance of Digital Equipment (Commercial Grade Dedication)**
- **MP #4 – Assessment for Modernization of the Instrumentation & Controls Regulatory Infrastructure**
 - MP #4A – ISG-06 Revision 2
 - MP #4B – Broader Modernization Activities

IAP Milestones

- SRM Issued October 15, 2016
- Revisions 0 and 1 to IAP prepared Fall of 2016 through Spring 2017
- First ACRS IAP briefing was on May 17, 2017
- Annual Update Paper per SRM--October, 2017
- Revision 2 to IAP—Issued January 2018
- Revision 3 to IAP – Issuance scheduled for September 2018

Revision 2 of IAP

(Collective changes since May 2017 ACRS meeting)

- Primarily updated schedules for each of the Modernization Plans
- Adjusted to reflect continued work on RIS 2002-22, Supplement 1
- Adjusted to reflect development of an update to ISG-06 (i.e., Rev. 2)
- Described progress on new Appendix D to NEI 96-07
- Outlined in greater detail the development longer-term activities

Plans for IAP Revision 3

- Potential Updates & Changes
 - Continue follow-up activities associated with RIS and ISG-06 (training, workshops, public comments)
 - Continue work on Appendix D, NEI 16-16 and Commercial Grade Dedication
 - Define longer-term activities beyond MP's #1-3
 - Transformation Paper initiatives (SECY-18-0060)
 - Design Review Standard for non-LWRs
 - Outline Proposed Research Activities

IAP Schedule

- Stakeholder Meetings: July/August 2018
- Issue Revision 3 to IAP: September 2018
- Annual Commission Paper: October 2018
- Commission Meeting: October 2018

Questions?

End

Backup Slides

Key CCF Activities

- **MP #1A** – RIS 2002-22, Supplement 1, “Clarification on Endorsement of Nuclear Energy Institute (NEI) Guidance in Designing Digital Upgrades in Instrumentation and Controls Systems”
- **MP #1B** – Review of NEI 16-16, “Guidance for Addressing Digital Common Cause Failure”
- **MP #1C** – Implementing Commission policy on protection against CCF in DI&C systems

RIS 2002-22, Supplement 1 (MP #1A)

Purpose and Scope

- Clarifies NRC's previous endorsement of NEI 01-01 for 10 CFR 50.59 upgrades
- Clarifies the use of qualitative assessments used to determine that CCF is sufficiently low
- "Sufficiently low" is based on assessing design attributes, quality of the design process, and operating experience
- Not applicable to major Reactor Protection System (RPS) and Engineered Safety Features Actuation System (ESFAS) upgrades

NEI 16-16 - Purpose and Scope (MP #1B)

- Originated in support of industry response to NRC's activities on Protection Against Common Cause Failure
- NEI 16-16 provides engineering guidance for industry to address CCF concerns. The guidance includes defensive measures that can be credited to address CCF, in addition to those in the current NRC guidance (i.e., branch technical position (BTP) 7-19) for both operating and new plants
- Based in part on the design measures in EPRI Technical Report (TR)-3002005326, "Methods for Assuring Safety and Dependability when Applying DI&C Systems"

Implementing Commission Policy on CCF in DI&C (MP #1C)

- Staff will update guidance documents to ensure the Commission policy in SRM/SECY-93-087 continues to be consistently applied and addresses evolving DI&C technologies
- Staff is not proposing nor requesting a change to Commission policy
- Staff is developing a Commission Information SECY on future improvement efforts in addressing CCF

Proposed Appendix D to NEI 96-07 (MP #2)

Purpose and Scope

- Intended to provide guidance for licensees to perform 10 CFR 50.59 reviews of activities involving digital modifications

Status and Next Steps

- Appendix D work had been delayed, by mutual agreement with NEI, until the issuance of RIS 2002-22, Supplement 1
- Category 2 public meeting was held with NEI on June 26, 2018 to resume work/discuss review topics and status
- NRC staff provided NEI with recommended next steps for completing the Appendix D review

Acceptance of Digital Equipment Purpose and Scope (MP#3)


- Improved guidance for acceptance of commercial grade digital equipment for safety-related applications
- Evaluate use of Safety Integrity Level (SIL) certification per IEC – 61508 data to supplement commercial grade dedication (CGD) of digital equipment per 10 CFR 50 Part 21
- NEI to submit guidance document for NRC endorsement based on EPRI research on Safety Integrity Level (SIL) certification process to credit identification and validation of dependability characteristics of digital equipment
- NEI has initiated drafting NEI 17-06, a guidance document for acceptance of digital equipment for NRC endorsement

Broader Modernization (MP #4B)

(Purpose and Scope)

- Objective - Broadly evaluate the current overall I&C regulatory infrastructure and the supporting technical bases and consider other important areas beyond those identified in the tactical activities (e.g., past review experiences, ongoing licensing review) to identify and prioritize the improvements to modernize the regulatory infrastructure over the longer term in light of evolving approaches to I&C
 - Develop a roadmap to modernize the I&C regulatory infrastructure
- The scope of this effort includes four areas:
 - Operating reactors
 - New and advanced reactors
 - Fuel cycle facilities
 - Research and test reactors

Our Regulatory Framework



Scope of MP#4B Assessment

- There are three standards IBR in 10 CFR 50.55a(h):
 - IEEE Std 279-1968, IEEE Std 279-1971, and IEEE Std 603-1991
- SRP Chapter 7
 - 27 RGs referenced in SRP Chapter 7 that endorses 32 standards
 - 17 BTPs referenced in SRP Chapter 7
 - 3 Generic Communications referenced in SRP Chapter 7
 - 14 NUREGs referenced in SRP Chapter 7
 - 52 other documents referenced in SRP Chapter 7 (e.g., EPRI Reports, IEEE, and ISO stds not endorsed)
- NuScale DSRS Chapter 7
 - 19 RGs in DSRS Chapter 7 that endorses 17 standards
 - 3 Generic Communications referenced in DSRS Chapter 7
 - 7 NUREGs referenced in DSRS Chapter 7
- Other Relevant Documents
 - 7 ISGs (most of them superseded)
 - 27 NUREGs
 - 11 SECY Papers
 - 14 Topical Reports
 - 3 RILs

Acronyms

ACRS: Advisory Committee on
Reactor Safeguards

BTP: branch technical position

CCF: common cause failure

DI&C: digital instrumentation and
control

DSRS: design-specific review
standard

EPRI: Electric Power Research
Institute

ESFAS: engineered safety features
actuation system

FAT: factory acceptance test

IAP: integrated action plan

I&C: instrumentation and control

IBR: incorporated by reference

IEEE: Institute of Electrical and
Electronics Engineers

ISG: interim staff guidance

ISO: International Organization For
Standardization

LAR: licensee amendment request

MP: modernization plan

NEI: Nuclear Energy Institute

Acronyms

NRC: U.S. Nuclear Regulatory
Commission

NuScale: NuScale Power, LLC

QA: quality assurance

RIL: research information letter

RIS: Regulatory Information
Summary

RPS: reactor protection system


SAT: site acceptance test

SRM: Staff Requirements
Memorandum

Std: standard (IEEE abbreviation)

TR: technical report

APR1400 Design and Safety Enhancement Features



**Presentation to the ACRS Full Committee
July 11, 2018**

Contents

- **Design Features of the APR1400**
- **Comparison of APR1400 and System 80+**
- **Enhancements addressed during the Review**
- **ITAACs addressed during the Review**
- **Topical Reports**
- **Request for Additional Information**
- **Summary**
- **Acronyms**


Design Features of the APR1400

- ❖ **APR1400 is an evolutionary PWR**
- ❖ **Major Improvements**
 - 4-train safety injection system
 - In-containment Refueling Water Storage Tank
 - Digital I&C
 - Severe accident mitigation system

Design Features of the APR1400

- ❖ **Design features different from System 80+**
 - Prestressed concrete cylindrical containment
 - Fluidic device in SIT to enhance safety injection system performance
 - Improved digital I&C and advanced control room design
 - PLUS 7 fuel
 - Use of PAR/igniter for hydrogen mitigation
 - Design enhancement to better execute SAM strategies such as ECSBS

Design Features of the APR1400




- ❖ Design Life Time : 60 Years for Class 1 Major Equipment
- ❖ Power : 4000MWth / 1400MWe
- ❖ Two-Loop : 2 HLs, 2 SGs, 4 RCPs, 4 CLs, 1 Pzr
- ❖ Primary Operating condition:
 - Pressure : 2250 psia
 - HL/CL Temp. : 615/555 °F
- ❖ Secondary Operating condition:
 - Steam Pressure : 1000psia
 - MF/MS Temp. : 450/545 °F
- ❖ Pzr Free volume : 2400 ft³
- ❖ SG U-tube : 13102/SG, I690

Design Features of the APR1400

❖ Safety Injection System

- Four independent trains through Direct Vessel Injection nozzle
- Safety Injection Tanks(SIT) with Fluidic Device
- Safety Injection Pumps(SIP) from IRWST




Full scale
SIT &
Fluidic
Device test
facility

Design Features of the APR1400

❖ Safety Injection System

- Fluidic Device in SIT
 - Extend injection duration of SIT
 - Based on vortex flow resistance
 - Standpipe: low resistance
 - Control port: high resistance



Design Features of the APR1400

❖ I&C System

- Fully digitalized I&C system with diverse platforms
 - Safety system : Programmable Logic Controller
 - Non-safety system : Distributed Control System
 - Diverse protection system : FPGA-based Logic Controller
- Data communication systems maintain independence between safety system and non-safety system
- Remote Shutdown Room available when MCR uninhabitable



Main Control Room

Design Features of the APR1400

❖ Probabilistic Risk Assessment (PRA)

Operation Mode	Risk Evaluation
At Power	Level 1 Internal Event
	Level 2 Internal Event
	Internal Fire
	Internal Flooding
	Seismic Risk Evaluation
	Other External Events
Low Power and Shutdown (LPSD)	Level 1 Internal Event
	Level 2 Internal Event
	Internal Fire
	Internal Flooding
	Seismic Risk Evaluation

Design Features of the APR1400

❖ Other design features

- Design feature to address GSI-191 Issue
 - No fibrous insulation in the zone of influence (ZOI)
 - Sump strainer performance tests were performed.
 - In-vessel downstream effects tests were performed.
- Design enhancement to implement RG 4.21 “Minimization of contamination and radioactive waste generation during life cycle” requirements.
 - Minimization of embedded and/or buried piping
 - Provision for early leak detection
 - Introduced trench/double-walled piping

Design Features of the APR1400

❖ Other design features

- Aircraft impact assessment(AIA) to show core cooling capability and spent fuel pool integrity
- Loss of Power
 - Four EDGs for emergency power
 - AAC GTG for SBO
- FLEX design
 - RCS makeup and core cooling using FLEX pumps
 - SFP makeup and spray using FLEX pumps
 - Power supply using mobile generators (onsite and offsite)
 - SFP level instrumentations

Comparison of APR1400 and System 80+

Containment

- System80+ : Spherical Steel
- APR1400 : Cylindrical PS Concrete

Thermal Power

- System80+ : 3,931 MWt
- APR1400 : 4,000 MWt

Hot-leg Temp.

- System80+ : 621 °F
- APR1400 : 615 °F

Safety Injection System

- System80+ : 4 train SIS + DVI
- APR1400 : 4 train SIS + DVI + Fluidic Device

- SIS: safety injection system
- DVI: direct vessel injection
- POS RV: pilot operated safety relief valve
- IHA: integrated head assembly
- CFS: core flooding system
- PAR: passive autocatalytic recombiner

RCS OPP / RD System


- System80+ : 4 PSV + 2 SDS
- APR1400 : 4 POSRV

RV Upper Structure

- System80+ : Conventional
- APR1400 : IHA

Severe Accident

- System80+ : CFS
- APR1400 : CFS + PAR



S Meeting (July 11, 2018)

Comparison of APR1400 and System 80+

Design Items	APR1400	System80+
NSSS Thermal Power	4,000 MWt (1,400MWe)	3,931MWt (1,400MWe)
Overpressure Protection and Rapid Depressurization	Four(4) POSRVs	4 PSV + 2 train SDS valve
Reactor Vessel Upper Head Assembly	Integrated Head Assembly	Previous complicated upper head structures
Safety Injection Tank	Installation of Fluidic Device inside the SIT	Conventional SIT
Main Control Room	Large Display Panel (LDP) indicating important parameters + Compact Workstation (WS) + Computerized Procedure System	LDP providing overview + Workstations for detailed information
Data Communication	Network + Data Link	Data Link

Comparison of APR1400 and System 80+

Design Items	APR1400	System80+
Containment	Steel-lined post-tensioned prestressed concrete with a cylindrical wall and a hemispherical dome	Steel spherical containment shell, surrounded by reinforced concrete shield building
Containment H ₂ Mitigation	PAR/Igniter	Igniter
Alternate AC Power	GTG	Combustion Turbine
Emergency Containment Spray Backup System	Additional Backup Supply of Spray Water	None

Enhancements addressed during the Review

- ❖ Application of graded approach for the piping design
- ❖ Construction sequence and post-construction analyses for NI building structure based on APR1400 SKN 3&4

Enhancements addressed during the Review

❖ Plant Protection System

- Switch panel added for trip channel bypass, setpoint reset and operating bypass
- Cross channel communication deleted except voting signals for reactor trip

❖ Diverse Protection System (DPS) & Diverse Indication System

- PLC(Programmable Logic Controller) → FLC (FPGA-based Logic Controller)
- DPS: 2 channels (2-out-of-2 trip) → 4 channels (2-out-of-4 trip)
- DPS: Motor-Generator Set Breaker trip → Reactor Trip Switchgear Breaker trip

❖ Reactor Trip Switchgear: 4 breakers (1 set) → 8 breakers (2 diverse sets)

ITAACs addressed during the Review

❖ Current APR1400 ITAAC

2.0	Design Descriptions and ITAAC	# in Rev.2	# in Rev.3
2.1	Site Parameters	0	0
2.2	Structural and Systems Engineering	30	36
2.3	Piping Systems and Component	2	2
2.4	Reactor Systems	213	209
2.5	Instrumentation and Controls	159	159
2.6	Electric Power	187	187
2.7	Plant Systems	484	483
2.8	Radiation Protection	3	3
2.9	Human Factors Engineering	2	2
2.10	Emergency Planning	6	6
2.11	Containment Systems	81	84
2.12	Physical Security Hardware	30	30
2.13	Design Reliability Assurance Program	1	1
Total		1198	1202

ITAACs addressed during the Review

❖ Key Changes in ITAAC

- ITAAC Wording Changes
- Communication Independence
- Incorporation of Standardized ITAAC Guidance
- Communication Independence of ESF-CCS
- ITAAC related to Structures
- Priority Logic within ESF-CCS
- CPU Load Restrictions
- Clarification of Diverse Design Group and Diversity between DAS & PPS/ESF-CCS

Topical Reports

❖ APR1400 reviewed and approved Topical Reports

	Title	Document No.	Supporting DCD Chapter
1	KHNP QAPD for the APR1400 DC	APR1400-K-Q-TR-11005-NP-A	17
2	KCE-1 Critical Heat Flux Correlation for PLUS7 Thermal Design	APR1400-F-C-TR-12002-P-A	4, 15
3	Fluidic Device Design for the APR1400	APR1400-Z-M-TR-12003-P-A	6, 15
4	Realistic Evaluation Methodology for Large-Break LOCA of the APR1400	APR1400-F-A-TR-12004-P	15
5	PLUS7 Fuel Design for the APR1400	APR1400-F-M-TR-13001-P	4

Topical Reports

❖ KCE-1 CHF Correlation Topical Report

- KCE-1 CHF Correlation Topical Report describes CHF tests for PLUS7 fuel, correlation development, verification/validation and its application to the APR1400.
- KCE-1 CHF Correlation Topical Report supports DCD Chapters 4 and 15 by assuring the design acceptance criterion under full compliance with “conditions and limitations” on FSER.

Topical Reports

❖ Fluidic Device Design Topical Report

- A passive flow controlling Fluidic Device has been developed and installed inside the SIT in order to improve the effectiveness of SIT water.
- Fluidic Device Topical Report contains the design requirements, detailed design of the SIT-FD, and the results of full-scaled performance verification tests.
- Fluidic Device Topical Report supports DCD Chapters 6 and 15 by assuring the design and performance of SIT-FD.

Topical Reports

❖ PLUS7 Design Topical Report

- PLUS7 Topical Report contains evaluation results for fuel assembly and rod supporting DCD Chapter 4.
- Main contents of PLUS7 Topical Report are:
 - Fuel rod design, fuel assembly design, and their evaluation results
 - Results of poolside examinations, hot-cell examinations, and commercial operating experiences
 - Consideration of Thermal Conductivity Degradation
- Evaluation results show the performance and integrity of PLUS7.

Topical Reports

❖ Large Break Loss-Of-Coolant Accident (LBLOCA) Topical Report

- LBLOCA topical report describes a realistic evaluation methodology, CAREM*, for the analysis of LBLOCA of the APR1400.
- CAREM follows NUREG/CR-5249 (CSAU) and Regulatory Guide 1.203.
- CAREM supports DCD Chapter 15.
- Evaluation results of CAREM for APR1400 show sufficient safety margin of ECCS performance.

*CAREM: Code-Accuracy-based Realistic Evaluation Methodology

Request for Additional Information

❖ 2,225 RAI Questions were issued and resolved

DCD Chapter	Contents	No. of RAI Question	No. of P3 Open Items*
1	Introduction & General Description	0	0
2	Site Characteristics	33	0
3	SSC and Equipment	260	47
4	Reactor	62	6
5	RCS and Connection Systems	78	19
6	Engineered Safety Features	151	8
7	I & C	191	40
8	Electric Power	78	5
9	Auxiliary Systems	277	30
10	Steam and Power Conversion System	74	17
11	Radioactive Waste Management	38	3
12	Radiation Protection	84	14
13	Conduct of Operations	52	0
14	Verification Programs	162	21
15	Transient and Accident Analyses	123	3
16	Technical Specifications	223	135
17	QA and Reliability Assurance	5	2
18	Human Factor Engineering	137	0
19	PRA and Severe Accident Evaluation	173	19
ER	Environmental Report	24	0
Total		2,225	366

* All open items are now resolved

ACRS Meeting (July 11, 2018)

Summary

- ❖ **APR1400 DCD is completed.**
 - All RAIs have been resolved with adequate and sufficient discussion with the staff.

- ❖ **Confirmatory items have been incorporated in DCD Rev.3.**

Acronyms

AAC	alternate alternating current
APR1400	advanced power reactor 1400
CHF	critical heat flux
DAS	diverse actuation system
ECSBS	emergency containment spray backup system
EDG	emergency diesel generator
ESF-CCS	engineered safety features-component control system
FPGA	field programmable gate array
GTG	gas turbine generator
IRWST	in-containment refueling water storage tank
ITAAC	inspections, tests, analyses, and acceptance criteria
LPSD	low power and shutdown
MCR	main control room
NI	nuclear island
PAR	passive autocatalytic recombiner
PLC	programmable logic controller
POSRV	pilot operated safety relief valve
PRA	probabilistic risk assessment
SAM	severe accident mitigation
SBO	station blackout
SDS	safety depressurization system
SFP	spent fuel pool
SIP	safety injection pump
SIT-FD	safety injection tank – fluidic device



NRC Staff Presentation to the ACRS Full Committee

**Korea Hydro and Nuclear Power Co., Ltd. (KHNP)
APR1400 Design Certification Application Review
Phase 5
Review of Advanced Safety Evaluations**

JULY 11, 2018

Overview



- **ACRS review (31 meetings in 27 months):**
 - ♦ Phase 3 FC meeting: 4/20/16 APR1400 DESIGN OVERVIEW
 - ♦ Phase 3 SC meetings: 9/21/16 to 8/24/17 (13 meetings, w/Topicals [TOP])
 - ♦ Phase 3 FC meetings: 2/9/17 to 9/7/17 (4 meetings, w/Topicals)
 - ♦ Phase 3 SC meeting: 9/20/17 GSI-191 and Long-Term Core Cooling [LTCC]
 - ♦ PRA Briefing FC meeting: 12/6/17 (1 meeting)
 - ♦ Phase 5 SC meetings: 10/17/17 to 6/19/18 (7 meetings)
 - ♦ Phase 5 FC meetings: 3/8/18 to 7/11/18 (4 meetings, 3 were TOP/LTCC)
- **RAI Questions: 2201-DCD, 69-TOP, 21-QA, & 24-ER [2315]**
 - ♦ Since the NRC staff first began providing ACRS with the Advanced Safety Evaluations in September 2017, the applicant has continued to submit revised RAI responses. These RAI response revisions primarily corrected typographical errors or errors in the previous response identified by NRC staff when reviewing the response.
 - ♦ NRC reviewed all RAI responses since 9/2017 and updated ACRS by chapter on any RAI response revision received after the respective Chapter SC.
 - ♦ A total of 52 revised responses received after the last SC meeting for each chapter have been identified to ACRS for review. None were considered significant revisions by NRC staff.
 - ♦ Fifty (50) confirmatory items remain pending submission of DCD Revision 3. All other questions are closed.

Chp 1 – Introduction and General Description of the Plant



- **Scope of review:**
 - ♦ Provides general descriptions of the APR1400 design, objectives, information regarding how the DCD was developed and is structured, and comparison with other facilities.
 - ♦ Later sections provide lists and tables of referenced material, COL items, conformance with guidance and regulatory documents, and other information referenced by Chapters 2 through 19.
- **Status of Confirmatory Items:** Since no design commitments are made specifically in Chapter 1, there was no separate review of the chapter and there are no confirmatory items.
- **Conclusions:**
 - ♦ The applicant provided an adequate general description of the APR1400 design, objectives, and DCD construction.
 - ♦ The applicant provided accurate information in the lists and tables as confirmed by evaluations of the individual chapters.

Chp 2 – Site Characteristics



- **Scope of review:**
 - ♦ Site-related design characteristics for the APR1400 design, including: geography, demography, nearby facilities, meteorology, hydrologic engineering, geology, seismology, and geotechnical engineering.
 - ♦ Postulated site parameters related to climatology, atmospheric dispersion, ground and surface water, precipitation, geology, seismology, and geotechnical engineering
- **Status of Confirmatory Items:** Two minor confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ♦ The applicant provided an adequate description of the site-specific information to ensure that potential COL applicants referencing the APR1400 design can meet the relevant requirements.
 - ♦ An applicant seeking a combined license (COL) must address site-specific information.

Chp 3 – Design of Structures, Systems, Components, and Equipment



- **Scope of review:** Classification of structures, systems, and components, wind and tornado loadings, water level (flood) design, missile protection, protection against dynamic effects associated with postulated rupture of piping, seismic design, design of category I structures, mechanical systems and components, seismic, dynamic, and environmental qualification of mechanical and electrical equipment, piping design review, and threaded fasteners.
 - ♦ The applicant applied a new approach to defining the ITAAC for the critical sections (steel and reinforced concrete) for the design of the safety-related structures (e.g. reactor building, auxiliary building, EDG building).
- **Status of Confirmatory Items:** Nine confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ♦ The applicant has demonstrated that the structures, system, components, and equipment comply with NRC regulations and conform to NRC guidance.

Chp 4 – Reactor



- **Scope of review:**
 - ♦ Fuel system design
 - ♦ Nuclear design
 - ♦ Thermal and Hydraulic design
 - ♦ Reactor materials
 - ♦ Functional design of reactivity control systems
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusions:**
 - ♦ The applicant provided an adequate description of all aspects of the reactor, thereby allowing the staff to conclude that proper methodologies were used, that proper codes were applied, and that all appropriate design criteria and other applicable regulatory criteria were met.
 - ♦ The staff concluded that the applicant has allowed for proper testing and inspection.
 - ♦ The staff performed confirmatory analysis for first-cycle core design.

Chp 5 – Reactor Coolant System and Connecting Systems



- **Scope of review:**
 - ♦ Thermal and Hydraulic design
 - ♦ Reactor materials
 - ♦ Code Requirements
- **Status of Confirmatory Items:** Two minor confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ♦ The applicant provided an adequate description of all aspects of the reactor coolant system and its connecting systems, thereby allowing the staff to conclude that proper methodologies were used, that proper codes were applied, and that all appropriate design criteria and other applicable regulatory criteria were met.
 - ♦ The staff concluded that the applicant has allowed for proper testing and inspection.

Chp 6 – Engineered Safety Features



- **Scope of review:**
 - ◆ Thermal and Hydraulic design
 - ◆ Material qualifications
 - ◆ Heat Removal Adequacy
 - ◆ Code and QA Requirements
 - ◆ Containment Functional Design
- **Status of Confirmatory Items:** Seven confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ◆ The applicant provided an adequate description of all aspects of the Engineered Safety Features, thereby allowing the staff to conclude that proper methodologies were used, that proper codes were applied, and that all appropriate design criteria and other applicable regulatory criteria were met.
 - ◆ The staff concluded that the applicant has allowed for proper testing and inspection.

Chp 7 – Instrumentation and Controls



- **Scope of review:** Safety-related I&C systems, non-safety-related I&C systems, data communication systems, quality, qualification, integrity, reliability, diversity, defense-in-depth, and single failure criterion.
- **Status of Confirmatory Items:** Four confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ◆ The applicant has demonstrated that the I&C systems and the overall I&C architecture meet the fundamental safety design principles of independence, diversity, defense-in-depth, determinism, and redundancy.
 - ◆ The applicant has provided sufficient information to demonstrate isolation of I&C systems from external interfaces.
 - ◆ The staff concludes that the I&C design complies with NRC regulations and conforms to NRC guidance.

Chp 8 – Electric Power



- **Scope of review:**
 - ◆ Offsite power systems
 - ◆ Onsite AC and DC power systems
 - ◆ Station blackout
- **Status of Confirmatory Items:** Four minor confirmatory items remain pending submission of DCD Revision 3.
- **Conclusions:**
 - ◆ The staff has concluded that offsite and onsite electrical systems comply with all applicable design criteria and standards.
 - ◆ The staff concluded that the applicant has provided sufficient information and identified necessary analysis to support a future COL application.
 - ◆ The staff concluded that the APR1400 design is capable of withstanding and recovering from a station blackout for the stated coping time.

Chp 9 – Auxiliary Systems



- **Scope of review:**
 - ◆ Fuel handling and storage
 - ◆ Water systems
 - ◆ Process auxiliaries
 - ◆ Heating ventilation and air conditioning
 - ◆ Other auxiliary systems
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusions:**
 - ◆ The staff has concluded that all auxiliary systems comply with the applicable design and other regulatory criteria and standards.
 - ◆ The staff has concluded that the applicant has allowed for adequate pre-operational testing.
 - ◆ The staff has concluded that the applicant has provided sufficient information and identified necessary analysis to support a future COL application.

Chp 10 – Steam and Power Conversion System



- **Scope of review:**
 - ◆ Turbine generator
 - ◆ Main steam system
 - ◆ Condensate and feed and associated systems
 - ◆ Auxiliary feed system
 - ◆ Auxiliary steam system
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2
- **Conclusions:**
 - ◆ The staff has concluded that the steam and power conversion systems comply with the applicable design and other regulatory criteria and standards.
 - ◆ The staff has concluded that the applicant has provided sufficient information and identified necessary analysis to support a future COL application.

Chp 11 – Radioactive Waste Management



- **Scope of review:** Liquid waste management system (LWMS), gaseous waste management system (GWMS), solid waste management system (SWMS), and process and effluent radiological monitoring and sampling system (PERMSS) including the instrumentation used to monitor and control releases of radioactive effluents and wastes.
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusion:** The applicant has demonstrated that the systems comply with NRC regulations and conform with NRC guidance to avoid unmonitored and uncontrolled radioactive releases to the environment.

Chp 12 – Radiation Protection



- **Scope of review:** Information on facility and equipment design and programs used to meet the radiation protection standards in 10 CFR Parts 20, 50, and 70.
- **Status of Confirmatory Items:** A minor confirmatory item remains pending submission of DCD Revision 3.
- **Conclusions:**
 - ♦ The applicant has demonstrated that the APR1400 design includes adequate design features to maintain the radiation doses resulting from exposure to radioactive sources to within the limits required by 10 CFR Part 20, and as low as is reasonably achievable (ALARA), if operated with an appropriate radiation protection program.
 - ♦ An applicant seeking a combined license (COL) must address the radiation protection program, as well as other identified radiation protection COL information items.

Chp 13 – Conduct of Operations



- **Scope of review:** Describes the required organizational structure, programs, and procedures required of a COL to safely operate the plant. These are passed on to the COL via 33 COL information items in five areas: organizational structure, training, emergency planning (EP), operational programs, and plant procedures. A sixth area (physical security, no COL items) and seventh area (Fitness for Duty, one COL item) are not presented to the ACRS.
- **Status of Confirmatory Items:** Two minor confirmatory items remain pending submission of DCD Revision 3.
- **Conclusion:**
 - ♦ The applicant provided adequate guidance and information, including establishing training programs per NEI 06-13A, EP facility design requirements, operational programs developed in accordance with SECY-05-0197, and GTGs/EOGs used to develop site-specific procedures, which when implemented by a COL provides adequate assurance that the COL will operate the plant safely.

Chp 14 – Verification Programs



- **Scope of review:**
 - ♦ Major phases of the ITP, including preoperational tests, initial fuel loading and initial criticality, low-power tests, and power ascension tests
 - ♦ Tier 1 information including definitions, general provisions, design descriptions, and ITAAC Tables
- **Status of Confirmatory Items:**
 - ♦ No confirmatory items pending for Sections 14.1 and 14.2 (ITP)
 - ♦ Two confirmatory items remain pending for Section 14.3 (ITAAC)
- **Conclusions:**
 - ♦ The applicant has fully addressed the information related to the ITP and demonstrated compliance with applicable regulations and guidance.
 - ♦ The ITAAC are necessary and sufficient to provide reasonable assurance that, if the Inspections, Tests, and Analyses are performed and the Acceptance Criteria are met, a facility that incorporates the certified APR1400 design has been constructed and will be operated in conformity with the applicable portions of the design certification, the AEA, and the NRC's rules and regulations.

Chp 15 – Transient and Accident Analyses



- **Scope of review:** Analyses of the APR1400 responses to postulated equipment failures or malfunctions to determine the limiting conditions for operation (LCO), limiting safety system settings (LSSS), and design specifications for safety-related structures, systems, and components (SSCs). Design Basis Accident (DBA) radiological consequence analysis.
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusion:** The applicant has demonstrated in its analysis of the APR1400 nuclear steam supply system (NSSS) to anticipated operational occurrences and postulated accidents, and in its analyses of the radiological consequences of DBAs that the APR1400 design complies with NRC regulations and conforms with NRC guidance.

Chp 16 – Technical Specifications



- **Scope of review:** Analyses of the APR1400 defined terms, limiting conditions for operation (LCO), limiting safety system settings (LSSS), and design specifications for safety-related structures, systems, and components (SSCs). Review of reactor trip and ESFAS setpoint and surveillance methodologies.
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusion:** The applicant has provided the APR1400 technical specifications that comply with applicable regulations and conform with NRC guidance.

Chp 17 – Quality Assurance and Reliability Assurance



- **Scope of review:** Quality assurance, including a quality assurance program inspection, the maintenance rule, and the reliability assurance programs, including the reliability assurance program list of structures, systems, and components.
- **Status of Confirmatory Items:** One confirmatory item remains pending submission of DCD Revision 3.
- **Conclusion:**
 - ♦ The applicant added three COL information items, making the reliability assurance program acceptable for use to identify risk-significant SSCs.
 - ♦ The applicant has demonstrated that the quality assurance, maintenance rule, and reliability assurance programs comply with NRC regulations and conform to NRC guidance.

Chp 18 – Human Factors Engineering



- **Scope of review:**
 - ♦ Human factors engineering (HFE) portion of the APR1400 design certification including the implementation plans (IPs) documented in technical reports incorporated by reference into the DCD that describe the proposed methodology a combined license (COL) applicant or holder will follow to complete the elements in NUREG-0711, Revision 3.
- **Status of Confirmatory Items:**
 - ♦ Six minor confirmatory items remain pending submission of DCD Revision 3.
- **Conclusion:**
 - ♦ The applicant's HFE design process conforms to NRC HFE-related guidance (NUREG-0711) and therefore provides reasonable assurance that HFE-related requirements are satisfied.

Chp 19 – Probabilistic Risk Assessment and Severe Accident Evaluation



- **Scope of review:** Probabilistic risk assessment and its uses; severe accident evaluation.
- **Status of Confirmatory Items:** Seven confirmatory items remain pending submission of DCD Revision 3.
- **Conclusion:**
 - ♦ The applicant provided PRA revisions to the at-power internal events level 1 & 2 PRA, the at-power internal fire level 1 & 2 PRA, the at-power internal flooding level 1 & 2 PRA, the low-power shut-down internal events level 2 PRA, the low-power shut-down internal fire level 1 & 2 PRA, and the low-power shut-down internal flooding level 1 & 2 PRA. These updates represented significant improvements.
 - ♦ The applicant has demonstrated that the probabilistic risk assessment and severe accident programs comply with NRC regulations and conform to NRC guidance.

Sect. 19.3 – Beyond Design Basis External Event (BDBEE)



- **Scope of review:** Conformance of the APR1400 design with SECY-12-0025, NRC Orders EA-12-049, and EA-12-051, and the details addressing the recommendations of the Near-Term Task Force with respect to managing and mitigating external events that are beyond the design basis of the plant.
- **Status of Confirmatory Items:** Two confirmatory items remain pending submission of DCD Revision 3.
- **Conclusion:** The applicant has addressed in the APR1400 application, the Commission-approved Fukushima actions described in SECY-12-0025 and NRC Orders EA-12-049 and EA-12-051, to the fullest extent practicable.

Sect. 19.4 – Loss of Large Area (LOLA)



- **Scope of review:** Guidance and strategies provided to a COL to address the loss of large areas of the APR1400 plant due to explosions or fires from a beyond design basis event using readily available resources and identifying potential practicable areas for the use of beyond-readily available resources. This is provided to aid the COL in meeting the requirements of 10 CFR 50.54(hh)(2).
- **Status of Confirmatory Items:** One confirmatory item remains pending submission of DCD Revision 3.
- **Conclusion:** The applicant has provided adequate guidance and strategies, using readily available resources consistent with its design, to address the loss of large areas of the APR1400 plant due to explosions or fires from a beyond design basis event. This information is adequate to enable a licensee who operates an APR1400 plant to meet the requirements of 10 CFR 50.54(hh)(2).

Sect. 19.5 – Aircraft Impact Assessment (AIA)



- **Scope of review:** Features considered in the APR1400 design to minimize or mitigate the impact of a large commercial aircraft. The APR1400 is designed to maintain the reactor core cooled and the integrity of the spent fuel pool. This section is provided to demonstrate compliance with 10 CFR 50.150(a).
- **Status of Confirmatory Items:** All confirmatory items were closed with DCD Revision 2.
- **Conclusion:** The applicant performed a design-specific assessment of the effects of the impact of a large, commercial aircraft on the APR1400 design. The applicant used the assessment to identify and incorporate into the design those design features and functional capabilities to show that, with reduced use of operator actions:
 - ♦ The reactor core remains cooled, or the containment remains intact; and
 - ♦ Spent fuel cooling or spent fuel pool integrity is maintained.

Conclusion/Next Steps



- **Objective:** On December 23, 2014, the applicant submitted the application for certification of the APR1400 reactor design under 10 CFR Part 52, Subpart B. On March 8, 2018, the applicant submitted Revision 2 to the DCD and requested a Final Design Approval (FDA). The FDA (previously 10 CFR 52, Appendix O) has been superseded by the Standard Design Approval (SDA, now 10 CFR 52, Subpart E) [See 72 FR 49352, August 28, 2007].
 - ♦ The requirements for approval of a design under either Subpart are essentially the same (up until the process for certification by the Commission under Subpart B). Both Subparts require a referral to the ACRS (52.53 and 52.141). The applicant and NRC staff believe that the information required (under both Subparts) for the ACRS to report on the portions of the application which concern safety have been provided.
- **Conclusion:** The APR1400 DC application contains a level of design information sufficient to enable the Commission to judge the applicant's proposed means of assuring that construction conforms to the design and the Commission can reach a final conclusion on all safety questions associated with the APR1400 design in order to grant certification under Subpart B. Also, the level of design information is sufficient to issue a Standard Design Approval under Subpart E.
- **Next Steps:** If ACRS agrees that sufficient information has been provided and is able to report as required by both Subparts, the applicant will issue Revision 3 of the DCD (and referenced technical reports) which will include all corrections identified to staff and ACRS (and no others), closing all remaining confirmatory items. Revision 3 will be the revision of record. NRC staff will verify the changes in DCD Revision 3 and the technical reports and complete the issuance of the APR1400 Final Safety Evaluation Report by September 30, 2018.
- **NRC Staff thanks the ACRS members and staff for all their support and assistance with the review and the logistics of holding 31 meetings in the past 27 months!!**

Acronyms



• AC/DC	Alternating Current/Direct Current
• AEA	Atomic Energy Act (of 1954, as amended)
• ALARA	As Low As Reasonably Achievable
• CFR	Code of Federal Regulations
• COL	Combined License
• DBA	Design Basis Accident
• DCD	Design Certification Document
• EP	Emergency Planning
• EOG	Emergency Operating Guidelines
• ESFAS	Engineered Safety Features Actuation System
• GTG	Generic Technical Guidelines
• GWMS	Gaseous Waste Management System
• HFE	Human Factors Engineering
• I&C	Instrumentation and Controls
• IP	Implementation Plan
• ITAAC	Inspections, Testing, Analyses and Acceptance Criteria
• ITP	Initial Test Program
• LCO	Limiting Conditions for Operations
• LSSS	Limiting Safety Systems Settings
• LWMS	Liquid Waste Management System
• NEI	Nuclear Energy Institute
• NSSS	Nuclear Steam Supply System
• PERMSS	Process and Effluent Radiological Monitoring and Sampling System
• SECY	Office of the Secretary of the Nuclear Regulatory Commission
• SSC	Structures, Systems, and Components
• SWMS	Solid Waste Management System