



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 16, 2018

LICENSEE: EXELON GENERATION COMPANY, LLC

FACILITY: BYRON STATION, UNIT 2, AND BRAIDWOOD STATION, UNIT 1

SUBJECT: SUMMARY OF AUGUST 8, 2018, MEETING WITH EXELON GENERATION COMPANY, LLC, ON A FUTURE RELIEF REQUEST TO EXTEND THE POST-PEENING FOLLOW UP INSPECTIONS FOR CERTAIN REACTOR PRESSURE VESSEL HEAD PENETRATIONS (EPID L-2018-LRM-0045)

On August 8, 2018, a Category 1 public meeting was held via teleconference between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Exelon Generation Company, LLC. The purpose of the teleconference was to discuss a future relief request (RR) to extend the post-peening follow up inspections for Byron Station, Unit 2, and Braidwood Station, Unit 1. The meeting notice and agenda, dated July 13, 2018, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML18220A762. A list of attendees is provided as Enclosure 1.

The licensee presented information (ADAMS Accession No. ML18218A112) that provided an overview of the future RR.

The NRC staff queried the licensee about the technical basis for the RR. The staff noted that submitting a request pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 50.55a(z)(1) provides a basis for an acceptable level of quality and safety and has a stronger technical basis than when submitting an RR pursuant to 10 CFR 50.55a(z)(2) that provides a basis for determining there is no compensating increase in quality and safety. The staff did not provide an opinion on the viability of 10 CFR 50.55a(z)(1) vs. 10 CFR 50.55a(z)(2).

The NRC staff pointed out that the licensee could achieve alignment of the timing of the follow-up inspections to a single refueling outage by moving some follow-up inspections to an earlier outage. The NRC staff recognizes that there is a strong technical basis for not moving the follow-up inspections to an earlier outage, but encouraged the licensee to provide that basis in the relief request.

Members of the public were not in attendance. Public Meeting Feedback forms were not requested.

Please direct any inquiries to me at 301-415-6606, or Joel.Wiebe@nrc.gov.

Sincerely,

A handwritten signature in black ink that reads "Joel S. Wiebe". The signature is written in a cursive style with a large initial "J" and "W".

Joel S. Wiebe, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-456 and STN 50-455

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES

AUGUST 8, 2018, MEETING WITH EXELON GENERATION COMPANY, LLC

FUTURE RELIEF REQUEST TO EXTEND THE POST-PEENING FOLLOW UP INSPECTIONS

FOR CERTAIN REACTOR PRESSURE VESSEL HEAD PENETRATIONS

Exelon Generation Company, LLC

Heather Malikowski

Jim Cirilli

Ben Youman

Brad Lanka

Darren Gardner

David Gullott

Doug Spitzer

Gary Contrady

Glenn White (Dominion)

Markus Burkardt (Dominion)

NRC Staff

John Tsao

Stephen Cumblidge

Jay Collins

Roger Kalikian

Ali Rezai

Seung Min

Joel Wiebe

Enclosure

SUBJECT: SUMMARY OF AUGUST 8, 2018, MEETING WITH EXELON GENERATION COMPANY, LLC, ON A FUTURE RELIEF REQUEST TO EXTEND THE POST-PEENING FOLLOW UP INSPECTIONS FOR CERTAIN REACTOR PRESSURE VESSEL HEAD PENETRATIONS (EPID L-2018-LRM-0045) DATED AUGUST 16, 2018

DISTRIBUTION:

PUBLIC
PM Reading File
RidsACRS_MailCTR Resource
RidsNrrDorlLpl3 Resource
RidsNrrPMBraidwood Resource
RidsNrrPMByron Resource
RidsNrrLASRohrer Resource
RidsRgn3MailCenter Resource
TWertz, NRR
JBowen, EDO

ADAMS Accession Nos.:
Meeting Notice ML18220A762
Handouts ML18218A112
Meeting Summary ML18225A304

OFFICE	NRR/DORL/LPL3/PM	NRR/DORL/LPL3LA	NRR/DORL/LPL3/BC	NRR/DORL/LPL3/PM
NAME	JWiebe	SRohrer	DWrona	JWiebe
DATE	08/16/18	08/14/18	08/16/18	08/16/18

OFFICIAL RECORD COPY