

# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**

## **Supplement 59**

### **Regarding Waterford Steam Electric Station, Unit 3**

Draft Report for Comment

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Library at [www.nrc.gov/reading-rm.html](http://www.nrc.gov/reading-rm.html). Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

#### 1. The Superintendent of Documents

U.S. Government Publishing Office  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: (202) 512-1800  
Fax: (202) 512-2104

#### 2. The National Technical Information Service

5301 Shawnee Road  
Alexandria, VA 22312-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: **U.S. Nuclear Regulatory Commission**  
Office of Administration  
Multimedia, Graphics, and Storage &  
Distribution Branch  
Washington, DC 20555-0001  
E-mail: [distribution.resource@nrc.gov](mailto:distribution.resource@nrc.gov)  
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at NRC's Web site address [www.nrc.gov/reading-rm/doc-collections/nuregs](http://www.nrc.gov/reading-rm/doc-collections/nuregs) are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

#### The NRC Technical Library

Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

#### American National Standards Institute

11 West 42nd Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**DISCLAIMER:** This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**

## **Supplement 59**

### **Regarding Waterford Steam Electric Station, Unit 3**

Draft Report for Comment

Manuscript Completed: August 2018  
Date Published: August 2018

## COMMENTS ON DRAFT REPORT

- 1
- 2 Any interested party may submit comments on this report for consideration by the NRC staff.  
3 Comments may be accompanied by additional relevant information or supporting data. Please  
4 specify the report number **NUREG-1437, Supplement 59**, in your comments, and send them by  
5 the end of the comment period specified in the *Federal Register* notice announcing the  
6 availability of this report.
- 7 **Addresses:** You may submit comments by any one of the following methods. Please include  
8 Docket ID **NRC-2016-0078** in the subject line of your comments. Comments submitted in  
9 writing or in electronic form will be posted on the NRC website and on the Federal rulemaking  
10 website <http://www.regulations.gov>.
- 11 **Federal Rulemaking Website:** Go to <http://www.regulations.gov> and search for documents  
12 filed under Docket ID **NRC-2016-0078**.
- 13 **Mail comments to:** May Ma, Director, Program Management, Announcements and Editing  
14 Branch (PMAE), Office of Administration, Mail Stop: TWFN-7-A-60M, U.S. Nuclear Regulatory  
15 Commission, Washington, DC 20555-0001.
- 16 For any questions about the material in this report, please contact: Elaine Keegan, Project  
17 Manager, 301-415-8517, or by e-mail at [Elaine.Keegan@nrc.gov](mailto:Elaine.Keegan@nrc.gov).
- 18 Please be aware that any comments that you submit to the NRC will be considered a public  
19 record and entered into the Agencywide Documents Access and Management System  
20 (ADAMS). Do not provide information you would not want to be publicly available.

1 **COVER SHEET**

2 **Responsible Agency:** U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor  
3 Regulation. There are no cooperating agencies involved in the preparation of this document.

4 **Title:** Generic Environmental Impact Statement for License Renewal of Nuclear Plants,  
5 Supplement 58, Regarding Waterford Steam Electric Station Unit 3 Draft Report for Comment  
6 (NUREG–1437). Waterford Steam Electric Station Unit 3 is located near Killona, St. Charles  
7 Parish, Louisiana.

8 For additional information or copies of this document contact:

9 Division of Materials and License Renewal  
10 U.S. Nuclear Regulatory Commission  
11 Office of Nuclear Reactor Regulation  
12 Mail Stop O-11F1  
13 11555 Rockville Pike  
14 Rockville, Maryland 20852  
15 Phone: 1-800-368-5642, extension 8517  
16 Fax: 301-415-2002  
17 Email: [elaine.keegan@nrc.gov](mailto:elaine.keegan@nrc.gov)

18 **ABSTRACT**

19 This supplemental environmental impact statement (SEIS) has been prepared in response to an  
20 application submitted by Entergy Louisiana and Entergy Operations, Inc. (collectively referred to  
21 as Entergy), to renew the operating license for the Waterford Steam Electric Station Unit 3  
22 (WF3) for an additional 20 years.

23 This SEIS includes the preliminary analyses that evaluate the environmental impacts of the  
24 proposed action and the alternatives to the proposed action. Alternatives considered include:  
25 (1) new nuclear power generation, (2) supercritical pulverized coal (SCPC) (3) natural gas  
26 combined cycle (NGCC), (4) a combination of NGCC, biomass and demand side management  
27 (DSM) and (5) the no-action alternative (i.e., no renewal of the license).

28 The U.S. Nuclear Regulatory Commission (NRC) staff's preliminary recommendation is that the  
29 adverse environmental impacts of license renewal for WF3 are not so great that preserving the  
30 option of license renewal for energy-planning decisionmakers would be unreasonable. The  
31 NRC staff based its recommendation on the following factors:

- 32
- 33 • the analysis and findings in NUREG–1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Volumes 1 and 2*;
  - 34 • the Environmental Report submitted by Entergy;
  - 35 • consultation with Federal, state, tribal, and local government agencies; and
  - 36 • the NRC staff's independent environmental review.

37 No public comments were received at the public meeting held on June 8, 2016 in Hahnville,  
38 Louisiana or during the scoping period.



# TABLE OF CONTENTS

1			
2	<b>ABSTRACT</b> .....		<b>iii</b>
3	<b>FIGURES</b> .....		<b>xv</b>
4	<b>TABLES</b> .....		<b>xvii</b>
5	<b>EXECUTIVE SUMMARY</b> .....		<b>xxi</b>
6	<b>ABBREVIATIONS AND ACRONYMS</b> .....		<b>xxvii</b>
7	<b>1.0 INTRODUCTION</b> .....		<b>1-1</b>
8	1.1 Proposed Federal Action.....		1-1
9	1.2 Purpose and Need for Proposed Federal Action .....		1-1
10	1.3 Major Environmental Review Milestones.....		1-1
11	1.4 Generic Environmental Impact Statement.....		1-3
12	1.5 Supplemental Environmental Impact Statement.....		1-5
13	1.6 Decisions To Be Supported by the SEIS.....		1-5
14	1.7 Cooperating Agencies.....		1-5
15	1.8 Consultations .....		1-6
16	1.9 Correspondence .....		1-6
17	1.10 Status of Compliance .....		1-6
18	1.11 Related State and Federal Activities .....		1-6
19	1.12 References .....		1-7
20	<b>2.0 ALTERNATIVES INCLUDING THE PROPOSED ACTION</b> .....		<b>2-1</b>
21	2.1 Proposed Action .....		2-1
22	2.1.1 Plant Operations during the License Renewal Term .....		2-1
23	2.1.2 Refurbishment and Other Activities Associated with License		
24	Renewal .....		2-2
25	2.1.3 Termination of Nuclear Power Plant Operations and		
26	Decommissioning after the License Renewal Term .....		2-2
27	2.2 Alternatives .....		2-3
28	2.2.1 No-Action Alternative.....		2-3
29	2.2.2 Replacement Power Alternatives.....		2-4
30	2.2.2.1 New Nuclear Alternative .....		2-7
31	2.2.2.2 Supercritical Pulverized Coal Alternative .....		2-8
32	2.2.2.3 Natural Gas Combined-Cycle Alternative.....		2-9
33	2.2.2.4 Combination Alternative (NGCC, Biomass, and DSM).....		2-10
34	2.3 Alternatives Considered but Dismissed.....		2-12
35	2.3.1 Solar Power.....		2-12
36	2.3.2 Wind Power .....		2-12
37	2.3.3 Biomass Power .....		2-13
38	2.3.4 DSM .....		2-13
39	2.3.5 Hydroelectric Power .....		2-14

## Table of Contents

1	2.3.6	Geothermal Power.....	2-15
2	2.3.7	Wave and Ocean Energy.....	2-15
3	2.3.8	Municipal Solid Waste .....	2-15
4	2.3.9	Petroleum-Fired Power.....	2-16
5	2.3.10	Coal—IGCC .....	2-16
6	2.3.11	Fuel Cells .....	2-16
7	2.3.12	Purchased Power .....	2-17
8	2.3.13	Delayed Retirement.....	2-17
9	2.4	Comparison of Alternatives .....	2-18
10	2.5	References .....	2-21
11	<b>3.0</b>	<b>AFFECTED ENVIRONMENT .....</b>	<b>3-1</b>
12	3.1	Description of Nuclear Power Plant Facility and Operation .....	3-1
13	3.1.1	External Appearance and Setting .....	3-1
14	3.1.2	Nuclear Reactor Systems .....	3-3
15	3.1.3	Cooling and Auxiliary Water Systems .....	3-3
16	3.1.3.1	River Water Intake and Circulating Water System .....	3-4
17	3.1.3.2	Circulating Water and Effluent Discharge .....	3-8
18	3.1.3.3	Component Cooling Water System.....	3-9
19	3.1.3.4	Auxiliary Component Cooling Water System .....	3-10
20	3.1.3.5	Other Auxiliary Systems .....	3-10
21	3.1.4	Radioactive Waste Management Systems .....	3-11
22	3.1.4.1	Radioactive Liquid Waste Management.....	3-11
23	3.1.4.2	Radioactive Gaseous Waste Management .....	3-13
24	3.1.4.3	Radioactive Solid Waste Management .....	3-16
25	3.1.4.4	Radioactive Waste Storage .....	3-16
26	3.1.4.5	Radiological Environmental Monitoring Program .....	3-17
27	3.1.5	Nonradioactive Waste Management Systems .....	3-17
28	3.1.6	Utility and Transportation Infrastructure .....	3-18
29	3.1.6.1	Electricity .....	3-18
30	3.1.6.2	Fuel .....	3-18
31	3.1.6.3	Water.....	3-19
32	3.1.6.4	Transportation Systems.....	3-19
33	3.1.6.5	Power Transmission Systems.....	3-19
34	3.1.7	Nuclear Power Plant Operations and Maintenance.....	3-20
35	3.2	Land Use and Visual Resources .....	3-20
36	3.2.1	Land Use.....	3-20
37	3.2.1.1	Onsite Land Use.....	3-20
38	3.2.1.2	Coastal Zone .....	3-22
39	3.2.1.3	Offsite Land Use.....	3-23
40	3.2.2	Visual Resources.....	3-24
41	3.3	Meteorology, Air Quality, and Noise.....	3-25

1	3.3.1	Meteorology and Climatology .....	3-25
2	3.3.2	Air Quality.....	3-26
3	3.3.3	Noise .....	3-30
4	3.4	Geologic Environment.....	3-31
5	3.4.1	Physiography and Geology.....	3-31
6	3.4.2	Soils .....	3-37
7	3.4.3	Land Subsidence.....	3-37
8	3.4.4	Seismic Setting.....	3-38
9	3.5	Water Resources .....	3-39
10	3.5.1	Surface Water Resources.....	3-39
11	3.5.1.1	Surface Water Hydrology.....	3-39
12	3.5.1.2	Surface Water Use .....	3-44
13	3.5.1.3	Surface Water Quality and Effluents .....	3-45
14	3.5.2	Groundwater Resources.....	3-51
15	3.5.2.1	Site Description and Hydrogeology.....	3-52
16	3.5.2.2	Groundwater Use .....	3-53
17	3.5.2.3	Groundwater Quality.....	3-53
18	3.6	Terrestrial Resources.....	3-55
19	3.6.1	WF3 Ecoregion.....	3-55
20	3.6.2	WF3 Site Surveys, Studies, and Reports.....	3-55
21	3.6.3	WF3 Site .....	3-56
22	3.6.4	Important Species and Habitats.....	3-58
23	3.6.5	Invasive and Non-native Species.....	3-60
24	3.7	Aquatic Resources.....	3-64
25	3.7.1	Environmental Changes in the Lower Mississippi River .....	3-64
26	3.7.2	Lower Mississippi River .....	3-65
27	3.7.2.1	Aquatic Habitats near WF3 .....	3-65
28	3.7.2.2	Aquatic Communities in the Lower Mississippi River .....	3-66
29	3.7.3	State-Listed Species.....	3-70
30	3.7.4	Non-Native and Nuisance Species .....	3-70
31	3.8	Special Status Species and Habitats.....	3-71
32	3.8.1	Species and Habitats Protected Under the Endangered Species	
33		Act.....	3-71
34	3.8.1.1	Action Area.....	3-71
35	3.8.1.2	Species and Habitats Under the FWS’s Jurisdiction .....	3-72
36	3.8.1.3	Species and Habitats under the NMFS’s Jurisdiction.....	3-75
37	3.8.2	Species and Habitats Protected under the Magnuson-Stevens	
38		Act.....	3-75
39	3.9	Historic and Cultural Resources.....	3-76
40	3.9.1	Cultural Background .....	3-76
41	3.9.2	Historic and Cultural Resources at Waterford Steam Electric	
42		Station, Unit 3.....	3-78

## Table of Contents

1	3.10	Socioeconomics.....	3-79
2	3.10.1	Regional Economic Characteristics .....	3-80
3	3.10.1.1	Regional Employment and Income .....	3-80
4	3.10.1.2	Unemployment .....	3-81
5	3.10.2	Demographic Characteristics.....	3-82
6	3.10.2.1	Transient Population.....	3-84
7	3.10.2.2	Migrant Farm Workers.....	3-85
8	3.10.3	Housing and Community Services.....	3-87
9	3.10.3.1	Housing .....	3-87
10	3.10.3.2	Education .....	3-87
11	3.10.3.3	Public Water Supply .....	3-87
12	3.10.4	Tax Revenues .....	3-88
13	3.10.5	Local Transportation.....	3-89
14	3.11	Human Health.....	3-90
15	3.11.1	Radiological Exposure and Risk .....	3-90
16	3.11.2	Chemical Hazards .....	3-91
17	3.11.3	Microbiological Hazards.....	3-91
18	3.11.4	Electromagnetic Fields .....	3-93
19	3.11.5	Other Hazards.....	3-93
20	3.12	Environmental Justice.....	3-94
21	3.12.1	Minority Individuals .....	3-94
22	3.12.2	Minority Populations .....	3-95
23	3.12.3	Low-income Population .....	3-95
24	3.13	Waste Management and Pollution Prevention.....	3-98
25	3.13.1	Radioactive Waste.....	3-98
26	3.13.2	Nonradioactive Waste .....	3-99
27	3.14	References .....	3-99
28	<b>4.0</b>	<b>ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS.....</b>	<b>4-1</b>
29	4.1	Introduction.....	4-1
30	4.2	Land Use and Visual Resources.....	4-1
31	4.2.1	Proposed Action .....	4-1
32	4.2.2	No-Action Alternative.....	4-2
33	4.2.2.1	Land Use .....	4-2
34	4.2.2.2	Visual Resources.....	4-2
35	4.2.3	New Nuclear Alternative .....	4-3
36	4.2.3.1	Land Use .....	4-3
37	4.2.3.2	Visual Resources.....	4-3
38	4.2.4	Supercritical Pulverized Coal Alternative .....	4-3
39	4.2.4.1	Land Use .....	4-3
40	4.2.4.2	Visual Resources.....	4-4
41	4.2.5	Natural Gas Combined-Cycle Alternative .....	4-4

1		4.2.5.1 Land Use .....	4-4
2		4.2.5.2 Visual Resources.....	4-5
3	4.2.6	Combination Alternative (NGCC, Biomass, and Demand-Side Management) .....	4-5
4			
5		4.2.6.1 Land Use .....	4-5
6		4.2.6.2 Visual Resources.....	4-6
7	4.3	Air Quality and Noise .....	4-6
8		4.3.1 Proposed Action .....	4-6
9		4.3.1.1 Air Quality.....	4-6
10		4.3.1.2 Noise .....	4-6
11		4.3.2 No-Action Alternative .....	4-7
12		4.3.2.1 Air Quality.....	4-7
13		4.3.2.2 Noise .....	4-7
14		4.3.3 New Nuclear Alternative .....	4-7
15		4.3.3.1 Air Quality.....	4-7
16		4.3.3.2 Noise .....	4-8
17		4.3.4 SCPC Alternative.....	4-9
18		4.3.4.1 Air Quality.....	4-9
19		4.3.4.2 Noise .....	4-11
20		4.3.5 NGCC Alternative .....	4-11
21		4.3.5.1 Air Quality.....	4-11
22		4.3.5.2 Noise .....	4-13
23		4.3.6 Combination Alternative (NGCC, Biomass, and DSM).....	4-13
24		4.3.6.1 Air Quality.....	4-13
25		4.3.6.2 Noise .....	4-15
26	4.4	Geologic Environment.....	4-16
27		4.4.1 Proposed Action .....	4-16
28		4.4.2 No-Action Alternative .....	4-16
29		4.4.3 New Nuclear Alternative .....	4-16
30		4.4.4 SCPC Alternative.....	4-17
31		4.4.5 NGCC Alternative .....	4-17
32		4.4.6 Combination Alternative (NGCC, Biomass, and DSM).....	4-17
33	4.5	Water Resources .....	4-17
34		4.5.1 Proposed Action .....	4-17
35		4.5.1.1 Surface Water Resources.....	4-17
36		4.5.1.2 Groundwater Resources .....	4-18
37		4.5.2 No-Action Alternative .....	4-19
38		4.5.2.1 Surface Water Resources.....	4-19
39		4.5.2.2 Groundwater Resources.....	4-19
40		4.5.3 New Nuclear Alternative .....	4-19
41		4.5.3.1 Surface Water Resources.....	4-19

## Table of Contents

1		4.5.3.2	Groundwater Resources.....	4-21
2	4.5.4		SCPC Alternative.....	4-21
3		4.5.4.1	Surface Water Resources.....	4-21
4		4.5.4.2	Groundwater Resources.....	4-22
5	4.5.5		NGCC Alternative.....	4-22
6		4.5.5.1	Surface Water Resources.....	4-22
7		4.5.5.2	Groundwater Resources.....	4-23
8	4.5.6		Combination Alternative (NGCC, Biomass, and DSM).....	4-23
9		4.5.6.1	Surface Water Resources.....	4-23
10		4.5.6.2	Groundwater Resources.....	4-24
11	4.6		Terrestrial Resources.....	4-24
12		4.6.1	Proposed Action.....	4-24
13		4.6.1.1	Generic Terrestrial Resource Issues.....	4-24
14		4.6.1.2	Effects on Terrestrial Resources (Noncooling System	
15			Impacts).....	4-25
16		4.6.2	No-Action Alternative.....	4-26
17		4.6.3	New Nuclear Alternative.....	4-26
18		4.6.4	SCPC Alternative.....	4-27
19		4.6.5	NGCC Alternative.....	4-28
20		4.6.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-29
21	4.7		Aquatic Resources.....	4-29
22		4.7.1	Proposed Action.....	4-29
23		4.7.1.1	Generic GEIS Issues.....	4-30
24		4.7.1.2	Impingement and Entrainment of Aquatic Organisms.....	4-30
25		4.7.1.3	Thermal Impacts on Aquatic Organisms.....	4-42
26		4.7.1.4	Mitigation.....	4-47
27		4.7.2	No-Action Alternative.....	4-48
28		4.7.3	New Nuclear Alternative.....	4-48
29		4.7.4	SCPC Alternative.....	4-48
30		4.7.5	NGCC Alternative.....	4-49
31		4.7.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-50
32	4.8		Special Status Species and Habitats.....	4-50
33		4.8.1	Proposed Action.....	4-50
34		4.8.1.1	Species and Habitats under the U.S. Fish and Wildlife	
35			Service's Jurisdiction.....	4-51
36		4.8.1.2	Species and Habitats under the NMFS's Jurisdiction.....	4-57
37		4.8.1.3	Cumulative Effects.....	4-57
38		4.8.1.4	Reporting Requirements.....	4-58
39		4.8.1.5	Species and Habitats Protected Under the	
40			Magnuson-Stevens Act.....	4-58
41		4.8.2	No-Action Alternative.....	4-58
42		4.8.3	New Nuclear Alternative.....	4-59

1	4.8.4	SCPC Alternative.....	4-59
2	4.8.5	NGCC Alternative .....	4-60
3	4.8.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-60
4	4.9	Historic and Cultural Resources.....	4-61
5	4.9.1	Proposed Action .....	4-61
6	4.9.2	No-Action Alternative.....	4-63
7	4.9.3	New Nuclear Alternative .....	4-63
8	4.9.4	Super-Critical Pulverized Coal Alternative .....	4-64
9	4.9.5	NGCC Alternative .....	4-64
10	4.9.6	Combination Alternative (NGCC, Biomass, and Demand Side Management).....	4-64
11			
12	4.10	Socioeconomics.....	4-65
13	4.10.1	Proposed Action .....	4-65
14	4.10.2	No-Action Alternative .....	4-66
15		4.10.2.1 Socioeconomics .....	4-66
16		4.10.2.2 Transportation .....	4-66
17	4.10.3	New Nuclear Alternative .....	4-66
18		4.10.3.1 Socioeconomics .....	4-66
19		4.10.3.2 Transportation .....	4-67
20	4.10.4	SCPC Alternative.....	4-67
21		4.10.4.1 Socioeconomics .....	4-67
22		4.10.4.2 Transportation .....	4-68
23	4.10.5	NGCC Alternative .....	4-68
24		4.10.5.1 Socioeconomics .....	4-68
25		4.10.5.2 Transportation .....	4-68
26	4.10.6	Combination Alternative NGCC, Biomass and DSM.....	4-68
27		4.10.6.1 Socioeconomics .....	4-68
28		4.10.6.2 Transportation .....	4-69
29	4.11	Human Health.....	4-69
30	4.11.1	Proposed Action .....	4-69
31		4.11.1.1 Normal Operating Conditions.....	4-70
32		4.11.1.2 Microbiological Hazards.....	4-71
33		4.11.1.3 Environmental Impacts of Postulated Accidents .....	4-72
34	4.11.2	No-Action Alternative .....	4-78
35	4.11.3	New Nuclear Alternative .....	4-79
36	4.11.4	SCPC Alternative.....	4-79
37	4.11.5	NGCC Alternative .....	4-79
38	4.11.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-80
39	4.12	Environmental Justice Impacts.....	4-80
40	4.12.1	Proposed Action .....	4-81
41	4.12.2	No-Action Alternative.....	4-83

## Table of Contents

1	4.12.3	New Nuclear Alternative .....	4-83
2	4.12.4	SCPC Alternative.....	4-84
3	4.12.5	NGCC Alternative .....	4-84
4	4.12.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-84
5	4.13	Waste Management and Pollution Prevention.....	4-85
6	4.13.1	Proposed Action .....	4-85
7	4.13.2	No-Action Alternative .....	4-86
8	4.13.3	New Nuclear Alternative .....	4-86
9	4.13.4	SCPC Alternative.....	4-86
10	4.13.5	NGCC Alternative .....	4-87
11	4.13.6	Combination Alternative (NGCC, Biomass, and DSM).....	4-87
12	4.14	Evaluation of New and Potentially Significant Information .....	4-87
13	4.15	Impacts Common to All Alternatives.....	4-88
14	4.15.1	Fuel Cycle .....	4-88
15	4.15.1.1	Uranium Fuel Cycle .....	4-88
16	4.15.1.2	Replacement Power Plant Fuel Cycles .....	4-89
17	4.15.2	Terminating Power Plant Operations and Decommissioning .....	4-90
18	4.15.2.1	Existing Nuclear Power Plant.....	4-90
19	4.15.2.2	Replacement Power Plants.....	4-91
20	4.15.3	Greenhouse Gas Emissions and Climate Change .....	4-91
21	4.15.3.1	Greenhouse Gas Emissions from the Proposed Project and Alternatives .....	4-92
22	4.15.3.2	Climate Change Impacts to Resource Areas .....	4-95
23	4.15.3.3	Climate Change Mitigation and Adaptation .....	4-101
24	4.16	Cumulative Impacts of the Proposed Action.....	4-102
25	4.16.1	Air Quality and Noise .....	4-103
26	4.16.1.1	Air Quality.....	4-103
27	4.16.1.2	Noise .....	4-104
28	4.16.2	Geology and Soils .....	4-104
29	4.16.3	Water Resources.....	4-105
30	4.16.3.1	Surface Water Resources.....	4-105
31	4.16.3.2	Groundwater Resources.....	4-109
32	4.16.4	Terrestrial Resources .....	4-109
33	4.16.5	Aquatic Resources .....	4-112
34	4.16.5.1	Modifications to the Mississippi River .....	4-112
35	4.16.5.2	Runoff from Industrial, Agricultural, and Urban Areas ....	4-113
36	4.16.5.3	Water Users and Discharges .....	4-113
37	4.16.5.4	Climate Change.....	4-114
38	4.16.5.5	Protected Habitats .....	4-114
39	4.16.5.6	Conclusion.....	4-115
40	4.16.6	Historic and Cultural Resources .....	4-115
41			

1	4.16.7	Socioeconomics .....	4-115
2	4.16.8	Human Health .....	4-116
3	4.16.9	Environmental Justice .....	4-117
4	4.16.10	Waste Management and Pollution Prevention .....	4-117
5	4.16.11	Global Greenhouse Gas Emissions .....	4-118
6	4.17	Resource Commitments Associated with the Proposed Action .....	4-120
7	4.17.1	Unavoidable Adverse Environmental Impacts.....	4-120
8	4.17.2	Relationship between Short-Term Use of the Environment and	
9		Long-Term Productivity .....	4-120
10	4.17.3	Irreversible and Irrecoverable Commitment of Resources .....	4-121
11	4.18	References .....	4-122
12	<b>5.0</b>	<b>CONCLUSION .....</b>	<b>5-1</b>
13	5.1	Environmental Impacts of License Renewal.....	5-1
14	5.2	Comparison of Alternatives .....	5-1
15	5.3	Recommendations .....	5-1
16	<b>6.0</b>	<b>LIST OF PREPARERS .....</b>	<b>6-1</b>
17	<b>7.0</b>	<b>LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES</b>	
18		<b>OF THIS SEIS ARE SENT .....</b>	<b>7-1</b>
19	<b>8.0</b>	<b>INDEX .....</b>	<b>8-1</b>
	<b>APPENDIX A</b>	<b>COMMENTS RECEIVED ON THE WATERFORD STEAM ELECTRIC</b>	
		<b>STATION, UNIT 3 ENVIRONMENTAL REVIEW .....</b>	<b>A-1</b>
	<b>APPENDIX B</b>	<b>APPLICABLE LAWS, REGULATIONS, AND OTHER</b>	
		<b>REQUIREMENTS .....</b>	<b>B-1</b>
	<b>APPENDIX C</b>	<b>CONSULTATION CORRESPONDENCE .....</b>	<b>C-1</b>
	<b>APPENDIX D</b>	<b>CHRONOLOGY OF ENVIRONMENTAL REVIEW</b>	
		<b>CORRESPONDENCE .....</b>	<b>D-1</b>
	<b>APPENDIX E</b>	<b>PROJECTS AND ACTIONS CONSIDERED IN THE CUMULATIVE</b>	
		<b>IMPACTS ANALYSIS.....</b>	<b>E-1</b>
	<b>APPENDIX F</b>	<b>U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION</b>	
		<b>OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR</b>	
		<b>WATERFORD STEAM ELECTRIC STATION, UNIT 3 IN SUPPORT</b>	
		<b>OF LICENSE RENEWAL APPLICATION REVIEW.....</b>	<b>F-1</b>



## FIGURES

1		
2	Figure 1–1.	Environmental Review Process..... 1-2
3	Figure 1–2.	Environmental Issues Evaluated for License Renewal ..... 1-4
4	Figure 3–1.	50-mi (80-km) Radius of WF3 ..... 3-2
5	Figure 3–2.	Once-Through Cooling Water System with River Water Source, WF3 ..... 3-4
6	Figure 3–3.	WF3 Cooling and Auxiliary Water System Facilities and Surface Water
7		Features ..... 3-6
8	Figure 3–4.	WF3 General Configuration of Intake Structure..... 3-7
9	Figure 3–5.	WF3 Site Layout ..... 3-21
10	Figure 3–6.	WF3 Topographic Cross Section ..... 3-33
11	Figure 3–7.	Recent (Holocene) Age Sediments in New Orleans Area..... 3-34
12	Figure 3–8.	Natural Levee Deposits in New Orleans Area ..... 3-35
13	Figure 3–9.	Geologic Cross Section Through Power Block..... 3-36
14	Figure 3–10.	Hydrologic Features of the Lower Mississippi River Basin near WF3..... 3-41
15	Figure 3–11.	Louisiana Pollutant Discharge Elimination System Permitted Outfalls..... 3-47
16	Figure 3–12.	Onsite Groundwater Monitoring Locations ..... 3-54
17	Figure 3–13.	Land Cover near WF3..... 3-57
18	Figure 3–14.	2010 Census Minority Block Groups Within a 50-mi (80-km) Radius
19		of WF3 ..... 3-97
20	Figure 3–15.	2010 Census Low-Income Block Groups Within a 50-mi (80-km) Radius
21		of WF3 ..... 3-98
22	Figure 4–1.	Relative Abundance of Commonly Impinged Species during the
23		1976-19777 and 2006-2007 Studies at Waterford 1 and 2 ..... 4-33



## TABLES

1			
2	Table ES–1.	Summary of NRC Conclusions Relating to Site-Specific Impacts of	
3		License Renewal.....	xxiii
4	Table 2–1.	Summary and Key Characteristics of Replacement Power Alternatives	
5		Considered In-Depth.....	2-6
6	Table 2–2.	Summary of Environmental Impacts of the Proposed Action and	
7		Alternatives.....	2-19
8	Table 3–1.	Entergy Property Land Uses by Area.....	3-22
9	Table 3–2.	Land Use within a 6-mi (10-km) Radius of WF3.....	3-23
10	Table 3–3.	Ambient Air Quality Standards.....	3-26
11	Table 3–4.	Permitted Air Emission Sources at WF3.....	3-28
12	Table 3–5.	Estimated Air Pollutant Emissions.....	3-29
13	Table 3–6.	Common Noise Sources and Noise Levels.....	3-30
14	Table 3–7.	Annual Surface Water Withdrawals and Return Discharges to the	
15		Mississippi River, WF3.....	3-44
16	Table 3–8.	Louisiana Pollutant Discharge Elimination System Permitted Outfalls,	
17		WF3.....	3-49
18	Table 3–9.	Important Terrestrial Species and Habitats in St. Charles Parish.....	3-61
19	Table 3–10.	Fish Species near WF3 from 1953 through 2007.....	3-67
20	Table 3–11.	Entergy Employees Residence by Louisiana Parish.....	3-79
21	Table 3–12.	Employment by Industry in the WF3 ROI (2011–2015, 5-year estimates).....	3-80
22	Table 3–13.	Estimated Income Information for the WF3 ROI (2011–2015, 5-year	
23		estimates).....	3-81
24	Table 3–14.	Population and Percent Growth in WF3 ROI Parishes 1980–2010, 2014	
25		(estimated), and Projected for 2020–2060.....	3-82
26	Table 3–15.	Demographic Profile of the Population in the WF3 ROI in 2010.....	3-83
27	Table 3–16.	Demographic Profile of the Population in the WF3 ROI (2011–2015,	
28		5-Year Estimates).....	3-83
29	Table 3–17.	2011–2015 5-Year Estimated Seasonal Housing in Parishes Located	
30		within 50 mi (80 km) of WF3.....	3-84
31	Table 3–18.	Migrant Farm Workers and Temporary Farm Labor in Parishes Located	
32		within 50 mi (80 km) of WF3 (2012).....	3-86
33	Table 3–19.	Housing in the WF3 ROI (2011–2015, 5-year Estimate).....	3-87
34	Table 3–20.	Public Water Supply Systems in St. Charles Parish and Jefferson Parish.....	3-88
35	Table 3–21.	Entergy Louisiana, LLC Property Tax Payments, 2010–2015.....	3-89
36	Table 3–22.	Louisiana State Routes in the Vicinity of WF3: 2016 Average Annual	
37		Daily Traffic Count.....	3-89
38	Table 4–1.	Land Use and Visual Resource Issues.....	4-2
39	Table 4–2.	Air Quality and Noise.....	4-6
40	Table 4–3.	Geology and Soils Issues.....	4-16

Tables

1	Table 4–4.	Surface Water Resources Issues.....	4-17
2	Table 4–5.	Groundwater Issues.....	4-18
3	Table 4–6.	Terrestrial Resource Issues .....	4-24
4	Table 4–7.	Aquatic Resource Issues .....	4-30
5	Table 4–8.	Plant Intake Characteristics .....	4-34
6	Table 4–9.	Occurrence Patterns in the Lower Mississippi River near WF3 for Species	
7		Comprising More than 1 Percent of the 1976–1977 and 2006–2007	
8		Impingement Studies .....	4-37
9	Table 4–10.	Special Status Species and Habitat Issues .....	4-51
10	Table 4–11.	Effect Determinations for Federally Listed Species under FWS’s	
11		Jurisdiction.....	4-51
12	Table 4–12.	Historic and Cultural Resources Issue .....	4-61
13	Table 4–13.	Socioeconomic NEPA Issues.....	4-65
14	Table 4–14.	Human Health Issues.....	4-69
15	Table 4–15.	Issues Related to Postulated Accidents .....	4-72
16	Table 4–16.	WF3 Core Damage Frequency for Internal Events.....	4-75
17	Table 4–17.	Breakdown of Population Dose and Offsite Economic Cost by	
18		Containment Release Mode <sup>1</sup> .....	4-76
19	Table 4–18.	Environmental Justice NEPA Issue.....	4-81
20	Table 4–19.	Waste Management Issues.....	4-85
21	Table 4–20.	Issues Related to the Uranium Fuel Cycle .....	4-88
22	Table 4–21.	Issues Related to Decommissioning .....	4-90
23	Table 4–22.	Estimated GHG Emissions from Operations at WF3 (MT/yr of CO <sub>2e</sub> ) .....	4-92
24	Table 4–23.	Direct GHG Emissions from Operation of the	
25		Proposed Action and Alternatives .....	4-94
26	Table 4–24.	Cumulative Surface Water Withdrawals from the Lower Mississippi River,	
27		Killona Segment.....	4-106
28	Table 4–25.	Comparison of GHG Emission Inventories .....	4-119
29	Table 6–1.	List of Preparers .....	6-1
30	Table 7–1.	List of Agencies, Organizations, and Persons to Whom Copies of This	
31		SEIS Are Sent.....	7-1
32	Table B–1.	Federal and State Requirements .....	B-1
33	Table B–2.	Licenses and Permits.....	B-5
34	Table C–1.	ESA Section 7 Consultation Correspondence with FWS.....	C-2
35	Table C–2.	EFH Correspondence with NMFS .....	C-3
36	Table C–3.	NHPA Correspondence.....	C-4
37	Table D–1.	Environmental Review Correspondence .....	D-1
38	Table E–1.	Projects and Actions Considered in the Cumulative Impacts Analysis.....	E-1
39	Table F–1.	Waterford Steam Electric Station Core Damage Frequency (CDF) for	
40		Internal Events.....	F-3

1 Table F-2. Base Case Mean Population Dose Risk and Offsite Economic Cost Risk  
 2 for Internal Events..... F-4

3 Table F-3. Summary of Major PSA Models and Corresponding CDF and LERF  
 4 Results..... F-6

5 Table F-4. SAMAs Cost/Benefit Analysis for Waterford Steam Electric Station Unit 3.  
 6 Percentage Risk Reductions are Presented for Core Damage Frequency  
 7 (CDF), Population Dose Risk (PDR), and Offsite Economic Cost Risk  
 8 (OECR)..... F-30

9 Table F-5. Estimated Cost Ranges for SAMA Applications ..... F-40



# EXECUTIVE SUMMARY

## BACKGROUND

By letter dated March 23, 2016, Entergy Louisiana, LLC and Entergy Operations, Inc. (collectively referred to as "Entergy") submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating license for Waterford Steam Electric Station Unit 3 (WF3) for an additional 20-year period.

Pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 51.20(b)(2), the renewal of a power reactor operating license requires preparation of an environmental impact statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that, in connection with the renewal of an operating license, the NRC shall prepare an EIS, which is a supplement to the Commission's NUREG-1437, *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants*.

Upon acceptance of Entergy's application, the NRC staff began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare a supplemental environmental impact statement (SEIS) and to conduct scoping. In preparation of this SEIS for WF3, the NRC staff performed the following:

- conducted a public scoping meeting on June 8, 2016, in Hahnville, Louisiana;
- conducted an environmental site audit at Waterford 3 from July 18, 2016, to July 21, 2016;
- reviewed Entergy's Environmental Report (ER) and compared it to the GEIS;
- consulted with Federal, state, tribal, and local agencies;
- conducted a review of the issues following the guidance set forth in *Standard Review Plans for Environmental Reviews for Nuclear Power Plants: Environmental Standard Review Plan for Operating License Renewal (NUREG-1555 Supplement 1, Revision 1, Final Report)*;

## PROPOSED ACTION

Entergy initiated the proposed Federal action (i.e., issuance of a renewed power reactor operating license) by submitting an application for license renewal of WF3 for which the existing license (NPF-38) expires on December 18, 2024. The NRC's Federal action is to decide whether to renew the license for an additional 20 years. The regulation at 10 CFR 2.109 states that, if a licensee of a nuclear power plant files an application to renew an operating license at least 5 years before the expiration date of that license, the existing license will not be deemed to have expired until the safety and environmental reviews are completed and until the NRC has made a final decision on whether to deny the application or to issue a renewed license for the additional 20 years.

## PURPOSE AND NEED FOR ACTION

The purpose and need for the proposed action (issuance of renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license to meet future system generating needs. Such needs may be determined by other energy-planning decisionmakers, such as states, operators, and, where

1 authorized, Federal agencies (other than the NRC). This definition of purpose and need reflects  
2 the NRC's recognition that, unless there are findings in the safety review required by the Atomic  
3 Energy Act of 1954, as amended, or findings in the National Environmental Policy Act of 1969,  
4 as amended, environmental analysis that would lead the NRC to reject a license renewal  
5 application, the NRC does not have a role in the energy-planning decisions as to whether a  
6 particular nuclear power plant should continue to operate.

## 7 ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

8 The SEIS evaluates the potential environmental impacts of the proposed action. The  
9 environmental impacts from the proposed action are designated as SMALL, MODERATE, or  
10 LARGE. As established in the GEIS, Category 1 issues are those that meet all of the following  
11 criteria:

12 The environmental impacts associated with the issue are  
13 determined to apply either to all plants or, for some issues, to  
14 plants having a specific type of cooling system or other specified  
15 plant or site characteristics.

16 A single significance level (i.e., SMALL, MODERATE, or LARGE)  
17 has been assigned to the impacts except for collective offsite  
18 radiological impacts from the fuel cycle and from high-level waste  
19 and spent fuel disposal.

20 Mitigation of adverse impacts associated with the issue is  
21 considered in the analysis, and it has been determined that  
22 additional plant-specific mitigation measures are likely not to be  
23 sufficiently beneficial to warrant implementation.

24 For Category 1 issues, no additional site-specific analysis is  
25 required in this SEIS unless new and significant information is  
26 identified. Chapter 4 of this SEIS presents the process for  
27 identifying new and significant information. Site-specific issues  
28 (Category 2) are those that do not meet one or more of the criteria  
29 for Category 1 issues; therefore, an additional site-specific review  
30 for these nongeneric issues is required, and the results are documented in the SEIS.

31 Neither Entergy nor the NRC identified information that is both new and significant related to  
32 Category 1 issues that would call into question the conclusions in the GEIS. This conclusion is  
33 supported by the NRC staff's review of the applicant's ER and other documentation relevant to  
34 the applicant's activities, the public scoping process and substantive comments raised, and the  
35 findings from the environmental site audit conducted by the NRC staff. Therefore, the NRC staff  
36 relied upon the conclusions of the GEIS for all Category 1 issues applicable to WF3.

37 Table ES-1 summarizes the Category 2 issues relevant to WF3 and the NRC staff's findings  
38 related to those issues. If the NRC staff determined that there were no Category 2 issues  
39 applicable for a particular resource area, the findings of the GEIS, as documented in  
40 Appendix B to Subpart A of 10 CFR Part 51, are incorporated for that resource area.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

1  
2**Table ES–1. Summary of NRC Conclusions Relating to Site-Specific Impacts of License Renewal**

<b>Resource Area</b>	<b>Relevant Category 2 Issues</b>	<b>Impacts</b>
<b>Groundwater Resources</b>	Radionuclides released to groundwater	SMALL
<b>Terrestrial Resources</b>	Effects on terrestrial resources (noncooling system impacts)	SMALL
<b>Aquatic Resources</b>	Impingement and entrainment of aquatic organisms	SMALL
	Thermal impacts on aquatic organisms	SMALL
<b>Special Status Species and Habitats<sup>(a)</sup></b>	Threatened, endangered, and species and essential fish habitat	May affect, but is not likely to adversely affect on the pallid sturgeon
		No effect, on Atlantic sturgeon, gulf subspecies and the West Indian Manatee
<b>Historic and Cultural Resources<sup>(b)</sup></b>	Historic and cultural resources	Would not adversely affect any known historic properties
<b>Human Health</b>	Microbiological hazards to the public (plants with cooling ponds, canals, or cooling towers that discharge to a river)	SMALL
	Electric shock hazards	SMALL
<b>Environmental Justice</b>	Minority and low-income populations	(c)

<sup>(a)</sup> For Federally protected species, the NRC reports the effects from continued operation of WF3 during the license renewal period in terms of its Endangered Species Act of 1973, as amended, findings of “no effect,” “may effect, but not likely to adversely effect,” or “may affect, and is likely to adversely affect.”

<sup>(b)</sup> The National Historic Preservation Act of 1966, as amended, requires Federal agencies to consider the effects of their undertakings on historic properties.

<sup>(c)</sup> There would be no disproportionately high and adverse impacts to minority and low-income populations and subsistence consumption from continued operation of WF3 during the license renewal period and from cumulative impacts.

### 3 SEVERE ACCIDENT MITIGATION ALTERNATIVES

4 Since severe accident mitigation alternatives (SAMAs) have not been previously considered in  
5 an environmental impact statement or environmental assessment for WF3,  
6 10 CFR 51.53(c)(3)(ii)(L) required Entergy to submit, with the ER, a consideration of alternatives  
7 to mitigate severe accidents. SAMAs are potential ways to reduce the risk or potential impacts  
8 of uncommon, but potentially severe accidents. SAMAs may include changes to plant  
9 components, systems, procedures, and training.

## Executive Summary

1 The NRC staff reviewed Entergy's analysis and concludes that the methods used and the  
2 implementation of those methods was sound. The treatment of SAMA benefits and costs  
3 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable  
4 and sufficient for the license renewal submittal.

5 The staff agrees with Entergy's conclusion that the 14 candidate SAMAs discussed in this  
6 section are potentially cost beneficial and are based on conservative treatment of costs,  
7 benefits, and uncertainties. The small number of potentially cost beneficial SAMAs is consistent  
8 with the low residual level of risk indicated in the WF3 probabilistic safety assessment and the  
9 fact that Entergy has already implemented the plant improvements identified from the individual  
10 plant examination and individual plant examination of external events. Because the potentially  
11 cost beneficial SAMAs do not relate to aging management during the period of extended  
12 operation, they do not need to be implemented as part of license renewal in accordance with 10  
13 CFR Part 54. Nevertheless, Entergy stated that each of these potentially cost beneficial SAMAs  
14 has been submitted for detailed engineering project cost-benefit analysis to further evaluate  
15 their implementation.

## 16 **ALTERNATIVES**

17 The NRC staff considered the environmental impacts associated with alternatives to license  
18 renewal. These alternatives include other methods of power generation, as well as not  
19 renewing the WF3 operating license (the no-action alternative). The NRC staff considered the  
20 following feasible and commercially viable replacement power alternatives:

- 21 • new nuclear power;
- 22 • supercritical pulverized coal
- 23 • natural gas combined-cycle (NGCC)
- 24 • a combination of NGCC, biomass and demand side management

25 The NRC staff initially considered a number of additional alternatives for analysis as alternatives  
26 to the license renewal of WF3. The NRC staff later dismissed these alternatives because of  
27 technical, resource availability, or commercial limitations that currently exist and that the NRC  
28 staff believes are likely to continue to exist when the current WF3 license expires.

29 Where possible, the NRC staff evaluated potential environmental impacts for these alternatives  
30 located at both the WF3 site and some other unspecified alternate location. The NRC staff  
31 considered the following alternatives, but dismissed them:

- 32 • solar power
- 33 • wind power
- 34 • biomass power
- 35 • demand-side management
- 36 • hydroelectric power
- 37 • geothermal power
- 38 • wave and ocean energy
- 39 • municipal solid waste
- 40 • petroleum-fired power

- 1 • coal-integrated gasification combined-cycle
- 2 • fuel cells
- 3 • purchased power
- 4 • delayed retirement

5 The NRC staff evaluated each alternative using the same resource areas that were used in  
6 evaluating impacts from license renewal.

## 7 **PRELIMINARY RECOMMENDATION**

8 The NRC staff's preliminary recommendation is that the adverse environmental impacts of  
9 license renewal for Waterford 3 are not so great that preserving the option of license renewal for  
10 energy-planning decisionmakers would be unreasonable. The NRC staff based its  
11 recommendation on the following:

- 12 • the analyses and findings in the GEIS;
- 13 • the ER submitted by Entergy;
- 14 • the NRC staff's consultation with Federal, state, tribal, and local agencies;
- 15 • the NRC staff's independent environmental review.



## ABBREVIATIONS AND ACRONYMS

1		
2	AADT	average annual traffic
3	ac	acre(s)
4	AC	alternating current
5	ACC	averted cleanup and decontamination costs
6	ACCWS	auxiliary component cooling water system
7	ACHP	Advisory Council on Historic Preservation
8	ADAMS	Agencywide Documents Access and Management System
9	AEA	Atomic Energy Act of 1954 (as amended)
10	AFW	auxiliary feedwater
11	ALARA	as low as is reasonably achievable
12	AOC	averted offsite property damage costs
13	AOE	averted occupational exposure
14	AOP	air operated valve
15	AOSC	averted onsite costs
16	APE	averted public exposure
17		area of potential effect
18	AQCR	Air Quality Control Region
19	ASME	American Society of Mechanical Engineers
20	ATWS	anticipated transient(s) without scram
21	BGEPA	Bald and Golden Eagle Protection Act of 1940, as amended
22	BLS	Bureau of Labor Statistics
23	BMP	best management practice
24	BMS	boron management system
25	BOEM	Bureau of Ocean Energy Management
26	BTA	best technology available
27	°C	degrees Celsius
28	CAA	Clean Air Act
29	CARS	containment atmosphere release system
30	CCF	common cause failure
31	CCW	component cooling water
32	CCWS	component cooling water system
33	CDC	Centers for Disease Control and Prevention
34	CDF	core damage frequency

## Abbreviations and Acronyms

1	CEQ	Council on Environmental Quality
2	CET	containment event tree
3	CFR	<i>Code of Federal Regulations</i>
4	cfs	cubic foot (feet) per second
5	CH <sub>4</sub>	methane
6	CHR	containment heat removal system(s)
7	Ci	curies
8	cm	centimeter
9	cm/sec	centimeters per second
10	CO	carbon monoxide
11	CO <sub>2</sub>	carbon dioxide
12	CO <sub>2</sub> e	carbon dioxide equivalent
13	CPMU	Coastal Plain Management Unit
14	CSP	concentrating solar power
15		condensate storage pool
16	CVCS	chemical and volume control system
17	CWA	Clean Water Act
18	CWIS	circulating water intake structure
19	CWS	circulating water system
20	CZMA	Coast Zone Management Act of 1972
21	dB	decibels
22	dBA	decibel(s) on the A-weighted scale
23	DBA	design-basis accident
24	DC	direct current
25	DMR	discharge monitoring report
26	DOE	U.S. Department of Energy
27	DSM	demand-side management
28	DWST	demineralized water storage tank
29	ECCS	emergency core cooling system
30	ECOS	Environmental Conservation Online System
31	EDG	emergency diesel generator
32	EEC	Energy Education Center
33	EFH	essential fish habitat
34	EFW	emergency feedwater
35	EIA	Energy Information Administration

## Abbreviations and Acronyms

1	EIS	environmental impact statement
2	EMF	electromagnetic field
3	EO	Executive Order
4	EOP	emergency operating procedure
5	EPA	U.S. Environmental Protection Agency
6	EPRI	Electric Power Research Institute
7	ER	Environmental Report
8	ERC	Energy Recovery Council
9	ERFBS	Electric Raceway Fire Barrier System
10	ESA	Endangered Species Act of 1973, as amended
11	°F	degrees Fahrenheit
12	FE	Federally endangered
13	FEIS	final environmental impact statement
14	FEMA	Federal Emergency Management Agency
15	FES	final environmental statement
16	FHA	Federal Housing Administration
17	FIVE	Fire-Induced Vulnerability Evaluation
18	FL	fork length
19	FLIGHT	Facility Level Information on Green House Gases Tool
20	fps	feet per second
21	FR	<i>Federal Register</i>
22	FRN	<i>Federal Register</i> Notice
23	FT	Federally threatened
24	ft	foot (feet)
25	ft <sup>3</sup>	cubic foot (feet)
26	FWS	U.S. Fish and Wildlife Service
27	gal	gallon(s)
28	GE	general emergency
29	GEIS	generic environmental impact statement
30	GHG	greenhouse gas
31	GI	generic issue
32	GL	generic letter
33	GMRS	ground motion response spectrum
34	gpd	gallons(s) per day
35	gpm	gallon(s) per minute

## Abbreviations and Acronyms

1	GT	gigatons
2	GWP	global warming potential
3	H <sub>2</sub> O	water vapor
4	ha	hectare(s)
5	HEPA	high-efficiency particulate absorption
6	HFC	hydrofluorocarbon(s)
7	Hg	mercury
8	HLR	high-level requirements
9	HPSI	high pressure safety injection
10	HRA	human reliability analysis
11	HRSG	heat recovery steam generator
12	HVAC	heating, ventilation, and cooling
13	ICF	ICF International
14	IE	initiating event
15	IEA	International Energy Agency
16	IEEE	Institute of Electrical and Electronics Engineers
17	IGCC	integrated gasification combined-cycle
18	ILRT	integrated leak rate test
19	in.	inch(es)
20	IPaC	Information for Planning and Conservation
21	IPCC	Intergovernmental Panel on Climate Change
22	IPE	individual plant examination
23	IPEEE	individual plant examination of external events
24	IRP	Integrated Resource Plan
25	ISFSI	independent spent fuel storage installation
26	ISLOCA	interfacing-systems loss-of-coolant accident
27	km	kilometer(s)
28	km <sup>2</sup>	square kilometer(s)
29	KMSY	Louis Armstrong New Orleans International Airport
30	kph	kilometer(s) per hour
31	kV	kilovolt(s)
32	kW	kilowatt(s)
33	kWh/m <sup>2</sup> /d	kilowatt hours per square meter per day
34	L	liter(s)
35	LAC	Louisiana Administrative Code

## Abbreviations and Acronyms

1	LaDOTD	Louisiana Department of Transportation & Development
2	LAR	license amendment request
3	lb	pound(s)
4	LCRP	Louisiana Coastal Resources Program
5	LDH	Louisiana Department of Health
6	L <sub>DN</sub>	day-night sound intensity level
7	LDNR	Louisiana Department of Natural Resources
8	LDEQ	Louisiana Department of Environmental Quality
9	LDWF	Louisiana Department of Wildlife and Fisheries
10	L <sub>EQ</sub>	equivalent sound intensity level
11	LERF	large early release frequency
12	LLRW	low-level solid radioactive waste
13	L <sub>n</sub>	statistical sound level
14	LNHP	Louisiana Natural Heritage Program
15	LOCA	loss-of-coolant accident
16	LOE	lines of evidence
17	LOOP	loss(es) of offsite power
18	LOPH	Louisiana Office of Public Health
19	LP&L	Louisiana Power & Light Company
20	LPDES	Louisiana Pollutant Discharge Elimination System
21	L/min	liter(s) per minute
22	LPSI	low-pressure safety injection
23	LRA	license renewal application
24	m	meter(s)
25	m <sup>3</sup>	cubic meter(s)
26	m <sup>3</sup> /d	cubic meter(s) per day
27	m <sup>3</sup> /s	cubic meter(s) per second
28	m <sup>3</sup> /y	cubic meter(s) per year
29	m/s	meter(s) per second
30	MAAP	Modular Accident Analysis Program
31	MACCS2	MELCOR Accident Consequence Code System 2
32	MATS	Mercury and Air Toxics Standards
33	mBq	megabecquerels
34	mgd	million gallons per day
35	MEA	monoethanolamine

## Abbreviations and Acronyms

1	mgY	million gallons per year
2	mGy	milligray
3	mi	mile(s)
4	mi <sup>2</sup>	square mile(s)
5	MISO	Midcontinent Independent System Operator
6	mm	millimeter
7	MMT	million metric ton(s)
8	MOV	motor-operated valve
9	mph	mile(s) per hour
10	mrad	millirad
11	mrem	millirem
12	MRS	Mississippi River Commission
13	MSA	Magnuson–Stevens Fishery Conservation and Management Act,
14		as amended through 2006
15		Mitigation Strategy Assessment
16	MSL	mean sea level
17	mSv	millisievert
18	MW	megawatt(s)
19	MWD/MTu	megawatt-days per metric ton
20	MWe	megawatt(s) electric
21	MWh	megawatt hour(s)
22	MWt	megawatt(s) thermal
23	NAAQS	National Ambient Air Quality Standards
24	NASS	National Agricultural Statistics Service (U.S. Department of
25		Agriculture)
26	NCDC	National Climatic Data Center
27	NCES	National Center for Education Statistics
28	NCF	no containment failure
29	NEI	Nuclear Energy Institute
30	NEPA	National Environmental Policy Act of 1969, as amended
31	NESC	National Electrical Safety Code
32	NETL	National Technology Energy Laboratory
33	NGCC	natural gas combined-cycle
34	NHPA	National Historic Preservation Act of 1966, as amended
35	NIEHS	National Institute of Environmental Health Sciences

## Abbreviations and Acronyms

1	NMFS	National Marine Fisheries Service (National Oceanic and Atmospheric Administration)
2		
3	N <sub>2</sub> O	nitrous oxide
4	NO <sub>2</sub>	nitrogen dioxide
5	NO <sub>x</sub>	nitrogen oxide(s)
6	NOAA	National Oceanic and Atmospheric Administration
7	NPDES	National Pollutant Discharge Elimination System
8	NPIS	nuclear plant island structure
9	NPS	National Park Service
10	NRC	U.S. Nuclear Regulatory Commission
11	NREL	National Renewable Energy Laboratory
12	NRHP	National Register of Historic Places
13	NRR	Nuclear Reactor Regulation, Office of (NRC)
14	NSR	New Source Review
15	O <sub>3</sub>	ozone
16	ODCM	Offsite Dose Calculation Manual
17	OECR	offsite economic cost risk
18	OSHA	Occupational Safety and Health Administration
19	Pb	lead
20	PDR	population dose risk
21	PFC	perfluorocarbon
22	PIC	Proposal for Information Collection
23	PM	particulate matter
24	PM <sub>2.5</sub>	particulate matter less than 2.5 micrometers in diameter
25	PM <sub>10</sub>	particulate matter less than 10 micrometers in diameter
26	PRA	probabilistic risk assessment
27	PSA	probabilistic safety assessment
28	PSD	prevention of significant deterioration
29	psi	pounds per square inch
30	PV	photovoltaic
31	PWR	pressurized water reactor
32	RAB	reactor auxiliary building
33	radwaste	radioactive waste
34	RAI	request(s) for additional information
35	RCP	reactor coolant pump

## Abbreviations and Acronyms

1	RCRA	Resource Conservation and Recovery Act of 1976, as amended
2	rem	roentgen equivalent(s) man
3	REMP	Radiological Environmental Monitoring Program
4	RHR	Regional Haze Rule
5	RKM	River Kilometer
6	RM	River Mile
7	ROI	region(s) of influence
8	ROW	right-of-way(s)
9	RPC	replacement power cost
10	RRW	risk reduction worth
11	RWSP	reactor water storage pool
12	SAFSTOR	safe storage, one of three NRC decommissioning strategies
13	SAMA	severe accident mitigation alternative
14	SAR	Safety Analysis Report
15	SBO	station blackout
16	SCP	St. Charles Parish
17	SCPC	supercritical pulverized coal
18	SCR	selective catalytic reduction
19	SE	safety evaluation
20	SEIS	supplemental environmental impact statement
21	SERC	Southeast Electric Reliability Corporation
22	SF <sub>6</sub>	sulfur hexafluoride
23	SGTR	steam generator tube rupture
24	SHPO	State Historic Preservation Office
25	SI	safety injection
26	SIP	State Implementation Plan
27	SL	standard length
28	SMA	seismic margins assessment
29	SO <sub>2</sub>	sulfur dioxide
30	SO <sub>x</sub>	sulfur oxide(s)
31	SPCC	spill prevention, control, and countermeasures
32	SR	supporting requirements
33	SSC	structure(s), system(s), and component(s)
34	SSE	safe shutdown earthquake
35	Sv	sievert(s)

## Abbreviations and Acronyms

1	SWMS	solid waste management system
2	SWPPP	stormwater pollution prevention plan
3	TDEFW	turbine-driven EFW
4	TEDG	temporary emergency diesel generator
5	TG	teragram(s)
6	TMDL	total maximum daily load
7	TOC	total organic compound
8	TSS	total suspended solids
9	UFSAR	updated final safety analysis report
10	UHS	ultimate heat sink
11	µm	micrometer
12	U.S.	United States
13	USACE	U.S. Army Corps of Engineers
14	U.S.C.	U.S. Code
15	USCB	U.S. Census Bureau
16	USDA	U.S. Department of Agriculture
17	USGS	U.S. Geological Survey
18	VOC	volatile organic compound
19	WF3	Waterford Steam Electric Station Unit 3
20	WMA	wildlife management area
21	WMS	waste management system



# 1.0 INTRODUCTION

The U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51 implement the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq., herein referred to as NEPA). The regulations at 10 CFR Part 51 require the preparation of an environmental impact statement (EIS) for issuance or renewal of a nuclear power plant operating license.

The Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 et seq.), specifies that licenses for commercial power reactors can be granted for up to 40 years. NRC regulations in 10 CFR 54.31 allow for an option to renew a license for up to an additional 20 years. The initial 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests entirely with nuclear power facility owners and, typically, is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny license renewal based on whether the applicant has demonstrated that the environmental and safety requirements in the agency's regulations can be met during the period of extended operation.

## 1.1 Proposed Federal Action

Entergy Louisiana, LLC and Entergy Operations, Inc. (collectively referred to as Entergy) initiated the proposed Federal action by submitting an application for license renewal of Waterford Steam Electric Station Unit 3 (WF3), for which the existing license (NPF-38) expires on December 18, 2024. The NRC's Federal action is to decide whether to renew the license for an additional 20 years.

## 1.2 Purpose and Need for Proposed Federal Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs because such needs may be determined by other energy-planning decisionmakers. This definition of purpose and need reflects the NRC's recognition that, unless there are findings in the safety review required by the Atomic Energy Act or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application (LRA), the NRC does not have a role in the energy-planning decisions of state regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

## 1.3 Major Environmental Review Milestones

Entergy submitted an Environmental Report (ER) (Entergy 2016b) as part of its LRA (Entergy 2016a) in March 2016. After reviewing the LRA and ER for sufficiency, the NRC staff published a *Federal Register* Notice of Acceptability and Opportunity for Hearing (81 FR 34379) on May 31, 2016. Then, on June 6, 2016, the NRC published another notice in the *Federal Register* (81 FR 36354) on the intent to conduct scoping, thereby beginning the 60-day scoping period.

## Introduction


1 A public scoping meeting was held on June 8, 2016, at the St. Charles Parish Emergency  
2 Operations Center in Hahnville, Louisiana. No comments from members of the public were  
3 presented at the scoping meeting. Additionally, no written comments were submitted during the  
4 scoping period.

5 To independently verify information provided in the ER, the NRC staff conducted a site audit at  
6 WF3 in July 2016. During the site audit, the NRC staff met with plant personnel, reviewed  
7 specific documentation, and toured the facility. A summary of that site audit and a list of the  
8 attendees is contained in "Summary of Site Audit in Support to the Environmental Review of the  
9 License Renewal Application for Waterford 3, (CAC No. MF7493)." (NRC 2017).

10 Upon completion of the scoping period and site audit, the NRC staff compiled its findings in a  
11 draft supplemental environmental impact statement (SEIS). This document is made available  
12 for public comment for 45 days. During this time, the NRC staff will collect comments from the  
13 public on the draft SEIS and may host a public meeting. Based on the information gathered, the  
14 NRC staff will amend the draft SEIS findings, as necessary, and publish the final SEIS.  
15 Figure 1–1 shows the major milestones of the NRC's LRA environmental review.

16

**Figure 1–1. Environmental Review Process**



17

18 The NRC has established a license renewal process that can be completed in a reasonable  
19 period of time with clear requirements to ensure safe plant operation for up to an additional  
20 20 years of plant life. The NRC staff conducts the safety review simultaneously with the  
21 environmental review. The staff documents the findings of the safety review in a safety  
22 evaluation report. The findings in the SEIS and the safety evaluation report are both factors in  
23 the NRC's decision to either grant or deny the issuance of a renewed license.

## 1 1.4 Generic Environmental Impact Statement

2 The NRC staff performed a generic assessment of the environmental impacts associated with  
 3 license renewal to improve the efficiency of its license renewal review. NUREG–1437, *Generic*  
 4 *Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS)  
 5 (NRC 1996, 1999, 2013), documented the results of the staff’s systematic approach to evaluate  
 6 the environmental consequences of renewing the licenses of individual nuclear power plants  
 7 and operating them for an additional 20 years. The staff analyzed, in detail, and resolved those  
 8 environmental issues that could be resolved generically in the GEIS. The GEIS originally was  
 9 issued in 1996, Addendum 1 to the GEIS was issued in 1999, and Revision 1 to the GEIS was  
 10 issued in 2013. Unless otherwise noted, all references to the GEIS include the GEIS,  
 11 Addendum 1, and Revision 1.

12 The GEIS establishes separate environmental impact issues for the NRC staff to independently  
 13 evaluate. Appendix B to Subpart A of 10 CFR Part 51 provides a summary of the staff findings  
 14 in the GEIS. For each potential environmental issue in the GEIS, the NRC staff:

- 15 • describes the activity that affects the environment,
- 16 • identifies the population or resource that is affected,
- 17 • assesses the nature and magnitude of the impact on the affected population  
 18 or resource,
- 19 • characterizes the significance of the effect for both beneficial and adverse  
 20 effects,
- 21 • determines whether the results of the analysis apply to all plants, and
- 22 • considers whether additional mitigation measures would be warranted for  
 23 impacts that would have the same significance level for all plants.

24 The NRC’s standard of significance for impacts was established using the Council on  
 25 Environmental Quality terminology for “significant.” The NRC established three levels of  
 26 significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below.

27 **SMALL:** Environmental effects are not  
 28 detectable or are so minor that they will neither  
 29 destabilize nor noticeably alter any important  
 30 attribute of the resource.

31 **MODERATE:** Environmental effects are  
 32 sufficient to alter noticeably, but not to  
 33 destabilize, important attributes of the resource.

34 **LARGE:** Environmental effects are clearly  
 35 noticeable and are sufficient to destabilize  
 36 important attributes of the resource.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: context and intensity.

Context is the geographic, biophysical, and social context in which the effects will occur.

Intensity refers to the severity of the impact in whatever context it occurs.

37 The GEIS includes a determination of whether the analysis of the environmental issue could be  
 38 applied to all plants and whether additional mitigation measures would be warranted. Issues  
 39 are assigned a Category 1 or Category 2 designation. As established in the GEIS, Category 1  
 40 issues are those that meet the following criteria:


- 41 • The environmental impacts associated with the issue have been determined  
 42 to apply either to all plants or, for some issues, to plants that have a specific  
 43 type of cooling system or other specified plant or site characteristics.

- 1 • A single significance level (i.e., SMALL, MODERATE, or LARGE) has been
- 2 assigned to the impacts (except for collective offsite radiological impacts from
- 3 the fuel cycle and from high-level waste and spent fuel disposal).
- 4 • Mitigation of adverse impacts associated with the issue has been considered
- 5 in the analysis, and it has been determined that additional plant-specific
- 6 mitigation measures are likely not to be sufficiently beneficial to warrant
- 7 implementation.

8 For generic issues (Category 1), no additional site-specific analysis is required in the SEIS  
 9 unless new and significant information is identified. The process for identifying new and  
 10 significant information for site-specific analysis is presented in Chapter 4. Site-specific issues  
 11 (Category 2) are those that do not meet one or more of the criteria of Category 1 issues;  
 12 therefore, additional site-specific review for these issues is required. A site-specific analysis is  
 13 required for 17 of the 78 issues evaluated in the GEIS. Figure 1–2 illustrates this process. The  
 14 results of that site-specific review are documented in the SEIS.

15 **Figure 1–2. Environmental Issues Evaluated for License Renewal**

16 *In the GEIS, the NRC evaluated 78 issues.*  
 17 *A site-specific analysis is required for 17 of those 78 issues.*



19

## 1.5 Supplemental Environmental Impact Statement

The SEIS presents an analysis that considers the environmental effects of the continued operation of WF3, alternatives to license renewal, and mitigation measures for minimizing adverse environmental impacts. Chapter 4 contains analysis and comparison of the potential environmental impacts from alternatives. Chapter 5 presents the NRC's recommendation on whether the environmental impacts of license renewal are so great that preserving the option of license renewal would be unreasonable. The final recommendation will be made after consideration of comments received on the draft SEIS during the public comment period.

In the preparation of the WF3 SEIS, the NRC staff carried out the following activities:

- reviewed the information provided in Entergy's ER;
- consulted with Federal agencies, State and local agencies, and Tribal Nations;
- conducted an independent review of the issues during the site audit; and
- considered the public comments received for the review (during the scoping process).

New information can be identified from many sources, including the applicant, the NRC, other agencies, or public comments. If a new issue is revealed, it is first analyzed to determine whether it is within the scope of the license renewal environmental evaluation. If the new issue is not addressed in the GEIS, the NRC staff would determine the significance of the issue and document the analysis in the SEIS.

New and significant information. To merit additional review, information must be both "new" and "significant," and it must bear on the proposed action or its impacts.

## 1.6 Decisions To Be Supported by the SEIS

The decision to be supported by the SEIS is whether to renew the operating license for WF3 for an additional 20 years. The regulation at 10 CFR 51.103(a)(5) specifies the NRC's decision standard as follows:

In making a final decision on a license renewal action pursuant to Part 54 of this chapter, the Commission shall determine whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy planning decisionmakers would be unreasonable.

There are many factors that the NRC takes into consideration when deciding whether to renew the operating license of a nuclear power plant. The analyses of environmental impacts evaluated in this GEIS will provide the NRC's decisionmaker (in this case, the Commission) with important environmental information for use in the overall decision-making process. There are also decisions outside the regulatory scope of license renewal that cannot be made on the basis of the GEIS analysis. These decisions include the following issues: (1) changes to plant cooling systems, (2) disposition of spent nuclear fuel, (3) emergency preparedness, (4) safeguards and security, (5) need for power, and (6) seismicity and flooding (NRC 2013).

## 1.7 Cooperating Agencies

During the scoping process, no Federal, State, or local agencies were identified as cooperating agencies in the preparation of this SEIS.

1 **1.8 Consultations**

2 The Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.); the  
3 Magnuson–Stevens Fisheries Conservation and Management Act of 1996, as amended  
4 (16 U.S.C. 1801 et seq.); and the National Historic Preservation Act of 1966, as amended  
5 (54 U.S.C. 300101 et seq.), require Federal agencies to consult with applicable State and  
6 Federal agencies and groups before taking action that may affect endangered species,  
7 fisheries, or historic and archaeological resources, respectively. The NRC consulted with the  
8 following agencies and groups; Appendix C discusses the consultation documents:

- 9 • U.S. Fish and Wildlife Service;
- 10 • Chitimacha Tribe of Louisiana;
- 11 • Coushatta Tribe of Louisiana;
- 12 • Jena Band of Choctaw Indians;
- 13 • Tunica-Biloxi Tribe of Louisiana;
- 14 • Louisiana Office of Cultural Development, State Historic Preservation Officer;  
15 and
- 16 • Advisory Council on Historic Preservation.

17 **1.9 Correspondence**

18 During the course of the environmental review, the NRC staff contacted Federal, State, regional,  
19 local, and Tribal agencies listed in Section 1.8. Appendices C and D contain a chronological list  
20 of all documents sent and received during the environmental review. Appendix C lists the  
21 correspondence associated with the Endangered Species Act, the Magnuson–Stevens  
22 Fisheries Conservation and Management Act, and the National Historic Preservation Act.  
23 Appendix D lists all other correspondence.

24 **1.10 Status of Compliance**

25 Entergy is responsible for complying with all NRC regulations and other applicable Federal,  
26 State, and local requirements. Appendix F of the GEIS describes some of the major applicable  
27 Federal statutes. Numerous permits and licenses are issued by Federal, State, and local  
28 authorities for activities at WF3. Appendix B of this SEIS contains further information about  
29 Entergy’s status of compliance.

30 **1.11 Related State and Federal Activities**

31 The NRC reviewed the possibility that activities of other Federal agencies might affect the  
32 renewal of the operating license for WF3. There are no Federal projects that would make it  
33 necessary for another Federal agency to become a cooperating agency in the preparation of  
34 this SEIS.

35 There are no known American Indian lands within 50 miles (mi) (80 kilometers (km)) of WF3  
36 (Entergy 2016a). One military installation, the Naval Air Station Reserve Base New Orleans, is  
37 located approximately 28 mi (45 km) east-southeast of WF3. The Bonnet Carre Spillway, a  
38 major flood control public works structure, is located approximately 1 mi (1.6 km) east-northeast  
39 of the plant on the east bank of the Mississippi River. No State parks are located within a 6-mi  
40 (10-km) radius of WF3. The Bayou Segnestte State Park is located approximately 19 mi

1 (30 km) southeast of the plant. The southern portion of the Maurepas Swamp Wildlife  
 2 Management Area is located about 6 mi (10 km) north of WF3. The Salvador/Timken Wildlife  
 3 Management Area is located about 15 mi (24 km) southeast of WF3. Both the Maurepas  
 4 Swamp and Salvador/Timken Wildlife Management Areas are managed by the Louisiana  
 5 Department of Wildlife and Fisheries. There are a number of small local parks managed by  
 6 St. Charles Parish in the vicinity of WF3. The Wetlands Watcher's Park is located within the  
 7 Bonnet Carre Spillway; Killona Park is about 1 mi (1.6 km) northwest of WF3; Montz Park is  
 8 approximately 1 mi (1.6 km) east-northeast of WF3; and Bethune Park is located approximately  
 9 3 mi (4.8 km) east-northeast of WF3.

10 The NRC is required under Section 102(2)(C) of NEPA to consult with and obtain comments  
 11 from any Federal agency that has jurisdiction by law or special expertise with respect to any  
 12 environmental impact involved in the subject matter of the EIS. For example, during the course  
 13 of preparing the SEIS, the NRC consulted with the U.S. Fish and Wildlife Service. Appendix D  
 14 provides a complete list of consultation correspondence.

## 15 **1.12 References**

16 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental  
 17 protection regulations for domestic licensing and related regulatory functions."

18 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for  
 19 renewal of operating licenses for nuclear power plants."

20 81 FR 34379. U.S. Nuclear Regulatory Commission. 2016. Entergy Operations, Inc.;  
 21 Waterford Steam Electric Station, Unit 3: License renewal application; opportunity to request a  
 22 hearing and to petition for leave to intervene. *Federal Register* 81(104):34379-34382.  
 23 May 31, 2016.

24 81 FR 36354. U.S. Nuclear Regulatory Commission. 2016. Entergy Operations, Inc.;  
 25 Waterford Steam Electric Station, Unit 3; Intent to Conduct Process and Prepare Environmental  
 26 Impact Statement. *Federal Register* 81(108):36354-36356. June 6, 2016.

27 Atomic Energy Act of 1954, as amended. 42 U.S.C. §2011 et seq.

28 Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.

29 [Entergy] 2016a. Entergy Louisiana, LLC and Entergy Operations, Inc. License Renewal  
 30 Application, Waterford Steam Electric Station, Unit 3, Facility Operating License NPF-38.  
 31 March 2016. ADAMS Nos. ML16088A331, ML16088A332, and ML16088A325.

32 [Entergy] 2016b. Entergy Louisiana, LLC and Entergy Operations, Inc. Applicant's  
 33 Environmental Report—Operating License Renewal Stage, Waterford Steam Electric Station,  
 34 Unit 3. March 2016. ADAMS Nos. ML16088A326, ML16088A327, ML16088A328,  
 35 ML16088A329, ML16088A333, and ML16088A335.

36 Magnuson–Stevens Fishery Conservation and Management Act, as amended.  
 37 16 U.S.C. §1801 et seq.

38 National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.

39 National Historic Preservation Act of 1966, as amended. 54 U.S.C. §300101 et seq.

40 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*  
 41 *for License Renewal of Nuclear Plants, Final Report*. Washington, DC: U.S. Nuclear  
 42 Regulatory Commission. NUREG–1437, Volumes 1 and 2. May 31, 1996. ADAMS  
 43 Nos. ML040690705 and ML040690738.

## Introduction

- 1 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3—Transportation, Table 9.1,  
2 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, in *Generic*  
3 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:  
4 U.S. Nuclear Regulatory Commission. NUREG–1437, Volume 1, Addendum 1. August 1999.  
5 ADAMS Accession No. ML040690720.
- 6 [NRC] U.S. Nuclear Regulatory Commission. 2013. *Generic Environmental Impact Statement*  
7 *for License Renewal of Nuclear Plants, Revision 1*. Washington, DC: U.S. Nuclear Regulatory  
8 Commission. NUREG–1437, Volumes 1, 2, and 3. June 19, 2013. 1,535 p. ADAMS  
9 Accession Nos. ML13106A241, ML13106A242, and ML13106A244.
- 10 [NRC] U.S. Nuclear Regulatory Commission. 2017. Summary of Waterford 3 Environmental  
11 and SAMA Audits for License Renewal. ADAMS Accession No. ML17356A317.

## 2.0 ALTERNATIVES INCLUDING THE PROPOSED ACTION

Although the U.S. Nuclear Regulatory Commission's (NRC's) decisionmaking authority in license renewal is limited to deciding whether to renew a nuclear power plant's operating license, the agency's implementation of the National Environmental Policy Act of 1969, as amended (NEPA) (42 U.S.C. 4321 et seq.), requires consideration of the environmental impacts of potential alternatives to renewing a plant's operating license. Although the ultimate decision on which alternative (or the proposed action) to carry out falls to operator, State, or other non-NRC Federal officials, comparing the impacts of renewing the operating license to the environmental impacts of alternatives allows the NRC to determine whether the environmental impacts of license renewal are so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable (Title 10 of the *Code of Federal Regulations* (10 CFR) 51.95(c)(4)).

Energy-planning decisionmakers and owners of the nuclear power plant ultimately decide whether the plant will continue to operate, and economic and environmental considerations play important roles in this decision. In general, the NRC's responsibility is to ensure the safe operation of nuclear power facilities, not to formulate energy policy or encourage or discourage the development of alternative power generation. The NRC does not engage in energy-planning decisions, and it makes no judgment as to which energy alternatives evaluated would be the most likely alternative in any given case.

The remainder of this chapter provides (1) a description of the proposed action, renewal of the operating license for Waterford Steam Electric Station, Unit 3 (WF3), (2) a description of alternatives to the proposed action (including the no-action alternative), and (3) alternatives to the proposed action that the NRC staff considered and eliminated from detailed study. Chapter 4 of this plant-specific supplemental environmental impact statement (SEIS) compares the impacts of renewing the operating license of WF3 and continued plant operations to the environmental impacts of the alternatives.

### 2.1 Proposed Action

As stated in Section 1.1 of this document, the NRC's proposed Federal action is the decision whether to renew the WF3 operating license for an additional 20 years. For the NRC staff to determine the impacts from continued operation of WF3, an understanding of that operation is needed. A description of normal power plant operations during the license renewal term is provided in Section 2.1.1. WF3 is a single-unit, nuclear-powered steam-electric generating facility that began commercial operation in September 1985. The nuclear reactor is a Combustion Engineering pressurized water reactor (PWR) that produces 1,188 megawatts electric (MWe) (Entergy 2016; NRC 2016).

#### 2.1.1 Plant Operations during the License Renewal Term

Most plant operation activities during license renewal would be the same as, or similar to, those occurring during the current license term. Section 2.1.1 of NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS), Volume 1, Revision 1 (NRC 2013), describes the general types of activities that are carried out

## Alternatives Including the Proposed Action

1 during the operation of nuclear power plants, such as WF3. These general types of activities  
2 include the following:

- 3 • reactor operation;
- 4 • waste management;
- 5 • security;
- 6 • office and clerical work;
- 7 • surveillance, monitoring, and maintenance; and
- 8 • refueling and other outages.

9 As stated in Entergy's Environmental Report (ER), WF3 will continue to operate during the  
10 license renewal term in the same manner as it would during the current license term except for,  
11 as appropriate, additional aging management programs to address structure and component  
12 aging in accordance with 10 CFR Part 54.

### 13 **2.1.2 Refurbishment and Other Activities Associated with License Renewal**

14 Refurbishment activities include replacement and repair of major structures, systems, and  
15 components (SSCs). The major refurbishment class of activities characterized in the GEIS is  
16 intended to encompass actions that typically take place only once in the life of a nuclear plant, if  
17 at all (NRC 2013). Examples of these activities include, but are not limited to, replacement of  
18 boiling water reactor recirculation piping and PWR steam generators. These actions may have  
19 an impact on the environment beyond those that occur during normal operations and may  
20 require evaluation, depending on the type of action and the plant-specific design.

21 In preparation for its license renewal application, Entergy performed an evaluation of these  
22 SSCs, in accordance with 10 CFR 54.21, to identify the need to undertake any major  
23 refurbishment activities that would be necessary to support the continued operation of WF3  
24 during the proposed 20-year period of extended operation (Entergy 2016).

25 As a result of its evaluation of SSCs, Entergy did not identify the need to undertake any major  
26 refurbishment or replacement activities associated with license renewal to support the continued  
27 operation of WF3 beyond the end of the existing operating license (Entergy 2016). Therefore,  
28 refurbishment activities are not discussed under the proposed action in Chapter 4.

### 29 **2.1.3 Termination of Nuclear Power Plant Operations and Decommissioning after the** 30 **License Renewal Term**

31 The impacts of decommissioning are described in NUREG-0586, *Generic Environmental*  
32 *Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Volumes 1 and 2,*  
33 *Regarding the Decommissioning of Nuclear Power Reactors* (NRC 2002). The majority of the  
34 activities associated with plant operations would cease with reactor shutdown. Some activities  
35 (e.g., security and oversight of spent nuclear fuel) would remain unchanged, whereas others  
36 (e.g., waste management; office and clerical work; laboratory analysis; and surveillance,  
37 monitoring, and maintenance) would continue at reduced or altered levels. Systems dedicated  
38 to reactor operations would cease operations; however, impacts from the physical presence of  
39 these systems may continue if they are not removed after reactor shutdown. Impacts  
40 associated with dedicated systems that remain in place or with shared systems that continue to  
41 operate at normal capacities would remain unchanged.

1 Decommissioning will occur whether WF3 is shut down at the end of its current operating  
 2 license or at the end of the period of extended operation. There are no site-specific issues  
 3 related to decommissioning. The GEIS concludes that license renewal would have a negligible  
 4 (SMALL) effect on the impacts of terminating operations and decommissioning on all resources  
 5 (NRC 2013).

## 6 **2.2 Alternatives**

7 As stated above, the NRC staff has the obligation to consider reasonable alternatives to the  
 8 proposed action of renewing the license for the nuclear power reactor at WF3. To be  
 9 reasonable, a replacement power alternative must be commercially viable on a utility scale and  
 10 operational before the expiration of the reactor’s operating license or must be expected to  
 11 become commercially viable on a utility scale and operational before the expiration of the  
 12 reactor’s operating license (NRC 2013). The 2013 GEIS update incorporated the latest  
 13 information on replacement power alternatives; however, rapidly evolving technologies are likely  
 14 to outpace the information presented in the GEIS. As such, a site-specific analysis of  
 15 alternatives must be performed for each SEIS, taking into account changes in technology and  
 16 science since the preparation of the GEIS.

17 Section 2.2.1 below describes the no-action alternative (i.e., the NRC takes no action and does  
 18 not issue a renewed license for WF3). Sections 2.2.2.1 through 2.2.2.4 describe the  
 19 characteristics of replacement power alternatives for WF3.

### 20 **2.2.1 No-Action Alternative**

21 At some point, operating nuclear power plants will terminate operations and undergo  
 22 decommissioning. The no-action alternative represents a decision by the NRC not to renew the  
 23 operating license of a nuclear power plant beyond the current operating license term. Under the  
 24 no-action alternative, the NRC does not renew the operating license, and WF3 shuts down at or  
 25 before the end of the current license in 2024. This SEIS describes those impacts that arise  
 26 directly from plant shutdown. Shutdown impacts are expected to be similar whether they occur  
 27 at the end of the current license (i.e., after 40 years of operation) or at the end of a renewed  
 28 license (i.e., after 60 years of operation).

29 After shutdown, plant operators will initiate decommissioning in accordance with 10 CFR 50.82,  
 30 “Termination of License.” Supplement 1 to NUREG–0586 (NRC 2002) describes the  
 31 environmental impacts from decommissioning and related activities. The analysis in  
 32 NUREG–0586 bounds the environmental impacts of decommissioning whenever Entergy  
 33 ceases to operate WF3. Chapter 4 of the GEIS (NRC 2013) and Section 4.15.2 of this SEIS  
 34 describe the incremental environmental impacts of license renewal on decommissioning  
 35 activities.

36 Termination of operations at WF3 would result in the total cessation of electrical power  
 37 production. Unlike the alternatives described below in Section 2.2.2, the no-action alternative  
 38 does not expressly meet the purpose and need of the proposed action, as described in  
 39 Section 1.2, because it does not provide a means of delivering baseload power to meet future  
 40 electric system needs. Assuming that a need currently exists for the power generated by WF3,  
 41 the no-action alternative would likely create a need for a replacement power alternative. The  
 42 following section describes the full range of replacement power alternatives, and Chapter 4  
 43 assesses their potential impacts. Although the NRC’s authority only extends to deciding  
 44 whether to renew the WF3 operating license, the replacement power alternatives described in  
 45 the following sections represent possible options for energy-planning decisionmakers if the NRC  
 46 decides not to renew the WF3 operating license.

1 **2.2.2 Replacement Power Alternatives**

2 In evaluating alternatives to license renewal, the NRC considered energy technologies or  
3 options currently in commercial operation, as well as technologies not currently in commercial  
4 operation but likely to be commercially available by the time the current WF3 operating license  
5 expires on December 18, 2024.

6 The GEIS presents an overview of some energy technologies, but does not reach conclusions  
7 about which alternatives are most appropriate. Because many energy technologies are  
8 continually evolving in capability and cost and because regulatory structures have changed to  
9 either promote or impede development of particular alternatives, the analyses in this chapter  
10 rely on a variety of sources of information to determine which alternatives would be available  
11 and commercially viable. In accordance with the NRC’s regulations at 10 CFR 51.45(b)(3),  
12 Entergy provided a discussion of alternatives that was “sufficiently complete to aid the  
13 Commission in developing and exploring, pursuant to section 102(2)(E) of NEPA, ‘appropriate  
14 alternatives to recommended courses of action in any proposal which involves unresolved  
15 conflicts concerning alternative uses of available resources.’” In addition to the information  
16 provided by Entergy in its ER, the analyses in this chapter may include updated information  
17 from the following sources:

- 18 • U.S. Department of Energy (DOE),  
19 U.S. Energy Information Administration  
20 (EIA);
- 21 • other offices within DOE;
- 22 • U.S. Environmental Protection Agency  
23 (EPA); and
- 24 • industry sources and publications.

25 Alternatives that cannot provide the equivalent of  
26 WF3’s current generating capacity and, in some  
27 cases, those alternatives whose costs or benefits do  
28 not justify inclusion in the range of reasonable  
29 alternatives, were not considered in detail. Further,  
30 alternatives not likely to be constructed and  
31 operational by the time the WF3 license expires were  
32 eliminated from detailed consideration. Each  
33 alternative eliminated is briefly discussed, and the  
34 basis for its elimination is provided in Section 2.3. To  
35 ensure that the alternatives considered in the SEIS  
36 are consistent with State or regional energy policies,  
37 the NRC staff reviewed energy-related statutes,  
38 regulations, and policies within the WF3 region.

39 In total, 17 alternatives to the proposed action were  
40 considered (see text box) and then narrowed to the  
41 4 replacement power alternatives considered in  
42 Sections 2.2.2.1 through 2.2.2.4.

43 The NRC staff evaluates the environmental impacts of these four alternatives and the no-action  
44 alternative in detail in Chapter 4 of this SEIS. The evaluation of each alternative in Chapter 4  
45 considers the environmental impacts across several impact categories: land use and visual

<p><b>Alternatives Evaluated in Depth:</b></p> <ul style="list-style-type: none"><li>• new nuclear</li><li>• supercritical pulverized coal (SCPC)</li><li>• natural gas combined-cycle (NGCC)</li><li>• combination alternative (NGCC, biomass, and demand-side management (DSM))</li></ul> <p><b>Other Alternatives Considered:</b></p> <ul style="list-style-type: none"><li>• solar power</li><li>• wind power</li><li>• biomass</li><li>• DSM</li><li>• hydroelectric power</li><li>• geothermal power</li><li>• wave and ocean energy</li><li>• municipal solid waste</li><li>• petroleum-fired power</li><li>• coal—integrated gasification combined-cycle (IGCC)</li><li>• fuel cells</li><li>• purchased power</li><li>• delayed retirement</li></ul>
---

1 resources, air quality and noise, geologic environment, water resources, ecological resources,  
 2 historic and cultural resources, socioeconomics, human health, environmental justice, and  
 3 waste management. Most site-specific issues (Category 2) have been assigned a significance  
 4 level of SMALL, MODERATE, or LARGE. For ecological resources subject to the Endangered  
 5 Species Act of 1973, as amended (16 U.S.C. 1531 et seq.); and the Magnuson–Stevens  
 6 Fishery Conservation and Management Reauthorization Act of 2006, as amended  
 7 (16 U.S.C. 1801–1884 et seq.); and historic and cultural resources subject to the National  
 8 Historic Preservation Act of 1966, as amended (54 U.S.C. 300101 et seq.), the impact  
 9 significance determination language is specific to the authorizing legislation. The order of  
 10 presentation of the alternatives is not meant to imply increasing or decreasing level of impact,  
 11 nor does it imply that an energy-planning decisionmaker would be more likely to select any  
 12 given alternative.

13 Region of Influence

14 If the NRC does not issue a renewed license, procurement of replacement power for WF3 may  
 15 be necessary. WF3 is owned and operated by Entergy Corporation and provides electricity  
 16 through the Midcontinent Independent System Operator (MISO) to the SERC Reliability  
 17 Corporation (SERC) (formerly the Southeastern Electric Reliability Council). The region served  
 18 by SERC includes all or portions of 16 States in the southeastern and central United States  
 19 (SERC 2016). The SERC region within Louisiana covers approximately two-thirds of the state  
 20 and constitutes the region of influence (ROI) for the NRC’s analysis of WF3 replacement power  
 21 alternatives.

22 In 2015, electric generators in Louisiana had a net summer generating capacity of  
 23 approximately 26,000 megawatts (MW). This capacity included units fueled by natural gas  
 24 (72 percent), coal (11 percent), nuclear power (8 percent), petroleum (4 percent), and biomass  
 25 (2 percent). Lesser amounts associated with several other miscellaneous energy sources  
 26 comprised the balance of generating capacity in the State (EIA 2017a).

27 The electric industry in Louisiana provided approximately 108 million megawatt hours (MWh) of  
 28 electricity in 2015. This electrical production was dominated by natural gas (61 percent),  
 29 nuclear (14 percent), coal (14 percent), petroleum (4 percent), and biomass (3 percent) (EIA  
 30 2015c). Hydroelectric and other miscellaneous energy sources collectively produced the other  
 31 4 percent of the electricity in the State (EIA 2017a).

32 Nationwide, natural gas generation rose from 16 percent of electricity generated in the  
 33 United States in 2000 to 27 percent in 2013. Given known technological and demographic  
 34 trends, the EIA predicts that the natural gas generation will account for 34 percent of electricity  
 35 generated in 2040 (EIA 2015c, 2016a). Electricity generation from renewable energy is  
 36 expected to grow from 13 percent of total generation in 2015 to 24 percent in 2040 (EIA 2016a).  
 37 However, Louisiana does not have a mandatory renewable portfolio standard, and there are  
 38 uncertainties that could affect these forecasts, particularly the implementation of policies aimed  
 39 at reducing greenhouse gas (GHG) emissions, which could have a direct effect on fossil  
 40 fuel-based generation technologies (DSIRE 2016).

41 The remainder of this section describes replacement power alternatives to license renewal  
 42 considered in depth in this SEIS. These include a new nuclear alternative in Section 2.2.2.1; an  
 43 SCPC alternative in Section 2.2.2.2; an NGCC alternative in Section 2.2.2.3; and a combination  
 44 of NGCC, biomass, and demand-side management (DSM) in Section 2.2.2.4. Table 2–1  
 45 summarizes key design characteristics of the alternative replacement power technologies  
 46 evaluated in-depth. The environmental impacts of these alternatives are evaluated  
 47 in Chapter 4.

1  
2

**Table 2–1. Summary and Key Characteristics of Replacement Power Alternatives Considered In-Depth**

	<b>New Nuclear Alternative</b>	<b>SCPC Alternative</b>	<b>NGCC Alternative</b>	<b>Combination Alternative</b>
<b>Summary of Alternative</b>	One 1,200-MWe single-unit nuclear plant	Two 600-MWe units for a total of 1,200 MWe	Two 600-MWe units for a total of 1,200 MWe	600 MWe from NGCC, 160 MWe from biomass, and 440 MWe from DSM energy savings
<b>Location</b>	On previously disturbed land within the Entergy Louisiana, LLC site. The Entergy Louisiana, LLC property could be developed for the new nuclear plant alternative. Transmission lines and some existing infrastructure currently supporting WF3 would be used. (Entergy 2016; INL 2011)	At another existing power plant site within the SERC region of Louisiana. It is assumed that the site would have sufficient previously disturbed land, be located adjacent to a rail line or waterway capable of supporting delivery of coal, and at or near a geologic formation capable of storing carbon emissions (Entergy 2016). Specific new infrastructure and infrastructure upgrades would depend on the selected site location.	On previously disturbed land within the Entergy Louisiana, LLC site. Some infrastructure upgrades may be required; as would construction of a new or upgraded pipeline. Transmission lines and some existing infrastructure currently supporting WF3 would be used. (Entergy 2016; INL 2011)	The NGCC and biomass components would be located on previously disturbed land within the Entergy Louisiana, LLC site. DSM energy savings are assumed to occur within the Entergy Louisiana, LLC service territory. (Entergy 2016).
<b>Cooling System</b>	Closed-cycle with mechanical draft cooling towers. Cooling water withdrawal—28 mgd; consumptive water use—24 mgd (NRC 2014a).	Closed-cycle with mechanical draft cooling towers. Cooling water withdrawal—32 mgd; consumptive water use—24 mgd (NETL 2013).	Closed-cycle with mechanical draft cooling towers. Cooling water withdrawal—8.3 mgd; consumptive water use—6.5 mgd (NETL 2013).	NGCC and biomass would use closed-cycle cooling systems with mechanical draft cooling towers. Collectively, cooling water withdrawal for these units would be 8.2 mgd; consumptive water use would be 5.2 mgd (NREL 2011; NETL 2013). No cooling system requirements would be required for DSM.

	<b>New Nuclear Alternative</b>	<b>SCPC Alternative</b>	<b>NGCC Alternative</b>	<b>Combination Alternative</b>
<b>Land Requirements</b>	Approximately 230 ac (93 ha) for the plant (Entergy 2016; SERI 2008)	Approximately 120 ac (49 ha) for major permanent facilities and up to 31,000 ac (12,500 ha) for coal mining and waste disposal (Entergy 2016; NRC 1996).	Approximately 60 ac (24 ha) would be required for the plant, with up to an additional 85 ac (34 ha) needed for right-of-way to connect with existing natural gas supply lines south of the site (Entergy 2016; NRC 1996).	Approximately 90 ac (36 ha) would be required for the NGCC and biomass plants, with up to an additional 85 ac (34 ha) needed for right-of-way to connect with existing natural gas supply lines south of the site. No changes to land use requirements would be required for DSM.
<b>Work Force</b>	3,500 workers during peak construction; 640 workers during operations (Entergy 2016; Times-Free Press 2015).	2,600 workers during peak construction; 350 workers during operations (Entergy 2016; NRC 1996).	1,650 workers during peak construction; 200 workers during operations (Entergy 2016; NRC 1996).	NGCC and biomass units would collectively require 920 workers during peak construction, and 180 workers during operations. No changes to work force requirements would be associated with DSM (Entergy 2016; NRC 2013).

Key: ac = acres, DSM = demand-side management, ha = hectares, mgd = million gallons per day, MWe = megawatts electric, NGCC = natural gas combined-cycle (alternative), ROI = region of influence, and SCPC = supercritical pulverized coal.

1 **2.2.2.1 New Nuclear Alternative**

2 In this section, the NRC staff describes the new nuclear alternative. The NRC staff evaluates  
 3 the environmental impacts from this alternative in Chapter 4. The NRC staff considered the  
 4 construction of a new nuclear plant to be a reasonable alternative to license renewal. For  
 5 example, nuclear generation currently provides approximately 14 percent of electricity  
 6 generation in Louisiana (EIA 2017a). Two nuclear power plants operate in the ROI, and both  
 7 plants have applied for renewed licenses from the NRC (NRC 2017a). The NRC staff  
 8 determined that there may be sufficient time for Entergy to prepare and submit an application,  
 9 build, and operate a new nuclear unit using a certified design before the WF3 license expires in  
 10 December 2024.

11 In evaluating the new nuclear alternative, the NRC staff assumed that one new nuclear reactor  
 12 would be built on a portion of the approximately 3,600-ac (1,400-ha) Entergy Louisiana, LLC  
 13 property, and would allow for the maximum use of existing ancillary facilities at those locations,  
 14 such as support buildings and transmission infrastructure. The Entergy Louisiana, LLC property

## Alternatives Including the Proposed Action

1 currently encompasses the WF3 nuclear station, as well as Waterford 1, 2, and 4 (fossil fuel  
2 plants). The property was previously the subject of a study by the Idaho National Laboratory,  
3 (INL 2011), which identified four onsite parcels adjacent to WF3 that could potentially serve as  
4 feasible siting locations for another nuclear plant. In its ER, Entergy estimated that  
5 approximately 230 ac (93 ha) of this available land would be required for new reactor  
6 construction of the power block and ancillary facilities (Entergy 2016).

7 For the purposes of this analysis, the NRC staff assumed one Westinghouse AP1000 reactor  
8 with an approximate net electrical output of 1,200 MWe would replace the WF3 reactor for this  
9 alternative. The heat rejection demands of a new nuclear would be similar to those of WF3. In  
10 its ER, Entergy indicated that WF3's existing cooling water intake and discharge structures  
11 could be used after undergoing some modifications (Entergy 2016). However, unlike WF3's  
12 existing once-through cooling system, the new reactor would use a mechanical draft closed-  
13 cycle cooling system.

14 The NRC staff also considered the installation of multiple small modular reactors as an  
15 alternative to renewing the WF3 license. The NRC established the Advanced Reactor Program  
16 in the Office of New Reactors because of considerable interest in small modular reactors along  
17 with anticipated license applications by vendors. Small modular reactors are approximately  
18 300 MW or less, would have lower initial capacity than that of large-scale units, and would have  
19 siting flexibility for locations not large enough to accommodate traditional nuclear reactors  
20 (DOE undated). The first design certification application for a small modular reactor was  
21 submitted to the NRC in December 2016 (NRC 2017b). The DOE has estimated that small  
22 modular reactors may achieve commercial operation by 2021 to 2025 (DOE undated). Because  
23 small modular reactors are not expected to be operational at a commercial scale until near the  
24 time WF3's license expires, it is unlikely that four such reactors (the minimum number of units  
25 required to replace WF3's current output) could be constructed in the ROI; therefore, this  
26 analysis focuses on nuclear generation by larger nuclear units.

### 27 2.2.2.2 *Supercritical Pulverized Coal Alternative*

28 In this section, the NRC describes the supercritical pulverized coal (SCPC) alternative. The  
29 NRC staff evaluates the environmental impacts from this alternative in Chapter 4.

30 In 2015, coal-fired generation accounted for approximately 14 percent of all electricity generated  
31 in Louisiana, a 44 percent decrease from 2000 levels (EIA 2017a). Although coal has  
32 historically been the largest source of electricity in the United States, it is expected to be  
33 surpassed by natural gas generation—and potentially renewable energy generation—by 2040  
34 (EIA 2016a). Nonetheless, coal provides the third-greatest share of electrical power in  
35 Louisiana, and coal-fired plants represent a feasible, commercially available option for providing  
36 electrical generating capacity beyond WF3's current license expiration. Therefore, the NRC  
37 considered supercritical coal-fired generation equipped with carbon capture and storage  
38 technology to be a reasonable alternative to WF3 license renewal.

39 Baseload coal units have proven their reliability and can routinely sustain capacity factors as  
40 high as 85 percent. Among the technologies available, pulverized coal boilers producing  
41 supercritical steam (SCPC boilers) are increasingly common for new coal-fired plants given their  
42 generally high thermal efficiencies and overall reliability. Although SCPC facilities are more  
43 expensive than subcritical coal-fired plants to construct, SCPC facilities consume less fuel per  
44 unit output, reducing environmental impacts. In a supercritical coal-fired power plant, burning  
45 coal heats pressurized water. As the supercritical steam and water mixture moves through  
46 plant pipes to a turbine generator, the pressure drops and the mixture flashes to steam. The  
47 heated steam expands across the turbine stages, which then spin and turn the generator to

1 produce electricity. After passing through the turbine, any remaining steam is condensed back  
2 to water in the plant's condenser.

3 To replace the 1,188 MWe that WF3 generates, the NRC considered two hypothetical SCPC  
4 units, each with a net capacity of 600 MWe. The hypothetical SCPC alternative would be  
5 located at a site other than WF3 because of space constraints. The NRC assumes that the  
6 SCPC site would be located within the SERC region of Louisiana, and that the site would have  
7 sufficient previously disturbed land, be located adjacent to a rail line or waterway capable of  
8 supporting delivery of coal, and at or near a geologic formation capable of storing carbon  
9 emissions (Entergy 2016). Most of the coal consumed in Louisiana is subbituminous coal  
10 shipped by rail from Wyoming, with a limited amount coming by barge from Illinois, Indiana, and  
11 Kentucky (EIA 2016b). Using an existing site (such as an existing power plant site) would  
12 maximize availability of infrastructure and reduce disruption to land and populations. The SCPC  
13 alternative would use similar amounts of water as WF3, and the NRC assumes the cooling  
14 system would use a closed-cycle system with mechanical draft cooling towers (Entergy 2016).

15 Depending on the specific site, construction of onsite visible structures could include the boilers,  
16 exhaust stacks, intake/discharge structures, transmission lines, and an electrical switchyard.  
17 The SCPC alternative would require approximately 120 ac (49 ha) of land for major permanent  
18 facilities, although it is assumed that most of this land would have been previously disturbed  
19 (Entergy 2016). To build the SCPC alternative, site crews would clear the plant site of  
20 vegetation, prepare the site surface, and begin excavation before other crews began actual  
21 construction on the plant and associated infrastructure. Construction materials would be  
22 delivered by rail spur, truck, or barge. In addition, it is estimated that up to 31,000 ac  
23 (12,500 ha) of land could be needed to support coal mining and waste disposal requirements  
24 during the operational life of the plant (Entergy 2016; NRC 1996).

### 25 2.2.2.3 *Natural Gas Combined-Cycle Alternative*

26 In this section, the NRC staff describes the NGCC alternative. The NRC staff evaluates the  
27 environmental impacts from this alternative in Chapter 4.

28 Baseload NGCC power plants have proven their reliability and can have capacity factors as high  
29 as 87 percent (EIA 2015a). In an NGCC system, electricity is generated using a gas turbine  
30 that burns natural gas. A steam turbine uses the heat from gas turbine exhaust through a heat  
31 recovery steam generator to produce additional electricity. This two-cycle process has a high  
32 rate of efficiency because the NGCC system captures the exhaust heat that otherwise would be  
33 lost and reuses it. Similar to other fossil fuel sources, NGCC power plants are a source of  
34 GHGs, including CO<sub>2</sub>. However, an NGCC power plant produces significantly fewer GHGs per  
35 unit of electrical output than conventional coal-powered plants (NRC 2013).

36 As discussed in Section 2.2.2, natural gas represents approximately 72 percent of the installed  
37 generation capacity and 61 percent of the electrical power generated in Louisiana (EIA 2017a).  
38 The NRC staff considers the construction of an NGCC power plant to be a reasonable  
39 alternative to license renewal because it is a feasible, commercially available option for  
40 providing baseload electrical-generating capacity beyond the expiration of WF3's current  
41 license.

42 For this alternative, the NRC staff assumes two NGCC units, each with a net capacity of  
43 600 MWe, which collectively would replace 1,200 MWe of WF3's generation capacity. Each  
44 plant configuration would consist of two combustion turbine generators, two heat recovery  
45 steam generators, and one steam turbine generator with mechanical draft cooling towers for  
46 heat rejection. The power plant is assumed to incorporate a selective catalytic reduction system  
47 to minimize the plant's nitrogen oxide emissions (NETL 2007). This 1,200-MWe NGCC plant

## Alternatives Including the Proposed Action

1 would consume approximately 54 billion cubic feet (1,530 million cubic meters) of natural gas  
2 annually (EIA 2013c). Natural gas would be extracted from the ground through wells and then  
3 treated to remove impurities and blended to meet pipeline gas standards before being piped  
4 through the State's pipeline system to the plant site. This NGCC alternative would produce  
5 waste, primarily in the form of spent catalysts used for control of nitrogen oxide emissions.

6 Similar to the new nuclear alternative (Section 2.2.2.1), the NRC staff assumes that the NGCC  
7 replacement power facility would be built on a portion of the approximately 3,600-ac (1,400-ha)  
8 Entergy Louisiana, LLC property, and would allow for the maximum use of existing ancillary  
9 facilities at those locations, such as support buildings and transmission infrastructure.

10 Approximately 60 ac (24 ha) of previously disturbed land would be used to construct and  
11 operate the NGCC plant (Entergy 2016). Depending on the specific site location and proximity  
12 of existing natural gas pipelines, the NGCC alternative may also require up to 85 ac (34 ha) of  
13 land for right-of-way to connect with existing natural gas supply lines south of the site. Because  
14 of the abundant gas supply available in the area, no new gas or collection wells would be  
15 needed to support operation of the plant (Entergy 2016).

16 The NRC staff assumes that the NGCC plant would use a closed-cycle cooling system with  
17 mechanical draft cooling towers. To support the cooling needs of the proposed NGCC plant,  
18 this system would withdraw approximately 8.3 million gallons per day (mgd) (32,000 cubic  
19 meters per day (m<sup>3</sup>/d)) of water and consume 6.5 mgd (24,000 m<sup>3</sup>/d) (NETL 2013). Because  
20 the overall thermal efficiency of this type of plant is high, an NGCC alternative would require  
21 less cooling water than WF3 requires. Onsite visible structures could include the cooling  
22 towers, exhaust stacks, intake and discharge structures, transmission lines, natural gas  
23 pipelines, and an electrical switchyard. Construction materials could be delivered by a  
24 combination of rail spur; truck; and barge.

### 25 2.2.2.4 *Combination Alternative (NGCC, Biomass, and DSM)*

26 In this section, the NRC staff describes an alternative to the continued operation of WF3 that  
27 considers a combination of replacement power technologies operating in conjunction with  
28 energy efficiency measures. The NRC staff evaluates the environmental impacts from this  
29 alternative in Chapter 4.

30 For the purpose of this evaluation, the NRC staff assumes that this combination alternative  
31 would be composed of approximately 600 MWe from an NGCC facility, 160 MWe from  
32 biomass-fired units, and 440 MWe of energy savings from energy efficiency and DSM initiatives  
33 within the ROI. The NRC staff assumes that both the NGCC and biomass-fired portions of this  
34 alternative would be located on previously disturbed land within Entergy Louisiana, LLC  
35 property, and it would use existing available site infrastructure to the extent practicable.

#### 36 NGCC Portion of Combination Alternative

37 To produce its required share of power, the NGCC portion, operating at an expected capacity  
38 factor of 87 percent (EIA 2015a), would need to have a collective nameplate rating of  
39 approximately 690 MWe.

40 For the combination alternative, the NRC staff assumed that a new NGCC plant of the type  
41 considered in Section 2.2.2.3 would be constructed and operated with a total net capacity of  
42 600 MWe. The appearance of an NGCC plant would be similar to that of the full NGCC  
43 alternative, although only one unit would be constructed.

44 Approximately 30 ac (12 ha) of land would be required to construct and operate the NGCC plant  
45 (Entergy 2016). Depending on the specific site location and proximity of existing natural gas  
46 pipelines, the NGCC alternative may also require up to 85 ac (34 ha) of land for right-of-way to

1 connect with existing natural gas supply lines south of the site. Because of the abundant gas  
 2 supply available in the area, no new gas or collection wells would be needed to support  
 3 operation of the plant (Entergy 2016).

4 The NRC staff assumes that the NGCC plant would use a closed-cycle cooling system with  
 5 mechanical draft cooling towers. To support the cooling needs of the proposed NGCC plant,  
 6 this system would withdraw approximately 4.2 mgd (16,000 m<sup>3</sup>/d) of water and consume  
 7 3.2 mgd (12,000 m<sup>3</sup>/d) (NETL 2013).

8 Biomass Portion of Combination Alternative

9 The 160-MWe biomass-fired portion of the combination alternative would be generated using  
 10 four 40-MWe facilities. Assuming a capacity factor of 83 percent (EIA 2015a), these biomass  
 11 facilities would need a collective nameplate rating of approximately 192 MWe.

12 Biomass fuels are abundant in Louisiana. From 2005 to 2015, Louisiana and other southern  
 13 states with ample forest resources led U.S. growth in biomass electricity generation  
 14 (EIA 2016c). Electricity generated using biomass fuels, particularly wood and wood wastes,  
 15 accounts for more than two-thirds of the state's renewable energy production (EIA 2017b).  
 16 Other resources used for biomass-fired generation could include agricultural residues, animal  
 17 manure, residues from food and paper industries, municipal green wastes, dedicated energy  
 18 crops, and methane from landfills (IEA 2007). With a 2015 installed capacity of nearly  
 19 500 MWe, biomass-fired facilities are the primary renewable energy source in operation in  
 20 Louisiana (EIA 2017a).

21 Collectively, a total of approximately 60 ac (24 ha) of land would be required to construct and  
 22 operate the four biomass plants (Entergy 2016; NRC 2014). Fuel feedstock for the biomass  
 23 plants would include energy crops, forest and crop residue, wood waste, and municipal solid  
 24 waste. It is assumed that land use impacts associated with the production of this feedstock  
 25 would be the same regardless of whether the feedstock is used for electricity generation,  
 26 although additional land could be required for storing, loading, and transporting these materials.

27 The NRC staff assumes that the biomass plants would use a closed-cycle cooling system with  
 28 mechanical draft cooling towers. Total cooling needs of the four proposed plants would  
 29 withdraw approximately 4.0 mgd (15,000 m<sup>3</sup>/d) of water and consume 2.0 mgd (7,500 m<sup>3</sup>/d)  
 30 (NREL 2011).

31 DSM Portion of Combination Alternative

32 DSM includes programs designed to improve the energy efficiency of facilities and equipment,  
 33 reduce energy demand through behavioral changes (energy conservation), and demand  
 34 response initiatives aimed to lessen customer usage or change energy use patterns during peak  
 35 periods. These programs and initiatives do not require the construction and operation of new  
 36 generating capacity. Although Louisiana does not have a mandatory energy efficiency resource  
 37 standard, DSM programs represent a fundamental component of Entergy's Integrated Resource  
 38 Planning considerations (Entergy 2015IRP; CNEE 2017).

39 For the combination alternative, approximately 440 MWe of the electrical generating capacity  
 40 that WF3 currently provides would have to be replaced by energy efficiency and DSM programs  
 41 deployed across the Entergy Louisiana, LLC service area.

42 A 2015 study of existing and potentially deployable DSM programs across Entergy's residential,  
 43 commercial, and industrial sectors projected that DSM programs could compensate for  
 44 457 MWe of electrical demand by 2025, and as much as 673 MWe by 2034 (Entergy 2015IRP;  
 45 ICF 2015; Entergy 2016). Therefore, the NRC staff determined that replacement of 440 MW of

1 WF3 output through DSM programs to be a reasonable assumption supporting the combination  
2 alternative.

### 3 **2.3 Alternatives Considered but Dismissed**

4 Alternatives to WF3 license renewal that were considered and eliminated from detailed study  
5 are presented in this section. These alternatives were eliminated because of technical,  
6 resource availability, or current commercial or regulatory limitations. Many of these limitations  
7 would continue to exist when the current WF3 license expires.

#### 8 **2.3.1 Solar Power**

9 Solar power, including solar photovoltaic (PV) and concentrating solar power (CSP)  
10 technologies, produce power generated from sunlight. PV components convert sunlight directly  
11 into electricity using solar cells made from silicon or cadmium telluride. CSP uses heat from the  
12 sun to boil water and produce steam to drive a turbine connected to a generator to produce  
13 electricity (NREL 2014). To be considered a viable alternative, a solar alternative must replace  
14 the amount of electricity that WF3 provides. Assuming capacity factors of 25 to 50 percent  
15 (DOE 2011), approximately 2,380 to 4,750 MWe of additional solar energy capacity would need  
16 to be installed in the ROI.

17 Solar generators are considered an intermittent resource because their availability depends on  
18 ambient exposure to the sun, also known as solar insolation (EIA 2017c). Insolation rates of  
19 solar PV resources in Louisiana range from 4.5 to 5.5 kilowatt hours per square meter per day  
20 (kWh/m<sup>2</sup>/day) (NREL 2017). Due to higher solar insolation requirements associated with CSP,  
21 utility-scale application of this technology has only occurred in western States with high solar  
22 thermal resources (California, Arizona, and Nevada) (EIA 2016b).

23 Nationwide, rapid growth in large solar PV facilities (greater than 5 MW) has resulted in an  
24 increase from 70 MW in 2009 to over 9,000 MW fully online at the end of 2015  
25 (Mendelsohn et al. 2012; Bolinger and Seel 2016). However, Louisiana is one of only a few  
26 States having no utility-scale solar generating capacity (EIA 2017c). In 2015, the State's small  
27 amount of solar generation was limited to small-scale solar PV units distributed at customer  
28 sites. Further, Louisiana does not have a mandatory renewable portfolio standard that would  
29 require generators to consider solar power (EIA 2016b). Taking these above factors into  
30 account, the NRC staff concludes that solar power energy facilities would not be a reasonable  
31 alternative to license renewal.

#### 32 **2.3.2 Wind Power**

33 As is the case with other renewable energy sources, the feasibility of wind resources serving as  
34 alternative baseload power is dependent on the location (relative to expected load centers),  
35 value, accessibility, and constancy of the resource. Wind energy must be converted to  
36 electricity at or near the point where it is extracted, and there are limited energy storage  
37 opportunities available to overcome the intermittency and variability of wind resources.

38 To be considered a viable alternative, a wind alternative must replace the amount of electricity  
39 that WF3 provides. Assuming a capacity factor of 35 percent for land based wind and  
40 40 percent for offshore wind, a range of 2,970 to 3,395 MWe of electricity would have to be  
41 generated by some combination of land-based and offshore wind energy facilities in the ROI.

42 The American Wind Energy Association reports a total of more than 84,000 MW of installed  
43 wind energy capacity nationwide as of March 31, 2017 (DOE 2017a). As of March 2017, Texas

1 leads all other States in installed land-based capacity with over 21,000 MW. In contrast,  
 2 Louisiana, which shares its western border with Texas, currently has no installed land-based  
 3 wind power capacity. The EIA indicates that Louisiana has little overall wind potential, and that  
 4 in 2013, the State Legislature repealed State tax credits for the development of future wind  
 5 systems (EIA 2017b).

6 Similarly, Louisiana does not have any utility-scale offshore wind farms in operation. In 2016, a  
 7 30 MW project off the coast of Rhode Island become the first operating offshore wind farm in the  
 8 United States (Energy Daily 2016). Although approximately 20 offshore wind projects  
 9 representing more than 15,000 MW of capacity were in the planning and permitting process as  
 10 of 2015, most of these projects are concentrated along the Nation’s North Atlantic coast, and  
 11 none are currently planned off the shores of Louisiana (EIA 2015b; NREL 2015).

12 Given the amount of wind capacity necessary to replace WF3 and the intermittency of the  
 13 resource, the current lack of any installed wind capacity in the State, and the limited potential for  
 14 any new development in the ROI, the NRC staff finds a wind based alternative—either on shore,  
 15 off shore, or a combination thereof—to be unreasonable.

16 **2.3.3 Biomass Power**

17 As described in Section 2.2.2.4, biomass fuels are abundant in Louisiana. Using biomass-fired  
 18 generation for baseload power depends on the geographic distribution, available quantities,  
 19 constancy of supply, and energy content of biomass resources. For this analysis, the NRC staff  
 20 assumed that biomass would be combusted for power generation in the electricity sector.  
 21 Biomass is also used for space heating in residential and commercial buildings and can be  
 22 converted to a liquid form for use in transportation fuels.

23 In 2015, Louisiana had an installed capacity of approximately 500 MW, and approximately  
 24 3 percent of the State’s total system power was produced from biomass (EIA 2016e;  
 25 EIA 2017a).

26 For utility scale biomass electricity generation, the NRC staff assumes that the technologies  
 27 used for biomass conversion would be similar to fossil fuel plants, including the direct  
 28 combustion of biomass in a boiler to produce steam (NRC 2013). Biomass generation is  
 29 generally more cost effective when co-fired with coal plants (IEA 2007). Biomass-fired  
 30 generation plants generally are small and can reach capacities of 50 MWe, which means that  
 31 more than 20 new facilities would be required to replace the generating capacity of WF3.  
 32 Sufficiently increasing biomass-fired generation capacity by expanding existing biomass plants  
 33 or constructing new biomass plants, by the time WF3’s license expires in 2024, is unlikely. For  
 34 this reason, the NRC staff does not consider using biomass-fired generation alone to be a  
 35 reasonable alternative to WF3 license renewal. However, the NRC staff describes an  
 36 alternative using biomass-fired power in combination with NGCC and DSM measures in Section  
 37 2.2.2.4.

38 **2.3.4 DSM**

39 Energy conservation can include reducing energy demand through behavioral changes or  
 40 altering the shape of the electricity load and usually does not require the addition of new  
 41 generating capacity. Conservation and energy efficiency programs are more broadly referred to  
 42 as DSM.

43 Conservation and energy efficiency programs can be initiated by a utility, transmission  
 44 operators, the State, or other load-serving entities. In general, residential electricity consumers  
 45 have been responsible for the majority of peak load reductions, and participation in most

## Alternatives Including the Proposed Action

1 programs is voluntary. Therefore, the existence of a program does not guarantee that  
2 reductions in electricity demand would occur. The GEIS concludes that, although the energy  
3 conservation or energy efficiency potential in the United States is substantial, there are likely no  
4 cases where an energy efficiency or conservation program has been implemented expressly to  
5 replace or offset a large baseload generation station (NRC 2013). A 2015 study of existing and  
6 potentially deployable DSM programs across Entergy's residential, commercial, and industrial  
7 sectors projected that DSM programs could only compensate for 457 MWe of electrical demand  
8 by 2025 (Entergy 2015IRP; ICF 2015; Entergy 2016). Therefore, although significant energy  
9 savings are possible in the ROI through DSM and energy efficiency programs, conservation and  
10 energy efficiency programs are not sufficient to replace WF3 as a standalone alternative.  
11 However, the NRC staff concludes that, when used in conjunction with other sources of  
12 generating capacity, DSM can provide a potentially viable alternative to license renewal. The  
13 NRC staff describes such a possible combination alternative in Section 2.2.2.4.

### 14 **2.3.5 Hydroelectric Power**

15 Currently, approximately 2,000 hydroelectric facilities operate in the United States.  
16 Hydroelectric technology captures flowing water and directs it to a turbine and generator to  
17 produce electricity (NRC 2013). There are three variants of hydroelectric power:  
18 (1) run-of-the-river (diversion) facilities that redirect the natural flow of a river, stream, or canal  
19 through a hydroelectric facility, (2) store and release facilities that block the flow of the river by  
20 using dams that cause water to accumulate in an upstream reservoir, and (3) pumped storage  
21 facilities that use electricity from other power sources to pump water to higher elevations during  
22 off-peak load periods to be released during peak load periods through the turbines to generate  
23 additional electricity.

24 A comprehensive survey of hydropower resources, completed in 1997, identified Louisiana as  
25 having 200 MWe of hydroelectric capacity when adjusted for environmental, legal, and  
26 institutional constraints (Conner et al. 1998). These constraints could include (1) scenic,  
27 cultural, historical, and geological values, (2) Federal and State land use, and (3) legal  
28 protection issues, such as wild and scenic legislation and threatened or endangered fish and  
29 wildlife legislative protection. A separate DOE assessment of nonpowered dams (dams that do  
30 not produce electricity) concluded that there is potential for 857 MW of electricity in the State  
31 (ORNL 2012). These nonpowered dams serve various purposes, such as providing water  
32 supply to inland navigation. Aside from biomass power, hydroelectric is the only other  
33 significant source of renewable power generation deployed in Louisiana, producing  
34 approximately 1,000,000 MWh of electricity in 2015, or 1 percent of the State's electric power  
35 production (EIA 2017a). Although the EIA projects that hydropower will remain a leading source  
36 of renewable generation in the United States through 2040, there is little expected growth in  
37 hydropower capacity. The potential for future construction of large hydropower facilities has  
38 diminished because of increased public concerns over flooding, habitat alteration and loss, and  
39 destruction of natural river courses (NRC 2013a).

40 Given the projected lack of growth in hydroelectric power production, the competing demands  
41 for water resources, and the expected public opposition to the large environmental impacts and  
42 significant changes in land use that would result from the construction of hydroelectric facilities,  
43 the NRC staff concludes that the expansion of hydroelectric power is not a reasonable  
44 alternative to WF3.

1 **2.3.6 Geothermal Power**

2 Geothermal technologies extract the heat contained in geologic formations to produce steam to  
 3 drive a conventional steam turbine generator. Facilities producing electricity from geothermal  
 4 energy have demonstrated capacity factors of 95 percent or greater, making geothermal energy  
 5 a potential source of baseload electric power. However, the feasibility of geothermal power  
 6 generation to provide baseload power depends on the regional quality and accessibility of  
 7 geothermal resources. Utility-scale geothermal energy generation requires geothermal  
 8 reservoirs with a temperature above 200 °F (93 °C). Utility-scale power plants range from small  
 9 300 kilowatts electric to 50 MWe and greater (TEEIC undated). Geothermal resources are  
 10 concentrated in the western United States. Specifically, these resources are found in Alaska,  
 11 Arizona, California, Colorado, Hawaii, Idaho, Montana, Nevada, New Mexico, Oregon, Utah,  
 12 Washington, and Wyoming. In general, most assessments of geothermal resources have been  
 13 concentrated on these western states (DOE 2013a; USGS 2008). Geothermal resources are  
 14 used in the ROI for heating and cooling purposes, but no electricity is currently being produced  
 15 from geothermal resources in the ROI (EIA 2017d). Given the low resource potential in the ROI,  
 16 the NRC staff does not consider geothermal to be a reasonable alternative to license renewal.

17 **2.3.7 Wave and Ocean Energy**

18 Waves, currents, and tides are often predictable and reliable, making them attractive candidates  
 19 for potential renewable energy generation. Four major technologies may be suitable to harness  
 20 wave energy: (1) terminator devices that range from 500 kilowatts to 2 MW, (2) attenuators,  
 21 (3) point absorbers, and (4) overtopping devices (BOEM undated). Point absorbers and  
 22 attenuators use floating buoys to convert wave motion into mechanical energy, driving a  
 23 generator to produce electricity. Overtopping devices trap a portion of a wave at a higher  
 24 elevation than the sea surface; waves then enter a tube and compress air that is used to drive a  
 25 generator that produces electricity (NRC 2013). Some designs are undergoing demonstration  
 26 testing at commercial scales, but none are currently used to provide baseload power  
 27 (BOEM undated).

28 A 2011 assessment conducted by the Electric Power Research Institute (EPRI) identified Gulf  
 29 Coast Louisiana as having modest potential ocean wave energy resources (EPRI 2011).  
 30 However, the infancy of the technologies and the current lack of commercial application  
 31 supports the NRC staff's conclusion that wave and ocean energy technologies are not  
 32 reasonable alternatives to WF3.

33 **2.3.8 Municipal Solid Waste**

34 Energy recovery from municipal solid waste converts nonrecyclable waste materials into usable  
 35 heat, electricity, or fuel through combustion (EPA 2014b). The three types of combustion  
 36 technologies include mass burning, modular systems, and refuse-derived fuel systems  
 37 (EPA 2014a). Mass burning is the method used most frequently in the United States. The heat  
 38 released from combustion is used to convert water to steam, which is used to drive a turbine  
 39 generator to produce electricity. Ash is collected and taken to a landfill, and particulates are  
 40 captured through a filtering system (EPA 2014a). As of 2016, 77 waste-to-energy plants are in  
 41 operation in 22 States, processing approximately 30 million tons of waste per year. These  
 42 waste-to-energy plants have an aggregate capacity of 2,547 MWe, and although some plants  
 43 have expanded to handle additional waste and to produce more energy, no new plants have  
 44 been built in the United States since 1995 (EPA 2014b; Michaels 2016). The average  
 45 waste-to-energy plant produces about 50 MWe, with some reaching 77 MWe, and can operate  
 46 at capacity factors greater than 90 percent (Michaels 2010). Although Louisiana recognizes

## Alternatives Including the Proposed Action

1 waste-to-energy facilities as a potential renewable energy resource, none of these facilities are  
2 currently planned or are in operation in the State (Michaels 2014). Approximately  
3 24 average-sized plants would be necessary to provide the same level of output as WF3.

4 The decision to burn municipal waste to generate energy is usually driven by the need for an  
5 alternative to landfills rather than energy considerations. Given the improbability that additional  
6 stable supplies of municipal solid waste would be available to support 24 new facilities and  
7 given that no such plants currently operate in the State, the NRC staff does not consider  
8 municipal solid waste combustion to be a reasonable alternative to WF3 license renewal.

### 9 **2.3.9 Petroleum-Fired Power**

10 Petroleum-fired electricity generation accounted for approximately 4 percent of Louisiana's  
11 statewide total in 2015 (EIA 2017a). However, the variable costs and environmental impacts of  
12 petroleum-fired generation tend to be greater than those of natural gas-fired generation. The  
13 historically higher cost of oil has also resulted in a steady decline in its use for electricity  
14 generation, and no growth in capacity using petroleum-fired power plants is forecast through  
15 2040 (EIA 2013a, 2015c). Therefore, the NRC does not consider petroleum-fired generation a  
16 reasonable alternative to WF3 license renewal.

### 17 **2.3.10 Coal—IGCC**

18 IGCC is a technology that generates electricity from coal and combines modern coal gasification  
19 technology with both gas-turbine and steam-turbine power generation. The technology is  
20 cleaner than conventional pulverized coal plants because some of the major pollutants are  
21 removed from the gas stream before combustion. An IGCC power plant consists of coal  
22 gasification and combined-cycle power generation. Coal gasifiers convert coal into a gas  
23 (synthesis gas, also referred to as syngas), which fuels the combined-cycle power generating  
24 units. Nearly 100 percent of the nitrogen from the syngas would be removed before combustion  
25 in the gas turbines and would result in lower nitrogen oxide emissions compared to conventional  
26 coal-fired power plants (DOE 2010).

27 Although several smaller IGCC power plants have been in operation since the mid-1990s, more  
28 recent large-scale projects using this technology have experienced a number of setbacks and  
29 opposition that have hindered IGCC's ability to fully integrate into the energy market. The most  
30 significant roadblock has been IGCC's high capital cost compared to conventional coal-fired  
31 power plants. Cost and schedule overruns have been experienced at both the Duke Energy  
32 Edwardsport Generation Station project in Indiana and the Kemper County IGCC project in  
33 east-central Mississippi, with work toward startup of the gasifier component of the latter plant  
34 ultimately suspended in June 2017 (Energy Daily 2017). Other issues associated with IGCC  
35 include a limited track record for reliable performance and opposition from an environmental  
36 perspective. Based upon these developments, the NRC staff determined that the IGCC  
37 technology would not be a reasonable source of baseload power to replace WF3 by the time its  
38 license expires in 2024.

### 39 **2.3.11 Fuel Cells**

40 Fuel cells oxidize fuels without combustion and its environmental side effects. Fuel cells use a  
41 fuel (e.g., hydrogen) and oxygen to create electricity through an electrochemical process. The  
42 only byproducts (depending on fuel characteristics) are heat, water, and carbon dioxide  
43 (depending on the hydrogen fuel type) (DOE 2013b). Hydrogen fuel can come from a variety of  
44 hydrocarbon resources. Natural gas is a typical hydrogen source.

1 Fuel cells are not economically or technologically competitive with other alternatives for  
 2 electricity generation. EIA estimates that fuel cells may cost \$7,108 per installed kilowatt  
 3 (total overnight capital costs in 2012 dollars), which is high compared to other alternative  
 4 technologies analyzed in this section (EIA 2013b). More importantly, fuel cell units are likely to  
 5 be small in size (approximately 10 MW). The world's largest fuel cell facility is a 59 MWe plant  
 6 that came online in South Korea in 2014 (Entergy 2016; PEI 2017). Replacing the power that  
 7 WF3 provides would be extremely costly. It would require the construction of approximately  
 8 120 average-sized units and modifications to the existing transmission system. Given the  
 9 immature status and high cost of fuel cell technology, the NRC staff does not consider fuel cells  
 10 to be a reasonable alternative to WF3 license renewal.

11 **2.3.12 Purchased Power**

12 It is possible that replacement power may be imported from outside the WF3 ROI. Although this  
 13 would likely have little or no measurable environmental impact in the vicinity of WF3, impacts  
 14 could occur where the power is generated or anywhere along the transmission route, depending  
 15 on the generation technologies used to supply the purchased power (NRC 2013).

16 As discussed in its Integrated Resource Plan (IRP), Entergy controls approximately 10,600 MW  
 17 of generating capacity in Louisiana, either through ownership or long-term purchase power  
 18 contracts (Entergy 2015IRP). However, there are currently no additional merchant generating  
 19 facilities in southeastern Louisiana available to offset the amount of energy needed to replace  
 20 WF3. Further, transmission constraints in Louisiana, Arkansas, and western Mississippi  
 21 historically have limited the ability to import electricity into this region (Entergy 2016).

22 Additionally, purchased power is generally economically adverse because the cost of generated  
 23 power historically has been less than the cost of the same power provided by a third party  
 24 (NRC 2013). Power purchase agreements also have an inherent risk that the contracted power  
 25 will not be delivered. Based on these considerations, the NRC staff determined that purchased  
 26 power would not be a reasonable alternative to WF3 license renewal.

27 **2.3.13 Delayed Retirement**

28 The retirement of a power plant ends its ability to supply electricity. Delaying the retirement of a  
 29 power plant enables it to continue supplying electricity. A delayed retirement alternative would  
 30 consider deferring the retirement of generating facilities within or near the ROI.

31 Because generators are required to adhere to additional regulations that will require significant  
 32 reductions in plant emissions, some power plants may similarly opt for early retirement of older  
 33 units rather than incur the cost for compliance. Additional retirements may be driven by low  
 34 natural gas prices, slow growth in electricity demand, and requirements of the Mercury and Air  
 35 Toxics Standards (EIA 2015c; EPA 2015).

36 Entergy's IRP indicates that its aging fleet has become increasingly susceptible to accelerated  
 37 deactivation as decisions are made regarding the economics associated with individual plants.  
 38 Accordingly, nearly 6,000 MWe of Entergy's older, gas-fired generating units within the ROI are  
 39 assumed to be retired by the end of the current planning horizon in 2034 (Entergy 2016,  
 40 2015IRP). Even if some of these retirements could be delayed through maintenance and  
 41 refurbishments, Entergy anticipates that it would still be necessary to add additional generating  
 42 capacity just to meet projected load growth over this period. Therefore, any system capacity  
 43 retained through delayed retirements would not be available to replace WF3's baseload  
 44 generation. Because of these considerations, the NRC staff determined that delayed retirement  
 45 would not be a reasonable alternative to WF3 license renewal.

1 **2.4 Comparison of Alternatives**

2 In this chapter, the NRC staff considered the following five alternatives to WF3 license renewal:  
3 (1) no-action alternative, (2) new nuclear generation, (3) SCPC generation, (4) NGCC  
4 generation, and (5) a combination of NGCC, biomass generation, and DSM. The impacts for  
5 these alternatives to WF3 license renewal are discussed in Chapter 4 and summarized in  
6 Table 2–2 below.

7 The environmental impacts of the proposed action (issuing a renewed WF3 operating license)  
8 would be SMALL for all impact categories. The environmental impacts from each of the other  
9 alternatives would be larger than the proposed license renewal in at least one resource area, as  
10 indicated in Table 2–2.

11 In conclusion, the environmentally preferred alternative is the granting of a renewed license for  
12 WF3. All other power-generation alternatives capable of meeting the needs currently served by  
13 WF3 entail potentially greater impacts than those of the proposed action of renewing the license  
14 for WF3. To make up the lost power generation if renewed licenses are not issued  
15 (the no-action alternative), one alternative or a combination of alternatives would be  
16 implemented, all of which have impacts to resource areas that are as great as, or greater than,  
17 the proposed action. Hence, the NRC staff concludes that the no-action alternative will have  
18 environmental impacts greater than or equal to those of the proposed license renewal action.

Table 2-2. Summary of Environmental Impacts of the Proposed Action and Alternatives

Impact Area (Resource)	WF3 License Renewal (Proposed Action)	No-Action Alternative	New Nuclear Alternative	SCPC Alternative	NGCC Alternative	Combination Alternative (NGCC, Biomass, and DSM)
Land Use	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL
Visual Resources	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL
Air Quality	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Noise	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Geologic Environment	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Surface Water Resources	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL
Groundwater Resources	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Terrestrial Resources	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Aquatic Resources	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL
Special Status Species & Habitats	SEE NOTE <sup>(a)</sup>	SEE NOTE <sup>(b)</sup>				
Historic and Cultural Resources	SEE NOTE <sup>(c)</sup>	SEE NOTE <sup>(d)</sup>	SEE NOTE <sup>(e)</sup>	SEE NOTE <sup>(f)</sup>	SEE NOTE <sup>(e)</sup>	SEE NOTE <sup>(e)</sup>
Socioeconomics	SMALL	SMALL to MODERATE	SMALL to LARGE	SMALL to LARGE	SMALL to LARGE	SMALL
Transportation	SMALL	SMALL	SMALL to LARGE	SMALL to LARGE	SMALL to LARGE	SMALL to MODERATE
Human Health	SMALL <sup>(g)</sup>	SMALL <sup>(g)</sup>	SMALL <sup>(g)</sup>	SMALL <sup>(g)</sup>	SMALL <sup>(g)</sup>	SMALL <sup>(g)</sup>
Environmental Justice	SEE NOTE <sup>(h)</sup>	SEE NOTE <sup>(i)</sup>				
Waste Management and Pollution Prevention	SMALL <sup>(k)</sup>	SMALL <sup>(k)</sup>	SMALL	MODERATE	SMALL	SMALL

<p><b>WF3 License Renewal (Proposed Action)</b></p> <p><b>Impact Area (Resource)</b></p>	<p><b>No-Action Alternative</b></p>	<p><b>New Nuclear Alternative</b></p>	<p><b>SCPC Alternative</b></p>	<p><b>NGCC Alternative</b></p>	<p><b>Combination Alternative (NGCC, Biomass, and DSM)</b></p>
					<p>(e) The NRC staff concludes that the proposed WF3 license renewal may affect, but is not likely to adversely affect, the pallid sturgeon. The proposed action would have no effect on essential fish habitat.</p> <p>(f) The types and magnitudes of adverse impacts to species listed in the Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.); designated critical habitat; and essential fish habitat would depend on shutdown activities, the proposed site, plant design, and operation, as applicable, and on listed species and habitats present when the alternative is implemented. Therefore, the NRC cannot forecast a particular level of impact for this alternative.</p> <p>(g) Based on (1) the location of NRHP-eligible historic properties within the area of potential effect, (2) tribal input, (3) Entergy’s cultural resource protection plans, (4) the fact that no license renewal-related physical changes or ground-disturbing activities would occur, (5) State Historic Preservation Office input, and (6) cultural resource assessment, license renewal would not adversely affect any known historic properties (36 CFR 800.4(d)(1)).</p> <p>(h) Until the Post-Shutdown Decommissioning Activities Report is submitted, the NRC staff cannot determine whether land disturbance would occur outside the existing operational areas after the nuclear plant is shut down.</p> <p>(i) This alternative would not adversely affect known historic properties.</p> <p>(j) The extent of impact on historic and cultural resources would depend on the resource richness of the land acquired for an SCPC power plant, and would depend on the specific location, plant design, and operational characteristics of the new SCPC power plant. Therefore, it cannot be determined whether this alternative would result in adverse impacts to historic properties.</p> <p>(k) The impacts on human health from chronic effects of electromagnetic fields are categorized as UNCERTAIN.</p> <p>(l) There would be no disproportionately high and adverse impacts to minority and low-income populations.</p> <p>(m) The reduction in tax revenue resulting from the no-action alternative would decrease the availability of public services in St. Charles County. This could disproportionately affect minority and low-income populations that may have become dependent on these services.</p> <p>(n) Based on the analysis of human health and environmental impacts presented in this SEIS, this alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations. However, this determination would depend on the location, plant design, and operational characteristics of the alternative. Therefore, it cannot be determined whether this alternative would result in disproportionately high and adverse human health and environmental effects on minority and low-income populations.</p> <p>(o) The environmental impact of spent fuel storage for the timeframe beyond the licensed life for reactor operations is discussed in NUREG–2157, <i>Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel</i> (NRC 2014).</p>

1 **2.5 References**

2 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic licensing of  
3 production and utilization facilities.”

4 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
5 protection regulations for domestic licensing and related regulatory functions.”

6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for  
7 renewal of operating licenses for nuclear power plants.”

8 [BOEM] Bureau of Ocean Energy Management. Undated. “Ocean Wave Energy.” Available at  
9 <[http://www.boem.gov/Renewable-Energy-Program/Renewable-Energy-Guide/  
10 Ocean-Wave-Energy.aspx](http://www.boem.gov/Renewable-Energy-Program/Renewable-Energy-Guide/Ocean-Wave-Energy.aspx)> (accessed 28 June 2017).

11 Bolinger M, Seel J. 2015. *Utility-Scale Solar 2015–An Empirical Analysis of Project Cost,  
12 Performance, and Pricing Trends in the United States*. LBNL-1006037. Lawrence Berkeley  
13 National Laboratory. August 2016. Available at <[https://emp.lbl.gov/sites/default/files/lbnl-  
14 1006037\\_report.pdf](https://emp.lbl.gov/sites/default/files/lbnl-1006037_report.pdf)> (accessed 30 June 2017).

15 Clean Water Act of 1972, as amended. 33 U.S.C. §1251 et seq.

16 [CNEE] The Center for the New Energy Economy. 2017. Louisiana–Energy Efficiency  
17 Resource Standard. Colorado State University. Available at  
18 <<https://spotforcleanenergy.org/state/louisiana/energy-efficiency-resource-standard/>>  
19 (accessed 22 June 2017).

20 Conner AM, Francfort JE, Rinehart BN. 1998. *U.S. Hydropower Resource Assessment, Final  
21 Report*. Idaho Falls, Idaho. Idaho National Engineering and Environmental Laboratory.  
22 DOE/ID-10430.2. December 1998. Available at  
23 <<http://hydropower.inl.gov/resourceassessment/pdfs/doeid-10430.pdf>> (accessed  
24 30 June 2017).

25 [DOE] U.S. Department of Energy. 2011. *2010 Solar Technologies Market Report*.  
26 November 2011. Available at <<http://www.nrel.gov/docs/fy12osti/51847.pdf>>  
27 (accessed 31 January 2017).

28 [DOE] U.S. Department of Energy. 2010. *Kemper County Integrated Gasification  
29 Combined-Cycle (IGCC) Project, Final Environmental Impact Statement (EIS)*.  
30 Washington, DC: DOE. DOE/EIS-0409, Volume 1. May 2010. 671 p. Available at  
31 <[http://energy.gov/sites/prod/files/nepapub/nepa\\_documents/RedDont/  
32 EIS-0409-FEIS-01-2010.pdf](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EIS-0409-FEIS-01-2010.pdf)> (accessed 5 July 2017).

33 [DOE] U.S. Department of Energy. 2013a. “Geothermal Resource Basics.” August 14, 2013.  
34 Available at <<http://energy.gov/eere/energybasics/articles/geothermal-resource-basics>>  
35 (accessed 30 June 2017).

36 [DOE] U.S. Department of Energy. 2013b. “Fuel Cell Basics.” August 14, 2013. Available at  
37 <<http://energy.gov/eere/energybasics/articles/fuel-cell-basics>> (accessed 6 July 2017).

38 [DOE] U.S. Department of Energy. 2017a. “WINDExchange: U.S. Installed Wind Capacity.”  
39 Available at <[http://www.windpoweringamerica.gov/wind\\_installed\\_capacity.asp](http://www.windpoweringamerica.gov/wind_installed_capacity.asp)>  
40 (accessed 6 July 2017).

## Alternatives Including the Proposed Action

- 1 [DOE] U.S. Department of Energy. 2017b. "WINDEXchange: Louisiana Offshore 90-Meter  
2 Wind Map and Wind Resource Potential." Available at  
3 <[https://apps2.eere.energy.gov/wind/windexchange/pdfs/wind\\_maps/la\\_90m\\_offshore.pdf](https://apps2.eere.energy.gov/wind/windexchange/pdfs/wind_maps/la_90m_offshore.pdf)>  
4 (accessed 6 July 2017).
- 5 [DOE] U.S. Department of Energy. Undated. "Small Modular Nuclear Reactors." Available at  
6 <<http://energy.gov/ne/nuclear-reactor-technologies/small-modular-nuclear-reactors>>  
7 (accessed 28 May 2017).
- 8 [DSIRE] Database of State Incentives for Renewable Energy. 2016. "Louisiana Renewable  
9 Energy Pilot Program." March 24, 2017. Available at  
10 <<http://programs.dsireusa.org/system/program/detail/4596>> (accessed 31 May 2017).
- 11 [EIA] U.S. Energy Information Administration. 2013a. *Annual Energy Outlook 2013 with*  
12 *Projections to 2040*. DOE/EIA 0383 (2013). Washington, DC: EIA. April 26, 2013. 244 p.  
13 Available at <[http://www.eia.gov/forecasts/aeo/pdf/0383\(2013\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2013).pdf)> (accessed 28 August 2016).
- 14 [EIA] U.S. Energy Information Administration. 2013b. "Updated Capital Cost Estimates for  
15 Utility Scale Electricity Generating Plants." April 2013. Available at  
16 <[http://www.eia.gov/forecasts/capitalcost/pdf/updated\\_capcost.pdf](http://www.eia.gov/forecasts/capitalcost/pdf/updated_capcost.pdf)> (accessed 31 March 2017).
- 17 [EIA] U.S. Energy Information Administration. 2013c. U.S. Energy Information Administration—  
18 Frequently Asked Questions. "How much coal, natural gas, or petroleum is used to generate a  
19 kilowatthour of electricity?" Available at <<http://www.eia.gov/tools/faqs/faq.cfm?id=667&t=2>>  
20 (accessed 1 September 2016).
- 21 [EIA] U.S. Energy Information Administration. 2015a. *Levelized Cost and Levelized Avoided*  
22 *Cost of New Generation Resources in the Annual Energy Outlook 2015*. Available at  
23 <[https://www.eia.gov/outlooks/archive/aeo15/pdf/electricity\\_generation\\_2015.pdf](https://www.eia.gov/outlooks/archive/aeo15/pdf/electricity_generation_2015.pdf)>  
24 (accessed 17 July 2016).
- 25 [EIA] U.S. Energy Information Administration. 2015c. *Annual Energy Outlook 2015 with*  
26 *Projections to 2040*. DOE/EIA-0383 (2015). Washington, DC: EIA. April 14, 2015. 154 p.  
27 Available at <[http://www.eia.gov/forecasts/aeo/pdf/0383\(2015\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2015).pdf)> (accessed 5 July 2017).
- 28 [EIA] U.S. Energy Information Administration. 2015e. "Today in Energy—First offshore wind  
29 farm in the United States begins construction." August 14, 2015. Available at  
30 <<http://www.eia.gov/todayinenergy/detail.cfm?id=22512>> (accessed 30 June 2016).
- 31 [EIA] U.S. Energy Information Administration. 2016a. *Annual Energy Outlook 2016 with*  
32 *Projections to 2040*. DOE/EIA-0383 (2016). Washington, DC: EIA. September 15, 2016.  
33 256 p. Available at <[http://www.eia.gov/outlooks/aeo/pdf/0383\(2016\).pdf](http://www.eia.gov/outlooks/aeo/pdf/0383(2016).pdf)>  
34 (accessed 6 January 2017).
- 35 [EIA] U.S. Energy Information Administration. 2016b. *Louisiana State Profile and Energy*  
36 *Estimates—Overview*. January 21, 2016. Available at  
37 <<https://www.eia.gov/state/analysis.php?sid=LA>> (accessed 12 December 2016).
- 38 [EIA] U.S. Energy Information Administration. 2016d. "Today in Energy—California has nearly  
39 half of the nation's solar electricity generating capacity." February 5, 2016. Available at  
40 <<https://www.eia.gov/todayinenergy/detail.php?id=24852#>> (accessed 18 February 2017).
- 41 [EIA] U.S. Energy Information Administration. 2016e. *Electric Power Annual*.  
42 November 21, 2016. Available at <[https://www.eia.gov/electricity/annual/html/epa\\_04\\_07\\_b.html](https://www.eia.gov/electricity/annual/html/epa_04_07_b.html)>  
43 (accessed 6 July 2017).

- 1 [EIA] U.S. Energy Information Administration. 2016c. “Today in Energy—Southern states lead  
2 growth in biomass electricity generation.” May 25, 2016. Available at  
3 <<https://www.eia.gov/todayinenergy/detail.php?id=26392>> (accessed 25 May 2016).
- 4 [EIA] U.S. Energy Information Administration. 2017a. *State Electricity Profiles*.  
5 January 17, 2017. Available at <<https://www.eia.gov/electricity/state/archive/2015/louisiana/>>  
6 (accessed 6 June 2017).
- 7 [EIA] U.S. Energy Information Administration. 2017b. *Louisiana State Profile and Energy*  
8 *Estimates*. January 19, 2017. Available at <<https://www.eia.gov/state/analysis.php?sid=LA>>  
9 (accessed 6 June 2017).
- 10 [EIA] U.S. Energy Information Administration. 2017c. “Today in Energy—Utility-scale solar has  
11 grown rapidly over the past five years. Available at  
12 <<https://www.eia.gov/todayinenergy/detail.php?id=31072>> (accessed 30 June 2017).
- 13 [EIA] U.S. Energy Information Administration. 2017d. *Geothermal Explained—State Rankings*  
14 *for Geothermal Electricity Generation, 2016*. Available at <[https://www.eia.gov/](https://www.eia.gov/energyexplained/index.cfm?page=geothermal_use)  
15 [energyexplained/index.cfm?page=geothermal\\_use](https://www.eia.gov/energyexplained/index.cfm?page=geothermal_use)> (accessed 27 June 2017).
- 16 Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.
- 17 [Energy Daily] IHS The Energy Daily. 2016. “First U.S. Offshore Wind Farm Delivers Power to  
18 Grid.” December 13, 2016. Volume 44, Number 238. Available at  
19 <<http://www.theenergydaily.com>> (accessed 14 December 2016).
- 20 [Energy Daily] IHS The Energy Daily. 2017. “Southern Stops Work on Kemper’s Lignite  
21 Gasification Technology.” June 29, 2017. Volume 45, Number 124. Available at  
22 <<http://www.theenergydaily.com>> (accessed 30 June 2017).
- 23 [Entergy] Entergy Louisiana, LLC. 2015IRP. 2015 Integrated Resource Plan. Available at  
24 <[http://www.entergy-louisiana.com/content/irp/2015\\_0803\\_Louisiana\\_Final\\_IRP\\_Public.pdf](http://www.entergy-louisiana.com/content/irp/2015_0803_Louisiana_Final_IRP_Public.pdf)>  
25 (accessed 22 June 2017).
- 26 [Entergy] Entergy Louisiana, LLC. 2016 Applicant’s Response to Environmental Report—  
27 Operating License Renewal Stage, Waterford Steam Electric Station, Unit 3, March. ADAMS  
28 Accession No. ML16088A326.
- 29 [EPA] U.S. Environmental Protection Agency. 2014a. “Municipal Solid Waste: Basic  
30 Information about Energy Recovery from Waste.” Available at  
31 <<http://www.epa.gov/osw/nonhaz/municipal/wte/basic.htm>> (accessed 28 June 2017).
- 32 [EPA] U.S. Environmental Protection Agency. 2014b. “Municipal Solid Waste: Energy  
33 Recovery from Waste.” Available at <<http://www.epa.gov/osw/nonhaz/municipal/wte/>>  
34 (accessed 28 June 2017).
- 35 [EPA] U.S. Environmental Protection Agency. 2015. “Mercury and Air Toxics Standards.”  
36 Available at <<http://www.epa.gov/mats/>> (accessed 6 July 2017).
- 37 [EPRI] Electric Power Research Institute. 2011. *Mapping and Assessment of the United States*  
38 *Ocean Wave Energy Resource*. Palo Alto, California: EPRI. 1024637. December 2011.  
39 176 p. Available at <<http://www1.eere.energy.gov/water//pdfs/mappingandassessment.pdf>>  
40 (accessed 28 June 2017).
- 41 [ICF] ICF International. 2015. “Long-Term Demand Side Management Potential in the Entergy  
42 Louisiana and Entergy Gulf States Louisiana Service Territories, *Summary Presentation*.  
43 February 24, 2015.” Available at <[http://www.entergy-louisiana.com/content/](http://www.entergy-louisiana.com/content/irp/LA_2015_IRP_ICF_DSM_Potential_Study.pdf)  
44 [irp/LA\\_2015\\_IRP\\_ICF\\_DSM\\_Potential\\_Study.pdf](http://www.entergy-louisiana.com/content/irp/LA_2015_IRP_ICF_DSM_Potential_Study.pdf)>(accessed 22 June 2017).

## Alternatives Including the Proposed Action

- 1 [IEA] International Energy Agency. 2007. "Biomass for Power Generation and CHP." IEA  
2 Energy Technology Essentials ETE03. Available at <[https://www.iea.org/publications/  
3 freepublications/publication/essentials3.pdf](https://www.iea.org/publications/freepublications/publication/essentials3.pdf)> (accessed 14 September 2016).
- 4 [INL] Idaho National Laboratory. 2011. *Next Generation Nuclear Plant Project Evaluation of  
5 Siting an HTGR Co-generation Plant on an Operating Commercial Nuclear Power Plant Site*.  
6 INL/EXT-11-23282, Revision 1. October 2011. Available at  
7 <[http://www.ngnpalliance.org/index.php/resources/download/czo0NzoiL2ltYWdlcy9nZW5lcmFs  
8 X2Z2pbGVzL2lubC0tZXh0LTExLTlzMjgycmV2MS5wZGYiOw](http://www.ngnpalliance.org/index.php/resources/download/czo0NzoiL2ltYWdlcy9nZW5lcmFsX2Z2pbGVzL2lubC0tZXh0LTExLTlzMjgycmV2MS5wZGYiOw)> (accessed 15 June 2016).
- 9 Magnuson–Stevens Fishery Conservation and Management Reauthorization Act of 2006, as  
10 amended. 16 U.S.C. §1801–1884 et seq.
- 11 Mendelsohn M, Lowder T, Canavan B. 2012. *Utility-Scale Concentrating Solar Power and  
12 Photovoltaics Projects: A Technology and Market Overview*. Golden, CO: National Renewable  
13 Energy Laboratory. NREL/TP–6A20–51137. April 2012. 65 p. Available at  
14 <<http://www.nrel.gov/docs/fy12osti/51137.pdf>> (accessed 30 June 2017).
- 15 Michaels T. 2010. *The 2010 ERC Directory of Waste-to-Energy Plants*. Washington, DC:  
16 Energy Recovery Council. November 12, 2010. 32 p. Available at  
17 <[http://www.seas.columbia.edu/earth/wtert/sofos/ERC\\_2010\\_Directory.pdf](http://www.seas.columbia.edu/earth/wtert/sofos/ERC_2010_Directory.pdf)> (accessed  
18 26 June 2017).
- 19 Michaels T. 2014. *The 2014 ERC Directory of Waste-to-Energy Plants*. Washington, DC:  
20 Energy Recovery Council. May 2014. 72 p. Available at <[http://energyrecoverycouncil.org/wp-  
21 content/uploads/2016/01/ERC\\_2014\\_Directory.pdf](http://energyrecoverycouncil.org/wp-content/uploads/2016/01/ERC_2014_Directory.pdf)> (accessed 26 June 2017).
- 22 Michaels T. 2016. *Energy Recovery Council 2016 ERC Directory of Waste-to-Energy Facilities*.  
23 Washington, DC: May 2014. 72 p. Available at <[http://energyrecoverycouncil.org/wp-  
24 content/uploads/2016/06/ERC-2016-directory.pdf](http://energyrecoverycouncil.org/wp-content/uploads/2016/06/ERC-2016-directory.pdf)> (accessed 26 June 2017).
- 25 National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.
- 26 National Historic Preservation Act of 1966, as amended. 54 U.S.C. §300101 et seq.
- 27 [NETL] National Energy Technology Laboratory. 2007. *Natural Gas Combined-Cycle Plant*.  
28 4 p. Available at <[http://www.netl.doe.gov/KMD/cds/disk50/  
29 NGCC%20Plant%20Case\\_FClass\\_051607.pdf](http://www.netl.doe.gov/KMD/cds/disk50/NGCC%20Plant%20Case_FClass_051607.pdf)> (accessed 1 September 2016).
- 30 [NETL] National Energy Technology Laboratory. 2013. *Cost and Performance Baseline for  
31 Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity*. Revision 2a.  
32 DOE/NETL–2010/1397. September 2013. 626 p. Available at <[http://www.netl.doe.gov/  
33 File%20Library/research/energy%20analysis/publications/BitBase\\_FinRep\\_Rev2.pdf](http://www.netl.doe.gov/File%20Library/research/energy%20analysis/publications/BitBase_FinRep_Rev2.pdf)>  
34 (accessed 31 August 2016).
- 35 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement  
36 for License Renewal of Nuclear Plants, Final Report*. Washington, DC: NRC. NUREG–1437,  
37 Volumes 1 and 2. May 1996. 1,204 p. ADAMS Accession Nos. ML040690705  
38 and ML040690738.
- 39 [NRC] U.S. Nuclear Regulatory Commission. 2002. *Final Generic Environmental Impact  
40 Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the  
41 Decommissioning of Nuclear Power Reactors*. NUREG–0586, Volumes 1 and 2.  
42 Washington, DC: NRC. November 2002. 516 p. ADAMS Accession Nos. ML023470327,  
43 ML023500228, and ML023500295.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2013. *Generic Environmental Impact Statement*  
 2 *for License Renewal of Nuclear Plants*. Revision 1. Washington, DC: NRC. NUREG-1437,  
 3 Volumes 1, 2, and 3. June 2013. 1,535 p. ADAMS Accession Nos. ML13106A241,  
 4 ML13106A242, and ML13106A244.
- 5 [NRC] U.S. Nuclear Regulatory Commission. 2014. *Generic Environmental Impact Statement*  
 6 *for License Renewal of Nuclear Plants, Supplement 51, Regarding Callaway Plant, Unit 1. Final*  
 7 *Report*. Washington, DC: NRC. October 2014. 613 p. ADAMS Accession No. ML14289A140.
- 8 [NRC] U.S. Nuclear Regulatory Commission. 2016. *2016–2017 Information Digest*.  
 9 Washington, DC. NUREG-1350, Volume 28. August 2016. ADAMS Accession  
 10 No. ML16243A018.
- 11 [NRC] U.S. Nuclear Regulatory Commission. 2017a. “Status of License Renewal Applications  
 12 and Industry Activities—Applications Currently Under Review.” Available at  
 13 <<https://www.nrc.gov/reactors/operating/licensing/renewal/applications.html>> (accessed  
 14 9 June 2017).
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2017b. *Design Certification Application—NuScale*.  
 16 Available at <<https://www.nrc.gov/reactors/new-reactors/design-cert/nuscale.html>> (accessed  
 17 9 June 2017).
- 18 [NREL] National Renewable Energy Laboratory. 2011. *A Review of Operational Water*  
 19 *Consumption and Withdrawal Factors for Electricity Generating Technologies*. Golden, CO:  
 20 National Renewable Energy Laboratory. NREL/TP-6A20-50900. March. Available at  
 21 <<http://www.nrel.gov/docs/fy11osti/50900.pdf>> (accessed 3 January 2017).
- 22 [NREL] National Renewable Energy Laboratory. 2014. “Concentrating Solar Power Projects in  
 23 the United States.” Available at <[http://www.nrel.gov/csp/solarpaces/by\\_country\\_](http://www.nrel.gov/csp/solarpaces/by_country_detail.cfm/country=US)  
 24 [detail.cfm/country=US](http://www.nrel.gov/csp/solarpaces/by_country_detail.cfm/country=US)> (accessed 24 March 2017).
- 25 [NREL] National Renewable Energy Laboratory. 2015. *2014–2015 Offshore Wind*  
 26 *Technologies Market Report*. NREL/TP-5000-64283. September 2015. Available at  
 27 <<http://www.nrel.gov/docs/fy15osti/64283.pdf>> (accessed 30 June 2017).
- 28 [NREL] National Renewable Energy Laboratory. 2017. “Dynamic Maps, GIS Data, and  
 29 Analysis Tools—Solar Maps.” February 2, 2015. Available at  
 30 <<http://www.nrel.gov/gis/solar.html>> (accessed 7 July 2017).
- 31 [ORNL] Oak Ridge National Laboratory. 2012. *An Assessment of Energy Potential at*  
 32 *Non-Powered Dams in the United States*. Oak Ridge, TN: ORNL. April. Available at  
 33 <[http://www1.eere.energy.gov/water/pdfs/npd\\_report.pdf](http://www1.eere.energy.gov/water/pdfs/npd_report.pdf)> (accessed 30 June 2017).
- 34 [PEI] Power Engineering International. 2017. “South Korea fuel cell plant comes online.”  
 35 Available at <[http://www.powerengineeringint.com/articles/2017/03/south-korea-fuel-cell-chp-](http://www.powerengineeringint.com/articles/2017/03/south-korea-fuel-cell-chp-plant-comes-online.html)  
 36 [plant-comes-online.html](http://www.powerengineeringint.com/articles/2017/03/south-korea-fuel-cell-chp-plant-comes-online.html)> (accessed 28 June 2017).
- 37 [SERC] SERC Reliability Corporation. 2016. SERC 2016 Information Summary Brochure.  
 38 August. Available at <[https://serc1.org/docs/default-source/program-areas/reliability-](https://serc1.org/docs/default-source/program-areas/reliability-assessment/reliability-assessments/2016-information-summary-brochure.pdf?sfvrsn=2)  
 39 [assessment/reliability-assessments/2016-information-summary-brochure.pdf?sfvrsn=2](https://serc1.org/docs/default-source/program-areas/reliability-assessment/reliability-assessments/2016-information-summary-brochure.pdf?sfvrsn=2)>  
 40 (accessed 16 March 2018).
- 41 [SERI] System Energy Resources, Inc. 2008. *Grand Gulf Nuclear Station Unit 3 Combined*  
 42 *License Application, Part 3, Environmental Report*. February 2008. ADAMS Accession  
 43 No. ML080640404.

## Alternatives Including the Proposed Action

- 1 [TEEIC] Tribal Energy and Environmental Information Clearinghouse. Undated. "Utility-Scale  
2 and Direct Use Geothermal Energy Generation." Available at  
3 <<http://teeic.indianaffairs.gov/er/geothermal/restech/scale/index.htm>> (accessed  
4 6 January 2017).
- 5 Times Free Press. 2015. "Regulators Complete Inspections for New TVA Nuclear Unit."  
6 October 17. Available at <[http://www.timesfreepress.com/news/business/  
7 aroundregion/story/2015/oct/17/regulators-complete-inspections-new-tvnuclear/331011/](http://www.timesfreepress.com/news/business/aroundregion/story/2015/oct/17/regulators-complete-inspections-new-tvnuclear/331011/)>  
8 (accessed 15 June 2016).
- 9 [USGS] U.S. Geological Survey. 2008. *Assessment of Moderate- and High-Temperature*  
10 *Geothermal Resources of the United States*. Menlo Park, CA: USGS. Fact Sheet 2008-3082.  
11 4 p. Available at <<http://pubs.usgs.gov/fs/2008/3082/pdf/fs2008-3082.pdf>> (accessed  
12 30 June 2017).

## 3.0 AFFECTED ENVIRONMENT

In this supplemental environmental impact statement (SEIS), the “affected environment” is the environment that currently exists at and around Waterford Steam Electric Station, Unit 3 (WF3). Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here.

### 3.1 Description of Nuclear Power Plant Facility and Operation

#### 3.1.1 External Appearance and Setting

WF3 is a pressurized water reactor (PWR) designed by Combustion Engineering. Entergy Louisiana, LLC, owns approximately 3,560 acres (ac) (1,441 hectares (ha)) where WF3 is collocated with Waterford generating plants 1, 2, and 4. Waterford 1 and 2 are 411 megawatts electric (MWe) oil/gas-fired generating plants, and Waterford 4 is a 33 MWe oil-fired peaking generating plant (Entergy 2016a).


WF3 is located on the west bank of the Mississippi River between Baton Rouge and New Orleans, in the northwestern section of St. Charles Parish, near the communities of Killona and Taft, Louisiana. New Orleans is the largest population center in the region and is about 25 miles (mi) (40 kilometers (km)) east of the plant site. Baton Rouge, approximately 50 mi (80 km) northwest of the site, is the second largest population center. Figure 3–1 shows the site location. The land use near the site is primarily industrial and residential, with agricultural fields and wetlands (Entergy 2016a).

The most prominent feature on the WF3 site is a 249-foot (ft) (76-meters (m)) high domed-roof reactor auxiliary building. The nuclear plant island structure (NPIS) is the principal site structure. The NPIS, a reinforced concrete box structure, provides a common structure and foundation for the reactor building and reactor auxiliary building, which includes the control room, fuel handling building, and component cooling water system (CCWS) structures.



The turbine generator building, water treatment building, condensate polisher building, fire pump house, chiller building, service building, independent spent fuel storage installation (ISFSI), radioactive material storage building, solidification facility, meteorological tower, and the intake and discharge structures are located outside the NPIS.

1

Figure 3–1. 50-mi (80-km) Radius of WF3



(USCB 2014c; USDOT 2014; USGS 2014a)



2

3

Source: Modified from Entergy 2016a

### 1   **3.1.2   Nuclear Reactor Systems**

2   WF3 is a two-loop PWR designed by Combustion Engineering. The plant's operating license  
3   was issued on March 16, 1985, for a reactor core power level less than 3,390 megawatts  
4   thermal (MWt). In March 2002, WF3's operating license was amended to raise the reactor core  
5   power level to 3,441 MWt (ADAMS Accession No. ML020910734). In April 2005, the operating  
6   license was amended again to raise the reactor core power level from 3,441 MWt to 3,716 MWt  
7   (ADAMS Accession No. ML051030082).

8   WF3 fuel is low-enriched uranium dioxide (less than 5 weight percent uranium-235) ceramic  
9   pellets. The pellets are hermetically sealed in pre-pressurized tubes made of Zircaloy™,  
10   ZIRLO™, or Optimized ZIRLO™. Refueling at WF3 is on an 18-month schedule.


### 11   **3.1.3   Cooling and Auxiliary Water Systems**

12   WF3 uses a once-through (open-cycle) circulating water system (CWS) for heat dissipation from  
13   the nuclear steam supply system. Water for the CWS is withdrawn from the Mississippi River.  
14   Heated cooling water from the main condenser along with other comingled effluents from  
15   auxiliary systems is discharged back to the Mississippi River through the discharge structure  
16   and canal on the river shoreline.

17   In PWRs, as used at WF3, water is heated to a high temperature under pressure inside the  
18   reactor. A PWR system uses three heat transfer (exchange) loops in this process. The water  
19   (primary coolant) that is heated in the reactor is first pumped in the primary loop to the steam  
20   generators serving each nuclear unit. Within the steam generators, water in the secondary loop  
21   is converted to steam. The steam is discharged to drive the turbines, and the turbines turn the  
22   generator to produce electricity. The tertiary condenser cooling water loop condenses the  
23   steam exiting the turbines and this condensate is returned to the steam generator. Heated  
24   water in the condenser cooling water loop can either flow to cooling towers where it is cooled by  
25   evaporation to dissipate waste heat or it can be discharged directly to a body of water  
26   (NRC 2013). At WF3, this heated water is returned directly to the Mississippi River.  
27   Figure 3–2 provides a basic schematic diagram of the CWS at WF3. The CWS is a non-safety  
28   related system.

29   Safety-related water systems at WF3 include the CCWS and the auxiliary component cooling  
30   water system (ACCWS). These serve as the ultimate heat sink (UHS) for WF3 utilizing dry and  
31   wet cooling towers.

1 **Figure 3–2. Once-Through Cooling Water System with River Water Source, WF3**



2  
3 Source: Modified from NRC 2013

4 No onsite groundwater is used at the site. Water for potable and sanitary use, fire protection,  
5 and plant demineralized water makeup is supplied by the St. Charles Parish water system,  
6 which also withdraws water from the Mississippi River.

7 **3.1.3.1 River Water Intake and Circulating Water System**

8 The primary function of the CWS is to cool and condense steam entering WF3’s main  
9 condenser and to transport the waste heat back to the environment. The system also serves  
10 the turbine closed cooling water heat exchanger, steam generator blowdown heat exchangers,  
11 and primary water treatment plant (Entergy 2014a). The CWS can also supply makeup water to  
12 the UHS wet cooling tower basins, if needed (Entergy 2014a).

13 Water for the CWS is withdrawn directly from the Mississippi River through the circulating water  
14 intake structure (CWIS). As described below, the CWIS consists of an intake canal, intake  
15 structure, eight trash racks, and eight traveling water screens. This intake and circulating water  
16 infrastructure also includes four 25-percent capacity CWS pumps and three 50-percent capacity  
17 screen wash pumps that are housed in the intake structure building (Entergy 2014a, 2016a).  
18 Each of the four CWS pumps has a design capacity of 250,000 gallons per minute (gpm)  
19 (557 cubic feet per second (cfs) or about 15.7 cubic meters per second (m<sup>3</sup>/s)). The screen  
20 wash pumps each have a capacity of 3,000 gpm (6.7 cfs or 0.19 m<sup>3</sup>/s) (Entergy 2016a, 2016b).

21 The intake structure and canal are located on the west (right descending) bank of the  
22 Mississippi near River Mile (RM) 129.6 (River Kilometer [RKm] 208.6), as shown in Figure 3–3.  
23 Neither the intake structure nor canal are safety-related structures.

24 The intake canal is formed from steel sheet piling driven into the river bottom and extending  
25 162 ft (49.4 m) out from the face of the intake structure. This sheet piling extends to a height of  
26 15 ft (4.6 m) mean sea level (MSL). The canal entrance with the river has dimensions of 36.9 ft  
27 (11.2 m) in length by 34 ft. (10.4 m) (Entergy 2016a). A fixed skimmer wall protects the  
28 entrance of the intake canal from floating debris and to withdraw water from a depth below the  
29 river surface at average low water level condition. The 16 ft (4.9 m) (16 ft) deep skimmer wall  
30 extends to -1 ft (-0.3 m) MSL (NRC 1981). The normal water level elevation of the Mississippi

1 River averages 4.0 ft (1.2 m) MSL. Water velocity through the intake canal entrance is  
2 approximately 1.9 feet per second (fps) (0.6 meters per second (m/s)) at maximum pump  
3 operation (Entergy 2016a).


4 River water entering the intake canal travels toward the intake structure, which is divided into  
5 eight intake bays, as shown in Figure 3–4. Each of the eight intake bays is approximately 11 ft  
6 (3.4 m) wide; a concrete wingwall separates the bays. A second curtain (skimmer) wall extends  
7 vertically from 15 ft (4.6 m) down to -4.0 ft (-1.2 m) MSL across each bay. This device further  
8 serves to reduce the volume of floating debris prior to the trash rack.

9 After the curtain wall, water then passes through the trash racks followed by the travelling water  
10 screens. The trash racks are designed to remove large debris in the incoming water. Each  
11 trash rack consists of a series of 0.5-in. (1.2-cm) by 3.5-in. (8.9-cm) bars spaced on 3-in.  
12 (7.6-cm) centers and oriented at an angle of approximately 10 degrees from vertical  
13 (Entergy 2016a). WF3 personnel clean the trash racks with a track-mounted mechanical trash  
14 rack cleaner once per week unless debris loading requires more frequent cleaning. Cleaning  
15 crews place collected debris including any fish in a dumpster for offsite disposal (Entergy 2016a,  
16 2016b).

17 The traveling water screens are located 19 ft (5.8 m) downstream from the trash racks and 30 ft  
18 (9.1 m) upstream of the CWS pumps. These screens (Figure 3–4) prevent smaller debris (not  
19 previously excluded by the curtain wall or trash racks) from entering the intake bay pump pits  
20 (Entergy 2016a).


1  
2

**Figure 3–3. WF3 Cooling and Auxiliary Water System Facilities and Surface Water Features**



**Legend**

-  Property Boundary
-  WF3 Structure
-  Drainage Ditches




3  
4

Source: Modified from Entergy 2016a

1 During the July 2016 environmental site audit (NRC 2017), NRC staff observed that Entergy had  
 2 replaced all but one set of its through-flow, band-type traveling screens with MultiDisc screens.  
 3 Entergy completed the replacement of the last of its four sets of original traveling screens in  
 4 October 2016 (Entergy 2016b). Entergy undertook the replacement project in an effort to  
 5 minimize condenser biofouling at WF3 (Entergy 2016a, 2016b). The new design incorporates  
 6 perforated sickle-shaped panels composed of polyethylene with 0.37-in. (0.94-cm) diameter  
 7 openings, replacing the vertical steel mesh traveling screens with 90 percent 3/8 in. (0.95-cm)  
 8 and 10 percent 0.25-in. (0.64-cm) openings. The new traveling water screens are oriented  
 9 perpendicular to the walls of the intake bays, in which the sickle-shaped discs capture debris on  
 10 the front face of the screen with the discs rotating about an axis that is perpendicular to the flow  
 11 of river water through the screen. Screen approach flow velocity is approximately 1.0 fps  
 12 (0.3 m/s) (Entergy 2016a, 2016b).

13 **Figure 3–4. WF3 General Configuration of Intake Structure**



14  
 15 Source: Modified from Entergy 2016a

16 The traveling water screens are equipped with a spray-wash system that cleans both the  
 17 ascending and descending sides of the travelling water screens. The spray-wash nozzles  
 18 are designed to operate at 115 gpm (435 liters [L] per minute) at 80 pounds per square inch (psi) of

1 pressure. Each traveling water screen includes a local pressure indicator, a pressure switch  
2 that triggers an alarm due to low screen wash pressure (below 70 psi). Each screen is also  
3 equipped with a sparger to prevent silt or other debris from settling in the spaces between the  
4 rotating screen wash panels and the bottom portions of the traveling water screens  
5 (Entergy 2016a). WF3 personnel normally operate the spray-wash system in manual mode  
6 once per shift, although it can also be set to operate automatically (Entergy 2016a, 2016b).

7 In automatic mode, the traveling water screens are designed to maintain the differential  
8 pressure across the screens below 18 in. (4.6 cm). At 6 in. (15 cm) of differential pressure, the  
9 screen wash system is activated, and the screen operates at slow speed and will remain in  
10 slow-speed operation until a decreasing differential pressure of 3 in. (7.6 cm) is reached. With a  
11 differential water level of 10 in. (25.4 cm), the screens switch to fast speed until a decreasing  
12 differential pressure of 3 in. (7.6 cm) is achieved. Screen washwater, debris, and any impinged  
13 fish are conveyed back to the river via a combined concrete trough system, also referred to as a  
14 fish handling system (Entergy 2016a). The intake structure is not currently equipped with a fish  
15 return system (Entergy 2016b). The concrete trough is not specifically identified as an outfall in  
16 WF3's current Louisiana Pollutant Discharge Elimination System (LPDES) permit (LDEQ 2017).

17 After passing through the traveling water screens, river water enters the intake bay pump pits.  
18 Each CWS water pump takes suction from two intake bays (Figure 3–4). With all four CWS  
19 pumps in operation, WF3 can withdraw a maximum (at design capacity) of 1,000,000 gpm  
20 (2,228 cfs; 62.9 m<sup>3</sup>/s) of water from the Mississippi River (Entergy 2016a, 2016b). This rate is  
21 equivalent to about 1,440 million gallons per day (mgd) (5.5 million cubic meters per day  
22 (m<sup>3</sup>/day)). This volume does not include the water withdrawn by operation of the three screen  
23 (spray) wash pumps, each with a capacity of 3,000 gpm (6.7 cfs; 0.19 m<sup>3</sup>/s), which is returned  
24 directly to the river without passing through WF3.

25 WF3 normally utilizes all four CWS pumps when river temperatures are warm (i.e., late spring to  
26 early fall) as is necessary for efficient condenser operation, but the plant changes to three-pump  
27 operation as river temperatures fall (Entergy 2016b).

28 From the intake structure, a series of piping systems convey water to the plant. The CWS  
29 pumps discharge water first through individual 96-in. (244-cm) steel pressure pipes. These  
30 pipes are routed into two 132-in (335-cm) pipelines, first steel and then concrete, that carry  
31 water over the levee to the condenser intake block. The pipes are equipped with air evacuation  
32 (vacuum breaker) pumps to maintain a siphon at the levee crossing. Water is ultimately  
33 conveyed via additional pipe routings to the main condenser; the piping is tapped along the way  
34 to supply circulating water to the plant auxiliary systems, as previously referenced.  
35 (Entergy 2014a)

36 At present, no chemical treatment of the circulating water is performed at WF3, and no chemical  
37 injection equipment is maintained at the intake structure. This is because the high solids  
38 content of the river water produces a scouring effect in the CWS that prevents biological growth  
39 (Entergy 2016b). However, treated (demineralized) water, rather than river water, is used for  
40 CWS pump sealing and for cooling the CWS pumps and bearings, screen wash pumps, and air  
41 evacuation pumps (Entergy 2014a). Section 3.1.3 of this SEIS presents additional information  
42 on surface water use, based on recorded withdrawals.

#### 43 3.1.3.2 *Circulating Water and Effluent Discharge*

44 As illustrated in Figure 3–2, heat gets rejected to the circulating cooling water that passes  
45 through the plant's main condenser and is then discharged. At full power and operating at the  
46 design flow rate, the temperature rise in the circulating water passing through WF3's main  
47 condenser is 16.4 °F (9.1 °C) above the intake water temperature. Nevertheless, according to

1 Entergy, current plant operating conditions limit the volume of water that passes through the  
2 WF3 main condenser to approximately 888,000 gpm (1,979 cfs; 55.9 m<sup>3</sup>/s). This smaller  
3 volume of water produces a temperature rise of approximately 18.9 °F (10.5 °C) in the  
4 circulating water (Entergy 2016a).

5 Heated circulating water from the condenser travels through the plant circulating return piping  
6 system to the condenser discharge block and then to the transition block. Along this path, other  
7 plant effluents from plant auxiliary systems combine with the return circulating water  
8 (Entergy 2014a, 2016a). At the transition block, this combined effluent flow is collected and  
9 ultimately conveyed through four 108-in. (274-cm)-diameter pipes that pass over the river levee  
10 and on to WF3's discharge structure (Entergy 2014a). The discharge structure is a concrete  
11 seal-well that measures approximately 52 ft by 45 ft (16 m by 14 m). Effluent in the seal well  
12 exits the structure by overflowing a system of weirs. Entergy personnel can adjust the top of the  
13 weir crests based on river level (Entergy 2016a). As shown in Figure 3–3, the discharge  
14 structure is located approximately 600 ft (183 m) downstream of WF3's intake structure on the  
15 Mississippi River. The discharge structure is also WF3's primary LPDES permitted outfall  
16 (Outfall 001).

17 Accounting for the addition of other effluents to the return circulating water, the combined flow  
18 exits the plant at a temperature averaging 18.6 °F (10.3 °C) above the river water intake  
19 temperature. The temperature of the heated water is continuously monitored by computer and  
20 an alarm is triggered in the main control room when the heated water approaches its thermal  
21 limit (118 °F; 47.8 °C) as prescribed in WF3's LPDES permit (Entergy 2016a).

22 From the discharge structure, the combined effluent flows to the discharge canal that opens up  
23 to the river. The sheet-pile-formed discharge canal (Figure 3–3) is roughly funnel-shaped and is  
24 approximately 177 ft (54 m) long. It varies from a width of 81 ft (25 m) along the river shoreline  
25 to 50 ft (15 m) at its mouth. The top of the sheet piling varies from an elevation of 15 ft (4.6 m)  
26 MSL at the head of the canal along the shoreline down to 10 ft (3 m) MSL along the rest of its  
27 length. The canal is concrete-lined to prevent erosion. The base elevation of the discharge  
28 structure and canal is at -5.0 ft (1.5 m) MSL (Entergy 2016a).

29 Operating at the design flow rate, the discharge structure and canal are configured to prevent  
30 recirculation of heated water and to promote rapid mixing of the combined effluent, with a  
31 design discharge velocity of 7 fps (2.1 m/s) to the river at average low-water level  
32 (Entergy 2016a). In addition to temperature, the LPDES permit (LDEQ 2017) issued to Entergy  
33 for WF3 also imposes a number of effluent limits for various chemical constituents.  
34 Section 3.5.1.3 presents additional information on water quality and WF3's LPDES permit.

### 35 3.1.3.3 *Component Cooling Water System*

36 The CCWS serves as the UHS and is designed to remove heat from plant safety-related  
37 essential and other non-essential systems during normal operation, shutdown, or during  
38 emergency shutdown associated with a loss of coolant accident (Entergy 2014a, 2016a). This  
39 closed-loop system consists of two independent cooling trains that is each capable of removing  
40 the heat load incurred from plant systems during both normal operating and accident conditions  
41 (Entergy 2014a). In total, the CCWS includes two component cooling water (CCW) heat  
42 exchangers, three 100-percent capacity pumps (two primary and one backup pump), two dry  
43 cooling towers, one surge tank (baffled), and one chemical addition tank. Each of the CCW  
44 pumps has a rated capacity of 6,800 gpm (15.15 cfs; 0.43 m<sup>3</sup>/s). The system uses  
45 demineralized water, which is buffered with a corrosion inhibitor. The CCWS operates by the  
46 CCW pumps sending water through the dry cooling towers and the tube side of the CCW heat  
47 exchangers, through the plant system components being cooled, and then back to the pumps  
48 (Entergy 2014a, 2016a).

1 3.1.3.4 *Auxiliary Component Cooling Water System*

2 Each CCWS train, as discussed above, is provided with an ACCWS loop (Entergy 2014a). The  
3 ACCWS removes heat, if required, from the CCWS via the CCW heat exchangers and  
4 dissipates it to the atmosphere via wet cooling towers. The ACCWS includes two full-capacity  
5 pumps, two mechanical draft cooling towers (wet type), and two cooling tower basins. Each  
6 basin stores sufficient water to complete a safe shutdown under all accident conditions. Water  
7 in the ACCWS is treated with biocides, caustic soda, a surfactant, and a dispersant as needed  
8 (Entergy 2014a, 2016a).

9 3.1.3.5 *Other Auxiliary Systems*

10 Potable Water System

11 The St. Charles Parish Department of Water Works (municipal water system operator) provides  
12 potable water to the WF3 site through valved and metered connections with the municipal water  
13 mains. The plant's water distribution system then supplies water to various buildings and uses  
14 throughout the site, including for fire protection.

15 The primary water treatment plant clearwell tank acts as a water storage reservoir for potable  
16 water. This tank, which is located inside the protected area of WF3, has a capacity of  
17 12,000 gal (45 m<sup>3</sup>). In turn, clearwell transfer pumps convey water from the clearwell tank for  
18 makeup to the demineralized water system and to the fire water storage tanks, as further  
19 discussed below (Entergy 2014a, 2016a). WF3's site-wide potable water usage averages  
20 3,400 gallons per day (gpd) (12.9 m<sup>3</sup>/d, or about 2.4 gpm) (Entergy 2016a).

21 The source of St. Charles Parish's water supply is the Mississippi River. The parish withdraws  
22 water through two river water intakes, which are located at 4.5 and 9 RM (7.2 and 14.5 Rkm)  
23 downstream of WF3 (Entergy 2016a; NRC 1981). The parish maintains two treatment systems  
24 (east and west banks) which, together, have a total water treatment capacity of 22 mgd  
25 (0.083 million m<sup>3</sup>/day). Total average production demand is approximately 9.1 mgd  
26 (0.034 million m<sup>3</sup>/day) (SCP 2016a). Thus, the parish has substantial available capacity.

27 Demineralized Water System

28 Certain in-plant uses at WF3, including the primary plant and reactor and related cooling and  
29 support systems, require demineralized (treated or ultrapure) water. Entergy produces  
30 demineralized water by processing potable water from St. Charles Parish (Entergy 2016a). As  
31 observed by NRC staff and discussed with Entergy personnel during the environmental site  
32 audit, a vendor-supplied, demineralized water system is used to produce demineralized water.  
33 The unit is located adjacent to the water treatment building; the current demineralizer system  
34 was installed in October 2011. Potable water is filtered through granulated activated carbon to  
35 remove chlorine and chloramines, then passes through a reverse osmosis unit, and then  
36 through electronic deionization units to produce ultrapure water. Final polishing of the treated  
37 water is accomplished through resin skids (Entergy 2016b). Demineralized water is stored in  
38 the following tanks prior to transfer to plant systems: 500,000-gal (1,890-m<sup>3</sup>) demineralized  
39 water storage tank; 260,000-gal (980-m<sup>3</sup>) condensate storage tank; and the 260,000-gal  
40 (980-m<sup>3</sup>) primary water storage tank. The demineralized water system can produce up to  
41 approximately 200 gpm (0.45 cfs; 0.013 m<sup>3</sup>/s) of treated water, which is equivalent to  
42 288,000 gpd (1,090 m<sup>3</sup>/d) (Entergy 2014a, 2016b).

43 Fire Protection Water System

44 Fire protection water mains provide a complete loop around the WF3 plant site. The fire  
45 protection water distribution system consists of underground yard piping serving all plant yard  
46 fire hydrants, sprinkler systems, water spray systems, and interior standpipe systems

1 (Entergy 2016a). Firewater is conveyed via three fire-water pumps housed in the fire pump  
2 house. One pump is electric-driven and the other two are diesel-driven pumps. Each pump has  
3 a rated capacity of 2,000 gpm (4.5 cfs; or 0.13 m<sup>3</sup>/s). The pumps take suction from two,  
4 260,000-gal (980-m<sup>3</sup>) firewater storage tanks. Each storage tank can satisfy the design  
5 fire-protection demand, with the tank, piping, and valve arrangement designed such that the  
6 pumps can take suction from either or both tanks. System pressure is maintained via a 30 gpm  
7 (0.07 cfs; 0.0019 m<sup>3</sup>/s) jockey pump. The firewater storage tanks are normally filled directly  
8 from the potable water distribution system; they can also be filled from the primary water  
9 treatment clearwell tank (Entergy 2014a).

### 10 **3.1.4 Radioactive Waste Management Systems**

11 As part of normal operations, and as a result of equipment repairs and replacements due to  
12 normal maintenance activities, nuclear power plants routinely generate both radioactive and  
13 nonradioactive wastes. Nonradioactive wastes include hazardous and nonhazardous wastes.  
14 There is also a class of waste, called mixed waste, which is both radioactive and hazardous.  
15 The systems used to manage (i.e., treat, store, and dispose of) these wastes are described in  
16 this section. Waste minimization and pollution prevention measures commonly employed at  
17 nuclear power plants are also discussed in this section.

18 All nuclear plants were licensed with the expectation that they would release radioactive  
19 material to both the air and water during normal operation. However, NRC regulations require  
20 that gaseous and liquid radioactive releases from nuclear power plants must meet radiation  
21 dose-based limits specified in Title 10 of the *Code of Federal Regulations* (10 CFR) Part 20, and  
22 the as low as is reasonably achievable (ALARA) criteria in Appendix I to 10 CFR Part 50.  
23 Regulatory limits are placed on the radiation dose that members of the public can receive from  
24 radioactive effluents released by a nuclear power plant. All nuclear power plants use  
25 radioactive waste management systems to control and monitor radioactive wastes.

26 WF3 uses liquid, gaseous, and solid waste processing systems to collect and process, as  
27 needed, radioactive materials produced as a by-product of plant operations. The liquid and  
28 gaseous radioactive effluents are processed to reduce the levels of radioactive material prior to  
29 discharge into the environment. This is to ensure that the dose to members of the public from  
30 radioactive effluents is reduced to levels that are ALARA in accordance with NRC's regulations.  
31 The radioactive material removed from the effluents is converted into a solid form for eventual  
32 disposal at a licensed radioactive disposal facility.

33 Entergy has a radiological environmental monitoring program (REMP) to assess the radiological  
34 impact, if any, to the public and the environment from radioactive effluents released during  
35 operations at WF3. The REMP measures the aquatic, terrestrial, and atmospheric environment  
36 for radioactivity, as well as the ambient radiation. In addition, the REMP measures background  
37 radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive material,  
38 including radon) (Entergy 2016c).

39 WF3 has an Offsite Dose Calculation Manual (ODCM) that contains the methods and  
40 parameters used to calculate offsite doses resulting from liquid and gaseous radioactive  
41 effluents. These methods are used to ensure that radioactive material discharges from the plant  
42 meet NRC and U.S. Environmental Protection Agency (EPA) regulatory dose standards. The  
43 ODCM also contains the requirements for the REMP (Entergy 2015a).

#### 44 **3.1.4.1 Radioactive Liquid Waste Management**

45 Radioactive liquid wastes at WF3 are processed by the waste management system (WMS) or  
46 the boron management system (BMS) before discharge. Potentially radioactive liquids are

## Affected Environment

1 processed by the chemical and volume control system (CVCS), fuel pool system, and the steam  
2 generator blowdown system before reuse. The contents of turbine building sumps and  
3 detergent wastes are routinely discharged unprocessed due to their very small potential for  
4 radioactive contamination.

5 In the WMS, miscellaneous non-detergent wastes are collected into one of two waste tanks and  
6 processed through a portable demineralization system on a per-batch basis. The  
7 demineralization system contains ion exchange resin and/or other various filtration media to  
8 remove suspended solids, dissolved solids, and radioactivity from the waste stream. If needed  
9 for further treatment, an ion exchanger is provided in the path from the portable demineralizer to  
10 the waste condensate tanks, where the effluent is collected for sampling and analysis before  
11 discharge. If sampling shows that further processing is necessary, the contents of one waste  
12 condensate tank can be recycled back through the system for further treatment, and collected in  
13 the second waste condensate tank.

14 The BMS processes and collects radioactive wastes from various plant systems for recycle or  
15 disposal, with the major contributor being the CVCS. Other input sources consist of valve and  
16 equipment leak-offs, miscellaneous drains, and relief-valve discharges. These wastes are  
17 collected in various storage and holdup tanks, where they can be sent for processing or held for  
18 decay. The chemical and radiological makeup of the various wastes determines what  
19 processing is necessary. These waste streams are normally sent to the boric acid condensate  
20 tanks through a set of preconcentrator filters, preconcentrator ion exchangers, and boric acid  
21 condensate ion exchangers. Prior to recycle or controlled discharge of the treated liquid waste,  
22 it is sampled and analyzed for both chemistry and radioactivity.

23 The filter media and ion exchange resins used in the WMS and the BMS for removing the  
24 radioactivity from the liquid waste streams are sent to the solid waste management system  
25 (SWMS) for packaging, storage, and shipment to an approved offsite disposal location. Any  
26 water recycled back to the reactor coolant system must meet the purity requirements for reactor  
27 coolant. Discharged water must meet the regulatory requirements found in 10 CFR Part 20 and  
28 Appendix I to 10 CFR Part 50. The WMS and the BMS are capable of monitoring radioactive  
29 liquid discharge from the systems to ensure that activity concentrations do not exceed  
30 predetermined limits. If a limit is exceeded, discharge will be automatically terminated.

31 Wastes from the steam generator blowdown system are collected in storage tanks and pumped  
32 into an aboveground concrete holding basin. From there the wastes are transferred to  
33 Waterford 1, 2, and 4 where they are processed and discharged in accordance with the terms of  
34 the Waterford 1, 2, and 4 LPDES Permit No. LA0007439. If radioactivity is detected in these  
35 waste streams, they can be transferred back into the WMS or BMS for processing prior to  
36 discharge (Entergy 2016a).

37 The use of these radioactive waste systems and the procedural requirements in the ODCM  
38 ensure that the dose from radioactive liquid effluents complies with NRC and EPA regulatory  
39 dose standards.

40 Dose estimates for members of the public are calculated based on radioactive liquid effluent  
41 release data and aquatic transport models. Entergy's annual radiological effluent release report  
42 contains a detailed presentation of the radioactive liquid effluents released from WF3 and the  
43 resultant calculated doses. The NRC staff reviewed 5 years of radioactive effluent release data:  
44 2011 through 2015 (Entergy 2012a, 2013a, 2014b, 2015b, 2016d). A 5-year period provides a  
45 data set that covers a broad range of activities that occur at a nuclear power plant such as  
46 refueling outages, routine operation, and maintenance activities that can affect the generation of  
47 radioactive effluents. The NRC staff compared the data against NRC dose limits and looked for  
48 indication of adverse trends (i.e., increasing dose levels) over the period of 2011 through 2015.

1 The NRC staff's review of WF3's radioactive liquid effluent control program showed that  
2 radiation doses to members of the public were controlled within the NRC's and EPA's radiation  
3 protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR  
4 Part 190. No adverse trends were observed in the dose levels. Routine plant refueling and  
5 maintenance activities currently performed will continue during the license renewal term. Based  
6 on the past performance of the radioactive waste system to maintain doses from radioactive  
7 liquid effluents to be ALARA, similar performance is expected during the license renewal term.  
8 The following summarizes the calculated doses from radioactive liquid effluents released from  
9 WF3 during 2015:

- 10 • The total-body dose to an offsite member of the public from WF3 radioactive liquid  
11 effluents was  $1.07 \times 10^{-3}$  millirem (mrem) ( $1.07 \times 10^{-5}$  millisievert (mSv)), which is well  
12 below the 3 mrem (0.03 mSv) dose criterion in Appendix I to 10 CFR Part 50.
- 13 • The organ dose (gastrointestinal tract) to an offsite member of the public from WF3  
14 radioactive liquid effluents was  $1.25 \times 10^{-3}$  mrem ( $1.25 \times 10^{-5}$  mSv), which is well below  
15 the 10 mrem (0.1 mSv) dose criterion in Appendix I to 10 CFR Part 50.

#### 16 3.1.4.2 Radioactive Gaseous Waste Management

17 Radioactive wastes generated at WF3 are collected and processed through the gaseous waste  
18 management system, the main condenser evacuation system, the turbine gland sealing system,  
19 various building ventilation systems, and atmospheric dump valves depending upon their origin.  
20 The systems are designed to process and control the release of gaseous radioactive wastes so  
21 that the total radiation exposure to members of the public complies with 10 CFR Part 20,  
22 10 CFR Part 50, Appendix I, and 40 CFR Part 190.

23 The gaseous waste management system handles hydrogenated, radioactive, or potentially  
24 radioactive gases from the vent gas collection header, the containment vent header, and the  
25 gas surge header. They are typically generated by reactor coolant degassing operations, the  
26 processing of radioactive liquid wastes, and various tank gas purgings. The vent gas collection  
27 header collects gases from the process equipment vents in the WMS, BMS, CVCS, and the fuel  
28 pool system. Due to their large volume and low radioactivity, these waste gases are routed  
29 directly to the plant stack, which is continuously monitored and will alarm if an abnormal  
30 radioactivity release is detected. Waste gases from the gas surge header, which include those  
31 from the containment vent header, are collected into a gas surge tank. These waste gases  
32 remain in the gas surge tank until there is enough pressure to operate a waste gas compressor  
33 to feed it into a preselected gas decay tank. Once in the gas decay tank, the waste gases are  
34 analyzed for oxygen, hydrogen, and radioactivity levels before being released through the  
35 procedural requirements via a batch release permit.

36 The main condenser evacuation system consists of three condenser vacuum pump assemblies.  
37 These vacuum pump assemblies pump non-condensable gases and water vapor from each  
38 shell of the condenser to the separator, where the non-condensable gases are released directly  
39 to the atmosphere through a discharge silencer and the water vapor is condensed to water and  
40 sent back through the condenser. The condensed water can also be fed to the industrial waste  
41 sump if necessary, and is monitored for radioactivity at the industrial waste discharge header. If  
42 a high-radiation signal is detected by the radiation monitor, discharge to the industrial waste  
43 sump will be stopped, and the water will be analyzed to determine where it should be routed to  
44 for proper treatment.

45 The turbine gland sealing system controls the steam pressure to the turbine glands and consists  
46 of individually controlled diaphragm-operated valves, relief valves, and a gland steam  
47 condenser. At startup, either main steam or auxiliary steam is used as the sealing source until

## Affected Environment

1 sufficient pressure has been established in the steam generator, at which time the auxiliary  
2 steam source valve is closed and main steam provides sealing. As the turbine load is  
3 increased, the steam pressure inside the high-pressure turbine increases, which eliminates the  
4 need to supply sealing steam to these glands. Any steam or air leakage from the glands are  
5 routed to the gland steam condenser, which feeds those wastes to the main condenser as  
6 condensate. The gland steam condenser is continuously monitored for radioactivity and, when  
7 detected, the waste gases are automatically routed to the plant vent instead of the normal path  
8 of direct atmospheric discharge.

9 The building ventilation systems at WF3 are designed to exhaust radioactive and nonradioactive  
10 waste gases in the reactor building, the reactor auxiliary building, the fuel handling building, and  
11 the turbine building.

12 The reactor building has an airborne radioactivity removal system, a containment atmosphere  
13 purge system, and a containment atmosphere release system (CARS) to handle radioactive  
14 gaseous wastes. The airborne radioactivity removal system consists of two airborne  
15 radioactivity removal units, each consisting of a medium-efficiency filter, high-efficiency  
16 particulate air (HEPA) prefilter, charcoal adsorber, and centrifugal fan. The airborne  
17 radioactivity removal units handle airborne radioactivity leaking from the reactor coolant system  
18 during normal operation, and their operation depends on the concentration of particulate and  
19 gaseous radioactivity in the closed containment atmosphere as measured by radiation monitors.  
20 Airborne radioactivity removal units are manually started and stopped from the main control  
21 room and the system is shut down automatically when the reactor coolant pump deluge system  
22 is actuated. The containment atmosphere purge system consists of a containment purge air  
23 makeup unit and a containment purge exhaust, which is connected to the exhaust portion of the  
24 reactor auxiliary building normal ventilation system. Area radiation monitors and airborne  
25 radiation monitors located inside the containment and at the plant stack will generate a  
26 containment purge isolation signal upon detection of radioactivity above their setpoint. This  
27 prevents release of containment air that contains an unacceptable level of radioactivity. The  
28 purge isolation valves are permitted to open when the radioactivity being monitored falls to an  
29 acceptable level, which is controlled by the airborne radioactivity removal system. The CARS is  
30 used if a loss-of-coolant accident (LOCA) occurs and consists of two redundant exhaust fans,  
31 their associated ductwork, and two redundant supply fans. When post-LOCA containment  
32 pressure has reduced sufficiently, the CARS handles combustible gases from inside  
33 containment, which are filtered to remove radioactive particulates and iodines before being  
34 released. The CARS supply ductwork includes a check valve in the discharge piping to prevent  
35 backflow from the containment.

36 The reactor auxiliary building ventilation supply system includes an outside air louver, a medium  
37 efficiency bag type filter, an electric heating coil, two fans, gravity discharge dampers, and a  
38 chilled water cooling coil. The flow of air throughout the reactor auxiliary building is from areas  
39 of low potential radioactivity to areas of progressively higher potential radioactivity. Air is  
40 exhausted from the reactor auxiliary building through a ventilation exhaust system that consists  
41 of a medium-efficiency prefilter, a HEPA filter, a charcoal adsorber, fan inlet vane dampers, two  
42 fans, and discharge dampers to prevent air recirculation. The system employs various air flow  
43 monitors that alarm in the control room if any pressures are below their designated flow rates.  
44 The ventilation exhaust system discharges to the plant stack.

45 In the fuel handling building, during normal operations, air is distributed by an air handling unit  
46 and is then exhausted from the building by normal exhaust fans. The air handling unit consists  
47 of a bank of medium-efficiency filters, an electric heating coil, and a fan. The ductwork is  
48 designed to assure that airflow is directed from areas of low potential radioactivity to areas of  
49 progressively higher potential radioactivity. The exhaust fans are interlocked with the air

1 handling unit so that they cannot function unless the air handling unit is operating. The exhaust  
2 fans each employ a gravity damper to prevent air recirculation if one is non-operational. In case  
3 of emergency, air is exhausted through the emergency filtration exhaust units. Each unit is  
4 redundant and includes an electric heating coil, a bank of medium-efficiency filters, a bank of  
5 HEPA prefilters, a charcoal adsorber, a bank of HEPA after-filters, and an exhaust fan. The  
6 emergency filtration units maintain the spent fuel handling area at a negative pressure relative  
7 to the outdoors.

8 The turbine building main ventilation system is a single-pass ventilation system that consists of  
9 ventilation air intake louvers and dampers, supply fans, exhaust fans, and exhaust louvers and  
10 dampers distributed about the periphery of the building on both the ground floor and the  
11 mezzanine floor. The turbine building switchgear room is separately ventilated from the turbine  
12 building main ventilation system. The turbine building switchgear room is ventilated by two air  
13 handling units, which each contain a medium-efficiency filter and fan. All filters are provided  
14 with local indication of pressure drop, and all fans are manually controlled by local switches  
15 mounted on a central heating, ventilation, and air conditioning control panel in the turbine  
16 building.

17 The atmospheric dump valves release steam from valve operation inside the plant. This source  
18 is considered radiologically negligible and is not monitored (Entergy 2016a).

19 The use of these gaseous radioactive waste systems and the procedural requirements in the  
20 ODCM ensure that the dose from radioactive gaseous effluents complies with the NRC's and  
21 EPA's regulatory dose standards.

22 Dose estimates for members of the public are calculated based on radioactive gaseous effluent  
23 release data and atmospheric transport models. Entergy's annual radioactive effluent release  
24 report contains a detailed presentation of the radioactive gaseous effluents released from WF3  
25 and the resultant calculated doses. The NRC staff reviewed 5 years of radioactive effluent  
26 release data: 2011 through 2015 (Entergy 2012a, 2013a, 2014a, 2015b, 2016d). A 5-year  
27 period provides a data set that covers a broad range of activities that occur at a nuclear power  
28 plant such as refueling outages, nonrefueling outage years, routine operation, and maintenance  
29 activities that can affect the generation of radioactive effluents. The NRC staff compared the  
30 data against NRC dose limits and looked for indication of adverse trends (i.e., increasing dose  
31 levels) over the period of 2011 through 2015. The following summarizes the calculated doses  
32 from radioactive gaseous effluents released from WF3 during 2015:

- 33 • The air dose at the site boundary from gamma radiation in gaseous effluents from  
34 WF3 was  $2.19 \times 10^{-3}$  millirad (mrad) ( $2.19 \times 10^{-5}$  milligray (mGy)), which is well below  
35 the 10 mrad (0.1 mGy) dose criterion in Appendix I to 10 CFR Part 50.
- 36 • The air dose at the site boundary from beta radiation in gaseous effluents from WF3  
37 was  $8.18 \times 10^{-4}$  mrad ( $8.18 \times 10^{-6}$  mGy), which is well below the 20 mrad (0.2 mGy)  
38 dose criterion in Appendix I to 10 CFR Part 50.
- 39 • The dose to an organ (child bone) from radioactive iodine, radioactive particulates,  
40 and carbon 14 from WF3 was 3.91 mrem ( $3.91 \times 10^{-2}$  mSv), which is below the  
41 15 mrem (0.15 mSv) dose criterion in Appendix I to 10 CFR Part 50.

42 The NRC staff's review of WF3's radioactive gaseous effluent control program showed that  
43 radiation doses to members of the public were controlled within the NRC's and EPA's radiation  
44 protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and  
45 40 CFR Part 190. No adverse trends were observed in the dose levels.

## Affected Environment

1 Routine plant refueling and maintenance activities currently performed will continue during the  
2 license renewal term. Based on the past performance of the radioactive waste system to  
3 maintain doses from radioactive gaseous effluents to be ALARA, similar performance is  
4 expected during the license renewal term.

### 5 3.1.4.3 *Radioactive Solid Waste Management*

6 Low-level solid radioactive wastes (LLRW) are processed, packaged, and stored for subsequent  
7 shipment and offsite burial by the SWMS, which is composed of the portable solidification  
8 system and/or dewatering system, the spent resin handling system, filter handling, and the dry  
9 active waste handling system. Solid radioactive wastes and potentially radioactive wastes  
10 include spent ion exchange resin, used filter cartridges, and miscellaneous refuse.

11 The portable solidification or dewatering system consists of solidification media storage, a  
12 fill-head assembly, pump and valve skids, a control panel, and liner shielding, and it provides  
13 WF3 with all of its waste solidification or dewatering requirements. This system is housed in a  
14 weatherproof structure with curbing and a sump that can be pumped to the liquid waste  
15 management system if necessary. These components are situated with appropriate shielding,  
16 remote sampling, necessary separation, and accessibility to reduce leakage and facilitate  
17 maintenance and operation.

18 The spent resin transfer system consists of a spent resin tank, a spent resin transfer pump, a  
19 spent resin dewatering pump, two spent resin strainers, all associated valves, piping, and  
20 controls, and it is used to collect and store spent radioactive ion exchanger resin and to transfer  
21 those resins to the portable solidification and/or dewatering system. When resin transfer is  
22 completed, the system may be flushed to remove residual resin from the piping system.

23 Radioactive filter handling is accomplished by a remote handling processes. Radioactive filters  
24 can be replaced using a bottom-loading filter transfer shield that facilitates transfer to a storage  
25 container by use of an overhead crane. The container is either stored on site or buried at an  
26 offsite licensed burial site.

27 Dry active waste handling consists of collecting bulk dry waste material, such as contaminated  
28 clothing, rags, paper, low activity filters, activated charcoal and HEPA filters from plant  
29 ventilation systems, and miscellaneous contaminated material generated by maintenance and  
30 operations of the facility. The dry active waste is placed in storage containers as it is generated.  
31 It is surveyed for radiation and monitored for materials that could cause spontaneous  
32 combustion or other chemical reactions. Volume reduction is handled by an onsite box  
33 compactor or an offsite licensed volume reduction facility (Entergy 2016a).

34 WF3 sends its LLRW to two licensed LLRW disposal sites: EnergySolutions in Clive, Utah, and  
35 Oak Ridge, Tennessee, and Waste Control Specialists in Andrews, Texas.

36 In 2014, 10 LLW shipments were made from DCCP to two locations: the EnergySolutions Clive  
37 facility in Clive, Utah, and the Waste Control Specialists Andrews facility in Andrews, Texas.  
38 The total volume and radioactivity of LLRW shipped offsite in 2015 was  $7.59 \times 10^{+2}$  cubic  
39 meters ( $m^3$ ) ( $2.68 \times 10^{+4}$  cubic feet ( $ft^3$ ) and  $5.99 \times 10^{+1}$  curies (Ci) ( $2.22 \times 10^{+6}$  megabecquerels  
40 (MBq)), respectively (Entergy 2016d). Routine plant operation, refueling outages, and  
41 maintenance activities that generate radioactive solid waste will continue during the license  
42 renewal term. Radioactive solid waste is expected to be generated and shipped off site for  
43 disposal during the license renewal term.

### 44 3.1.4.4 *Radioactive Waste Storage*

45 Low-level radioactive waste is stored temporarily on site before being shipped off site for  
46 treatment and/or disposal at licensed LLRW treatment and disposal facilities. Entergy indicated

1 in its ER that it also has sufficient capability to store LLRW and that its long-term plans,  
2 including during the license renewal term, do not include the need to construct additional onsite  
3 storage facilities to accommodate generated radwaste (Entergy 2016a).

4 WF3 stores its spent fuel in a spent fuel pool and also in an onsite ISFSI. The ISFSI is used to  
5 safely store spent fuel in licensed and approved dry cask storage containers on site. The  
6 installation and monitoring of this facility is governed by NRC requirements in 10 CFR Part 72,  
7 "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level  
8 Radioactive Waste, and Reactor-Related Greater than Class C Waste." The WF3 ISFSI will  
9 remain in place until the U.S. Department of Energy (DOE) takes possession of the spent fuel  
10 and removes it from the site for permanent disposal or processing (Entergy 2016a).

#### 11 3.1.4.5 *Radiological Environmental Monitoring Program*

12 Entergy conducts a REMP to assess the radiological impact, if any, to the public and the  
13 environment from the operations at WF3.

14 The REMP measures the aquatic, terrestrial, and atmospheric environment for ambient  
15 radiation and radioactivity. Monitoring is conducted for the following: direct radiation, air, water,  
16 groundwater, milk, local agricultural crops, fish, and sediment. The REMP also measures  
17 background radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive  
18 material, including radon).

19 In addition to the REMP, WF3 has an onsite ground water protection program designed to  
20 monitor the onsite plant environment for detection of leaks from plant systems and pipes  
21 containing radioactive liquid (Entergy 2016c). Information on the groundwater protection  
22 program is contained in Section 3.5.2.

23 The NRC staff reviewed 5 years of annual radiological environmental monitoring data: 2011  
24 through 2015 (Entergy 2012b, 2013b, 2014c, 2015c, 2016c). A 5-year period provides a data  
25 set that covers a broad range of activities that occur at a nuclear power plant such as refueling  
26 outages, routine operation, and maintenance activities that can affect the generation and  
27 release of radioactive effluents into the environment. The NRC staff looked for indication of  
28 adverse trends (i.e., buildup of radioactivity levels) over the period of 2011 through 2015.

29 The NRC staff's review of Entergy's data showed no indication of an adverse trend in  
30 radioactivity levels in the environment. The data showed that there was no measurable impact  
31 to the environment from operations at WF3.

#### 32 3.1.5 **Nonradioactive Waste Management Systems**

33 Like any other industrial facility, nuclear power plants generate wastes that are not  
34 contaminated with either radionuclides or hazardous chemicals.

35 WF3 has a nonradioactive waste management program to handle its nonradioactive hazardous  
36 and nonhazardous wastes. The waste is managed in accordance with Entergy's procedures.  
37 WF3 has vendor contracts in place to transfer nonradioactive hazardous and nonhazardous  
38 wastes to licensed offsite treatment and disposal facilities. Listed below is a summary of the  
39 types of waste materials generated and managed at WF3.

- 40 • WF3 is classified as a small quantity hazardous waste generator. The amounts of  
41 hazardous wastes generated are only a small percentage of the total wastes  
42 generated. These wastes consist of paint wastes; spent, off-specification, and  
43 shelf-life expired chemicals; and occasional project-specific wastes (Entergy 2016a).

## Affected Environment

- 1 • WF3's nonhazardous wastes include plant trash and small quantities of medical  
2 wastes generated at an onsite medical clinic. Medical wastes generated at the  
3 onsite clinic are considered a special classification of wastes and are regulated  
4 under Louisiana Administrative Code (LAC) Title 51, Section XXVI (LAC 51:XXVII).
- 5 • Universal wastes include fluorescent lamps, batteries, devices containing mercury,  
6 electronics, and antifreeze. Universal wastes are managed in accordance with  
7 Entergy procedures and LAC 33:V standards. Recycled wastes, such as scrap  
8 metals, used oils, and certain battery types are managed according to Entergy  
9 procedures and Louisiana regulations in LAC 33:VII.

10 Entergy operates an onsite sewage treatment plant. The onsite sewage treatment plant treats  
11 sanitary wastewater from the Energy Education Center (EEC) before being discharged to  
12 40 Arpent Canal under LPDES permit LA0007374. WF3 has an aboveground concrete basin  
13 where nonradioactive wastewaters are transferred from the chiller building sump, the  
14 regenerative waste sump, and the auxiliary boiler sump. Those nonradioactive wastewaters are  
15 pumped to the Waterford 1 and 2 wastewater sump where they are treated and discharged into  
16 the Mississippi River. All other sanitary wastewaters collected from WF3 are discharged to the  
17 St. Charles Parish publicly owned treatment works for appropriate treatment (Entergy 2016a,  
18 2016b).

### 19 **3.1.6 Utility and Transportation Infrastructure**

20 The utility and transportation infrastructure at nuclear power plants typically interfaces with  
21 public infrastructure systems available in the region. Such infrastructure includes utilities, such  
22 as suppliers of electricity, fuel, and water, as well as roads and railroads that provide access to  
23 the site. The following sections briefly describe the existing utility and transportation  
24 infrastructure at WF3.

#### 25 *3.1.6.1 Electricity*

26 Nuclear power plants generate electricity for other users; however, they also use electricity to  
27 operate. Offsite power sources provide power to engineered safety features and emergency  
28 equipment in the event of a malfunction or interruption of power generation at the plant.  
29 Independent backup power sources provide power in the event that power is interrupted from  
30 both the plant itself and offsite power sources. At WF3, two 230-kilovolt (kV) transmission lines  
31 connect to the regional electric grid at the onsite switchyard (Entergy 2016a). These lines  
32 transmit electricity to the grid and supply offsite power to the plant during outages  
33 (Entergy 2016a).

#### 34 *3.1.6.2 Fuel*

35 The WF3 nuclear units are operated using low-enriched uranium dioxide (UO<sub>2</sub>) fuel with  
36 enrichment not exceeding 5 percent by weight of uranium-235 (<sup>235</sup>U). WF3 burns fuel at an  
37 average of rate of 45,000 megawatt-days per metric ton of uranium (MWD/MTU), and refueling  
38 occurs on an 18 month cycle (Entergy 2016a). Fresh (i.e., unirradiated) fuel arrives on site in  
39 shipping containers and is stored in on site fuel storage racks in the fuel handling building prior  
40 to installation in the reactor cores (Entergy 2014a). Entergy stores spent fuel in a spent fuel  
41 pool and an ISFSI.

42 In addition to nuclear fuel, WF3 requires diesel fuel to operate emergency diesel generators.  
43 Entergy stockpiles diesel fuel for the emergency diesel generators in three diesel fuel oil storage  
44 tanks, each with capacities ranging from 42,500 to 100,000 gal (161,000 to 379,000 L)  
45 (Entergy 2016a).

### 1 3.1.6.3 *Water*

2 In addition to cooling and auxiliary water (described in Section 3.1.3), nuclear power plants  
3 require potable water for sanitary and everyday uses by personnel (e.g., drinking, showering,  
4 cleaning, laundry, toilets, and eye washes). At WF3, the St. Charles Parish water system  
5 provides a metered supply of potable water to the site through municipal water main lines. The  
6 WF3 potable water distribution system then supplies water to various buildings throughout the  
7 site. A branch from this system supplies the majority of water demand within the protected  
8 area, including water to the administration building, chiller building, fuel handling building,  
9 polisher building, reactor auxiliary building, service building, and turbine building. The WF3  
10 potable water distribution system also supplies makeup water to the fire-protection water  
11 storage tanks and to the primary water treatment plant clearwell tank (Entergy 2016a).

### 12 3.1.6.4 *Transportation Systems*

13 All nuclear power plants are served by controlled access roads. In addition to roads, many  
14 plants also have railroad connections for moving heavy equipment and other materials. Some  
15 plants that are located on navigable waters, such as the Mississippi River, have facilities to  
16 receive and ship loads on barges.

17 The WF3 site can be accessed from the north via Louisiana State Highway 18 (LA-18) and  
18 Louisiana State Highway 628 (LA-628) and from the south via Louisiana Highway 3127  
19 (LA-3127). To the southwest, Route 3127 serves as the major artery between U.S. Highway 90  
20 in Boutte, Louisiana, and Route 3141 in Killona, Louisiana (Entergy 2014a). Section 3.10.6  
21 describes local transportation systems, including roadway access, in more detail.

22 The Union Pacific Railroad includes an east-west line that runs 0.5 mi (0.8 km) south-southeast  
23 of the WF3 site. A rail spur from the main line extends into the WF3 industrial area  
24 (Entergy 2016a). Additionally, the Illinois Central Gulf, Louisiana, and Arkansas Railroads have  
25 lines that run within 5 mi (8 km) of the WF3 site (Entergy 2014FSAR).

26 The Mississippi River, upon which WF3 is located, is one of the major inland waterway shipping  
27 routes in the United States. Within 5 mi (8 km) of the WF3 site, there are eight docks and  
28 mooring locations, including Entergy's fuel unloading dock at Waterford 1 and 2, approximately  
29 0.5 mi (0.8 km) from the reactor building (Entergy 2014FSAR).

30 Within 10 mi (16 km) of the site, air traffic relies on three private heliports, one private airfield,  
31 and one general aviation airport. The Louis Armstrong New Orleans International Airport, a  
32 full-service commercial airport, lies 13 mi (21 km) east of WF3 (Entergy 2016a).

### 33 3.1.6.5 *Power Transmission Systems*

34 Two 230-kV transmission lines extend from the WF3 switching station to the Waterford 230-kV  
35 switchyard for a distance of approximately 0.6 mi (1 km) and connect WF3 to the regional  
36 electric grid. Additionally, the Waterford 230-kV switchyard includes connections to other  
37 230-kV lines related to Waterford 1, 2, and 4 and a tie to the adjacent 500-kV switchyard  
38 (Entergy 2016a).

39 For license renewal, the NRC evaluates as part of the proposed action the continued operation  
40 of those transmission lines that connect the nuclear power plant to the substation where  
41 electricity is fed into the regional power distribution system and transmission lines that supply  
42 power to the nuclear plant from the grid (NRC 2013). In its ER, Entergy (2016a) states that the  
43 only transmission lines that fit this description are those portions of the two 230-kV lines that  
44 connect WF3 to the onsite switchyard. Accordingly, all of the in-scope portions of the  
45 transmission lines lie within the owner-controlled and industrial-use area of the site.

1 **3.1.7 Nuclear Power Plant Operations and Maintenance**

2 Maintenance activities conducted at WF3 include inspection, testing, and surveillance to  
3 maintain the current licensing basis of the facility and to ensure compliance with environmental  
4 and safety requirements. Various programs and activities are currently in place at WF3 to  
5 maintain, inspect, and monitor the performance of facility structures, components, and systems.  
6 These activities include in-service inspections of safety-related structures, systems, and  
7 components, quality assurance and fire protection programs, and radioactive and  
8 nonradioactive water chemistry monitoring.

9 Additional programs include those implemented to meet technical specification surveillance  
10 requirements and those implemented in response to NRC generic communications and consist  
11 of various periodic maintenance, testing, and inspection procedures necessary to manage the  
12 effects of aging on structures and components. Certain program activities are performed during  
13 the operation of the units, whereas others are performed during scheduled refueling outages.  
14 Reactor refueling occurs on an 18 month cycle (Entergy 2016a).

15 **3.2 Land Use and Visual Resources**

16 **3.2.1 Land Use**

17 *3.2.1.1 Onsite Land Use*

18 WF3 is located on a 3,560-ac (1,440-ha) Entergy-owned property in St. Charles Parish,  
19 Louisiana, that borders the west bank of the Mississippi River. The site lies 25 mi (40 km) west  
20 of New Orleans, Louisiana, and 50 mi (80 km) southeast of Baton Rouge, Louisiana. WF3  
21 shares the property with three other energy-generating units: Waterford 1 and 2, which are  
22 411-MWe oil/gas-fired generating plants, and Waterford 4, which is a 33-MWe oil-fired peaking  
23 generating plant. St. Charles Parish has zoned the Entergy property for industrial use and  
24 regulates it as an M-2 Heavy Manufacturing Zoning District, a designation applicable to  
25 energy-generating facilities. (Entergy 2016a)

26 Wetlands occupy approximately 63 percent or 2,276 ac (921 ha) of the Entergy property.  
27 Approximately 23 percent or 823 ac (333 ha) of the property are in agricultural use. Entergy  
28 leases 660 ac (270 ha) to Raceland Raw Sugar, LLC for growing sugar cane, milo, and  
29 soybeans. The current lease expires November 1, 2017, but it can be extended for an  
30 additional three crop years (Entergy 2016a). Entergy anticipates continuing to lease for  
31 agricultural purposes the 660 ac (270 ha) of land currently in sugar production during the  
32 proposed license renewal term (Entergy 2016b).

33 The WF3 plant area encompasses 40.1 ac (16 ha) within the northern portion of the Entergy  
34 property and adjacent to the Mississippi River. The principle structure within the WF3 plant area  
35 is the NPIS, which is a reinforced concrete box structure that houses all safety-related  
36 components, including the reactor building, reactor auxiliary building, fuel handling building, and  
37 CCWS structures. The property also houses an ISFSI adjacent and to the south of the NPIS.  
38 Two meteorological towers lie to the east, and a 230-kV switchyard and 500-kV switchyard lie to  
39 the south. The WF3 once-through cooling circulating water intake and discharge structures are  
40 located at the northern end of the property off the western shore of the Mississippi River.

41 Table 3–1 lists site land uses and associated acreage, and Figure 3–5 depicts the site layout.  
42 Sections 3.1 and 3.6 describe the developed and natural areas of the site in more detail,  
43 respectively.

1

Figure 3–5. WF3 Site Layout




Source: Esri, DigitalGlobe, GeoEye, Earthstar, USDA, USGS, AEX, Getmapping, Aerogrid, IGN, IGP, swisstopo, and the GIS User

(Entergy 2013a; ESRI 2014; USCB 2014c; WF3 2009)

**Legend**

- Property Boundary
- + Railroad
- Protected Area
- Exclusion Area Boundary
- WF3 Structure
- Waterford 1, 2 & 4 Structures



2

3

Source: Modified from Entergy 2016a

1

**Table 3–1. Entergy Property Land Uses by Area**

<b>Land Use</b>	<b>Area (in acres)<sup>(a)</sup></b>	<b>Percent</b>
Woody Wetlands	2,128.3	58.5
Cultivated Crops	820.2	22.6
Developed Land	467.7	12.9
<i>Developed, Low Intensity</i>	309.8	8.5
<i>Developed, Medium Intensity</i>	35.8	1.0
<i>Developed, High Intensity</i>	52.9	1.5
<i>Developed, Open Space</i>	69.2	1.9
Emergent Herbaceous Wetlands	148.1	4.1
Open Water	46.9	1.3
Barren Land	12.5	0.3
Grassland / Herbaceous	7.8	0.2
Pasture / Hay	2.9	0.1
Shrub/Scrub	1.6	<0.1
<b>Total</b>	<b>3,635.9<sup>(b)</sup></b>	<b>100</b>

(a) To convert acres to hectares, divide by 2.4711.

(b) The acreages presented in this table are based on the Multi-Resolution Land Characteristic consortium land use/land cover data. Because these data are presented in pixel format, acreages do not exactly match the Entergy property boundary, and thus, the total acreage presented in this table is slightly different from the property acreage presented elsewhere in this SEIS.

Source: Entergy 2016a

2 **3.2.1.2 Coastal Zone**

3 In 1972, Congress promulgated the Coastal Zone Management Act (16 USC 1451 et seq.;  
 4 CZMA) to encourage and assist States and territories in developing management programs that  
 5 preserve, protect, develop, and, where possible, restore the resources of the coastal zone  
 6 (i.e., the coastal waters and the adjacent shore lands strongly influenced by one another, which  
 7 may include islands, transitional and intertidal areas, salt marshes, wetlands, beaches, and  
 8 Great Lakes waters). Individual states are responsible for developing a Federally approved  
 9 Coastal Management Plan and implementing a coastal management program in accordance  
 10 with such a plan. In Louisiana, the Louisiana Department of Natural Resources (LDNR), Office  
 11 of Coastal Management, administers the coastal management program.

12 Section 307(c)(3)(A) of the CZMA requires that applicants for Federal permits whose proposed  
 13 activities could reasonably affect coastal zones certify to the licensing agency (here, the NRC)  
 14 that the proposed activity would be consistent with the State’s coastal management program.  
 15 The regulations that implement the CZMA indicate that this requirement is applicable to renewal  
 16 of Federal licenses for actions not previously reviewed by the State (15 CFR 930.51(b)(1)). By  
 17 letter dated April 9, 2015, Entergy (2015d) requested a determination from the LDNR  
 18 concerning whether the proposed WF3 license renewal would be consistent with the Louisiana  
 19 Coastal Resources Program (LCRP). The LDNR replied by letter dated April 14, 2015, with a  
 20 determination that the proposed license renewal is consistent with the LCRP (LDNR 2015).

1 3.2.1.3 Offsite Land Use

2 Within the immediate vicinity of the Entergy property, the banks of the Mississippi River contain  
 3 heavy industrial and commercial development. In addition to Waterford 1, 2, and 4, which lie  
 4 0.4 mi (0.6 km) west-northwest of WF3 and share the Entergy property, Little Gypsy Steam  
 5 Electric Station, Units 1, 2, and 3, lie across the river and 0.8 mi (1.3 km) north-northeast of  
 6 WF3. Additionally, Occidental Chemical Corporation, Aire Liquide America, Galata Chemicals,  
 7 Paxair Distribution, Inc., Union Carbide, and a number of other refineries, petrochemical  
 8 manufacturers, sugar manufacturers, and grain elevators are located along the Mississippi River  
 9 north and south of the site and extending from Baton Rouge to New Orleans and along LA-3142  
 10 (Entergy 2016a).

11 Within a 6-mi (10-km) radius of WF3, most lands are contained within St. Charles Parish;  
 12 however, this radius also includes a small portion of St. John the Baptist Parish to the north and  
 13 east. Wetlands, including woody wetlands and emergent herbaceous wetlands, are the primary  
 14 land cover type and cover 55 percent of land within this area. Agriculture and open water are  
 15 the next most prevalent land cover type and account for 13.6 and 10.5 percent of land use  
 16 within the 6-mi (10-km) vicinity respectively. Developed land, including open space and low,  
 17 medium, and high intensity, account for a collective 18.5 percent. Table 3–2 characterizes the  
 18 land uses within a 10-km (6-mi) radius of WF3.

19 **Table 3–2. Land Use within a 6-mi (10-km) Radius of WF3**

Land Use	Area (in acres) <sup>(a)</sup>	Percent
Woody Wetlands	28,381.1	39.2%
Developed	13,408.8	18.5%
<i>Developed, Open Space</i>	1,877.0	2.6%
<i>Developed, Low Intensity</i>	8,625.6	11.9%
<i>Developed, Medium Intensity</i>	1,240.3	1.7%
<i>Developed, High Intensity</i>	1,666.0	2.3%
Emergent Herbaceous Wetlands	11,534.3	15.9%
Cultivated Crops	9,860.8	13.6%
Open Water	7,632.1	10.5%
Pasture/Hay	1,008.3	1.4%
Shrub/Scrub	465.0	0.6%
Grassland/Herbaceous	45.4	0.1%
Barren Land	35.4	0.0%
Deciduous Forest	8.7	0.0%
Mixed Forest	3.8	0.0%
<b>Total</b>	<b>72,383.7</b>	<b>100</b>

<sup>(a)</sup> To convert acres to hectares, divide by 2.4711.

Source: Entergy 2016a

20 St. Charles Parish, in which WF3 is located, occupies 177,830 ac (71,965 ha). The Mississippi  
 21 River bisects the parish east to west, and the banks of the river are heavily developed for  
 22 industrial use. Approximately 31 percent of the parish is open water, while another 61 percent

## Affected Environment

1 is wetlands, scrub, or marsh. Only about 11 percent of land area (20,000 ac (8,090 ha)) in the  
2 parish is developable land, of which 12,300 ac (4,980 ha) is already developed (SCP 2011).  
3 Agriculture is the predominant land use within developable lands; more than 7,000 ac (2,800 ha)  
4 are in use for crop cultivation and livestock pastureland (SCP 2011). The primary agricultural  
5 products include forage, vegetables, and beef cows (USDA 2014). The St. Charles Parish  
6 Comprehensive Plan (SCP 2011) anticipates that the parish will experience an estimated  
7 8 percent increase in population over the next 15 years and will reach an estimated  
8 60,580 people by 2030. The parish plan includes policies and actions aimed at developing  
9 high-value local agriculture, strengthening existing industrial and business parks, and recruiting  
10 new information-based manufacturing and service industries (SCP 2011). The plan also  
11 includes provisions to protect and restore wetlands, water resources, and other sensitive  
12 habitats and protect and enhance the St. Charles Parish's coastal zone (SCP 2011).

13 Two wildlife management areas (WMAs) are located near WF3. Maurepas Swamp is a  
14 122,098-ac (49,411 ha) WMA that includes flooded cypress tupelo swamp, much of which is  
15 accessible only by boat (LDWF 2016a). A portion of this WMA lies within a 6-mi (10-km) radius  
16 of WF3. The Salvador WMA lies 17 mi (27 km) south of WF3 and includes 30,192 ac  
17 (12,218 ha) of freshwater marsh and cypress stands (LDWF 2016b). The Bonnet Carre  
18 Spillway is also located near WF3, on the opposite side of the Mississippi River. In addition to  
19 providing flood control, the spillway lands, which total 7,623 ac (3,085 ha) are open to public  
20 recreational use, including such uses as fishing, hunting, camping, boating, and picnicking  
21 (Entergy 2016a). Additionally, several local parks are located near WF3, including Montz,  
22 Killona, Bethune, Cambridge, Emily C. Watkins, Highway 51, and Larayo Parks  
23 (Entergy 2016a).

### 24 **3.2.2 Visual Resources**

25 As described in the previous section, the WF3 site is located on the west bank of the Mississippi  
26 River in a highly industrialized area within a broader region that is predominantly covered by  
27 wetlands. The profile of WF3 is dominated by the 249.5-ft (76-m) reactor auxiliary building,  
28 which is situated 50 ft (15 m) below ground to reduce the height of the plant's profile. The site's  
29 auxiliary structures, ducts, pipes, and tanks are painted a blue-gray color that blends in with the  
30 concrete of the principle structures. Several large industrial facilities are located near WF3,  
31 including Waterford 1 and 2 (0.4 mi (0.6 km) west-northwest of WF3), Little Gypsy Steam  
32 Electric Station Units 1, 2, and 3 (0.8 mi (1.2 km) north-northeast of WF3 and across the river),  
33 and Occidental Chemical Corporation (0.8 mi (1.2 km) east-southeast of WF3). A number of  
34 other large industries, including refineries, petrochemical manufacturers, sugar manufacturers,  
35 and grain elevators, lie along the Mississippi River both north and south of the site as far as  
36 Baton Rouge and New Orleans. Additionally, a number of industrial facilities are located along  
37 LA-3142 near WF3, including Air Liquide America, Galata Chemicals, Occidental Chemical  
38 Corp., Praxair Distribution, Inc., and Union Carbide.

39 WF3 buildings and infrastructure are visible from the adjacent industrial facilities and to  
40 individuals traveling along LA-18, LA-628, LA-3127, and the Mississippi River. Travelers on  
41 these roads must be within 1.1 mi (1.8 km) to view any buildings or infrastructure associated  
42 with WF3, and river traffic must be within 0.2 mi (0.3 km) to view the WF3 intake and discharge  
43 structures due to the curvature of the river and shoreline vegetation (Entergy 2016a).

44 The nearest residences to WF3 lie approximately 0.9 mi (1.4 km) to the northeast,  
45 east-northeast, northwest, and west-northwest, and the nearest parks are Killona and Montz  
46 Parks, each of which are 1 mi (0.8 km) from the site. Although WF3 buildings and infrastructure  
47 may be visible from these locations, WF3 blends into the adjacent skyline given the highly  
48 industrialized nature of the surrounding area.

### 1 3.3 Meteorology, Air Quality, and Noise

#### 2 3.3.1 Meteorology and Climatology

3 The state of Louisiana is characterized by a humid subtropical climate, with long, hot summers  
4 and short, mild winters. The climate of Louisiana is primarily influenced by the Gulf of Mexico;  
5 the warm water temperatures of the Gulf provide warm, moist air particularly to the southern and  
6 coastal regions. In general, temperature and precipitation are more stable in southern  
7 Louisiana as a result of the moderating effect of the Gulf of Mexico. The northern regions of  
8 Louisiana experience more variable changes in temperature and precipitation because of  
9 stronger continental influences. During summer months, rainfall decreases with distance from  
10 the Gulf Coast and during the winter months, this pattern is reversed. During the summer, a  
11 semi-permanent high pressure system, known as the Bermuda High, draws moisture northward  
12 or westward from the Atlantic and Gulf of Mexico, resulting in warm and moist summers with  
13 frequent thunderstorms in the afternoons and evening hours (NOAA 2013). Louisiana is  
14 vulnerable to tropical cyclones (tropical storms and hurricanes) that develop in the Gulf of  
15 Mexico. Tropical cyclones make landfall an average of once every 3 years along southeastern  
16 Louisiana (NOAA 2013).

17 The staff obtained 30-year (1989-2015) climatological data from the Louis Armstrong New  
18 Orleans International Airport (KMSY) weather station; this station is approximately 13 mi  
19 (21 km) east of WF3 and is used to characterize the region's climate because of its nearby  
20 location and long period of record. Additionally, Entergy maintains a meteorological monitoring  
21 system composed of two 200-ft (61-m) tower facilities, a primary meteorological system and a  
22 backup system, that measure wind speed and direction, ambient temperature, ambient  
23 humidity, and precipitation (Entergy 2016). Meteorological observations (temperature and wind  
24 speed and direction) from the WF3 site were made available to the staff (Entergy 2016a,  
25 2016b); these data were evaluated in context with the climatological record from the Louis  
26 Armstrong Airport weather station.

27 The prevailing wind directions at the KMSY station for the 2010-2014 timeframe are from the  
28 south-southeast and northeast with a mean wind speed of 7.8 miles per hour (mph)  
29 (12.6 kilometers per hour (kph)) (NCDC 2010, 2011, 2012, 2013, and 2014). Annual wind rose  
30 data for the period 2010–2014 from the meteorological tower at WF3 display prevailing wind  
31 directions from the south, south-southeast, and northeast and an hourly average wind speed of  
32 6.6 mph (10.6 kph) (Entergy 2016a).

33 The mean annual temperature for the period of record (1986-2015) at the KMSY station is  
34 69.7 °F (20.9 °C) with a mean monthly temperature ranging from a low of 53.7 °F (12.1 °C) in  
35 January to a high of 83.3 °F (28.5 °C) in August (NCDC 2015). The mean annual temperature  
36 from WF3's onsite meteorological tower for the 1995 to 2015 time period is 68.5 °F (20.3 °C)  
37 with a mean monthly temperature ranging from a low of 53.4 °F (11.9 °C) in January to a high of  
38 81.3 °F (27.2 °C) in August (Entergy 2016b). Mean annual precipitation for the period of record  
39 (1986-2015) at the KMSY station is 62.4 in. (160 cm). The wettest year for the period of record  
40 is 102.37 in. (260 cm) in 1991; the driest year for the same period is 45.88 in. (120 cm) in 2006.  
41 Precipitation is generally constant by month throughout the year, with summer months (June,  
42 July, and August) being slightly wetter than the rest of the year.

## Affected Environment

1 St. Charles Parish, where WF3 is located, experiences severe weather events, such as  
 2 tornadoes, hurricanes, and thunderstorms. In the past 65 years (1950–2015), the following  
 3 number of events have been reported in St. Charles Parish (NCDC 2016a):

- 4 • Hurricane: 5 events
- 5 • Tornado: 17 events
- 6 • Thunderstorms: 99 events
- 7 • Floods: 5 events

8 On August 29, 2005, Hurricane Katrina made landfall in southeastern Louisiana near Buras as a  
 9 Category 3 storm. The center of the hurricane passed 40 mi (64 km) southeast of New Orleans  
 10 and inundated the city of New Orleans with up to 20 ft (6.1 m) of water when several levees  
 11 were breached (NCDC 2016b). In response to the National Weather Service issuing a  
 12 hurricane warning, Entergy declared an Unusual Event at WF3 and on August 28, 2005, WF3  
 13 began a plant shutdown to ensure that all safety precautions were in place ahead of the storm  
 14 (NRC 2005a). On September 9, 2005, the NRC authorized the restart of WF3 after it  
 15 independently verified that key plant systems and structures were able to support safe  
 16 operations at the plant (NRC 2005b).

### 17 3.3.2 Air Quality

18 Under the Clean Air Act (CAA), the EPA has set primary and secondary National Ambient Air  
 19 Quality Standards (NAAQS, 40 CFR Part 50) for six common criteria pollutants to protect  
 20 sensitive populations and the environment. The NAAQS criteria pollutants include carbon  
 21 monoxide (CO), lead (Pb), nitrogen dioxide (NO<sub>2</sub>), ozone (O<sub>3</sub>), sulfur dioxide (SO<sub>2</sub>), and  
 22 particulate matter (PM). PM is further categorized by size—PM<sub>10</sub> (diameter between 2.5 and  
 23 10 micrometers) and PM<sub>2.5</sub> (diameter of 2.5 micrometers or less). Table 3–3 presents the  
 24 NAAQS for the six criteria pollutants.

25 **Table 3–3. Ambient Air Quality Standards**

Pollutant	Averaging Time	National Standard Concentration
Carbon Monoxide (CO)	8-hr	9 ppm (primary standard)
	1-hr	35 ppm (primary standard)
Lead (Pb)	Rolling 3-month average	0.15 µg/m <sup>3</sup>
	30-day	-
Nitrogen Dioxide (NO <sub>2</sub> )	1-hr	100 ppb (primary standard)
	Annual	53 ppb (primary and secondary standard)
Ozone (O <sub>3</sub> )	1-hr	-
	8-hr	0.075 ppm (primary and secondary standard)
Particulate matter less than 2.5 µm (PM <sub>2.5</sub> )	Annual	12 µg/m <sup>3</sup> (secondary) 15 µg/m <sup>3</sup> (secondary)
	24-hr	35 µg/m <sup>3</sup> (primary and secondary standard)
	24-hr	150 µg/m <sup>3</sup> (primary and secondary standard)
Particulate matter less than 10 µm (PM <sub>10</sub> )	24-hr	150 µg/m <sup>3</sup> (primary and secondary standard)
	Annual	-

Pollutant	Averaging Time	National Standard Concentration
Sulfur Dioxide (SO <sub>2</sub> )	1-hr	75 ppb (primary standard)
	3-hr	0.5 ppm (secondary standard)
	Annual	-

Key: ppb = parts per billion; ppm = parts per million; µg/m<sup>3</sup> = micrograms per cubic meter. To convert ppb to ppm, divide by 1000.

Source: EPA 2016a

- 1 The EPA designates areas of “attainment” and “nonattainment” with respect to the NAAQS.  
2 Areas for which there is insufficient data to determine designation status are denoted as  
3 “unclassifiable.” Areas that were once in nonattainment, but are now in attainment, are called  
4 “maintenance” areas; these areas are under a 10-year monitoring plan to maintain the  
5 attainment designation status. States have primary responsibility for ensuring attainment and  
6 maintenance of the NAAQS. Under Section 110 of the CAA (42 U.S.C. 7410) and related  
7 provisions, States are to submit, for EPA approval, State Implementation Plans (SIPs) that  
8 provide for the timely attainment and maintenance of the NAAQS.
- 9 In Louisiana, air quality designations are made at the parish level. For the purpose of planning  
10 and maintaining ambient air quality with respect to the NAAQS, EPA has developed Air  
11 Quality Control Regions (AQCRs). AQCRs are intrastate or interstate areas that share a  
12 common airshed. WF3 is located in St. Charles Parish, which is part of the Southern  
13 Louisiana-Southeast Texas Interstate AQCR (40 CFR 81.53); the Southern  
14 Louisiana-Southeast Texas Interstate AQCR consists of 36 parishes in Louisiana and  
15 15 counties in Texas. With regard to NAAQS, St. Charles Parish is designated  
16 unclassifiable/attainment for all criteria pollutants (40 CFR 81.319). The nearest designated  
17 nonattainment area for the ozone NAAQS is Ascension Parish, approximately 16 mi (26 km)  
18 northwest from WF3.
- 19 Air emissions at WF3 are regulated under a minor source air permit (Air Permit 2520-00091-00)  
20 issued by the Louisiana Department of Environmental Quality (LDEQ 2004). WF3’s minor  
21 source air permit was issued in April 2004, and Entergy plans to submit an air permit renewal  
22 application to LDEQ by October 2017 (Entergy 2016a). Permitted air pollutant emission  
23 sources and air permit-specified conditions are listed in Table 3–4. In accordance with the  
24 minor source permit and LAC 33:III.501.C.6, Entergy submits semi-annual and annual air  
25 emissions reports to LDEQ. During the environmental audit, NRC staff reviewed the 2011–2015  
26 annual air emissions reports. Entergy is in compliance with WF3’s minor air source permit, and  
27 WF3 has not received any notices of violation pertaining to the air permit for the 2011–2016  
28 period (Entergy 2016a). In accordance with LAC 33:III.2113.A.4, LDEQ requires the  
29 development of a written plan for housekeeping and maintenance emphasizing the prevention  
30 or reduction of volatile organic compound (VOC) emissions from the facility wherever feasible.  
31 Entergy has submitted and developed site procedures to meet this requirement (including a  
32 waste minimization plan, housekeeping, waste management program, and chemical control  
33 program). In accordance with LAC 33:III.5611, WF3 has a standby plan to reduce or eliminate  
34 emissions during an Air Pollution Alert, Air Pollution Warning or Air Pollution Emergency  
35 (Entergy 2004).
- 36 Annual emissions from permitted sources at WF3 are provided in Table 3–5. Emergency diesel  
37 engines, portable engines, and the portable boiler at WF3 are operated only during testing and  
38 during outages as these are intended to be used to supply back-up emergency power for safe  
39 shutdown of the reactor. Water flowing through the wet cooling towers is filtered water and

Affected Environment

- 1 therefore not a significant source of particulate matter (Entergy 2016b). Additionally, WF3's  
 2 LDEQ air permit limits PM<sub>10</sub> emissions to less than 0.57 tons/year for each wet cooling tower.

3 **Table 3–4. Permitted Air Emission Sources at WF3**

<b>Equipment</b>	<b>Air Permit Condition</b>
Emergency Diesel Generators	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Fire Water Diesel Pumps	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Security Emergency Diesel Generators	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Emergency Operations Facility Emergency Diesel Generator	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Dry Cooling Tower Diesel Pumps	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
IT Emergency Diesel Generator	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Portable Diesel Generator	Opacity < = 20 percent PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
ACCW Wet Cooling Towers	PM limit
Diesel Fuel Oil Storage Tank	VOC limit
Emergency Diesel Fuel Oil Storage Tanks	VOC limit
Lube Oil Batch Tanks	VOC limit
Main Turbine Lube Oil Reservoir	VOC limit
Gasoline Fuel Storage Tank	VOC limit
Portable Diesel Engines	Opacity < = 20 percent Diesel fuel rate < = 200,640 gallons/yr PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Portable Gasoline Engines	Opacity < = 20 percent Gasoline fuel rate < = 9,600 gallons/yr PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit
Portable Auxiliary Boiler	Opacity < = 20 percent Gasoline fuel rate < = 9,600 gallons/yr PM, NO <sub>x</sub> , CO, SO <sub>2</sub> , VOC limit

Key: PM = particulate matter, NO<sub>x</sub> = nitrogen oxides, CO = carbon monoxide, SO<sub>2</sub> = sulfur dioxide, VOC = volatile organic compounds, VOC limit

Sources: Entergy 2016a, 2016b

1

**Table 3–5. Estimated Air Pollutant Emissions**

Emissions (tons/year)						
Year	SO <sub>x</sub>	NO <sub>x</sub>	CO	PM <sub>10</sub>	VOCs	HAPs
2010	0.4	15.0	3.9	0.7	1.0	0.01
2011	0.5	20.5	5.3	1.0	1.2	0.02
2012	1.8	38.5	9.1	2.2	2.7	0.04
2013	0.6	18.1	4.7	0.8	1.0	0.03
2014	0.6	22.2	5.5	1.2	1.5	0.02

Key: CO = carbon monoxide, NO<sub>x</sub> = nitrogen oxides, HAPs = hazardous air pollutants; SO<sub>x</sub> = sulfur dioxides, PM<sub>10</sub> = particulate matter less than 10 micrometers, VOC = volatile organic compounds

To convert tons per year to metric tons per year, multiply by 0.90718.

Sources: Entergy 2016a, 2016b

2 According to the 2014 National Emissions Inventory, estimated emissions for St. Charles Parish  
3 are 33,812, 17,372, 4,028, 4,762, 2,391, and 16,502 tons for CO, NO<sub>x</sub>, SO<sub>2</sub>, PM<sub>10</sub>, and VOCs,  
4 respectively (EPA 2014). Permitted air emissions at WF3 are 0.2 percent or less of St. Charles  
5 Parish's total emissions.

6 On October 30, 2009, EPA published a rule for the mandatory reporting of greenhouse gases  
7 (GHGs) from sources that in general emit 25,000 MT or more of carbon dioxide equivalent<sup>1</sup>  
8 (CO<sub>2</sub>e) per year in the United States (74 FR 56260). Most small facilities across all sectors of  
9 the economy fall below the 25,000 MT threshold and are not required to report GHG emissions  
10 to EPA. On June 3, 2010, EPA promulgated the Prevention of Significant Deterioration (PSD)  
11 and Title V GHG Tailoring Rule<sup>2</sup> (75 FR 31514). Beginning January 2, 2011, operating permits  
12 issued to major sources of GHGs under the PSD or Title V Federal permit programs were  
13 required to have provisions requiring the use of best available control technology to limit the  
14 emissions of GHGs, if those sources would be subject to PSD or Title V permitting requirements  
15 because of their non-GHG pollutant emission potentials and their estimated GHG emissions are  
16 at least 75,000 tons/yr of CO<sub>2</sub>e. Additional GHG emission discussions are presented in  
17 Section 4.15.3 and Section 4.16.11.

18 The EPA promulgated the Regional Haze Rule (RHR) to improve and protect visibility in  
19 national parks and wilderness areas from haze, which is caused by numerous, diverse air  
20 pollutant sources located across a broad region (40 CFR 51.308-309). Specifically, 40 CFR 81  
21 Subpart D lists mandatory Class I Federal Areas where visibility is an important value. The  
22 RHR requires States to develop SIPs to reduce visibility impairment at Class I Federal Areas.  
23 There are no Class I Federal Areas within 50 mi (80 km) of WF3. The nearest Class 1 Federal  
24 Area is Breton Wilderness Area, approximately 85 mi (137 km) southeast of WF3. Federal land

<sup>1</sup> CO<sub>2</sub>e is a metric used to compare the emissions of GHG based on their global warming potential (GWP), which is a measure used to compare how much heat a GHG traps in the atmosphere. GWP is the total energy that a gas absorbs over a period of time compared to carbon dioxide. CO<sub>2</sub>eq is obtained by multiplying the amount of the GHG by the associated GWP.

<sup>2</sup> On June 23, 2014, the U.S. Supreme Court issued a decision that EPA may not treat GHGs as an air pollutant for determining whether a source is a major source required to obtain a PSD or Title V permit but could continue to require PSD and Title V permits, which are otherwise required based on emissions of conventional pollutants. On October 3, 2016, the EPA proposed revisions to the PSD and Title V permitting regulations for GHG to ensure that neither the PSD nor Title V rules require a source to obtain a permit solely because the source emits or has the potential to emit GHGs above the applicable threshold (81 FR 68110).

1 management agencies that administer Federal Class I areas consider an air pollutant source  
 2 that is located greater than 50 km (31 mi) from a Class I area to have negligible impacts with  
 3 respect to Class I areas if the total SO<sub>2</sub>, NO<sub>x</sub>, PM<sub>10</sub> and sulfuric acid annual emissions from the  
 4 source are less than 500 tons per year (70 FR 39104; NRR 2010). Given the distance of the  
 5 Class I area to WF3 and the air emissions as presented in Table 3-5, there is little likelihood that  
 6 ongoing activities at WF3 adversely affect air quality and air quality-related values (e.g., visibility  
 7 or acid deposition) in any of the Class I areas.

8 **3.3.3 Noise**

9 Noise is unwanted sound and can be generated by many sources. Sound intensity is measured  
 10 in logarithmic units called decibels (dB). A dB is the ratio of the measured sound pressure level  
 11 to a reference level equal to a normal person’s threshold of hearing. Most people barely notice  
 12 a difference of 3 dB or less. Another characteristic of sound is frequency or pitch. Noise may  
 13 be composed of many frequencies, but the human ear does not hear very low or very high  
 14 frequencies. To represent noise as closely as possible to the noise levels people experience,  
 15 sounds are measured using a frequency-weighting scheme known as the A-scale. Sound levels  
 16 measured on this A-scale are given in units of A-weighted decibels (dBA). Table 3–6 presents  
 17 common noise sources and their respective noise levels. Noise levels can become annoying at  
 18 80 dBA and very annoying at 90 dBA. To the human ear, each increase of 10 dBA sounds  
 19 twice as loud (EPA 1981).

20 **Table 3–6. Common Noise Sources and Noise Levels**

Noise Source	Noise Level (dBA)
Human hearing threshold	0
Soft whisper	30
Quiet residential area	40
Dishwasher	55–70
Lawn mower	65–95
Blender	80–90
Ambulance siren, jet plane	120

Source: CHC undated

21 Several different terms are commonly used to describe sounds that vary in intensity over time.  
 22 The equivalent sound intensity level (L<sub>eq</sub>) represents the average sound intensity level over a  
 23 specified interval, often 1 hour. The day-night sound intensity level (L<sub>DN</sub>) is a single value  
 24 calculated from hourly L<sub>eq</sub> over a 24-hour period, with the addition of 10 dBA to sound levels  
 25 from 10 p.m. to 7 a.m. This addition accounts for the greater sensitivity of most people to  
 26 nighttime noise. Statistical sound level (L<sub>n</sub>) is the sound level that is exceeded ‘n’ percent of the  
 27 time during a given period. For example, L<sub>90</sub>, is the sound level exceeded 90 percent of time  
 28 and is considered the background level.

1 There are no Federal regulations<sup>3</sup> for public exposures to noise. The EPA recommends  
 2 day-night average sounds levels ( $L_{DN}$ ) of 55 dBA as guidelines or goals for outdoors in  
 3 residential areas (EPA 1974). However, these are not standards. The Federal Housing  
 4 Administration (FHA) has established noise assessment guidelines for housing projects and  
 5 finds that  $L_{DN}$  of 65 dBA or less are acceptable (HUD 2014). St. Charles Parish has a noise  
 6 ordinance that sets maximum permissible sound levels based on the receiving land use  
 7 category (e.g., residential, commercial, industrial) (Chapter 24 of Code, Parish of St. Charles).  
 8 The WF3 site has been designated for industrial land use within a heavy manufacturing zoning  
 9 district (Chapter 24 of Code, Parish of St. Charles). The St. Charles Parish noise ordinance  
 10 does not set maximum permissible sound levels for areas zoned as industrial. However, for  
 11 designated residential zones, maximum sound levels range from 50 dBA from 7 a.m. to 10 p.m.  
 12 and 45 dBA from 10 p.m. to 7 a.m.

13 Common noise sources from nuclear power plant operations include transformers,  
 14 loudspeakers, auxiliary equipment, and worker vehicles (NRC 2013). Major noise sources at  
 15 WF3 include turbine generator and the onsite gun range, which are located 1,400 ft (0.3 mi) and  
 16 2,250 ft (0.4 mi) from the site boundary, respectively (Entergy 2016a). Waterford power plant  
 17 Units 1, 2 and 4 are adjacent to WF3 and within the Entergy property boundary; common noise  
 18 sources from these units include transformers, transmission lines, pumps, and turbines. Major  
 19 off-site noise sources in the vicinity of WF3 include vehicular traffic and industrial machinery  
 20 from nearby refineries, petrochemical manufacturers, and sugar manufacturers. In 1977, a  
 21 noise survey was conducted in the vicinity of WF3 and within the plant property. At the time of  
 22 the survey, WF3 was under construction and noise levels ranged between a  $L_{eq}$  of 49 dBA at  
 23 the plant site and 59 dBA near the towns of Lucy (northwest of WF3) and Taft (to the east of  
 24 WF3) (LP&L 1979). The NRC staff did not identify the existence of more recent noise surveys  
 25 in the vicinity of WF3. The nearest residents from WF3 are approximately 0.9 mi (1.4 m) away  
 26 (Entergy 2016c). Entergy has not received noise complaints pertaining to WF3 plant operation  
 27 and outage activities (Entergy 2016a).

## 28 **3.4 Geologic Environment**

29 This section describes the current geologic environment of the WF3 site and vicinity, including  
 30 landforms, geology, soils, and seismic conditions.

### 31 **3.4.1 Physiography and Geology**

32 WF3 is located next to the Mississippi River in the southern portion of the Mississippi River  
 33 deltaic plain physiographic province. The Mississippi River has been the dominant force in  
 34 shaping the topography. The topography consists of low marshy terrain, much of which is  
 35 covered by water. The land surface in the area around the plant and New Orleans is generally  
 36 flat with elevations of 0 to 5 ft (0 to 1.5 m) above MSL and with some areas as much as 5 ft  
 37 (1.5 m) below MSL (Prakken 2009). Areas of higher elevation generally formed along the  
 38 natural levees of existing and abandoned stream courses (Entergy 2016a). The Waterford plant  
 39 is located on natural levee deposits that were built up by historical flooding from the Mississippi  
 40 River. The plant is separated from the Mississippi River by natural and man-made levees.  
 41 Figure 3–6 provides a topographic profile that illustrates the change in topographic elevation  
 42 that occurs between the Mississippi River and the area of the plant buildings.

---

<sup>3</sup> In 1972, Congress passed the Noise Control Act of 1972 establishing a national policy to promote an environment free of noise that impacts the health and welfare of the public. However, in 1982 there was a shift in Federal noise control policy to transfer the responsibility of regulation noise to state and local governments. The Noise Control Act of 1972 was never rescinded by Congress but remains unfunded (EPA 2016b).

## Affected Environment

1 The WF3 site, within the 3,600 ac (1,400 ha) Entergy Louisiana, LLC property, is located on the  
2 Mississippi Delta. An enormous thickness of sediment has been deposited on the Mississippi  
3 Delta in southern Louisiana. During the Pleistocene Epoch, or Ice Age (11,700 to 2.6 million  
4 years ago), the ancient Mississippi River deposited a large thickness of sediment (up to 3,600 ft  
5 (10.973 m)) beneath what is now New Orleans. Over the last 6,000 to 7,000 years (Holocene  
6 Epoch), the Mississippi River created the present Mississippi Delta by depositing large amounts  
7 of sediment on sediments previously deposited during the Pleistocene Epoch. During this  
8 period, the modern delta was created when distributary channels of the Mississippi River  
9 periodically overflowed and deposited sediment in shallow swamps and marshes lying between  
10 the channels. River channel sands, which are deposited beneath and near river channels, are  
11 laterally restricted to the main stem channel of the Mississippi River, or to major distributary  
12 channels, while the vast majority of the coastal lowland is infilled with silt, clay, peat, and  
13 organic matter (ILIT 2006). Vertically and laterally, the sedimentary layers of the delta are  
14 largely made up of interbedded layers of sand, silt, and clay. Figure 3–7 illustrates the different  
15 types of recent (Holocene) aged delta sediments that occur at the site and in the New Orleans  
16 area. At WF3, these sediments form the surface and lay on top of sediments deposited during  
17 the Pleistocene Epoch. Pleistocene-age sediments were deposited under similar geologic  
18 processes to the present (Holocene Epoch) depositional environment.

19 The plant buildings of WF3 are located entirely upon a natural levee created by the Mississippi  
20 River. Figure 3–8 shows the extent of the natural levees in the WF3 and New Orleans area.  
21 Figure 3–9 contains a geologic cross section through the power block (nuclear island) before  
22 the WF3 was constructed. It illustrates the geologic sediments that lie beneath the power block.  
23 On site, the deepest site boring (drill holes) penetrate to a depth of about 500 ft (152 m). Data  
24 from these bore holes indicates that the land surface at the WF3 site is composed of recent  
25 (Holocene) aged sediments that are approximately 40 to 50 ft (12 to 15 m) thick. They are  
26 composed of soft and silty clays with interbedded sand lenses or pockets. In the power block  
27 area, these sediments are missing as they were removed when the power block area was  
28 constructed. In this area, where the sediments were not replaced by plant structures, they were  
29 replaced by engineered fill (sands) to a depth of about 40 ft (12 m) (Entergy 2016a;  
30 FTN Associates Ltd 2014).

1

Figure 3–6. WF3 Topographic Cross Section





2

3

Source: NRC staff-generated

1

Figure 3–7. Recent (Holocene) Age Sediments in New Orleans Area




2

3

Source: Modified from APA 2016

1

Figure 3–8. Natural Levee Deposits in New Orleans Area




2

3

Source: Modified from ILIT 2006

1

Figure 3-9. Geologic Cross Section Through Power Block



2

3

Source: Modified from Entergy 2016

1 The recent (Holocene Epoch) aged deposits were deposited on top of sediments from the  
2 Pleistocene Epoch. They are immediately underlain by 279 ft (85 m) of clays containing some  
3 silt layers and two laterally continuous silty sand strata. These sand strata occur at elevations  
4 of -80 ft (-24 m) and -230 ft (-70 m), as shown in Figure 3–9. In turn these clay and silty clay  
5 deposits are underlain by more than 180 ft (55 m) of silty sand and sand deposits (at elevations  
6 of -321 ft (-98 m) and below as shown in Figure 3–9). Data from offsite exploratory oil and gas  
7 drill holes show that the clays and with increasing depth, shales, are interbedded with  
8 sandstone layers to a depth of around 40,000 ft (12,200 m) below the ground surface. The WF3  
9 site is not known to contain any economically valuable geologic (mineral) or energy (oil and gas)  
10 deposits (Entergy 2016a).

### 11 **3.4.2 Soils**

12 Soils types within the WF3 site, consist of silty clay loam, clay, and muck (Entergy 2016;  
13 USDA 2016). Power block seismic Category I structures have been backfilled with engineered  
14 fill that consists of 17 ft (5.2 m) of Class A material which is then overlain by Category B material  
15 up to the land surface. The Class A material is basically clean, pumped Mississippi River sand  
16 with a content of no more than 12 percent fines (silt and clay). The overlying Class B material  
17 consists of sand with a 1-ft- (30-cm)-thick layer of sand and clam shell material at the land  
18 surface (Entergy 2016).

19 Road LA 3127 roughly divides the site area in two. The area between LA 3127 and the  
20 Mississippi River contains all of the plant structures. The soils in this area were developed from  
21 natural levee deposits and are silty clay loams. They are somewhat poorly drained and are  
22 classified as prime farmland soils.

23 The area south of LA3127 and the site boundary consists of soils that are made up of poorly  
24 drained to somewhat poorly drained clay or muck. They are in a marsh environment and are  
25 subject to frequent surface flooding. They are not considered prime farmland (Entergy 2016;  
26 USDA 2016).

27 No significant construction activities are planned for the site over the license renewal period.  
28 Should soil-disturbing activities occur, sediment transport and any erosion will be managed in  
29 accordance with the WF3 Storm Water Pollution Prevention Plan (SWPPP) (Entergy 2016a).  
30 Section 3.5.1.3 further describes the use of this plan.

### 31 **3.4.3 Land Subsidence**

32 Land subsidence is a significant issue in southern Louisiana and the New Orleans area. Land  
33 subsidence has resulted in significant losses to coastal wetlands in Louisiana. Between 1956  
34 and 2000, Louisiana lost some 1525 mi<sup>2</sup> (3,950 km<sup>2</sup>) of coastal wetlands to open water.  
35 Subsidence in the New Orleans area can increase the potential for flooding and threaten the  
36 structural integrity of buildings and levees. Subsidence and land loss in Louisiana can be  
37 caused by a number of natural processes; faulting (via growth faults), compaction of sediments  
38 rich in fines and organics, global sea-level rise, wave erosion, and erosion caused by storms.  
39 Over the millennia sea-level rise, land subsidence, delta erosion, evacuation and kinetics, and  
40 load-induced crustal down warping, were countered by the deposition of sediments from the  
41 Mississippi River across southern Louisiana (Reed and Wilson 2004; Van Kooten 2005; Yuill et  
42 al 2009).

43 However, since the mid-to late 20th century, human activities have impacted these natural  
44 processes to favor land subsidence and loss in southern Louisiana. Processes contributing to  
45 land subsidence include aquifer and reservoir compaction from the extraction of groundwater,

## Affected Environment

1 oil, and gas. Increased subsidence also can be caused by river boat traffic, and the introduction  
2 of nutria that degrade wet land vegetation.

3 Reduced sediment loads delivered to the Louisiana delta have also increased subsidence. The  
4 Mississippi River currently delivers a reduced sediment load to southern Louisiana because of  
5 numerous upstream dams and flood-control projects. In southern Louisiana, levees built to  
6 protect urban and agricultural areas have prevented the delivery of sediment and nutrients to  
7 surrounding low-lying marshes. In addition, major secondary river channels on the delta were  
8 closed, preventing their sediment load from being delivered to other areas of the delta.  
9 Furthermore, river control structures were built to keep the Mississippi from changing course.  
10 Today only two channels remain; the Mississippi River and the Atchafalaya River. While river  
11 control structures support river traffic and keep the Mississippi River from moving away from the  
12 Port City of New Orleans, it also means the Mississippi River delivers most of its sediment to the  
13 deep water of the Gulf of Mexico where it is lost to the delta (Reed and Wilson 2004; Van  
14 Kooten 2005).

15 While New Orleans was above sea level when it was first settled, much of New Orleans is now  
16 below sea level. In addition to lack of sediment deposition in low-lying areas; groundwater  
17 removal by wells and surface and groundwater removal by drainage projects has also caused  
18 land in and around New Orleans to subside as sediments compacted from the effects of  
19 dewatering. A recent study on anthropogenic and geologic influences on subsidence in the  
20 vicinity of New Orleans, Louisiana, included the WF3 site. The study suggested the most likely  
21 drivers of subsidence are groundwater withdrawal and surficial drainage/dewatering activities.  
22 There is no use of groundwater at the WF3 site. Maps produced by this study  
23 (Jones et al. 2016) show little if any subsidence at the WF3 site (Reed and Wilson 2004; Jones  
24 et al. 2016; Van Kooten 2005; Yuill et al 2009).

### 25 **3.4.4 Seismic Setting**

26 The State of Louisiana is located within the geologic tectonic province known as the Gulf Coast  
27 Basin. This basin contains a very thick volume of sedimentary rocks. The basin contains  
28 shallow growth faults (normal faults) with decreasing dip with depth. These growth faults trend  
29 for considerable distances and roughly parallel the Louisiana coastline. Fault movement along  
30 these growth faults is through a process of gradual creep as opposed to the sudden breaking of  
31 rock associated with earthquakes. As a result, Louisiana is not considered to be seismically  
32 active. Historical earthquakes within Louisiana have occurred infrequently, have been of low  
33 magnitude, and have produced little damage (LGS 2001).

34 Outside of Louisiana, the New Madrid Seismic Zone (NMSZ) is the most likely area where  
35 earthquakes could occur that might affect southern Louisiana (LGS 2001). The NMSZ has been  
36 the most active earthquake region in the United States east of the Rocky Mountains. It covers  
37 parts of Arkansas, Illinois, Kentucky, Missouri, and Tennessee (MODNR 2014). Historically,  
38 some ground shaking in Louisiana was reported from large earthquakes originating in this area  
39 (LGS 2001) A large magnitude earthquake in the NMSZ would cause major damage in  
40 southeastern and eastern Missouri, northeastern Arkansas, southern Illinois, and western  
41 Kentucky and Tennessee. Significant damage could extend down the Mississippi River valley  
42 into the State of Mississippi (MODNR 2014). However, during the greater than 295-year period  
43 since New Orleans was settled, only three shocks from the NMSZ (1811 through 1812) have  
44 probably been felt at the site and the surrounding area (Entergy 2016a).

45 The NRC's evaluation of the potential effects of seismic activity on a nuclear power plant is an  
46 ongoing process that is separate from the license renewal process. The NRC requires every  
47 nuclear plant to be designed for site-specific ground motions that are appropriate for its location.

1 Nuclear power plants, including WF3, are designed and built to withstand site-specific ground  
 2 motion based on their location and the potential for nearby earthquake activity. The seismic  
 3 design basis is established during the initial siting process, using site-specific seismic hazard  
 4 assessments. For each nuclear power plant site, applicants estimate a design-basis ground  
 5 motion based on potential earthquake sources, seismic wave propagations, and site responses,  
 6 which is then accounted for in the design of the plant. In this way, nuclear power plants are  
 7 designed to safely withstand the potential effects of large earthquakes. Over time, the NRC's  
 8 understanding of the seismic hazard for a given nuclear power plant may change as methods of  
 9 assessing seismic hazards evolve and the scientific understanding of earthquake hazards  
 10 improves (NRC 2014). As new seismic information becomes available, the NRC expects that  
 11 licensees will evaluate the new information to determine if changes are needed to safety  
 12 systems at a plant. The NRC also evaluates new seismic information and independently  
 13 confirms that licensee's actions appropriately consider potential changes in seismic hazards at  
 14 the site.

### 15 **3.5 Water Resources**

16 This section describes the current surface water resources within and in the vicinity of the WF3  
 17 site. NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear*  
 18 *Plants* (GEIS) (NRC 2013), states that surface water encompasses all water bodies that occur  
 19 above the ground surface, including rivers, streams, lakes, ponds, and manmade reservoirs or  
 20 impoundments.

#### 21 **3.5.1 Surface Water Resources**

##### 22 *3.5.1.1 Surface Water Hydrology*

##### 23 Local and Regional Hydrology

24 The WF3 site in Killona, Louisiana is located on the west (right descending) bank of the  
 25 Mississippi River near RM 129.6 (RKm 208.6) above Head of Passes<sup>4</sup> (as shown in  
 26 Figures 3-3 and 3-10). The Mississippi River comprises the largest river system in the United  
 27 States. In total, the mainstem of the river runs for 2,340 mi (3,766 km) from its headwaters in  
 28 northern Minnesota to the Gulf of Mexico, and drains a total area of about 1,250,000 square  
 29 miles (mi<sup>2</sup>) (3,240,000 square kilometers (km<sup>2</sup>)) (Kammerer 1990; Entergy 2016a).

30 Regionally, WF3 is located within the Lower Mississippi-New Orleans watershed (hydrologic  
 31 unit 08090100) portion of the Lower Mississippi River Basin (EPA 2016c; Entergy 2016a). The  
 32 Lower Mississippi encompasses the approximately 980-mi (1,600-km) long segment of the  
 33 Mississippi River that flows south from the confluence of the Ohio River in Illinois to Head of  
 34 Passes in Louisiana, where the mainstem of the river branches off into the Gulf of Mexico  
 35 (Alexander et al. 2012; Entergy 2016a).

36 Near the WF3 site, the Mississippi River is up to about 2,850 ft (870 m) wide. Channel depths  
 37 are at least 100 ft (30 m) and 550 ft (168 m) in width at a distance of approximately 450 ft  
 38 (137 m) from the shoreline (NRC 1981). Based on 1992 U.S. Army Corps of Engineers  
 39 (USACE) bathymetry for the river near the WF3 plant, the average maximum river depth is  
 40 about 129 ft (39.3 m) (Entergy 2016a). Flow velocity averages 3.65 fps (1.1 m/s). The normal

---

<sup>4</sup> The Head of Passes is considered the location of the mouth of the Mississippi River. Locations along the main river channel are specified in units of River Miles (RM), starting with RM 0.0 at Head of Passes and RM 953.8 (RKm 1,535) at the mouth of the Ohio River.

## Affected Environment

1 water level elevation of the river is approximately 4.0 ft (1.2 m) MSL (Entergy 2016a). By  
2 comparison, the plant grade elevation surrounding the nuclear plant island ranges from 14.5 ft  
3 (4.4 m) MSL<sup>5</sup> on the south to 17.5 ft (5.3 m) MSL on the north toward the engineered levee  
4 (Entergy 2014a, 2016a).

5 A system of drainage ditches (shown in Figure 3–3) collects stormwater runoff from the WF3  
6 site. The overall direction of surface drainage from the plant site is generally to the south and  
7 southeast across the Entergy property and away from WF3. This runoff is conveyed through  
8 monitored outfalls to a canal (i.e., 40 Arpent Canal) that eventually drains to Lac Des  
9 Allemands. Lac Des Allemands is located approximately 6 mi (9.7 km) southwest of WF3. As  
10 indicated in Figure 3–10, this lake drains southeast toward Lake Salvador and ultimately into the  
11 Gulf of Mexico (Entergy 2014a, 2016a). Section 3.5.1.3 provides a detailed discussion of plant  
12 effluents including stormwater management.

---

<sup>5</sup> The vertical datum (e.g. MSL, NGVD20) cited in this SEIS is that identified in the cited reference documentation. Therefore, cited elevations may not be directly comparable.

1 **Figure 3–10. Hydrologic Features of the Lower Mississippi River Basin near WF3**



2  
3

Source: Modified from Entergy 2016a

1 River System Management and Flood Control

2 The Mississippi River System is closely managed and heavily engineered for flood control and  
3 navigation. Federal authority for coordinating the management of the river system lies with the  
4 Mississippi River Commission (MRC). The MRC was established in 1879 and its mission is to  
5 develop plans to improve the condition of the river, promote commerce, and prevent destructive  
6 floods. MRC's plans are implemented by six USACE districts (Alexander et al. 2012).

7 Major engineered features in the Lower Mississippi near WF3 include a levee system along the  
8 mainstem of the river and its tributaries in the alluvial plain, reservoirs on tributary streams,  
9 floodways to divert excess flow from the river, and channel improvements such as revetment  
10 and dikes to direct channel flow and to prevent migration of channels. Dredging is performed to  
11 increase the flow capacity of river channels. Additional engineered features include various  
12 flood control structures, cut-offs to shorten the river and to reduce flood heights, pumping plants,  
13 floodwalls, and floodgates (Entergy 2014a, 2016a; USACE 2016a).

14 The engineered levee line on the west bank of the Mississippi River begins just south of Cape  
15 Girardeau, Missouri, and extends almost to Venice, Louisiana near the Gulf of Mexico. Gaps  
16 occur only where river tributaries enter the main stem of the Mississippi River (Entergy 2014a,  
17 2016a). Specifically, the Lower Mississippi River has over 5,630 km (3,500 mi) of levees to  
18 prevent flooding during times of high discharge. Because of levee construction, the river's  
19 natural floodplain has been reduced by approximately 90 percent (Alexander et al. 2012).  
20 Further, levee construction has altered the natural process of sediment accretion during flooding  
21 across the Mississippi River Delta region, including St. Charles Parish. The absence of  
22 sediment replenishment that would occur as floodwaters spread across the landscape has  
23 accelerated the natural processes of coastal erosion and land subsidence in the delta region  
24 (St. Charles Parish 2015).

25 As referenced above and as shown in Figure 3–10 in relation to the WF3 site and vicinity, the  
26 levees of the Lower Mississippi River are augmented by flood control structures that divert the  
27 Mississippi River floodwaters into the Gulf of Mexico via the Atchafalaya River or Lake  
28 Pontchartrain. Such structures include the Old River Control Structure, Morganza Floodway,  
29 and Bonnet Carre Spillway, which function to divert water around Baton Rouge upstream of  
30 WF3 and New Orleans downstream of WF3, as appropriate.

31 Of particular relevance to the Entergy property, the Bonnet Carre Spillway is located  
32 approximately 0.75 mi (1.2 km) downstream from WF3. This structure is 7,700 ft (2,350 m) long  
33 and contains 350 bays, each 20 ft (6.1 m) wide. It has the capacity to divert 250,000 cfs  
34 (7,060 m<sup>3</sup>/s) from the Mississippi River to Lake Pontchartrain to prevent overtopping of levees at  
35 and below New Orleans (Entergy 2016a; USACE 2016b). Lake Pontchartrain is an  
36 approximately 40-mi (64-km) wide estuary that connects to the Gulf of Mexico and is located  
37 about 7 mi (11 km) northeast of WF3.

38 The Lower Mississippi River delta area is subject to flooding such as from hurricane-induced  
39 surge flooding (Entergy 2016a). Levees present along the western shoreline of the Mississippi  
40 River at WF3 are designed to protect against flooding. The Federal Emergency Management  
41 Agency (FEMA) has delineated the flood hazard areas along the Lower Mississippi River in the  
42 vicinity of WF3. The WF3 main plant complex, including the nuclear island, is mapped as  
43 Zone X, which represents areas protected from the 100-year flood by levees or other structures  
44 but subject to failure or overtopping during larger floods (Entergy 2016a; FEMA 1992).  
45 Southern portions of the Entergy property and generally along and south of Louisiana  
46 Highway 3127 are within the 100-year floodplain (Zone AE) with base flood elevations of 4 to  
47 5 ft (1.2 to 1.5 m) NGVD29. As stated earlier, the grade elevation at WF3 surrounding the  
48 nuclear plant island ranges from 14.5 to 17.5 ft (4.4 to 5.3 m) MSL. WF3's NPIS, which houses

1 all safety-related components, is flood protected up to elevation 29.27 ft (8.9 m) MSL  
2 (Entergy 2016a). The crest of the Mississippi River flood-control levee on the Entergy property  
3 is 30 ft (9.1 m) MSL (Entergy 2014a, 2016a).

4 The NRC's evaluation of the potential effects of floods on a nuclear power plant is a separate  
5 process from the license renewal process. The NRC requires every nuclear power plant to be  
6 designed for site-specific flood protection for safety-related equipment and facilities. WF3's  
7 site-specific flood design considerations and flooding protection requirements are documented  
8 in the Updated Final Safety Analysis Report (Entergy 2014a). Furthermore, on March 12, 2012,  
9 the NRC requested nuclear power plant licensees to reevaluate flood hazards using present day  
10 information and guidance (NRC 2012). Entergy submitted a flooding hazard reevaluation report  
11 to the NRC on July 21, 2015 (Entergy 2015e). The NRC is currently reviewing Entergy's report.

#### 12 Flow Characteristics of the Lower Mississippi River and Saltwater Migration

13 In its ER, Entergy states that the average flow in the Mississippi River in the vicinity of the WF3  
14 plant is approximately 500,000 cfs (14,120 m<sup>3</sup>/s) (Entergy 2016a). The nearest and active  
15 USGS gaging station with historical river discharge information for the Mississippi River is at  
16 Belle Chasse, Louisiana (gaging station no. 07374525, approximately 54 RM (87 Rkm)  
17 downstream from WF3. The mean annual discharge measured at the USGS gage at Belle  
18 Chasse, for water years 2009 through 2015, is 588,000 cfs (16,600 m<sup>3</sup>/s). For water year 2015,  
19 the mean discharge was 603,300 cfs (17,040 m<sup>3</sup>/s). The mean 90 percent exceedance flow is  
20 235,000 cfs (6,640 m<sup>3</sup>/s) for the period of record (USGS 2016a). The 90 percent exceedance  
21 flow is an indicator value of hydrologic drought. It signifies a rate of streamflow that is equaled  
22 or exceeded 90 percent of the time as compared to the average flow for the period of record.  
23 Based on average monthly flow over the limited period of record at the station, September is the  
24 low-flow month and April is the high-flow month for the Belle Chasse segment of the Lower  
25 Mississippi River (USGS 2016a).

26 Upstream from WF3, the USGS also maintains a gaging station with historical discharge  
27 monitoring data at Baton Rouge (gaging station no. 07374000), approximately 100 RM  
28 (160 Rkm) from WF3. For water years 2004 through 2015, the mean annual discharge at  
29 Baton Rouge is 536,600 cfs (15,160 m<sup>3</sup>/s). For water year 2015, the mean discharge was  
30 591,600 cfs (16,710 m<sup>3</sup>/s). The mean 90 percent exceedance flow is 235,500 cfs (6,650 m<sup>3</sup>/s)  
31 for the period of record (USGS 2016b). For this gaging station, September is the low-flow  
32 month and May is the high-flow month (USGS 2016b).

33 WF3 is located upstream of the saltwater wedge (salt line) that marks the distinct boundary  
34 between the relatively freshwater of the Lower Mississippi River with the denser saltwater from  
35 the Gulf of Mexico. This boundary can migrate upriver along the river bottom, particularly during  
36 periods of low river flow. The maximum recorded upriver migration of the saltwater wedge  
37 occurred in October 1939, when the wedge reached RM 120 (193 Rkm), approximately 10 RM  
38 (16 Rkm) downstream of the WF3 plant site. During this time, river flows were extremely low  
39 and ranged between 75,000 and 90,000 cfs (2,120 to 2,540 m<sup>3</sup>/s) for 30 consecutive days.  
40 Since the Old River Control Structure was completed in 1963, minimum low flows would not be  
41 expected to fall below 100,000 cfs (2,820 m<sup>3</sup>/s). Given the completion of the old river control  
42 structure, Entergy considers the potential occurrence of the saltwater wedge near WF3 to be  
43 highly unlikely (Entergy 2016a).

44 Additionally, the USACE maintains a mitigation program for limiting upriver salt-water  
45 encroachment above RM 64 (103 Rkm) that involves the placement of a sand sill in the main  
46 river channel when necessary to arrest the migration of the wedge. The USACE last  
47 constructed a sand sill in 2012 (USACE 2016c).

## Affected Environment

### 1 3.5.1.2 Surface Water Use

2 As described in Section 3.1.3, WF3 withdraws surface water from the Mississippi River for the  
3 CWS. Heated cooling water from the main condenser along with other comingled effluents from  
4 auxiliary systems is discharged back to the Mississippi River via permitted outfall (Outfall 001)  
5 under WF3's LPDES permit (LDEQ 2017) (see Figure 3–3).

6 The maximum (hypothetical) surface water withdrawal rate for WF3 is 1,000,000 gpm  
7 (2,228 cfs; 62.9 m<sup>3</sup>/s) of water from the Mississippi River (Section 3.1.3.1). This rate is  
8 equivalent to about 1,440 mgd (5.5 million m<sup>3</sup>/day).

9 Table 3–7 summarizes WF3 surface water withdrawals for the period 2011–2015. Based on the  
10 NRC's staff's review of Entergy's reported surface water withdrawals, WF3 withdraws an  
11 average of 376,800 million gallons per year (mgy) (1,429 million cubic meters per year (m<sup>3</sup>/yr))  
12 of water from the Mississippi River. This is equivalent to an average withdrawal rate of  
13 approximately 714,76 gpm (1,593 cfs; 45.0 m<sup>3</sup>/s), or about 1,029 mgd.

14 Actual consumptive water use is not measured at WF3. This is because Entergy does not  
15 meter its total return discharges through its primary outfall (Outfall 001) but instead uses total  
16 withdrawal to approximate total return discharge (Entergy 2016b). Regardless, surface water  
17 consumptive use has not been found to be a problem at operating nuclear power plants with  
18 once-through heat dissipation systems, such as WF3, because such systems inherently return  
19 all but a very small fraction of the water they withdraw to the water source, as compared to  
20 closed-cycle systems (NRC 2013). NRC (1981) estimated that WF3's consumptive use rate is  
21 approximately 0.01 percent of the volume withdrawn from the river. Based on WF3's average  
22 withdrawal rate of 1,029 mgd (1,593 cfs; 45.0 m<sup>3</sup>/s), WF3 consumptive use averages 10.2 mgd  
23 (15.9 cfs; 0.45 m<sup>3</sup>/s).

24 **Table 3–7. Annual Surface Water Withdrawals and Return Discharges to the Mississippi**  
25 **River, WF3**

Year	Withdrawals (mgy) <sup>(a)</sup>	mgd	Discharges (mgy) <sup>(b)</sup>	mgd
2011	391,800	1,073	-	-
2012	382,900	1,049	-	-
2013	388,400	1,064	-	-
2014	393,200	1,077	-	-
2015	322,100	882	-	-
Average	376,800	1,029	-	-

Note: All reported values are rounded. To convert million gallons per year (mgy) to million cubic meters (m3), divide by 264.2.

<sup>(a)</sup> Values are the sum of monthly surface water withdrawals/discharges based on totaling daily average circulating water flows or other estimating methods (Entergy 2016b).

<sup>(b)</sup> Total discharge at WF3's primary outfall is not separately metered but uses total withdrawal to approximate total return discharge.

Source: Entergy 2016b

26 WF3's surface water withdrawals are not currently subject to any water appropriation, allocation,  
27 or related permitting requirements. In Louisiana, no general permitting system exists for surface  
28 water withdrawals from the Mississippi River (Entergy 2016a). The Louisiana Department of

1 Natural Resources does coordinate a surface water resources management program that  
 2 includes the establishment of cooperative agreements with water users for the withdrawal of  
 3 surface water from the State's water bodies (LDNR 2016).

4 Waterford power generating Units 1, 2 and 4 are located within the Entergy property and  
 5 situated just to the west of WF3. They withdraw water and discharge effluents to the Mississippi  
 6 River, but they do not share a common intake or discharge structure with WF3 and have a  
 7 separate LPDES permit (LA0007439). Waterford Units 1, 2 and 4 are further considered in the  
 8 cumulative impact discussions in **Section 4.16.3**.

### 9 3.5.1.3 *Surface Water Quality and Effluents*

#### 10 Water Quality Assessment and Regulation

11 In accordance with Section 303(c) of the Federal Water Pollution Control Act (i.e., Clean Water  
 12 Act of 1972, as amended (CWA) (33 U.S.C. 1251 et seq.), states have the primary responsibility  
 13 for establishing, reviewing, and revising water quality standards for the Nation's navigable  
 14 waters. Such standards include the designated uses of a water body or water body segment,  
 15 the water quality criteria necessary to protect those designated uses, and an anti-degradation  
 16 policy with respect to ambient water quality. As set forth under Section 101(a) of the CWA,  
 17 water quality standards are intended in part to restore and maintain the chemical, physical, and  
 18 biological integrity of the Nation's waters and to attain a level of water quality that provides for  
 19 the protection and propagation of fish, shellfish, and wildlife and recreation in and on the water.  
 20 The EPA reviews state-promulgated water quality standards to ensure they meet the goals of  
 21 the CWA and Federal water quality standards regulations (40 CFR Part 131).

22 The Louisiana Department of Environmental Quality promulgates surface water quality  
 23 standards in Louisiana. Designated use categories include: (1) agriculture, (2) drinking water  
 24 supply, (3) fish and wildlife propagation (including a subcategory for limited aquatic life and  
 25 wildlife), (4) outstanding natural resource waters, (5) oyster propagation, (6) primary contact  
 26 recreation, and (7) secondary contact recreation. All surface waters of the State are designated  
 27 and protected for recreational uses and for the preservation and propagation of desirable  
 28 species of aquatic biota and indigenous species of wildlife. The State also considers the use  
 29 and value of water for public water supplies, agriculture, industry, and other purposes, as well  
 30 as navigation, in setting standards (LAC 33:IX.1111).

31 The mainstem of the Lower Mississippi River from Monte Sano Bayou near Baton Rouge to  
 32 Head of Passes (segment 070301), that encompasses the WF3 shoreline, is designated for the  
 33 following uses: primary contact recreation, secondary contact recreation, fish and wildlife  
 34 propagation, and drinking water supply (Entergy 2016a; LAC 33:IX.1111). River waters must  
 35 normally meet the specified numeric criteria for chlorides (75 mg/L); sulfate (120 mg/L);  
 36 dissolved oxygen (5 mg/L); pH range (6 to 9 units); bacteria (not to exceed a fecal coliform  
 37 density of 400/100 mL); maximum temperature (32 °C [90 °F] ); and total dissolved solids  
 38 (400 mg/L) (LAC 33:IX.1111).

39 Section 303(d) of the Federal CWA requires states to identify all "impaired" waters for which  
 40 effluent limitations and pollution control activities are not sufficient to attain water quality  
 41 standards in such waters. Similarly, CWA Section 305(b) requires states to assess and report  
 42 on the overall quality of waters in their state. States prepare a 303(d) "list" that comprises those  
 43 water quality limited stream segments that require the development of total maximum daily  
 44 loads (TMDLs) to assure future compliance with water quality standards. The list also identifies  
 45 the pollutant or stressor causing the impairment, and establishes a priority for developing a  
 46 control plan to address the impairment. The TMDLs specify the maximum amount of a pollutant  
 47 that a waterbody can receive and still meet water quality standards. Once established, TMDLs

## Affected Environment

1 are typically implemented through watershed-based programs administered by the state,  
2 primarily through the NPDES permit program, pursuant to Section 402 of the CWA, and  
3 associated point and nonpoint source water quality improvement plans and associated best  
4 management practices (BMPs). States are required to update and resubmit their impaired  
5 waters list every 2 years. This process ensures that impaired waters continue to be monitored  
6 and assessed by the state until applicable water quality standards are met.

7 The 2014 Louisiana Water Quality Integrated Report includes Louisiana's 303(d) list. According  
8 to the 2014 report, the 259-mi (417-km) Mississippi River segment (water body  
9 segment 070301) from Monte Sano Bayou to the Head of Passes adjacent to WF3 fully  
10 supports the designated uses for primary contact recreation, secondary contact recreation, fish  
11 and wildlife propagation, and drinking water supply and is not impaired (Entergy 2016a;  
12 LDEQ 2014). However, Lac Des Allemands (water body segment 20202), which may receive  
13 stormwater runoff from the WF3 site, has been listed by the State as impaired for fish and  
14 wildlife propagation because of the introduction of non-native plants (LDEQ 2014). EPA  
15 approved the State's 2014 report, with revisions, on July 21, 2015 (LDEQ 2016).

### 16 NPDES Permitting Status and Plant Effluents

17 To operate a nuclear power plant, NRC licensees must comply with the CWA, including  
18 associated requirements imposed by EPA or the state, as part of the NPDES permitting system  
19 under Section 402 of the CWA. The Federal NPDES permit program addresses water pollution  
20 by regulating point sources (i.e., pipes, ditches) that discharge pollutants to waters of the United  
21 States. NRC licensees must also meet state water quality certification requirements under  
22 Section 401 of the CWA. The EPA or the State, not the NRC, sets the limits for effluents and  
23 operational parameters in plant-specific NPDES permits. Nuclear power plants cannot operate  
24 without a valid NPDES permit and a current Section 401 Water Quality Certification.

25 EPA authorized the State of Louisiana to assume NPDES program responsibility in Louisiana in  
26 August 1996, including general permit authority (EPA 2016). LDEQ administers the NPDES  
27 program as the Louisiana Pollutant Discharge Elimination System (LPDES). The State of  
28 Louisiana's regulations for administering the NPDES program are contained in Louisiana  
29 Administrative Code (LAC), Title 33, IX., Chapter 23 (LAC 33:IX.23). Like NPDES permits,  
30 LPDES permits are generally issued on a 5-year cycle.

31 WF3 is authorized to discharge various wastewater (effluent) streams including return  
32 circulating water and plant-site stormwater under LPDES permit No. LA0007374, issued to  
33 Entergy on August 1, 2017 by LDEQ (LDEQ 2017). The renewed LPDES permit for WF3 was  
34 issued pursuant to Entergy's submittal of a permit renewal application on March 30, 2015  
35 (Entergy 2015f) that LDEQ accepted as administratively complete on April 15, 2015  
36 (LDEQ 2015a). The permit is valid until September 30, 2022.

37 WF3's LPDES permit specifies the monitoring requirements for effluent chemical and thermal  
38 quality and stormwater discharges. WF3's LPDES permit authorizes discharge from 13 outfalls  
39 including 9 internal outfalls (internal monitoring points) for effluents to primary Outfall 001;  
40 discharge from most of these outfalls is ultimately to the Mississippi River via the discharge  
41 structure (Outfall 001) or to 40 Arpent Canal (which ultimately drains to the Lac de Allemands).  
42 The location of WF3's outfalls are shown in Figure 3-11, and Figure 3-3 also provides a more  
43 detailed view of Outfall 001 at the discharge structure.

1 **Figure 3–11. Louisiana Pollutant Discharge Elimination System Permitted Outfalls**



2  
3

Source: Modified from Entergy 2016a

## Affected Environment

1 Table 3–8 summarizes the contributing industrial processes and associated effluent  
2 (wastewater) streams, including stormwater runoff, discharged through WF3’s outfalls. The  
3 LPDES permit requires that Entergy monitor and report various parameters for WF3’s effluent  
4 discharges. Depending on the outfall, Entergy is required to monitor and report discharge  
5 monitoring results for various parameters such as flow rate, discharge temperature, total organic  
6 carbon (TOC), total suspended solids (TSS), oil and grease, and pH. As for flow, Entergy does  
7 not meter its total return discharges through its primary outfall (Outfall 001) but instead uses  
8 total withdrawal to approximate total return discharge (Entergy 2016b-RAI).

9 Entergy is approved under the WF3 LPDES permit to treat river water to control biofouling  
10 (macro- and micro-biological fouling) of the CWS, including for zebra mussel control, using  
11 chlorine and bromine compounds (e.g., sodium hypochlorite, sodium bromide). Entergy also  
12 has approval to control siltation in the CWS using a polyacrylate and a polymeric dispersant  
13 (Entergy 2015f, 2016a; LDEQ 2017). For this reason, WF3’s LPDES permit also imposes an  
14 effluent limit on Outfall 001 for total residual chlorine as well as requiring Entergy to conduct  
15 whole effluent aquatic toxicity testing. At present, however, no chemical treatment of the CWS  
16 water is performed at WF3, and no chemical injection equipment is maintained at the intake  
17 structure, as previously discussed in Section 3.1.3.1.

18 Nevertheless, WF3’s CCWS is treated with biocides, corrosion inhibitors, and other compounds  
19 as needed to maintain acceptable water and component quality (Entergy 2015f, 2016a). The  
20 dry and wet cooling towers that comprise this system ultimately discharge to Outfall 001 through  
21 internal Outfalls 501–801. The CWS and CCWS are described in Section 3.1.3.

22 Additionally, for Outfall 001, Entergy is also required to calculate and report total heat  
23 discharged to the river, and the LPDES permit imposes a maximum temperature limit of 118 °F  
24 (47.8 °C). As previously described in Section 3.1.3.2, the maximum temperature rise of  
25 discharged circulating water relative to ambient intake water temperature is 18.9 °F (10.5 °C).  
26 Entergy personnel continuously monitor the temperature of the discharged return circulating  
27 water by computer and an alarm is triggered in the WF3 main control room if the thermal limit is  
28 approached. Temperature measurements are made at the main condenser water boxes while  
29 heat measurements are determined from electrical generation and the continuous temperature  
30 recordings (Entergy 2015f). WF3’s discharge structure is designed to promote rapid mixing of  
31 the heat discharge with river water. A detailed description of the discharge structure is provided  
32 in Section 3.1.3.2.

33 As described in Table 3–8, Outfall 004 predominantly receives stormwater collected by the WF3  
34 drainage ditch system. Plant personnel sample the stormwater quarterly for TOC, oil and  
35 grease, TSS, and pH. As identified by Entergy (2016a) and further specified in the WF3 LPDES  
36 permit, Entergy is required to develop, maintain, and implement a SWPPP. Such plans serve to  
37 identify sources of pollution that would reasonably be expected to affect the quality of  
38 stormwater and which specifies BMPs that will be used to prevent or reduce the pollutants in  
39 stormwater discharges. Based on the NRC staff’s review of the SWPPP implemented by  
40 Entergy for WF3 (Entergy 2007), the plan identifies potential sources of pollution, including  
41 sediment, debris accumulation, petroleum products, and chemical products that could affect  
42 stormwater, groundwater, and/or offsite surface water quality including practices, controls, and  
43 inspections used to prevent or reduce pollutants in storm water discharges.

44 Other than WF3 site drainage ditches, which may retain stormwater for periods of time, the only  
45 other pond, impoundment, or other feature on the site that receives effluent from WF3  
46 operations is the concrete holding basin. This basin, located just to the northwest of the WF3  
47 main plant complex (see Figure 3–3), is a concrete structure that measures 92 by 92 ft (28 by  
48 28 m) with a depth of 8 ft (2.4 m). The concrete holding basin is a reservoir for nonradioactive

1 wastewater with potentially unacceptable pH levels and/or high levels of metals and other  
 2 chemicals. Sources of this wastewater include three WF3 sumps including the chiller building  
 3 sump, regenerative waste sump, and the auxiliary boiler sump. Wastewater collected by the  
 4 holding basin is pumped to the Waterford 1 and 2 wastewater treatment facility for treatment  
 5 and discharge to the Mississippi River. The basin is used on a daily basis, and standing water  
 6 is always present (Entergy 2016b).

7 **Table 3–8. Louisiana Pollutant Discharge Elimination System Permitted Outfalls, WF3**

<b>Outfall</b>	<b>Average Flow (mgd)</b>	<b>Description<sup>(a,b)</sup></b>
001	1,076 <sup>(b)</sup>	Once-through non-contact cooling water—combined with previously monitored intermittent discharges including but not limited to: steam generator blowdown, cooling tower blowdown, metal cleaning wastewaters, low-volume wastewater, and stormwater. Discharge to Mississippi River.
004	0.541 <sup>(b)</sup>	Stormwater runoff and miscellaneous wastewaters—intermittent discharge from the plant drainage ditch system, potable water from the fire water system, and maintenance wastewaters. Discharge to 40 Arpent Canal. <sup>(d)</sup>
005	0.013 <sup>(b)</sup>	Energy Education Center—intermittent discharge of treated sanitary wastewater (package treatment plant) and discharge from the HVAC unit. Discharge to 40 Arpent Canal.
101 (internal) <sup>(c)</sup>	0.012 <sup>(b)</sup>	Liquid waste management system—intermittent low-volume wastes from the turbine and reactor building equipment and floor drains, primary plant water makeup, laboratory drains, and other sources; system concentrates and removes radioactive pollutants.
201 (internal) <sup>(c)</sup>	0.012 <sup>(b)</sup>	Boron management system—intermittent low-volume wastewater from the turbine and reactor building equipment and floor drains, primary plant water makeup, laboratory drains, and other sources; system concentrates and recovers boron.
301 (internal) <sup>(c)</sup>	0.012 <sup>(b)</sup>	Filter flush system—intermittent discharge of filter flush water from the primary water treatment system; [There have been no discharges from this outfall for several years and no future discharges are planned; the system is not being utilized but remains in place.] <sup>(b)</sup>
401 (internal) <sup>(c)</sup>	0.045 <sup>(c)</sup>	Steam generator blowdown—intermittent discharge of blowdown and other low-volume wastewaters.
501 (internal) <sup>(c)</sup>	NA <sup>(b)</sup>	Auxiliary cooling water basin A—intermittent discharge from Basin A including auxiliary component cooling water, component cooling water, Mississippi River water used for flow testing, and stormwater.
601 (internal) <sup>(c)</sup>	0.18 <sup>(b)</sup>	Auxiliary cooling water basin B—intermittent discharge from Basin B including auxiliary component cooling water, component cooling water, Mississippi River water used for flow testing, and stormwater.
701 (internal) <sup>(c)</sup>	0.0064 <sup>(b)</sup>	Dry cooling tower sump no. 1—intermittent discharge of cooling tower blowdown and low-volume wastewaters including wet cooling tower leakage, auxiliary component cooling water, component cooling water, secondary plant water system wastewater, and stormwater.
801 (internal) <sup>(c)</sup>	0.0011 <sup>(b)</sup>	Dry cooling tower sump no. 2—intermittent discharge of cooling tower blowdown and low-volume wastewaters including wet cooling tower leakage, auxiliary component cooling water, component cooling water, secondary plant water system wastewater, and stormwater.

## Affected Environment

Outfall	Average Flow (mgd)	Description <sup>(a,b)</sup>
901 (internal) <sup>(c)</sup>	0 <sup>(b)</sup>	Mobile metal cleaning wastewater—intermittent discharge of metal cleaning wastewaters (both chemical and non-chemical) from various plant equipment components, including the steam generator, cooling water heat exchangers, and piping. [Discharges are rare and no discharges are anticipated in the foreseeable future.] <sup>(b)</sup>
1001 (internal) <sup>(c)</sup>	0.020 <sup>(b)</sup>	Miscellaneous intermittent wastewater—intermittent discharge from the yard oil separator system; wastewater includes auxiliary boiler blowdown, stormwater, and low-volume wastewaters from various sources, including plant floor drains and discharge from the industrial waste system.

Note: To convert million gallons per day (mgd) to cubic feet per second (cfs), multiply by 1.547; mgd=million gallons per day.

<sup>(a)</sup> Summarized from LPDES Permit No. LA0007374 (LDEQ 2017).

<sup>(b)</sup> As cited in Entergy's renewal application for LPDES Permit No. LA0007374 (Entergy 2015f).

<sup>(c)</sup> NPDES permit internal monitoring point prior to Outfall 001.

<sup>(d)</sup> During maintenance, this is an optional outfall for effluent from the Dry Cooling Tower Sump No. 1 (Internal Outfall 701), Dry Cooling Tower Sump No. 2 (Internal Outfall 801), and treated discharge from the yard oil separator system, including, but not limited to plant floor drains and discharge from the industrial waste system (Internal Outfall 1001).

Source: Entergy 2015f, 2016a; LDEQ 2017.

- 1 Sanitary effluent from WF3, with the exception of the Energy Education Center, is not directly
- 2 discharged to surface water; instead, it is discharged to a publicly-owned treatment works
- 3 (St. Charles Parish Department of Public Works and Wastewater) (Entergy 2016a). As
- 4 identified in Table 3–8, sanitary wastewater from the Entergy Energy Education Center is
- 5 discharged to the 40 Arpent Canal via Outfall 005.
- 6 Effluent monitoring results for WF3's LPDES-regulated outfalls must be reported in discharge
- 7 monitoring reports (DMRs) submitted to LDEQ at intervals specified in the permit (generally, on
- 8 a quarterly basis). Entergy has reported that it has received no Federal, State, or local notices
- 9 of violation associated with environmental activities including LPDES permitted discharges
- 10 during the 2010 through 2015 time period (Entergy 2016a, 2016b). The NRC staff's
- 11 independent review of WF3 DMR records maintained by Entergy for the period 2014 through
- 12 June 2016 revealed no apparent exceedances of LPDES permit limits or unusual conditions of
- 13 current operations, with reported discharges in compliance with specified effluent limitations and
- 14 monitoring requirements. Additionally, a review of EPA's Enforcement and Compliance History
- 15 Online database by the NRC staff revealed several apparent reporting noncompliances
- 16 associated with WF3's LPDES permit but no apparent effluent violations or systemic reporting
- 17 issues (EPA 2016c).
- 18 WF3 is also subject to the requirements of EPA's oil pollution prevention regulation
- 19 (40 CFR Part 112) and Entergy has developed and implemented a Spill Prevention, Control,
- 20 and Countermeasure (SPCC) Plan. The SPCC Plan describes the procedures, materials,
- 21 equipment, and facilities used at WF3 to minimize the frequency and severity of oil spills
- 22 (Entergy 2016a).

## 1 Other Surface Water Resources Permits and Approvals

2 Section 401 of the CWA (33 U.S.C. 1251 et seq.) requires an applicant for a Federal license to  
3 conduct activities that may cause a discharge of regulated pollutants into navigable waters to  
4 provide the licensing agency with water quality certification from the State. This certification  
5 implies that discharges from the project or facility to be licensed will comply with CWA  
6 requirements and will not cause or contribute to a violation of state water quality standards. If  
7 the applicant has not received Section 401 certification, the NRC cannot issue a license unless  
8 that State has waived the requirement. The NRC recognizes that some NPDES-delegated  
9 states explicitly integrate their Section 401 certification process with NPDES permit issuance.

10 WF3's current LPDES permit does not explicitly convey water quality certification under  
11 Section 401 of the CWA. On January 21, 1972, the State of Louisiana Stream Control  
12 Commission issued a letter of water quality certification proposing that discharges from WF3, as  
13 well as Waterford 1 and 2, would not violate Louisiana water quality standards (Stream Control  
14 Commission 1972). On January 30, 2015, LDEQ responded to Entergy's request pertaining to  
15 water quality certification to support license renewal. In summary, LDEQ informed Entergy that:  
16 (1) no new or additional water quality certification pursuant to Section 401 of the CWA  
17 (33 U.S.C. Section 1341) is required in support of the WF3 license renewal application;  
18 (2) LDEQ deems the January 21, 1972 certification issued by the State Stream Control  
19 Commission to be a certification obtained pursuant to 33 U.S.C. Section 1341(a)(1) with respect  
20 to construction of WF3; and (3) LDEQ deems the current WF3 LPDES (permit No. LA0007374)  
21 to be a certification pursuant to 33 U.S.C. Section 1341(a)(1) with respect to operation of WF3  
22 (LDEQ 2015b). The NRC staff concludes that the LDEQ's response provides the NRC with the  
23 necessary certification pursuant to CWA Section 401.

24 Entergy does not currently possess any permits or approvals that would authorize the discharge  
25 of dredge or fill material in surface waters or wetlands as regulated under CWA Section 404  
26 (Entergy 2016a).

27 WF3's CWIS extends approximately 162 ft (49 m) off the western shore of the Mississippi River.  
28 As discussed in Section 3.1.3.1, the CWIS consists of an intake canal, intake structure, eight  
29 trash racks, and eight traveling water screens. Entergy has not performed dredging activities at  
30 either WF3's intake or intake structure to remove sediment deposition (Entergy 2016a).  
31 Therefore, Entergy does not maintain any regulatory approvals for maintenance dredging of the  
32 CWIS.

33 Nonetheless, at the time of the July 2016 environmental audit, Entergy was completing a project  
34 to replace the second of two of its five piling structures (known as dolphins) that protect the  
35 intake structure weir-wall and that had suffered damage due to barge collisions  
36 (Entergy 2016b--RAI). The project was being conducted in accordance with a Department of  
37 the Army installation and maintenance permit originally issued for WF3 construction  
38 (USACE 1972) and a U.S Coast Guard permit for private aids to navigation associated with  
39 WF3's intake structure (USCG 1996). To support the replacement project, Entergy also  
40 obtained letters of authorization from the USACE (USACE 2013), Louisiana Department of  
41 Wildlife and Fisheries (LDWF) (LDWF 2013), and a Coastal Use Authorization/Consistency  
42 Determination from the Louisiana Department of Natural Resources (LDNR 2013).

### 43 **3.5.2 Groundwater Resources**

44 This section describes the current groundwater resources at the WF3 site and vicinity.

1 3.5.2.1 *Site Description and Hydrogeology*

2 Groundwater in southeastern Louisiana that can be extracted for use is usually available in beds  
3 of sand that dip and thicken southward. These sand beds are separated by beds of clay and silt  
4 that have low permeability and that do not readily transmit groundwater. The beds of clay and  
5 silt also dip and thicken southward. They form barriers to groundwater flow (aquitards) that  
6 separate the sands (aquifers) from each other. In the New Orleans area, the aquifers are  
7 comprised of silty sand, sand, and sand-gravel beds (Entergy 2016a; Prakken 2009;  
8 Tomaszewski 2003a).

9 Shallow groundwater aquifers in the New Orleans area include the Mississippi River point bar  
10 deposits. A point bar is a depositional feature made of stream-deposited sediment that  
11 accumulates on the inside bend of streams and rivers. Mississippi River point bar deposits in  
12 the New Orleans area have a maximum thickness of about 130 ft (40 m), and they are overlain  
13 by 20 to 30 ft (6 to 9 m) of natural levee deposits (Entergy 2016a). In the New Orleans area,  
14 Mississippi River point bar deposits contain freshwater in some areas adjacent to the  
15 Mississippi River. However, in general, the shallow aquifers in the New Orleans area contain  
16 saltwater (Entergy 2016a; Prakken 2009; Tomaszewski 2003a, 2003b). Shallow groundwater is  
17 found beneath WF3 in sand and gravel layers of the point bar deposits that are part of the  
18 natural levee that underlies WF3. It is also found in the engineered fill (sand) around the power  
19 block area. Groundwater in the natural levee deposits and in the engineered fill is encountered  
20 at a depth of approximately 5 to 7 ft (1.5 to 2.1 m) (Entergy 2016a).

21 Other aquifers of note in the New Orleans area are the Gramercy Aquifer, the Norco Aquifer,  
22 and the Gonzales-New Orleans Aquifer. Lying beneath the shallow aquifers of the point bar  
23 deposits is the Gramercy Aquifer. It contains only saltwater in the New Orleans area, but  
24 beneath the WF3 site, it contains freshwater (Prakken 2009; Tomaszewski 2003b). In the area  
25 of WF3, the Gramercy Aquifer is irregular in thickness and laterally discontinuous  
26 (Entergy 2016a). At the WF3 site, it is about 100-ft (30-m) thick and is found at an elevation of  
27 approximately -200 ft (-61 m) MSL. However it does not occur beneath the WF3 power block  
28 and is only found beneath the southern portion of Entergy property that includes the WF3 site  
29 (Tomaszewski 2003b; Entergy 2016a).

30 The next deepest aquifer in the New Orleans area is the Norco Aquifer. In New Orleans, except  
31 for an area about 1 mi (1.6 km) wide and 6 mi (9.7 km) long along the Lake Pontchartrain  
32 shoreline in Jefferson Parish, the aquifer contains saltwater (Prakken 2009). However, beneath  
33 the WF3 site it contains freshwater and is the principle source of groundwater around the site  
34 and in the Norco area (Entergy 2016a; Tomaszewski 2003c). At the WF3 site, where the  
35 Gramercy Aquifer occurs, the Noroco Aquifer is separated from it by about 25 ft (7.6 m) of beds  
36 of clay with interbedded sand. Beneath the WF3 site, the Norco Aquifer is found at an elevation  
37 of -325 ft (-99 m) MSL and is about 125 ft (38 m) thick (see Figure 4 in Section 3.4.1).

38 The Gonzales-New Orleans Aquifer is the deepest aquifer of importance beneath WF3. The top  
39 of the aquifer occurs at about -600 ft (183 m) MSL beneath WF3 and it is about 250 ft (76 m)  
40 thick. The Gonzales-New Orleans Aquifer is separated from the overlying Norco Aquifer by  
41 200 to 300 ft (61 to 91 m) of clay with sand interbeds (Entergy 2016a). In the New Orleans area  
42 it usually contains freshwater. Almost all groundwater withdrawals in the New Orleans area  
43 come from the Gonzales-New Orleans Aquifer (Entergy 2016a; Prakken 2009). Fresh water  
44 (less than 250 ppm chloride) is generally encountered in the Gonzales-New Orleans Aquifer  
45 north of the Mississippi River (Entergy 2016a; Tomaszewski 2003d). However, WF3 is located  
46 south of the Mississippi River, where the water quality in the Gonzales-New Orleans Aquifer is  
47 likely either brackish or saltwater. Fresh water is not generally encountered in deeper units  
48 beneath the Gonzales-New Orleans Aquifer (Griffith 2003; Prakken 2009).

1 Shallow near surface groundwater flow at WF3 is considered to flow generally south-southwest  
2 away from the Mississippi River, except during low river stages when some of the groundwater  
3 near the power block flows toward the river (Entergy 2016a). Prior to inception of heavy  
4 pumping in both the New Orleans and Norco areas, groundwater movement in the Norco and  
5 the Gonzales-New Orleans aquifers was generally down-dip to the south. However, as  
6 groundwater usage has increased, the direction of movement has been altered and it is now  
7 toward areas of heavy pumping (Entergy 2016a).

#### 8 3.5.2.2 *Groundwater Use*

9 The shallow aquifers in the point bar deposits in the area of WF3 are not commonly used  
10 because of their poor water quality, limited area extent, and low permeability; and they are  
11 unlikely to be developed as a future source of water. Within 2 mi (3.2 km) of the site,  
12 groundwater is extracted from the Norco and Gramercy aquifers and is primarily used for  
13 non-domestic purposes (Entergy 2016a).

14 Groundwater is not used as a water source to support WF3 operations; therefore, WF3 activities  
15 do not reduce the availability of groundwater resources in the area. Cooling water to remove  
16 heat from the condensers is supplied from the Mississippi River, as described in Sections 3.1.3  
17 and 3.5.1.2. Potable water is provided to WF3 by the St. Charles Parish Department of Water  
18 Works, which obtains its water from the Mississippi River (Entergy 2016a).

#### 19 3.5.2.3 *Groundwater Quality*

20 Entergy performs shallow groundwater monitoring at WF3 from onsite locations to monitor for  
21 potential radioactive releases to the groundwater. Figure 3–12 shows the location of monitor  
22 wells at WF3. The shallow groundwater system includes groundwater in the engineered fill  
23 beneath and around the WF3 nuclear island and in sand and gravel layers within recent  
24 (Holocene) aged deposits. While deeper aquifers of local and regional extent exist beneath the  
25 site, these aquifers are separated from shallow groundwater by thick sequences of relatively  
26 impermeable silts and clays. These act as aquitards and make impacts to these aquifers from  
27 inadvertent radiological releases at the site unlikely (FTN Associates Ltd 2014).

28 Groundwater samples are collected from monitor wells at WF3 on a quarterly basis, or if  
29 deemed necessary, more frequently. The results are publicly reported to the NRC in annual  
30 radiological environmental operating reports. No leaks or inadvertent releases of radionuclides  
31 to groundwater have been detected at the WF3 site. Since monitoring began in 2007, all  
32 radionuclide concentrations have been below minimum detectable levels (Entergy 2008, 2009,  
33 2010, 2011, 2012a, 2013a, 2014b, 2015b, 2016a, 2016d; FTN Associates Ltd 2014).

1

Figure 3–12. Onsite Groundwater Monitoring Locations



2

3

Source: Modified from Entergy 2016a

## 1 3.6 Terrestrial Resources

### 2 3.6.1 WF3 Ecoregion

3 WF3 lies within the Mississippi Alluvial Plain Level III Ecoregion (NHEERL 2011). This  
 4 ecoregion consists of a long thin band that extends from southern Illinois at the confluence of  
 5 the Ohio River with the Mississippi River south through parts of Missouri, Tennessee, Arkansas,  
 6 Mississippi, and Louisiana to the Gulf of Mexico (Wiken et al. 2011). The climate is mild, humid  
 7 subtropical, and the terrain is mostly broad, flat alluvial plain with river terraces, swales, and  
 8 levees (Wiken et al. 2011). Prior to settlement, this ecoregion was dominated by bottomland  
 9 deciduous forest; however, much of the ecoregion has been cleared for agricultural use. Virgin  
 10 cypress stands were typically 400 to 600 years old at the time of European settlement, but over  
 11 the last century most of these trees have been logged and few individuals over 200 years old  
 12 remain (Sharitz and Mitsch 1993). Wiken et al. (2011) reports that the Mississippi Alluvial Plain  
 13 is one of the most altered ecoregions in the United States. Today, over 90 percent of the  
 14 landscape has been converted to cropland (Weakley et al. 2016). Primary crops include  
 15 soybeans, cotton, corn, rice, wheat, pasture, and sugarcane (Wiken et al. 2011).

16 Remaining forest communities are distinctly segregated by hydroperiod, or seasonal pattern of  
 17 water inundation, which determines the amount of oxygen and moisture available to a given  
 18 forest community. The most intact habitats are confined to the wettest areas, which are difficult  
 19 to cultivate or alter for other economic purposes (Weakley et al. 2016). Common forest  
 20 communities include (in decreasing flood duration) river swamp forest, lower hardwood swamp  
 21 forest, backwater and flats forest, and upland transitional forest (Weakley et al. 2016). River  
 22 swamp forests contain bald cypress (*Taxodium distichum*) and water tupelo (*Nyssa aquatica*)  
 23 (Wiken et al. 2011). Hardwood swamp forests include water hickory (*Carya aquatica*), red maple  
 24 (*Acer rubrum*), green ash (*Fraxinus pennsylvanica*), and river birch (*Betula nigra*) (Wiken et  
 25 al. 2011). Seasonally flooded areas of higher elevation contain these species as well as  
 26 sweetgum (*Liquidambar* spp.), sycamore (*Platanus occidentalis*), laurel oak (*Quercus laurifolia*),  
 27 Nuttall oak (*Q. texana*), and willow oak (*Q. phellos*) (Wiken et al. 2011). Common herbs include  
 28 butterweed (*Senecio glabellus*), jewelweed (*Impatiens capensis*), and royal fern (*Osmunda*  
 29 *regalis*); and woody vines include poison ivy (*Toxicodendron radicans*), greenbriers (*Smilax*  
 30 spp.), and trumpet-creeper (*Campsis radicans*) (Weakley et al. 2016).

31 Common wildlife in the Mississippi Alluvial Plains include white-tailed deer (*Odocoileus*  
 32 *virginianus*), black bear (*Ursus americanus*), bobcat (*Lynx rufus*), gray fox (*Urocyon*  
 33 *cinereoargenteus*), raccoon (*Procyon lotor*), swamp rabbit (*Sylvilagus aquaticus*), migratory  
 34 waterfowl, wild turkey (*Meleagris gallopavo*), cormorants (*Phalacrocorax* spp.), egrets (*Egretta*  
 35 spp.), herons, mourning dove (*Zenaida macroura*), wood thrush (*Hylocichla mustelina*),  
 36 yellow-throated vireo (*Vireo flavifrons*), and alligators (*Alligator mississippiensis*).

### 37 3.6.2 WF3 Site Surveys, Studies, and Reports

38 This section summarizes the wildlife and vegetation surveys, studies, and reports that have  
 39 been conducted on and near the WF3 site in chronological order.

#### 40 Preoperational Terrestrial Habitat and Wildlife Study

41 Between April 1973 and August 1976, Louisiana Power & Light Company (LP&L) commissioned  
 42 preconstruction terrestrial ecology studies on the WF3 site. These studies are documented in  
 43 the Environmental Report for WF3 operation (LP&L 1978). The first phase of the study included  
 44 general walk-through and systematic transect surveys of plant communities within the site's  
 45 batture areas, the alluvial land between the Mississippi River at low-water stage and the levee.

## Affected Environment

1 The second phase of the study expanded surveys to the swamp forest communities.  
2 Vegetation cover, abundance, and species were recorded within defined plots and transects.  
3 LP&L also commissioned wildlife surveys for amphibians, reptiles, birds, and mammals during  
4 the preconstruction period. Methodology and results of these studies are described in the  
5 Environmental Report (LP&L 1978).

### 6 2014 Threatened and Endangered Species Survey

7 In 2014, Enercon Services, Inc. (Enercon) performed a survey to determine the habitat  
8 availability and presence of plants and animals Federally listed by the U.S. Fish and Wildlife  
9 Service (FWS) or State-listed by the LDWF as being threatened, endangered, or proposed for  
10 listing. The report (Enercon 2014) encompassed a desktop survey to determine relevant  
11 species for St. Charles Parish and those species' habitat requirements, as well as a pedestrian  
12 survey of the Entergy property northeast of Highway LA-3127 to assess the presence or  
13 absence of the identified species and associated habitat.

### 14 **3.6.3 WF3 Site**

15 As described in Section 3.2, WF3 is located on a 3,560-ac (1,440-ha) Entergy-owned property  
16 in St. Charles Parish, Louisiana, which borders the west bank of the Mississippi River. Within  
17 the property, 2,345 ac (949 ha) (66 percent) are undeveloped natural areas consisting of the  
18 following land cover types: woody wetlands, emergent herbaceous wetlands, grasslands,  
19 shrub/scrub, barren land, and open water (see Figure 3–13).

20 The principle plant communities on the Entergy property include agricultural land; cypress-gum  
21 swamp; and batture, wax myrtle, and marsh communities. The following subsections describe  
22 these communities in more detail. Unless otherwise noted, the descriptions of these vegetative  
23 communities are derived from Entergy's ER (Entergy 2016a).

#### 24 Agricultural Lands

25 Approximately 23 percent or 823 ac (333 ha) of the Entergy property is in agricultural use.  
26 Entergy leases 660 ac (270 ha) to Raceland Raw Sugar LLC for growing sugar cane, milo, and  
27 soybeans. These lands provide habitat for mourning dove, bobwhite (*Colinus virginianus*),  
28 eastern cottontail (*Sylvilagus floridanus*), common snipe (*Gallinago gallinago*), and various  
29 rodents.

#### 30 Cypress-Gum Swamp

31 Bald cypress and tupelo gum (*Nyssa sylvatica*) dominate the cypress-gum swamp. Button bush  
32 (*Cephalanthus occidentalis*) and duckweed (Subfamily Lemnoideae) are also present in these  
33 areas. This vegetative community is very tolerant to extended periods of water inundation and  
34 provides habitat for a variety of birds, including northern parula (*Parula americana*),  
35 prothonotary warbler (*Protonotaria citrea*), barred owl (*Strix varia*), downy woodpecker (*Picoides*  
36 *pubescens*), yellow-billed cuckoo (*Coccyzus americanus*), and wood duck (*Aix sponsa*).  
37 Common mammals include swamp rabbit, raccoon, white-tailed deer, nutria (*Myocastor*  
38 *coypus*), North American mink (*Mustela vison*), and muskrat (*Ondatra zibethicus*).

#### 39 Batture, Wax Myrtle, and Marsh Communities

40 Batture is the alluvial land between a river and a levee that becomes exposed at low-water  
41 stages. These areas of the Entergy property are characterized by willow (*Salix* spp.), which is  
42 the predominant canopy species, and understory species that include asters (*Aster* spp.),  
43 peppervine (*Ampelopsis arborea*), climbing hempweed (*Mikania scandens*), beggar's lice  
44 (*Hackelia virginiana*), and other weedy species. Other batture areas are dominated by sugar  
45 berry (*Celtis* spp.) with a shrub and herbaceous understory typical of a disturbed habitat.


1

Figure 3–13. Land Cover near WF3



**Legend**

- |                              |                              |
|------------------------------|------------------------------|
| Property Boundary            | Shrub/Scrub                  |
| Open Water                   | Grassland/Herbaceous         |
| Developed, Open Space        | Pasture/Hay                  |
| Developed, Low Intensity     | Cultivated Crops             |
| Developed, Medium Intensity  | Woody Wetlands               |
| Developed, High Intensity    | Emergent Herbaceous Wetlands |
| Barren Land (Rock/Sand/Clay) |                              |



2  
3

Source: Modified from Entergy 2016a

## Affected Environment

1 The wax myrtle community has developed in areas previously under agricultural cultivation.  
2 This community occupies approximately 12 percent or 420 ac (170 ha) of the Entergy property.  
3 Wax myrtle (*Myrica cerifera*) forms a fairly dense cover in these areas, although maple (*Acer*  
4 spp.), ash (*Faxinus* spp.), and dogwood (*Cornus* spp.) are also present. Giant ragweed  
5 (*Ambrosia trifida*) and briars (*Rosa* spp.) are also common in wax myrtle areas bordering  
6 agricultural land.

7 The marsh community occurs near the southern border of the Entergy property and occupies  
8 approximately 23 percent or 808 ac (327 ha). This community is sustained through overflow  
9 and inundation from the Lac des Allemands, which lies about 5.5 mi (8.9 km) southwest of the  
10 Entergy property. Common vegetation includes alligator weed (*Alternanthera philoxeroides*),  
11 water hyacinth, giant cutlass (*Pisum* spp.), cattail (*Typha* spp.), pennywort (*Gotu kola*),  
12 bull-tongue (*Sagittaria* spp.), maidencane (*Panicum hemitomom*), water hyssop (*Bacopa*  
13 *rotundifolia*), and sprangletop (*Leptochloa* spp.). The wetlands likely provide high-quality habitat  
14 for a variety of amphibians and reptiles, including alligators (*Alligator mississippiensis*), western  
15 cottonmouth (*Agkistrodon piscivorus leucostoma*), and bullfrogs (*Rana catesbeiana*).

### 16 **3.6.4 Important Species and Habitats**

17 The Louisiana Natural Heritage Program (LNHP) within the LDWF oversees the State's  
18 Threatened and Endangered Species Conservation Program, as described in Part IV,  
19 "Threatened and Endangered Species," of Title 56 of the Louisiana Revised Statutes. The  
20 Revised Statutes give the LNHP the authority to list species as State-threatened or endangered;  
21 to issue regulations necessary and advisable to provide for conservation of such species; and to  
22 prohibit the export, take, possession, sale, or transport of such species.

23 As part of the Threatened and Endangered Species Conservation Program, the LNHP  
24 maintains a database of rare, threatened, and endangered species of plants and animals and  
25 natural communities in Louisiana. Table 3–9 identifies the plants, animals, and natural  
26 communities listed in the LNHP's database as occurring in St. Charles Parish. The table also  
27 includes habitat associations and the potential for occurrence on the WF3 site based on a  
28 Threatened and Endangered Species Survey performed by Enercon Services, Inc.  
29 (Enercon 2014) to support Entergy's license renewal application. One species, the bald eagle  
30 (*Haliaeetus leucocephalus*) is occasionally observed on the WF3 site. Suitable habitat for three  
31 additional species—floating antler-fern (*Ceratopteris pteridoides*), square-stemmed  
32 monkey-flower (*Mimulus ringens*), and western umbrella sedge (*Fuirena simplex* var.  
33 *aristulata*)—occurs on the WF3 site, but these species do not occur on the site. Each species is  
34 described in more detail below.

#### 35 Bald Eagle (*Haliaeetus leucocephalus*)

36 Bald eagles are protected under the Bald and Golden Eagle Protection Act (16 USC 668 et seq.  
37 (BGEPA)). This Federal act prohibits anyone from taking or disturbing eagles, including their  
38 nests or eggs, without an FWS-issued permit. Additionally, the bald eagle is State-threatened  
39 and has been designated by the LNHP as "S3," rare and local throughout the State or found  
40 locally in a restricted region of the State with 21 to 100 known populations.

41 The bald eagle breeds throughout the coastal United States, southern Canada, and Baja  
42 California, and it winters throughout the United States along river systems, large lakes, and  
43 coastal areas. In Louisiana, the species primarily nests in southeastern coastal parishes and  
44 occasionally on large lakes in northern and central parishes and it is most closely associated  
45 with the Atchafalaya, Barataria, Mississippi, Ouachita, Pearl, Pontchartrain, Red, Sabine,  
46 Terrebonne, and Vermilion-Teche River basins. The LDWF (2016c) considers St. Charles  
47 Parish to be part of the bald eagle's breeding range; therefore, nesting in this parish is possible.

1 No records of nesting on the WF3 site exist. However, the species is known to nest in the  
 2 immediate area of WF3, and Entergy (Entergy 2016a) reports the occasional observation of  
 3 individuals on the WF3 site. The species has historically occurred on and near the site since  
 4 before construction of WF3 (AEC 1973).

5 Floating Antler-fern (*Ceratopteris pteridoides*)

6 The floating antler-fern is not Federally or State-listed, but the LNHP has designated it with a  
 7 State Rank of "S2," imperiled in Louisiana because of rarity with 6 to 20 known populations.

8 The floating antler fern is a member of the water fern family, Parkeriaceae. Its range includes  
 9 Florida and Louisiana south to the West Indies, Central and South America, and southeastern  
 10 Asia. It is a dimorphic fern with two frond types: fertile and sterile. Sterile fronds are broad and  
 11 thin with net-like veins and pinnate lobing. Fertile fronds are erect, longer, and have very  
 12 narrowly divided segments with in-rolled margins. Buds form on sterile frond margins that  
 13 eventually separate from the mother plant to become new plants. Floating antler ferns can be  
 14 found in shade to full sun in swamps, sluggish bayous, ditches, and canals. Plants are usually  
 15 floating and occasionally occur in mud during low water periods. Within Louisiana, floating  
 16 antler-ferns occur in the Pontchartrain, Barataria, Terrebonne, Atchafalaya, and  
 17 Vermilion-Teche River basins (LDWF 2016d).

18 While Enercon (2014) identified suitable habitat for this species in ditches on the WF3 site, the  
 19 species itself was not observed during site surveys.

20 Square-stemmed Monkey-flower (*Mimulus ringens*)

21 The square-stemmed monkey-flower is not Federally or State-listed, but the LNHP has  
 22 designated it with a State Rank of "S2," imperiled in Louisiana because of rarity with 6 to  
 23 20 known populations.

24 The square-stemmed monkey-flower is a member of the figwort family, Scrophulariaceae. Its  
 25 range includes the eastern half of Canada and United States except Florida and several  
 26 western states. It is a 0.3- to 1-m (1- to 3-ft)-tall perennial plant with opposite, sessile leaves  
 27 and double-lipped lavender flowers from April to September. Square-stemmed monkey-flowers  
 28 can be found in partial shade to full sun on sand bars, banks, and in battures of large rivers  
 29 such as the lower Atchafalaya and Mississippi Rivers. Within Louisiana, the species occurs in  
 30 the Pontchartrain, Mississippi, Barataria, Atchafalaya, Vermilion-Teche, Red, and Ouachita  
 31 River basins (LDWF 2016e).

32 While Enercon (2014) identified suitable habitat for this species along the Mississippi River east  
 33 of the WF3 discharge, the species itself was not observed during site surveys.

34 Western Umbrella Sedge (*Fuirena simplex* var. *aristulata*)

35 The western umbrella sedge is not Federally or State-listed, but the LNHP has designated it  
 36 with a State Rank of "S1," critically imperiled in Louisiana because of extreme rarity with 5 or  
 37 fewer known populations.

38 The western umbrella sedge is a member of the sedge family, Cyperaceae. Its range includes  
 39 Arizona east to Mississippi and throughout the southern Great Plains. It is a grass-like  
 40 perennial that grows up to 0.3 m (1 ft) in height. Leaves are alternate, simple, and linear, and  
 41 small green flowers bloom August through November (LBJWC 2016).

42 While Enercon (2014) identified suitable habitat for this species in ditches on the WF3 site, the  
 43 species itself was not observed during site surveys.

1 **3.6.5 Invasive and Non-native Species**

2 The University of Georgia Center for Invasive Species and Ecosystem Health reports  
3 270 invasive species in St. Charles Parish (UGA 2016). Entergy describes the prominent  
4 terrestrial invasive species likely occurring on or adjacent to the WF3 site as: annual bluegrass  
5 (*Poa annua*), bermudagrass (*Cynodon dactylon*), chinaberry (*Melia azedarach*), cogongrass  
6 (*Imperata cylindrica*), Japanese climbing fern (*Lygodium japonicum*), Japanese honeysuckle  
7 (*Lonicera japonica*), Japanese privet (*Ligustrum japonicum*), johnsongrass (*Sorghum*  
8 *halepense*), kudzu (*Pueraria montana* var. *lobata*), Asian tiger mosquito (*Aedes albopictus*),  
9 feral hogs (*Sus scrofa*), formosan termites (*Coptotermes formosanus*), nutria, and red imported  
10 fire ants (*Solenopsis invicta*). Entergy does not maintain any management programs or  
11 procedures specifically related to invasive species because none have interfered with plant  
12 operation (Entergy 2016a).

Table 3–9. Important Terrestrial Species and Habitats in St. Charles Parish

Species	Common Name	State Rank <sup>(a)</sup>	Global Rank <sup>(b)</sup>	State Status <sup>(c)</sup>	Federal Status <sup>(d)</sup>	Habitat Associations	Suitable Habitat Present on WF3 site <sup>(e)</sup>	Record of Species Occurrence on WF3 site <sup>(e)</sup>
<b>Important Animals</b>								
<i>Haliaeetus leucocephalus</i>	bald eagle	S3	G5	SE	FD	Cypress trees near open water; open lakes and rivers.	Yes	Yes, AEC (1973) notes that species is likely to be present within the site's wooded swamps and marshlands and Energy (2016a) reports that individuals occasionally transit the site.
<b>Important Plants</b>								
<i>Asclepias incarnata</i>	swamp milkweed	S2	G5	—	—	Full sun to partial shade in freshwater swamps and marshes; roadside ditches.	No	No
<i>Canna flaccida</i>	golden canna	S4	G4	—	—	Full sun in freshwater marshes and open swamps.	No	No
<i>Ceratopteris pteridoides</i>	floating antler-fern	S2	G5	—	—	Full sun to shade in freshwater wetlands, sluggish bayous, ditches, and canals.	Yes	No
<i>Cyperus distinctus</i>	marshland flatsedge	S1	G4	—	—	Full sun in wetlands, wet meadows, and wet ditches.	No	No

Species	Common Name	State Rank <sup>(a)</sup>	Global Rank <sup>(b)</sup>	State Status <sup>(c)</sup>	Federal Status <sup>(d)</sup>	Habitat Associations	Suitable Habitat Present on WF3 site? <sup>(e)</sup>	Record of Species Occurrence on WF3 site? <sup>(e)</sup>
<i>Fuirena simplex</i> <i>var. aristulata</i>	western umbrella sedge	S1	G5	—	—	Wetland areas throughout the southern Great Plains.	Yes	No
<i>Mimulus ringens</i>	square-stemmed monkey-flower	S2	G5	—	—	Full sun to partial shade in wetlands, sand bars, banks, and battures of large rivers such as the lower Atchafalaya and Mississippi.	Yes	No
<i>Physostegia correllii</i>	Correll's false dragon-head	S1	G2	—	—	Roadside ditches, river banks, and within flowing water.	No	No
<b>Important Natural Communities</b>								
brackish marsh		S3	G4	—	—	Between salt and intermediate marsh and adjacent to the Gulf of Mexico.	No	n/a
cypress-tupelo swamp		S4	G3	—	—	Along river channels, oxbow lakes, floodplains, and low-lying areas.	No	n/a
freshwater marsh		S3	G3	—	—	Adjacent to intermediate marsh along the northern extent of coastal marshes; beside	No	n/a

Species	Common Name	State Rank <sup>(a)</sup>	Global Rank <sup>(b)</sup>	State Status <sup>(c)</sup>	Federal Status <sup>(d)</sup>	Habitat Associations	Suitable Habitat Present on WF3 site <sup>(e)</sup>	Record of Species Occurrence on WF3 site <sup>(e)</sup>
intermediate marsh		S3	G4	—	—	coastal bays where freshwater enters the bay. Between brackish and freshwater marsh; infrequently adjacent to the Gulf of Mexico.	No	n/a
live oak natural levee forest		S1	G2	—	—	In southeastern Louisiana on natural levees or frontlands and on "islands" within marshes and swamps.	No	n/a

<sup>(a)</sup> S1 = critically imperiled in Louisiana because of extreme rarity (5 or fewer known extant populations); S2 = imperiled in Louisiana because of rarity (6 to 20 known extant populations); S3 = rare and local throughout the State or found locally in a restricted region of the State (21 to 100 known extant populations); S4 = apparently secure in Louisiana with many occurrences (100 to 1,000 known extant populations).

<sup>(b)</sup> G1 = critically imperiled globally because of extreme rarity (5 or fewer known extant populations); G2 = imperiled globally because of rarity (6 to 20 known extant populations); G3 = either very rare and local throughout its range or found locally in a restricted area (21 to 100 known extant populations); G4 = apparently secure globally, though it may be quite rare in parts of its range, especially at the periphery (100 to 1,000 known extant populations).

<sup>(c)</sup> SE = State-endangered, taking or harassment of these species is a violation of State law; ST = State-threatened, taking or harassment of these species is a violation of State law; — = not State-listed

<sup>(d)</sup> FE = Federally endangered under the Endangered Species Act of 1973, as amended (ESA); FT = Federally threatened under the ESA; FD = Previously listed, but delisted from the ESA; — = not Federally listed under the ESA.

<sup>(e)</sup> Presence of suitable habitat and records of species occurrences based on 2014 Threatened and Endangered Species Survey (Enercon 2014), Entergy's Environmental Report (Entergy 2016a), and available historical records (AEC 1973; NRC 1981; LP&L 1978).

Source: AEC 1973; Enercon 2014; Entergy 2016a; LNHP 2016sbp; LP&L 1978; NRC 1981

## 1 **3.7 Aquatic Resources**

2 The aquatic communities of interest for the WF3 site occur in the Lower Mississippi River. The  
3 Mississippi River makes up the northwest boundary of the WF3 site, and it supplies makeup  
4 water to WF3's cooling system. The Mississippi River also receives cooling system blowdown.  
5 Section 3.1.3 describes the cooling system in detail, and Section 3.5.1 describes the surface  
6 water characteristics of the Mississippi River.

7 The sections below describe the environmental changes within the Lower Mississippi River  
8 (Section 3.7.1), the aquatic habitats and species within the Lower Mississippi River near WF3  
9 (Section 3.7.2), State-listed aquatic species near WF3 (Section 3.7.3), and non-native species  
10 that occur near WF3 (Section 3.7.4).

### 11 **3.7.1 Environmental Changes in the Lower Mississippi River**

12 The Mississippi River has fluctuated between a meandering and braided river within its geologic  
13 history. During the most recent glacial retreat, the Lower Mississippi River returned to a  
14 meandering river. A river meanders as it erodes the outer bank and then deposits the sediment  
15 on the inner bank, which results in a diverse set of habitats such as extensive floodplains, deep  
16 backwaters, oxbow lakes, and other shallow-water habitats. These waterbody features often  
17 provide high-quality habitat for aquatic biota because of the structural complexity and low flows  
18 that support spawning, feeding, and refuge from large predators. These diverse habitats  
19 support high biological richness with an abundance of fish and invertebrate species that occur  
20 within the Mississippi River (Baker et al. 1991).

21 The Mississippi River has a long history of humans using the river as a mode of transportation,  
22 and subsequently modifying much of the high-quality, shallow-water habitats associated with a  
23 meandering river (Baker et al. 1991). For example, beginning in the 1800s, human  
24 modifications to allow for ship traffic along the Mississippi River and to minimize flooding events  
25 changed the relative abundance and types of habitats, access to fish migratory routes, flow  
26 patterns, and river channelization. For over 300 years, levees have been built along the  
27 Mississippi River to control flooding. By 1844, levees were nearly continuous up to the  
28 confluence with the Arkansas River (Baker et al. 1991). As of 2005, nearly 3,000 km (1,864 mi)  
29 of levees lined the Lower Mississippi River and an additional 1,000 km (621 mi) of levees lined  
30 its tributaries (Brown et al. 2005). Levees decrease the frequency of flooding events, during  
31 which aquatic biota can move between the Mississippi and floodplain habitats. The flow of  
32 aquatic resources from floodplain habitats into the river is one reason that the Lower Mississippi  
33 is so rich in species diversity.

34 Beginning in 1824, the U.S. Government removed snags, such as trees or tree roots, from the  
35 river. Snags provide natural habitat for invertebrates that require a firm attachment site and  
36 places to hide for fish and other aquatic biota. On the other hand, revetments, which are built to  
37 prevent erosion and river meandering, have increased availability of hard-surface habitats but  
38 decreased the availability of soft-surface river bank habitats. Approximately 50 percent of the  
39 banks of the Lower Mississippi River are covered by revetments, such as timber, wooden or  
40 wire fences, rocks, and tires (Baker et al. 1991; Brown et al. 2005).

41 In addition, the USACE has artificially created cutoffs that shortened the length of the river by  
42 cutting across a point bar or neck of a meander. Baker et al. (1991) estimate that artificially  
43 created cutoffs have shortened the length of the Lower Mississippi River by 25 to 30 percent, or  
44 approximately 500 km (310 mi). Cutoffs can also increase the river speed and erosion of river  
45 banks (Baker et al. 1991).

1 In addition to physical changes, runoff from over 40 percent of the conterminous 48 states  
2 drains into the Mississippi River. Land use changes over time has increased the concentration  
3 of industrial, chemical, and sediment inputs into the river. Farming practices currently include  
4 the use of fertilizers, pesticides, and herbicides, which wash into the Mississippi River,  
5 especially after large rain events (Brown et al. 2005). Plowed fields, as compared to forested  
6 areas, also increase the amount of sediments entering the Mississippi River.

7 Currently, the USACE continues to dredge, install river bank revetments and levees, and  
8 regulate upstream reservoirs to minimize the historical movements of the river and create a  
9 relatively stable channel.

### 10 **3.7.2 Lower Mississippi River**

11 The Lower Mississippi River can be divided into two distinct sections: the upper section ranging  
12 from Cairo, Illinois, to Baton Rouge, Louisiana, and the lower section from Baton Rouge to the  
13 Gulf of Mexico. The lower section has been more heavily modified by human activity. For  
14 example, a 12-m (39-ft) channel is maintained in the lower section to promote navigation,  
15 Levees occur along both sides of the rivers, revetments have replaced natural habitats along  
16 much of the riverside, large meander loops are infrequent, and floodplains are rare (Baker et  
17 al. 1991).

18 The aquatic habitats and biota in the Lower Mississippi River near WF3 are discussed below.

#### 19 *3.7.2.1 Aquatic Habitats near WF3*

20 Four types of aquatic habitats occur near WF3: seasonally inundated floodplains along the river  
21 levee, revetments, natural steep river banks, and the channel. A description of each habitat is  
22 provided below.

##### 23 Floodplains

24 Floodplains are one of the most biologically important habitats in the Lower Mississippi River  
25 because the shallow water and habitat structure from trees and plants support use as spawning  
26 grounds, nursery habitats, refuges from predators, and foraging grounds. Seasonally inundated  
27 floodplains near WF3 contain some areas of forested wetlands. However, the habitat quality is  
28 degraded because it is routinely cleared for security reasons (Entergy 2016a). In addition, no  
29 oxbow lakes, sloughs, borrow pits, or ponds occur within the floodplains. Therefore, limited  
30 spawning likely occurs near WF3 (NRC 1981).

##### 31 Steep River Banks

32 Steep river banks occur on the sides of river bends where the main channel current flows  
33 against them (Baker et al. 1991). The fast flow of the Lower Mississippi River often increases  
34 erosion along the river bank. Upstream flow, or eddies, is common along the river bank and  
35 may provide an important refuge of slower moving water for some fish species. Fallen trees  
36 and brush alongside the river provide an important high-quality habitat for fish and substrate for  
37 macroinvertebrates to attach and grow.

##### 38 Revetments

39 Revetments are river banks that are usually cleared and lined with human-modified materials to  
40 prevent erosion (Baker et al. 1991). The revetment banks downstream of the WF3 intake are  
41 lined with crushed concrete both above and below the water surface (ENSR 2007). While  
42 revetments provide a hard substance to support the growth of macroinvertebrates, habitat  
43 quality is lower than river banks for fish because of the lack of structure and refuges provided by  
44 fallen trees and brush typically found along river banks.

## Affected Environment

### 1 Channel

2 The channel near WF3 is characterized by deep water, high current speeds, high levels of  
3 suspended solids, high turbidity, high levels of nutrients, low algal biomass, and uniform bottom  
4 habitat consisting of sand and/or gravel (Baker et al. 1991; ENSR 2007; Entergy 2016a). The  
5 channel typically supports the lowest amount of biological richness because of the lack of  
6 structure to hide from predators and high levels of suspended solids that prevents primary  
7 production, which is the base of many food webs. In addition, high current speeds limit  
8 biological productivity because mobile organisms need to expend additional energy to move,  
9 hover feeding is not possible, and sessile organisms may not be able to stay attached to hard  
10 surfaces. Furthermore, these conditions do not provide suitable habitat for spawning.

### 11 3.7.2.2 *Aquatic Communities in the Lower Mississippi River*

12 Human activities, such as channelization of the river, replacing trees with artificial materials to  
13 line the river, construction of levees, polluted land runoff, and the influx of municipal and  
14 industrial water effluents, has degraded the habitat quality surrounding WF3, thereby influencing  
15 the relatively low biological productivity near WF3, as described below (NRC 1981; Baker et  
16 al. 1991; ENSR 2007).

### 17 Plankton

18 Plankton are small organisms that float or drift in rivers and other water bodies. Plankton are a  
19 primary food source for many fish and other animals. They consist of bacteria, protozoans,  
20 certain algae, tiny crustaceans such as copepods, and many other organisms. High turbidity  
21 (small suspended particles that make the water murky) and fluctuating water levels near WF3  
22 limit primary production for plankton that are dependent upon light for growth, such as  
23 phytoplankton and periphyton (NRC 1981). Low levels of primary production may also limit the  
24 growth of zooplankton and other organisms that feed upon phytoplankton and periphyton.

25 *Phytoplankton.* Phytoplankton are microscopic floating photosynthetic organisms that form  
26 the base of aquatic food webs by producing biomass from inorganic compounds and sunlight.  
27 As primary producers, phytoplankton play key ecosystem roles in the distribution, transfer, and  
28 recycling of nutrients and minerals.

29 Preoperational studies in the 1970s documented extremely low concentrations of phytoplankton  
30 near WF3, likely due to the high suspended sediment load that blocks light from entering the  
31 water and prevents photosynthesis, and therefore growth, of phytoplankton (LPL 1978).  
32 NRC (1981) suggested that locally present phytoplankton likely grew in nearby backwaters or  
33 tributaries and drifted downstream to WF3. Diatoms were the most common type of  
34 phytoplankton, including *Cyclotella* and/or *Melosira* (LPL 1978). Preoperational studies  
35 documented a total of 20 genera of phytoplankton (LPL 1978).

36 *Periphyton.* Periphyton includes a mixture of algae, cyanobacteria (in the past often called  
37 “blue-green algae”), heterotrophic microbes, other small organisms, and detritus that attach to  
38 submerged surfaces. Like phytoplankton, periphyton are primary producers and provide a  
39 source of nutrients to many bottom-feeding organisms.

40 Similar to phytoplankton, preoperational studies in the 1970s documented extremely low  
41 concentrations of periphyton, likely due to the high suspended sediment load that blocks light  
42 from entering the water and prevents photosynthesis, and therefore growth, of periphyton.  
43 Cyanobacteria were most dominant during summer months (LPL 1978).

44 *Zooplankton.* Zooplankton are small animals that float, drift, or weakly swim in the water column  
45 and include ichthyoplankton (fish eggs and larvae) with no or limited swimming ability and larvae

1 of benthic invertebrates. Zooplankton are important trophic links between primary producers  
 2 (e.g., phytoplankton and periphyton) and carnivores (e.g., fish).  
 3 Preoperational studies from 1974–1976 found low levels of zooplankton, including fish eggs and  
 4 larvae (ichthyoplankton), rotifers, protozoa, and copepods (LPL 1978; NRC 1981). Given the  
 5 lack of spawning grounds near WF3, high current flows, and high levels of suspended solids,  
 6 LPL (1978) suggested that most zooplankton originated in backwaters or shallow habitats and  
 7 then drifted toward the WF3 site. Peak densities of ichthyoplankton of 0.043/m<sup>3</sup> (0.033/yd<sup>3</sup>)  
 8 occurred from May through July (LPL 1978; NRC 1981). Commonly collected ichthyoplankton  
 9 taxa included Clupeidae or herrings (threadfin shad [*Dorosoma petenense*], gizzard shad  
 10 [*Dorosoma cepedianum*], and skipjack herring [*Alosa chrysochloris*]); Cyprinidae or minnow  
 11 family (carp, chubs, minnows, and shiners); Ictaluridae or catfish family, including blue catfish  
 12 (*Ictalurus furcatus furcatus*) and channel-catfish (*Ictalurus punctatus*) larvae; Centrarchidae or  
 13 sunfish family (sunfish, bass, and crappies) and Sciaenidae (freshwater drum [*Aplodinotus*  
 14 *grunniens*]) (LPL 1978; NRC 1981). River shrimp (*Macrobrachium ohione*) larvae were also  
 15 commonly collected (Entergy 2016a).

16 Fish

17 Between 100 to 200 fish species are known to occur within the Lower Mississippi River  
 18 (Baker et al. 1991). Prior to operations, LPL conducted preoperational surveys near WF 1, 2,  
 19 and 3 (ENSR 2007). Entergy conducted fish surveys near WF3 from 1973 through 1980.  
 20 However, Entergy has not conducted fish surveys near WF3 since operations began in 1985.  
 21 Entergy’s impingement studies at WF 1 and 2 also provide information regarding the ambient  
 22 fish populations near WF3. In order to gather additional data regarding fish populations near  
 23 WF3, the NRC staff reviewed survey data recorded within an online database, FishNet (2014).  
 24 This database is a collaborative effort by natural history museums and biodiversity institutions to  
 25 compile fish survey data. The database included fish surveys within the vicinity of WF3 from  
 26 1953, 1982, 1997, 1998, and 2000. The NRC staff notes that the surveys used different  
 27 methodologies, sampling locations, sampling protocols, and equipment. Therefore, a species  
 28 may occur near WF3 but may not have been captured in a survey due to the various survey  
 29 methods and sampling regimes. Table 3–10 describes fish species that have been observed  
 30 during three time periods: 1953, 1972–1982, and 1997–2007.

31 The fish survey data indicate that common fish species near WF3 include gizzard shad,  
 32 threadfin shad, skipjack herring, Gulf menhaden (*Brevoortia patronus*), bay anchovy (*Anchoa*  
 33 *mitchilli*), blue and channel catfish, river carpsucker (*Carpionodes carpio*), hogchoker (*Trinectes*  
 34 *maculatus*), silverband shiner (*Notropis shumardi*), white bass (*Morone chrysops*), striped mullet  
 35 (*Mugil cephalus*), and freshwater drum (Table 3–10). Commercially important fish species  
 36 include blue catfish, bigmouth buffalo (*Ictiobus cyprinellus*), smallmouth buffalo (*Ictiobus*  
 37 *bubalus*), channel catfish, flathead catfish (*Pylodictis olivaris*), and freshwater drum  
 38 (LDWF 2015).

39 **Table 3–10. Fish Species near WF3 from 1953 through 2007**

Species	Common Name <sup>(b)</sup>	Survey Year(s) <sup>(a)</sup>		
		1953 <sup>(c)</sup>	1973-1982 <sup>(d)</sup>	1997-2007 <sup>(e)</sup>
<b>Achiridae</b>				
<i>Trinectes maculatus</i>	hogchoker		X	X
<b>Acipenseridae</b>				
<i>Scaphirhynchus platyrhynchus</i>	shovelnose sturgeon		X	X

Affected Environment

Species	Common Name <sup>(b)</sup>	Survey Year(s) <sup>(a)</sup>		
		1953 <sup>(c)</sup>	1973-1982 <sup>(d)</sup>	1997-2007 <sup>(e)</sup>
<b>Atherinidae</b>				
<i>Menidia audens</i>	Mississippi silverside	X	X	
<b>Catostomidae</b>				
<i>Carpiodes carpio</i>	river carpsucker	X	X	
<i>Cycleptus elongatus</i>	blue sucker			X
<i>Ictiobus bubalus</i>	smallmouth buffalo	X	X	X
<i>Ictiobus cyprinellus</i>	bigmouth buffalo		X	X
<b>Centrarchidae</b>				
<i>Lepomis cyanellus</i>	green sunfish		X	
<i>Lepomis gulosus</i>	warmouth		X	
<i>Lepomis humilis</i>	orangespotted sunfish	X	X	X
<i>Lepomis macrochirus</i>	bluegill		X	X
<i>Lepomis megalotis</i>	longear sunfish		X	
<i>Lepomis symmetricus</i>	bantam sunfish		X	
<i>Micropterus dolomieu</i>	smallmouth bass			X
<i>Micropterus salmoides</i>	largemouth bass		X	
<i>Pomoxis annularis</i>	white crappie		X	
<i>Pomoxis nigromaculatus</i>	black crappie		X	X
<b>Clupeidae</b>				
<i>Alosa chrysochloris</i>	skipjack herring	X	X	X
<i>Brevoortia patronus</i>	Gulf menhaden		X	
<i>Dorosoma cepedianum</i>	gizzard shad		X	X
<i>Dorosoma petenense</i>	threadfin shad	X	X	X
<b>Cyprinidae</b>				
<i>Carassius auratus</i>	goldfish			X
<i>Cyprinella lutrensis</i>	red shiner			X
<i>Cyprinella spiloptera</i>	spotfin (spottail) shiner			X
<i>Cyprinus carpio</i>	common carp			X
<i>Hypophthalmichthys nobilis</i>	bighead carp			X
<i>Notropis atherinoides</i>	emerald shiner		X	X
<i>Notropis blennioides</i>	river shiner		X	X
<i>Notropis dorsalis</i>	bigmouth shiner			X
<i>Notropis shumardi</i>	<b>silverband shiner</b>	X	X	X
<i>Notropis texanus</i>	weed shiner	X		
<i>Notropis volucellus</i>	mimic shiner			X
<i>Opsopoeodus emiliae</i>	pugnose minnow	X	X	
<i>Pimephales vigilax</i>	bullhead minnow		X	

Species	Common Name <sup>(b)</sup>	Survey Year(s) <sup>(a)</sup>		
		1953 <sup>(c)</sup>	1973-1982 <sup>(d)</sup>	1997-2007 <sup>(e)</sup>
<b>Engraulidae</b>				
<i>Anchoa mitchilli</i>	bay anchovy		X	X
<b>Fundulidae</b>				
<i>Fundulus chrysotus</i>	golden topminnow		X	
<b>Hiodontidae</b>				
<i>Hiodon alosoides</i>	mooneyes			X
<b>Ictaluridae</b>				
<i>Ameiurus melas</i>	black bullhead	X	X	
<i>Ictalurus furcatus furcatus</i>	blue catfish	X	X	X
<i>Ictalurus punctatus</i>	channel catfish		X	X
<i>Pylodictis olivaris</i>	flatheaded catfish		X	X
<b>Lepisosteidae</b>				
<i>Lepisosteus osseus</i>	longnose gar		X	X
<b>Moronidae</b>				
<i>Morone chrysops</i>	white bass		X	X
<i>Morone saxatilis</i>	striped bass		X	X
<b>Mugilidae</b>				
<i>Mugil cephalus</i>	striped mullet		X	X
<b>Percidae</b>				
<i>Sander canadensis</i>	sauger		X	X
<b>Poeciliidae</b>				
<i>Gambusia affinis</i>	mosquitofish		X	
<i>Heterandria formosa</i>	least killifish		X	
<b>Polyodontidae</b>				
<i>Polyodon spathula</i>	paddlefish		X	X
<b>Sciaenidae</b>				
<i>Aplodinotus grunniens</i>	freshwater drum	X	X	X

(a) X = Studies where species were identified.

(b) Bold = Commonly collected species (more than 10% of the reported collection)

(c) FishNet 2014: Survey conducted by R.D. Suttkus & Webb in 1953 in Mississippi River by the U.S. Bonnet Carre Spillway

(d) LPL 1978, ENSR 2007: Aquatic sampling within the vicinity of WF3 from 1973-1980; Commonly impinged species at WF1 & WF 2 in 1976-1977

FishNet 2014: Survey conducted by E.B. Pebbles & D.L. Rome in 1982 in Mississippi River by the U.S. Bonnet Carre Spillway

(e) ENSR 2007: Impinged species at WF1 and WF2 during 2006-2007 surveys

FishNet 2014: Surveys conducted by Atwood and Walsh (1997), Atwood (1998), and Atwood and Walsh (2000) in the Mississippi River by Little Rock Ferry (RM 125.3)

Sources: LPL 1978; ENSR 2007; FishNet 2014

1 Invertebrates

2 At least 200 macroinvertebrate species occur in the Lower Mississippi River (Harrison and  
3 Morse 2012). LPL (1978) conducted macroinvertebrate sampling from 1973 through 1976 near  
4 WF3. LPL (1978) reported relatively low numbers of macroinvertebrates likely due to the fast  
5 current, scouring, and shifting bottom surfaces that prevent sessile macroinvertebrates from  
6 attaching to hard surfaces to grow. The most common benthic (bottom dwelling) taxa were  
7 aquatic worms (Oligochaetes) and Asian clams (*Corbicula*). River shrimp and grass shrimp  
8 (*Palaemonetes* spp.), both decapods, have also been commonly observed near WF3  
9 (LPL 1978, ENSR 2007; Entergy 2016a). During preoperational sampling, LPL (1978) observed  
10 female river shrimp carrying eggs near WF3.

11 Blue crabs (*Callinectes sapidus*) are a commercially important benthic invertebrate that  
12 infrequently occur near WF3, usually during periods of extremely low river discharge  
13 (ENSR 2007; LDWF 2015). Blue crabs typical occur within estuarine waters, but they may  
14 travel upriver, especially for spawning activities. No suitable spawning for blue crabs occur near  
15 WF3.

16 **3.7.3 State-Listed Species**

17 Paddlefish (*Polyodon spathula*) and pallid sturgeon (*Scaphirhynchus albus*) are the only aquatic  
18 State-protected species within St. John the Baptist Parish and St. Charles Parish (LDFW 2016).  
19 Pallid sturgeon is a Federally endangered species and discussed in further detail in Section 3.8.

20 LDWF (2016) rank paddlefish as S4, or a species that is apparently secure in Louisiana with  
21 100 to 1,000 known populations. Paddlefish are large freshwater fish with several primitive  
22 features. This species typically occurs in large, free-flowing rivers and spawn in shallow, fast  
23 moving waters above gravel bars. Paddlefish previously occurred throughout the Mississippi  
24 River and Great Lake drainages, but they are currently confined to the Mississippi drainage  
25 area. Threats to paddlefish include habitat alteration, especially to spawning habitat; pollution;  
26 and harvesting for caviar (LDWF undated; NatureServe 2015).

27 LPL (1978) observed paddlefish within the vicinity of WF3 during preoperational studies from  
28 1973 through 1976. Juvenile paddlefish were impinged at WF 1 and 2 during the 1976 to 1977  
29 study as well as the 2006 to 2007 study (ENSR 2007). ENERCON (2014) conducted a  
30 reconnaissance survey for threatened and endangered plants and animals and noted that  
31 paddlefish may swim by the intake and discharge. However, ENERCON (2014) did not conduct  
32 any in-water surveys.

33 **3.7.4 Non-Native and Nuisance Species**

34 Several species of aquatic plants, fish, and invertebrates have been introduced within the Lower  
35 Mississippi River. Many of these species become an ecological concern if they outcompete  
36 native species for space, prey, or other limited resources. Water hyacinth (*Eichhornia*  
37 *crassipes*) and some *Salvinia* species are invasive aquatic plants that grow rapidly on the  
38 surface of the Mississippi River. These plants can outcompete native species by fundamentally  
39 changing water quality parameters and habitat structure as they reduce available space on the  
40 surface of the river and reduce the available oxygen and light levels for native species within the  
41 Mississippi River (Toft et al. 2003; McFarland et al. 2004). These physical effects can lead to a  
42 decline in oxygen and light sensitive species, as well as trophic-level cascades. For example,  
43 Toft et al. (2003) documented trophic level changes after the introduction of water hyacinth  
44 whereby predators of oxygen and light-sensitive species decreased and prey of oxygen and  
45 light-sensitive species increased.

1 Several species of invasive Asian carp occur near WF3, including silver carp  
 2 (*Hypophthalmichthys molitrix*), grass carp (*Ctenopharyngodon idella*), bighead carp  
 3 (*Hypophthalmichthys nobilis*) (Entergy 2016a; ACOE undated). Common carp (*Cyprinus carpio*),  
 4 which come from coastal areas of the Caspian and Aral Seas, also occur near WF3  
 5 (Entergy 2016a). Common and Asian carp tend to grow quickly and outcompete native fish  
 6 species while rapidly consuming prey items such as aquatic plants, plankton, and benthic  
 7 invertebrates. Common carp also degrade water quality conditions by increasing turbidity and  
 8 uprooting submerged aquatic vegetation during active feeding sessions (Nico et al. 2005).

9 The Rio Grande cichlid (*Cichlasoma cyanoguttatum*) is native to southern Texas and  
 10 northeastern Mexico and was likely introduced into the Lower Mississippi River watershed as a  
 11 result of an aquarium release or fish farm escape (Nico et al. 2013). The Rio Grande cichlid  
 12 tends to be tolerant of physical disturbances and low-quality habitat conditions. Given this wide  
 13 tolerance level, Lorenz and O'Connell (2011) suggest that this invasive species can likely  
 14 spread post-flooding events and may outcompete native species post-disturbances, such as  
 15 hurricanes or floods, when water quality tends to be low and natural habitat structures have  
 16 been degraded.

17 In addition to fish, non-native invertebrate species have been introduced and established  
 18 substantial populations within the Mississippi River. Zebra mussels are native to the Black and  
 19 Caspian Seas, and they were introduced into the Great Lakes within the ballast water of  
 20 freighters around 1988. Since that time, zebra mussels spread throughout the Great Lakes and  
 21 Mississippi River. Zebra mussels attached to hard surfaces to grow. When attached to  
 22 underwater piping or other structures related to the intake system, these organisms can cause  
 23 biofouling. Entergy occasionally detects zebra mussels at WF3 (Entergy 2016a).

## 24 **3.8 Special Status Species and Habitats**

25 This section addresses species and habitats Federally protected under the Endangered Species  
 26 Act of 1973 (16 U.S.C. § 1531 et seq.) (ESA) and the Magnuson–Stevens Fishery Conservation  
 27 and Management Reauthorization Act, as amended (16 U.S.C. §§ 1801–1884) (MSA). The  
 28 NRC has direct responsibilities under the ESA and MSA prior to taking a Federal action, such  
 29 as Waterford license renewal. The terrestrial and aquatic resource sections (Sections 3.6  
 30 and 3.7, respectively) discuss species and habitats protected by other Federal acts and the  
 31 State of Louisiana under which the NRC does not have direct responsibilities.

### 32 **3.8.1 Species and Habitats Protected Under the Endangered Species Act**

33 The FWS and the National Marine Fisheries Service (NMFS) jointly administer the ESA. The  
 34 FWS manages the protection of, and recovery effort for, listed terrestrial and freshwater  
 35 species, and NMFS manages the protection of and recovery effort for listed marine and  
 36 anadromous species. This section describes the action area and considers separately those  
 37 species that could occur in the action area under both FWS's and NMFS's jurisdictions.

#### 38 **3.8.1.1 Action Area**

39 The implementing regulations for section 7(a)(2) of the ESA define "action area" as all areas  
 40 affected directly or indirectly by the Federal action and not merely the immediate area involved  
 41 in the action (50 CFR 402.02). The action area effectively bounds the analysis of  
 42 ESA-protected species and habitats because only species that occur within the action area may  
 43 be affected by the Federal action.

44 For the purposes of the ESA analysis in this SEIS, the NRC staff considers the action area to be  
 45 the 3,560-ac (1,440-ha) Entergy site (described in Sections 3.2 and 3.6) and the Mississippi

## Affected Environment

1 River (described in Section 3.7) from the WF3 intake at RM 129.6 to the downstream extent of  
2 the 2.8 °C (5 °F) isotherm within WF3's thermal plume. The WF3 thermal plume varies with  
3 season, but the plume generally increases as flow decreases, such that the thermal plume is  
4 largest under low flow conditions. Section 4.7.1.3 describes the WF3 thermal plume and  
5 associated LPDES permit limitations on thermal effluent in detail. Section 3.1.3 describes the  
6 WF3 intake and discharge, and Section 3.5.1 describes the characteristics of the Mississippi  
7 River within the vicinity of WF3.

8 The NRC staff recognizes that while the action area is stationary, Federally listed species can  
9 move in and out of the action area. For instance, a migratory fish species could occur in the  
10 action area seasonally as it travels up or down the Mississippi River past WF3. Similarly, a  
11 flowering plant known to occur near, but outside, of the action area could appear within the  
12 action area over time if its seeds are carried into the action area by wind, water, or animals.  
13 Thus, in its analysis, the NRC staff considers not only those species known to occur directly  
14 within the action area, but also those species that may passively or actively move into the action  
15 area. The staff then considers whether the life history of each species makes the species likely  
16 to move into the action area where it could be affected by the proposed WF3 license renewal.

17 Within the action area, Federally listed terrestrial species could experience impacts such as  
18 habitat disturbance associated with ground-disturbing activities, collisions with transmission  
19 lines, exposure to radionuclides, and other direct and indirect impacts associated with station,  
20 cooling system, and in-scope transmission line operation and maintenance (NRC 2013). The  
21 proposed action has the potential to affect Federally listed aquatic species in several ways,  
22 including impingement or entrainment of individuals into the cooling system, thermal discharges  
23 from cooling system operation, and exposure to radionuclides or other contaminants  
24 (NRC 2013).

25 The following sections first discuss species under the FWS's jurisdiction followed by those  
26 under NMFS's jurisdiction.

### 27 3.8.1.2 Species and Habitats Under the FWS's Jurisdiction

28 The NRC staff used the FWS's Environmental Conservation Online System (ECOS) Information  
29 for Planning and Conservation (IPaC) tool to determine species that may be present in the WF3  
30 action area. The ECOS IPaC tool identified three species under the FWS's jurisdiction as  
31 potentially occurring in the action area: the gulf subspecies of Atlantic sturgeon (*Acipenser*  
32 *oxyrinchus desotoi*), pallid sturgeon (*Scaphirhynchus albus*), and West Indian manatee  
33 (*Trichechus manatus*) (FWS 2017). No proposed species, candidate species, or proposed or  
34 designated critical habitat occurs within the action area (FWS 2017).

#### 35 Atlantic Sturgeon, Gulf Subspecies (*Acipenser oxyrinchus desotoi*)

36 On September 30, 1991, the FWS listed the gulf sturgeon as threatened wherever found  
37 (56 FR 49653). The FWS designated critical habitat for the species on March 19, 2003  
38 (68 FR 13370). In 2014, the FWS reclassified the gulf sturgeon as a subspecies of the Atlantic  
39 sturgeon. Overfishing, damming on rivers containing spawning habitat, dredging and other  
40 channel improvement and maintenance activities, water quality degradation through point and  
41 nonpoint discharges, and climate change are the primary factors that have contributed to this  
42 species' decline (FWS and NMFS 2009). Unless otherwise noted, information about this  
43 species is derived from the FWS's final critical habitat rule (68 FR 13370).

44 The gulf subspecies of the Atlantic sturgeon ("gulf sturgeon") is an anadromous fish that inhabits  
45 coastal rivers from Louisiana to Florida during the warmer months and overwinters in estuaries,  
46 bays, and the Gulf of Mexico. The species is a nearly cylindrical primitive fish with embedded  
47 bony plates or scutes, an extended snout, and an asymmetrical tail. Adults range from 1.2 to

1 2.4 m (4 to 8 ft) in length, and females are larger than males. The gulf sturgeon is  
2 geographically separated from the Atlantic coast subspecies (*Acipenser oxyrinchus oxyrinchus*)  
3 and is morphologically distinguished by its longer head and pectoral fins.

4 Historically, the gulf sturgeon occurred from the Mississippi River east to Tampa Bay. Its  
5 present range extends from Lake Pontchartrain and the Pearl River system in Louisiana and  
6 Mississippi east to the Suwannee River in Florida. Spawning currently occurs in seven river  
7 systems: the Pearl, Pascagoula, Escambia, Yellow, Choctawhatchee, Apalachicola, and  
8 Suwannee (FWS and NMFS 2009).

9 Gulf sturgeon can reach 42 years of age. Females reach maturity at 8 to 17 years, and males  
10 reach maturity at 7 to 21 years. Females spawn at intervals from every 3 to 5 years and males  
11 every 1 to 5 years. Mature females produce an average of 400,000 eggs, which they typically  
12 lay on limestone bluff and outcroppings, cobble, limestone bedrock covered with gravel and  
13 small cobble, gravel, or sand in waters 1.4 to 7.9 m (4.6 to 26 ft) in depth and 18.2 to 23.9 °C  
14 (64.8 to 75.0 °F) in temperature. Eggs are demersal, adhesive, and gray to brown to black in  
15 color. Larval survival is optimal at water temperatures of 15 to 20 °C (59 to 68 °F) according to  
16 laboratory tests. Young-of-the-year disperse widely throughout their natal river and are typically  
17 found on sandbars and sand shoals over rippled bottom and in shallow, relatively open waters.

18 Migratory behavior of gulf sturgeon appears to be influenced by a number of factors, including  
19 sex, reproductive status, water temperature, and river flow. Gulf sturgeon spend their adult lives  
20 in marine and estuarine environments and migrate upriver to freshwater to breed and spawn. In  
21 the spring (March to May), adults and subadults return to the upper reaches of their natal river,  
22 where sexually mature sturgeon spawn. Once adults spawn, individuals typically move  
23 downriver to summer resting or holding areas, where they remain until October or November.  
24 Individuals spend late fall through early spring in estuarine areas, bays, or in the Gulf of Mexico.

25 Although the historic range of the gulf sturgeon includes the Mississippi River, individuals rarely  
26 migrate far into the Mississippi River because of a lack of spawning habitat (Nature  
27 Conservancy 2016), and no known spawning sites presently occur within the Mississippi River  
28 (68 FR 13370; FWS and NMFS 2009). The NRC staff reviewed available impingement studies  
29 conducted 0.4 mi (0.6 km) west-northwest of WF3 at Waterford 1 and 2 from 1976–1977 and  
30 2006–2007 (ENSR 2007; Espey Huston & Associates 1977). The Gulf sturgeon was not  
31 collected during either of these studies. In its review of aquatic data from other Lower  
32 Mississippi River energy-generating facilities, ENSR (2007) stated that no Entergy plant in the  
33 area has recorded impingement of Gulf sturgeon. Based on the available information, the NRC  
34 staff concludes that adult gulf sturgeon may occasionally occur in the Mississippi River  
35 downriver of WF3, but that individuals are unlikely to travel as far upriver as the WF3 site.  
36 Therefore, the gulf sturgeon is unlikely to occur in the action area.

### 37 Pallid Sturgeon (*Scaphirhynchus albus*)

38 On September 6, 1990, the FWS listed the pallid sturgeon as endangered wherever found  
39 (55 FR 36641). The FWS has not designated critical habitat for the species. Overfishing,  
40 curtailment of range, habitat destruction and modification, altered flow regimes, water quality  
41 issues, low population size, and lack of recruitment are the primary factors that have contributed  
42 to this species' decline (55 FR 36641; FWS 2014). Unless otherwise noted, information about  
43 this species is derived from the FWS's (2014) revised recovery plan.

44 Pallid sturgeon is a benthic, riverine fish with a flattened shovel-shaped snout and a long,  
45 slender, and armored peduncle (the tapered portion of the body that terminates at the tail).  
46 Adults can reach lengths of 1.8 m (6 ft). The species is similar in appearance to the more

## Affected Environment

1 common shovelnose sturgeon (*Scaphirhynchus platyrhynchus*), which is Federally listed as  
2 threatened due to similarity of appearance.

3 The pallid sturgeon is native to the Mississippi River Basin, including the Mississippi River,  
4 Missouri River, and their major tributaries (i.e., Platte, Yellowstone, and Atchafalaya Rivers).  
5 Historically, the species' range encompassed about 3,515 continuous RM (5,656 Rkm) in these  
6 rivers and its tributaries within Montana, North Dakota, South Dakota, Nebraska, Iowa, Kansas,  
7 Missouri, Kentucky, Tennessee, Arkansas, Louisiana, and Mississippi. The present known  
8 range spans the length of the historical range, but consists of disconnected reaches of these  
9 rivers as a result of damming and other obstructions to fish passage.

10 Pallid sturgeon can reach ages of 60 years or more. Females reach maturity at 15 to 20 years,  
11 and males reach maturity at approximately 5 years. Females spawn at intervals of every 2 to  
12 3 years. Mature females in the upper reaches of the Missouri River produce 150,000 to  
13 170,000 eggs, while females in the southern extent of the range typically produce significantly  
14 fewer eggs (43,000 to 58,000). Females spawn adjacent to or over coarse substrate such as  
15 boulder, gravel, or cobble or in bedrock within deeper water with relatively fast, converging  
16 flows. Incubation is approximately 5 to 7 days, and newly hatched larvae are pelagic and drift  
17 downstream in currents for 11 to 13 days. Habitat requirements for larvae and  
18 young-of-the-year are unknown due to low populations of spawning adults and poor recruitment  
19 across the species' range. However, requirements may be similar to other *Scaphirhynchus*  
20 species. *Scaphirhynchus* young-of-the-year in the Middle Mississippi River are often found in  
21 channel border and island-side channel habitats with low velocities (1 meter per second (m/s) or  
22 3.3 feet per second (fps)), moderate depths (2 to 5 m or 6.6 to 16.4 ft), and sand substrate.

23 Adults prefer bottom habitats of large river systems. Juveniles and adults are almost always  
24 observed in flowing portions of main channels in the upper reaches of the species' range and in  
25 channel border habitats and inundated floodplain habitats with flowing water in the more  
26 channelized lower Missouri and Mississippi Rivers. Pallid sturgeon are most often associated  
27 with sandy and fine bottom substrates, and individuals exhibit a selection for sand over mud,  
28 silt, or vegetation. Across their range, individuals have been documented in waters of varying  
29 depths and velocities that range from 0.58 m to greater than 20 m (1.9 to greater than 65 ft) and  
30 velocities of less than 1.5 m/s (less than 4.9 ft/s) and an average of 0.58 m/s to 0.88 m/s  
31 (1.9 fps to 2.9 fps). Pallid sturgeon have been collected from a variety of turbidity conditions,  
32 including highly altered systems with low turbidity and relatively natural systems with seasonally  
33 high turbidity.

34 Age-0 pallid sturgeon eat zooplankton, mayflies (Ephemeroptera) and midge (Chironomidae)  
35 larvae, and small invertebrates. Juveniles and adults eat fish and aquatic insect larvae with a  
36 trend toward piscivory as individuals increase in size. Cyprinidae, Sciaenidae, and Clupeidae  
37 make up the majority of the adult diet, although diet varies by season and location (Hoover  
38 et al. 2007).

39 Prior to listing, pallid sturgeon collections on the Lower Mississippi River were rare, so the  
40 historical baseline population size is undocumented (FWS 2013). A few juveniles have been  
41 collected in the 1970s during impingement and entrainment studies associated with Lower  
42 Mississippi River energy-generating facilities near WF3 as described below.

- 43 • Between April 1973 and September 1976, LP&L (1979) collected four juvenile pallid  
44 sturgeon in the Mississippi River during a CWA 316(b) demonstration study  
45 associated with WF3. LP&L collected samples via surface trawl, otter trawl,  
46 electrofishing, and gill net at five locations both upstream and downstream of WF3.  
47 Gear type and specific collection sites associated with the pallid sturgeon collections  
48 are not specified in the study.

- 1 • In 1976, Espey Huston & Associates (1977) collected two juvenile pallid sturgeon  
2 during the May 18–19, 1976, and July 27–28, 1976, 24-hour sampling periods of a  
3 Waterford 1 and 2 screen impingement study. Waterford 1 and 2 lies at RM 129.9  
4 (209.1 RKM) directly upstream and on the same side (west bank) of the Mississippi  
5 River as WF3.
- 6 • Between January 1976 and January 1977, one juvenile pallid sturgeon was impinged  
7 over the course of a CWA 316(a) and 316(b) impingement and entrainment study  
8 associated with Willow Glen Power Station, which lies upstream of WF3 at RM 201  
9 (RKm 323) (ENSR 2007).

10 Pallid sturgeon in the Lower Mississippi River belong to the Coastal Plain Management Unit  
11 (CPMU), which includes the Lower Mississippi River from the confluence of the Ohio River,  
12 Illinois, to the Gulf of Mexico in Louisiana. As of 2013, over 1,100 pallid sturgeon had been  
13 captured in the CPMU since listing (more than 500 from the Lower Mississippi River and more  
14 than 600 from the Atchafalaya River) (FWS 2013). The southernmost collection of pallid  
15 sturgeon has been at RM 95.5 (RKm 154), which is 34.1 RM (54.9 RKm) downstream of where  
16 WF3 withdraws Mississippi River water for cooling. Given the location of the WF3 intake and  
17 the fact that pallid sturgeon have been collected in historical studies at other Lower Mississippi  
18 River energy-generating plants, pallid sturgeon individuals have the potential to occur in the  
19 WF3 action area. For instance, in 2008, during an emergency opening of the Bonnet Carre  
20 Spillway, which lies 1 mi (1.6 km) east-northeast and downstream of WF3, the FWS (2013)  
21 estimated that up to 92 pallid sturgeon were injured or killed due to entrainment.

22 Based on the available information, the NRC staff concludes that pallid sturgeon may occur in  
23 the Mississippi River within the WF3 action area.

#### 24 West Indian Manatee (*Trichechus manatus*)

25 The FWS listed the West Indian manatee as endangered in the first Endangered Species List  
26 under the Endangered Species Preservation Act of 1966, a predecessor to the ESA. Following  
27 the promulgation of the ESA in 1973, the FWS designated critical habitat in 1976  
28 (41 FR 41914), which was subsequently amended in 1977 (42 FR 47840). All critical habitat  
29 units lie within Florida and its coastal waters. On April 5, 2017, the FWS downlisted the species  
30 from endangered to threatened due to the species' partial recovery (82 FR 16668). Within the  
31 United States, primary threats to the species include watercraft collisions and the loss of winter  
32 warm-water habitat; outside the United States, primary threats are habitat fragmentation and  
33 loss (82 FR 16668). The West Indian manatee is also protected under the Marine Mammal  
34 Protection Act of 1972, as amended (16 U.S.C. § 1361 et seq.), which established a moratorium  
35 on the direct or indirect taking of all species of marine mammals in the United States.

36 The West Indian manatee is a marine species. Although it occurs in the Gulf of Mexico, it does  
37 not occur in the Mississippi River; therefore, it would not occur in the WF3 action area. For this  
38 reason, this species is not described in any further detail in this SEIS.

#### 39 *3.8.1.3 Species and Habitats under the NMFS's Jurisdiction*

40 The NRC staff did not identify any Federally listed species or critical habitats under the NMFS's  
41 jurisdiction with the potential to occur in the action area.

### 42 **3.8.2 Species and Habitats Protected under the Magnuson-Stevens Act**

43 NMFS has not designated essential fish habitat within the Mississippi River. Therefore, this  
44 section does not contain a discussion of any species or habitats protected under the MSA.

### 1 **3.9 Historic and Cultural Resources**

2 This section describes the cultural background and the historic and cultural resources found at  
3 WF3 and in the surrounding area. The National Historic Preservation Act of 1966, as amended  
4 (NHPA) (54 U.S.C. 300101 et seq.), requires Federal agencies to consider the effects of their  
5 undertakings on historic properties. Renewing the operating license of a nuclear power plant is  
6 an undertaking that could potentially affect historic properties. Historic properties are defined as  
7 resources included on, or eligible for inclusion on, the National Register of Historic Places  
8 (NRHP). The criteria for eligibility are listed in the 36 CFR 60.4 and include (1) association with  
9 significant events in history; (2) association with the lives of persons significant in the past;  
10 (3) embodiment of distinctive characteristics of type, period, or construction; and (4) sites or  
11 places that have yielded, or are likely to yield, important information.

12 In accordance with 36 CFR 800.8(c), the NRC complies with the obligations required under  
13 NHPA Section 106 through its process under the National Environmental Policy Act of 1969, as  
14 amended (NEPA) (42 U.S.C. 4321 et seq.). In the context of NHPA, the area of potential effect  
15 (APE) for a license renewal action is the area at the WF3 and its immediate environs. WF3 is  
16 located within the 3,560-acre (1,440-ha) Entergy Louisiana, LLC property. This property  
17 constitutes the APE and consists primarily of wetlands, agriculture, and developed areas.  
18 These land areas may be impacted by maintenance and operations activities during the license  
19 renewal term. The APE may extend beyond the immediate WF3 environs if Entergy's  
20 maintenance and operations activities affect offsite historic properties. This is irrespective of  
21 land ownership or control.

22 In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort  
23 to identify historic properties within the APE. If the NRC finds that either there are no historic  
24 properties within the APE or the undertaking (license renewal) would have no effect on historic  
25 properties, the NRC provides documentation of this finding to the State Historic Preservation  
26 Officer (SHPO). In addition, the NRC notifies all consulting parties, including Indian tribes, and  
27 makes this finding public (through the NEPA process) prior to issuing the renewed operating  
28 licenses. Similarly, if historic properties are present and could be affected by the undertaking,  
29 the NRC is required to assess and resolve any adverse effects in consultation with the SHPO  
30 and any Indian tribe that attaches religious and cultural significance to identified historic  
31 properties. The Louisiana Office of Cultural Development is responsible for administering  
32 Federal and State-mandated historic preservation programs to identify, evaluate, register, and  
33 protect Louisiana's archaeological and historical resources. Within this office, the Division of  
34 Historic Preservation and the Division of Archaeology jointly comprise the State Historic  
35 Preservation Office (SHPO) (LOCD 2011, 2017).

#### 36 **3.9.1 Cultural Background**

37 The history of the human occupation of the WF3 area is briefly described in this section using  
38 the following chronologic cultural sequence (Entergy 2016a):

- 39 • Paleo-Indian Period (8,000+ years BP),
- 40 • Archaic Period (8,000 BP to 3,500 BP),
- 41 • Woodland Period (3,500 BP to AD 1,200),
- 42 • Mississippi Period (AD 1200 to 1450),
- 43 • Protohistoric and European Contact (AD 1450 to 1700), and
- 44 • Historic Era (AD 1700 to present).

1 The Paleo-Indian Period is generally characterized by highly mobile bands of hunters and  
2 gatherers hunting small and large game animals (e.g., giant armadillo, mammoth, and dire wolf)  
3 and gathering plants. Paleo-Indian sites are not common in Louisiana because these nomadic  
4 people left very few artifacts at any one location. Paleo-Indian groups who may have been  
5 living in the vicinity of WF3 during this period would have exploited the rich coastal and riverine  
6 resources. However, because over time the sea level has risen and the course of the  
7 Mississippi River has shifted, many Paleo-Indian coastal remains are now either submerged,  
8 washed away, or deeply buried under silt. A typical Paleo-Indian archaeological site might  
9 consist of an isolated Clovis stone point or knife characteristic of the period. A few such points  
10 have been found in the parishes north of Lake Pontchartrain (Neuman and Hawkins 2013;  
11 Entergy 2016a).

12 The Archaic Period represents a continuation of the hunter and gatherer subsistence economy  
13 practiced during the Paleo-Indian Period. In contrast to their predecessors, these groups  
14 generally remained longer in each camp and limited their roaming to several favored campsites  
15 within a smaller geographical range. Archaeological sites in southeast Louisiana from this  
16 period tend to be located predominantly along coastal and inland waters, and they are  
17 characterized by well-developed shell middens, large numbers of milling implements and fishing  
18 tools, and evidence of earthen mounds (Neuman and Hawkins 2013; Entergy 2016a).

19 The Woodland Period experienced a transition from earlier hunting and gathering cultures to  
20 one characterized by village settlements, food production, pottery manufacture, and shell and  
21 earthen mound building. The Woodland period in Louisiana lasted from approximately  
22 3,500 BP to AD 1200, and included several distinct occupations, including the Poverty Point,  
23 Tchefuncte, Marksville, Troyville, and Coles Creek cultures. During the Woodland Period,  
24 Louisiana Indians likely traded with members of the highly influential Hopewell Culture that was  
25 centered in Ohio and Illinois, as evidenced by their use of similarly-fashioned burial mounds,  
26 pottery, pipes, and ornamental objects. Archaeological sites from this period indicate an  
27 increased use of habitation areas for longer periods of time than those that pre-date this period,  
28 but they are not considered to have been permanently occupied. (Neuman and Hawkins 2013,  
29 Entergy 2016a).

30 The Mississippi Period is characterized by major changes in settlement, subsistence patterns,  
31 and social structure. Large, highly centralized chiefdoms with permanent settlement sites  
32 supported by numerous satellite villages emerged during this period. The platform mound, a  
33 new ceremonial earthen mound, appeared in association with these permanent settlements.  
34 Platform mounds, burial mounds, and fortified defensive structures were often constructed in  
35 clusters in settlements of this period. Mississippian Period subsistence relied heavily on maize  
36 agriculture, as well as hunting and gathering. Long-distance trading increased and craft  
37 specialists produced highly specialized lithic and ceramic artifacts, beadwork, and shell  
38 pendants. Mississippian Culture spread rapidly through the major river valleys of the Southeast.  
39 In the Lower Mississippi Valley of Louisiana, the Mississippian culture is believed to have  
40 encountered and merged with the resident Plaquemine Culture, thought to be decedents of the  
41 earlier Troyville/Coles Creek occupations. Over time, the Plaquemine adopted distinctive  
42 Mississippian customs and techniques for making pottery and other ceremonial objects.  
43 Louisiana peoples that may have descended from the Mississippian Culture include those who  
44 speak the Tunican, Chitimachan, and Muskogean languages, whereas those that may have  
45 descended from the Plaquemine Culture include the Taensa and Natchez (Neuman and  
46 Hawkins 2013; Entergy 2016a).

47 In 1682, French explorers—led by Robert de La Salle—travelling downriver on the Mississippi  
48 were the first Europeans to lay claim to southeast Louisiana. These European explorers  
49 encountered several native villages established along the Mississippi River, including the

## Affected Environment

1 Acolapissa, Quinipissa, Bayagoula/Mugulasha, Ouacha, Chaouacha, Tangipahoa, and Houma.  
2 Diseases carried by the European explorers spread rapidly through these native groups and  
3 killed many of their members, resulting in significant changes to their way of life. Attempts at  
4 colonization of the area by the French were unsuccessful until 1699. (Neuman and  
5 Hawkins 2013; Entergy 2016a).

6 The Historic Era in Louisiana can be characterized by three settlement periods, each under  
7 different sovereign rule. During the French Colonial Period (AD 1700 to 1763), most settlers in  
8 the French colony of Louisiana were of French or French-Canadian descent, although large  
9 numbers of Germans and Swiss also settled along the Mississippi River above New Orleans in  
10 what is now St. Charles and St. John the Baptist parishes. In 1762, France secretly ceded  
11 Louisiana to Spain as part of the Treaty of Fontainebleau, leading to the Spanish Colonial  
12 Period (AD 1763 to 1803). Spain saw the colony as a means to limit British expansionism in the  
13 area, and it was during this time that vegetable and indigo production came to prominence in  
14 the region, to eventually be replaced by sugarcane and cotton production.

15 Control over Louisiana was transferred back to France by way of treaty in 1800, who in turn sold  
16 the territory to the United States in 1803 as part of the Louisiana Purchase. Early in the ensuing  
17 American Period (AD 1803 to present), plantations harvesting sugarcane, rice, and cypress  
18 timber dominated the economy and culture of the area. Sugar production fell dramatically  
19 following the Civil War and the abolition of slavery as plantations struggled to maintain sufficient  
20 labor supplies. Chinese, Portuguese, Italian, and German immigrant labor was used to  
21 augment the African-American workers who chose to remain.

22 During the 20th century, agricultural cultivation and timbering enterprises began to give way to  
23 the establishment of large petrochemical industrial complexes and marine terminals along both  
24 banks of the Mississippi River in St. Charles Parish. To provide adequate electrical supply to  
25 the area's growing industrial and residential customers, LP&L (later Entergy Louisiana, LLC)  
26 acquired the Killona and Waterford Plantations in 1963 as the sites on which to construct and  
27 operate the Waterford 1 and 2 steam electric stations. A third unit, WF3, began commercial  
28 operation in 1985 (Entergy 2016a).

### 29 **3.9.2 Historic and Cultural Resources at Waterford Steam Electric Station, Unit 3**

30 Historic and cultural resources in the vicinity of WF3 include prehistoric era and historic era  
31 archaeological sites, historic districts, and buildings, as well as any site, structure, or object that  
32 may be considered eligible for listing on the NRHP. Historic and cultural resources also include  
33 traditional cultural properties that are important to a living community of people for maintaining  
34 their culture. "Historic property" is the legal term for a historic or cultural resource that is  
35 included on, or eligible for inclusion on, the NRHP.

36 Construction of the existing WF3 facility likely disturbed any historic and archaeological  
37 resources that may have been located within its footprint. However, much of the surrounding  
38 area is still used for agriculture and remains largely undisturbed. Although no comprehensive  
39 Phase I cultural resources survey has been completed for the entire 3,560-acre Entergy  
40 Louisiana, LLC property, several cultural resources studies of the WF3 site were conducted  
41 between 1976 and 2004 (Entergy 2016a). In addition, Entergy conducted a literature review of  
42 archaeological sites in the vicinity of WF3 in 2014. The results of these studies indicate that  
43 there are 42 known historic and cultural resources within a 6-mi (10-km) radius of WF3,  
44 encompassing portions of both St. Charles and St. John the Baptist parishes. Ten of these  
45 resources are either NRHP-listed, eligible for listing on the NRHP, or have the equivalent  
46 eligibility or potential eligibility under national heritage or legacy commission designations, and  
47 are therefore considered historic properties within the context of NHPA. One of these historic

1 properties, the former Waterford Plantation and its associated areas, is located on site. This  
 2 archaeological site (16SC41) occupies almost half of the Entergy Louisiana, LLC property, and  
 3 a portion of it has been determined eligible for inclusion on the NRHP. The eligibility of the rest  
 4 of site 16SC41 is unknown (DOI 2017; Entergy 2016a).

5 Outside of the Entergy Louisiana, LLC property, but within a 6-mi (10-km) radius, are eight  
 6 NRHP-listed properties, as well as one other that has been determined eligible for inclusion on  
 7 the NRHP. The NRHP-listed properties include six aboveground properties and two  
 8 archaeological sites. The nearest aboveground property to WF3 is the Dorvin House, located  
 9 approximately 3 mi (5 km) east. The two archaeological sites (16SC50 and 16SC51) comprise  
 10 the Kenner and Kugler Cemeteries Archaeological District, located approximately 2 mi (3 km)  
 11 northeast of the plant (DOI 2017; Entergy 2016a).

12 Of the remaining 32 archaeological resources identified within the 6-mi (10-km) radius, 7 have  
 13 been determined ineligible by the SHPO; 2 have been determined as partially  
 14 ineligible/unknown; and 23 have not been evaluated and are therefore unknown (Entergy 2016).  
 15 Additional areas that likely contain *in situ* archaeological deposits have also been identified in  
 16 association with the Waterford Plantation and nearby Killona Plantation sugarhouses. Although  
 17 no specific traditional cultural properties have yet to be identified on the Entergy Louisiana, LLC  
 18 property, there is a high probability that a portion of the WF3 site was once the location of an  
 19 Ouacha Indian village from 1718 to 1721, and later served as the site of two German  
 20 settlements in 1721 and 1724 (Entergy 2016a).

21 **3.10 Socioeconomics**

22 This section describes current socioeconomic factors that have the potential to be directly or  
 23 indirectly affected by changes in operations at WF3. WF3 and the communities that support it  
 24 can be described as a dynamic socioeconomic system. The communities supply the people,  
 25 goods, and services required to operate the nuclear power plant. Power plant operations, in  
 26 turn, supply wages and benefits for people and dollar expenditures for goods and services. The  
 27 measure of a community’s ability to support WF3 operations depends on its ability to respond to  
 28 changing environmental, social, economic, and demographic conditions.

29 **3.10.1 Power Plant Employment**

30 The socioeconomics region of influence (ROI) is defined by the areas where WF3 workers and  
 31 their families reside, spend their income, and use their benefits, thus affecting the economic  
 32 conditions of the region. Entergy employs a permanent workforce of approximately 641 workers  
 33 (Entergy 2016 ER). Approximately 90 percent of WF3 workers reside in nine Louisiana  
 34 parishes (see Table 3–11). The remaining workers are spread among 18 parishes and counties  
 35 in Louisiana and four other states, with numbers ranging from 1 to 21 workers per parish or  
 36 county (Entergy 2016 ER). Given the residential locations of WF3 workers, the most significant  
 37 effects of plant operations are likely to occur in St. Charles and Jefferson parishes. Table 3–11  
 38 presents geographic distribution of the Entergy workforce at WF3 across nine parishes. The  
 39 focus of the impact analysis, therefore, is on the socioeconomic impacts of continued WF3  
 40 operations on St. Charles and Jefferson parishes.

41 **Table 3–11. Entergy Employees Residence by Louisiana Parish**

Parish	Number of Employees	Percentage of Total
Ascension	65	10
Jefferson	98	15

## Affected Environment

Parish	Number of Employees	Percentage of Total
Lafourche	45	7
Orleans	35	6
St. Charles	187	29
St. James	30	5
St. John the Baptist	46	7
St. Tammany	30	5
Tangipahoa	34	5
Other parishes and counties outside of Louisiana	71	11
<b>Total</b>	<b>641</b>	<b>100</b>

Source: Entergy 2016a

1 Entergy purchases goods and services to facilitate WF3 operations. Although specialized  
 2 equipment and services are procured from a wider region, some proportion of the goods and  
 3 services used in plant operations are acquired from within the ROI. These transactions fuel a  
 4 portion of the local economy because jobs are provided and plant suppliers make local  
 5 purchases.

6 Refueling outages occur on an 18-month cycle and historically have lasted approximately 25 to  
 7 30 days. During refueling outages, site employment typically increases by an additional 700 to  
 8 900 temporary workers (Entergy 2016a). Outage workers are drawn from all regions of the  
 9 country; however, the majority would be expected to come from Louisiana.

### 10 3.10.1 Regional Economic Characteristics

11 This section presents information on employment and income in the WF3 socioeconomic ROI.

#### 12 3.10.1.1 Regional Employment and Income

13 From 2010 to 2016, the labor force in the WF3 ROI increased 2.9 percent to just over 900,000.  
 14 In addition, the number of employed persons increased by 4.9 percent, to approximately  
 15 860,000. Consequently, the number of unemployed people in the ROI decreased by nearly  
 16 22 percent to over 53,000, or about 6.0 percent of the total current workforce—down from  
 17 7.7 percent in 2010 (BLS 2017).

18 According to the U.S. Census Bureau's (USCB's) 2011–2015 American Community Survey  
 19 5-Year Estimates, the educational, health, and social services industry represented the largest  
 20 employment sector in the socioeconomic ROI (approximately 20 percent) followed by retail  
 21 trade and arts, entertainment, recreation, accommodation, and food services (approximately  
 22 12 percent) and professional, scientific, management, administrative, and waste management  
 23 services (approximately 11 percent). A list of employment by industry in each parish of the ROI  
 24 is provided in Table 3–12.

25 **Table 3–12. Employment by Industry in the WF3 ROI (2011–2015, 5-year estimates)**

Industry	St. Charles	Jefferson	Total	Percent
Total employed civilian workers	24,804	210,346	235,150	–
Agriculture, forestry, fishing, hunting, and mining	240	3,975	4,215	1.8
Construction	2,431	21,086	23,517	10.0

Industry	St. Charles	Jefferson	Total	Percent
Manufacturing	3,044	13,468	16,512	7.0
Wholesale Trade	1,095	7,155	8,250	3.5
Retail Trade	2,760	24,790	27,550	11.7
Transportation, warehousing, and utilities	1,992	12,419	14,411	6.1
Information	295	3,368	3,663	1.6
Finance, insurance, real estate, rental, and leasing	1,081	13,148	14,229	6.1
Professional, scientific, management, administrative, and waste management services	2,086	23,015	25,101	10.7
Educational, health, and social services	5,256	41,474	46,730	19.9
Arts, entertainment, recreation, accommodation, and food services	2,238	25,117	27,355	11.6
Other services (except public administration)	1,219	10,835	12,054	5.1
Public administration	1,067	10,496	11,563	4.9

Source: USCB 2017a

1 Estimated income information for the WF3 ROI is presented in Table 3–13. According to the  
2 USCB’s 2011–2015 American Community Survey 5-Year Estimates, 15.2 percent of families  
3 and 19.8 percent of people in Louisiana were living below the Federal poverty threshold and the  
4 median household and per capita incomes for Louisiana were \$45,047 and \$24,981,  
5 respectively (USCB 2017a). People living in St. Charles Parish have higher median household  
6 and per capita incomes (\$59,990 and \$27,247, respectively) than the state averages, with fewer  
7 families and people (8.8 percent and 11.8 percent, respectively) living below the poverty level.  
8 In addition, people living in Jefferson Parish also have higher median household and per capita  
9 incomes (\$47,947 and \$27,127, respectively) than the state averages, with 13.0 percent of  
10 families and 16.8 percent of persons living below the official poverty level (USCB 2017a).

11 **Table 3–13. Estimated Income Information for the WF3 ROI (2011–2015, 5-year estimates)**

	St. Charles	Jefferson	Louisiana
Median household income (dollars) <sup>(a)</sup>	59,900	47,947	45,047
Per capita income (dollars) <sup>(a)</sup>	27,247	27,127	24,981
Families living below the poverty level (percent)	8.8	13.0	15.2
People living below the poverty level (percent)	11.8	16.8	19.8

<sup>(a)</sup> In 2015 inflation adjusted dollars.

Source: USCB 2017a

### 12 3.10.1.2 Unemployment

13 According to the USCB’s 2011–2015 American Community Survey 5-Year Estimates, the  
14 unemployment rates in St. Charles Parish and Jefferson Parish were 7.7 and 6.7 percent,  
15 respectively. Comparatively, the unemployment rate in the State of Louisiana during this same  
16 time period was 8.1 percent (USCB 2017a).

1 **3.10.2 Demographic Characteristics**

2 According to the 2010 Census, an estimated 371,976 people lived within 20 mi (32 km) of WF3,  
 3 which equates to a population density of 296 persons per square mile (Entergy 2016a). This  
 4 translates to a Category 4, “least sparse” population density using the license renewal GEIS  
 5 (NRC 1996) measure of sparseness (greater than or equal to 120 persons per square mile  
 6 within 20 miles). An estimated 2,006,583 people live within 50 miles (80 km) of WF3 with a  
 7 population density of 255 persons per square mile (Entergy 2016a). This translates to a  
 8 Category 4 density, using the license renewal GEIS (NRC 1996) measure of proximity (greater  
 9 than or equal to 190 persons per square mile within 50 mi (80 km)). In addition, three  
 10 communities within a 50-mile (80-km) radius have a population greater than 100,000 residents.  
 11 Therefore, WF3 is located in a high population area based on the GEIS sparseness and  
 12 proximity matrix.

13 Table 3–14 shows population projections and percent growth from 1980 to 2060 in the  
 14 two-Parish WF3 ROI. Over the last several decades, St. Charles Parish has experienced  
 15 increasing population yet declining growth rates. In contrast, Jefferson Parish has experienced  
 16 a fluctuating growth rate with periods of decline as well as small growth. From both 1980 to  
 17 1990 and from 1990 to 2000, St. Charles Parish’s growth rates were relatively large. From 2000  
 18 to 2010, the St. Charles Parish population growth rate was 9.8 percent, while Jefferson Parish’s  
 19 population decreased by 5 percent. Based on forecasts, the population in both parishes is  
 20 expected to increase at moderate to low rates.

21 **Table 3–14. Population and Percent Growth in WF3 ROI Parishes 1980–2010,**  
 22 **2014 (estimated), and Projected for 2020–2060**

Year	St. Charles		Jefferson	
	Population	Percent Change	Population	Percent Change
1980	37,259	–	454,592	–
1990	42,437	13.9	448,306	-1.4
2000	48,072	13.3	455,466	1.6
2010	52,780	9.8	432,522	-5.0
<b>2015</b>	<b>52,639</b>	<b>-0.3</b>	<b>435,092</b>	<b>0.6</b>
2020	57,930	9.8	450,200	4.1
2030	60,580	4.6	454,670	1.0
2040	63,230	4.4	459,140	1.0
2050	65,880	4.2	463,610	1.0
2060	68,530	4.0	468,080	1.0

Sources: Decennial population data for 1970-2010 and estimated 2015 (USCB 2017b); projections for 2020–2030 by State of Louisiana, Division of Administration (Louisiana Division of Administration, No Date); 2040–2060 calculated.

23 The 2010 Census demographic profile of the two-parish ROI population is presented in  
 24 Table 3–15. According to the 2010 Census, minorities (race and ethnicity combined) comprised  
 25 approximately 43 percent of the total two-parish population. The largest minority populations in

1 the ROI were Black or African American (approximately 26 percent) and Hispanic, Latino, or  
 2 Spanish origin of any race (approximately 12 percent).

3 **Table 3–15. Demographic Profile of the Population in the WF3 ROI in 2010**

	St. Charles	Jefferson	ROI
<b>Total Population</b>	<b>52,780</b>	<b>432,552</b>	<b>485,332</b>
<b>Race (percent of total population, Not-Hispanic or Latino)</b>			
White	66.2	56.0	57.1
Black or African American	26.4	25.9	25.9
American Indian and Alaska Native	0.3	0.4	0.4
Asian	0.8	3.8	3.5
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0
Some other race	0.1	0.2	0.2
Two or more races	1.2	1.2	1.2
<b>Ethnicity</b>			
Hispanic or Latino	2,648	53,702	56,350
Percent of total population	5.0	12.4	11.6
<b>Minority population (including Hispanic or Latino ethnicity)</b>			
Total minority population	17,855	190,284	208,139
Percent minority	33.8	44.0	42.9

Source: USCB 2017b

4 According to the USCB's 2011–2015 American Community Survey 5-Year Estimates  
 5 (USCB 2017), since 2010 minority populations in the ROI were estimated to have increased by  
 6 approximately 8,200 persons and now comprise approximately 44 percent of the ROI population  
 7 (see Table 3–16). The largest increase occurred in the Hispanic, Latino, or Spanish origin of  
 8 any race population (nearly 6,000 persons since 2010, an increase of approximately  
 9 10 percent). The next largest increase in minority population was Asian, an increase of  
 10 approximately 1,500 persons or approximately 9 percent from 2010.

11 **Table 3–16. Demographic Profile of the Population in the WF3 ROI (2011–2015,**  
 12 **5-Year Estimates)**

	St. Charles	Jefferson	ROI
<b>Total Population</b>	<b>52,639</b>	<b>435,092</b>	<b>487,731</b>
<b>Race (percent of total population, Not-Hispanic or Latino)</b>			
White	65.7	54.4	55.6
Black or African American	26.1	25.9	25.9
American Indian and Alaska Native	0.2	0.4	0.3
Asian	1.1	4.1	3.8
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0

Affected Environment

	St. Charles	Jefferson	ROI
Some other race	0.2	0.3	0.2
Two or more races	1.0	1.4	1.4
Ethnicity			
Hispanic or Latino	2,971	58,988	61,959
Percent of total population	5.6	13.6	12.7
Minority population (including Hispanic or Latino ethnicity)			
Total minority population	18,049	198,334	216,383
Percent minority	34.3	45.6	44.4

Source: USCB 2017c

1 3.10.2.1 Transient Population

2 Within 50 mi (80 km) of WF3, colleges and recreational opportunities attract daily and seasonal  
3 visitors who create a demand for temporary housing and services. In 2015, approximately  
4 35,000 students attended colleges and universities within 50 mi (80 km) of WF3 (NCES 2016a).

5 Based on USCB’s 2011–2015 American Community Survey 5-Year Estimates (USCB 2017d),  
6 approximately 22,200 seasonal housing units are located within 50 mi (80 km) of WF3. Of  
7 those, 2,781 were located in the socioeconomic ROI. Table 3–17 presents information about  
8 seasonal housing for the parishes located all or partly within 50 mi (80 km) of WF3.

9 **Table 3–17. 2011–2015 5-Year Estimated Seasonal Housing in Parishes Located within**  
10 **50 mi (80 km) of WF3**

Parish	Total Housing Units	Vacant Housing Units: for Seasonal, Recreation, or Occasional Use	Percent
Louisiana			
Ascension	43,255	468	1.1
Assumption	10,470	634	6.1
East Baton Rouge	190,343	3,197	1.7
Iberia	30,002	345	1.1
Iberville	12,914	461	3.6
<b>Jefferson</b>	<b>189,163</b>	<b>2,659</b>	<b>1.4</b>
Lafourche	39,418	851	2.2
Livingston	52,888	1,146	2.2
Orleans	191,951	5,929	3.1
Plaquemines	9,813	506	5.2
St. Bernard	16,800	452	2.7
<b>St. Charles</b>	<b>20,209</b>	<b>122</b>	<b>0.6</b>
St. Helena	5,163	431	8.3
St. James	8,650	61	0.7
St. John the Baptist	17,584	20	0.1

Parish	Total Housing Units	Vacant Housing Units: for Seasonal, Recreation, or Occasional Use	Percent
St. Martin	22,390	1,109	5.0
St. Mary	23,162	532	2.3
St. Tammany	97,891	1,342	1.4
Tangipahoa	51,938	1,096	2.1
Terrebonne	44,363	787	1.8
West Baton Rouge	9,873	30	0.3
<b>Total</b>	<b>1,088,240</b>	<b>22,178</b>	<b>2.5</b>

Parishes within 50 mi (80 km) of WF3 with at least one block group located within the 50-mi (80-km) radius.

Note: ROI parishes are in bold italics.

Source: USCB 2017d

1 **3.10.2.2 Migrant Farm Workers**

2 Migrant farm workers are individuals whose employment requires travel to harvest agricultural  
 3 crops. These workers may or may not have a permanent residence. Some migrant workers  
 4 follow the harvesting of crops, particularly fruit, throughout rural areas of the United States.  
 5 Others may be permanent residents living near WF3 and travel from farm to farm harvesting  
 6 crops.

7 Migrant workers may be members of minority or low-income populations. Because they travel  
 8 and can spend a significant amount of time in an area without being actual residents, migrant  
 9 workers may be unavailable for counting by census takers. If uncounted, these minority and  
 10 low-income workers would be “underrepresented” in the decennial Census population counts.

11 In the 2002 Census of Agriculture, farm operators were asked whether they hired migrant  
 12 workers—defined as a farm worker whose employment required travel—to do work that  
 13 prevented the migrant workers from returning to their permanent place of residence the same  
 14 day. The Census is conducted every 5 years and results in a comprehensive compilation of  
 15 agricultural production data for every county and Parish in the nation.

16 Information about both migrant and temporary farm labor (working less than 150 days) can be  
 17 found in the 2012 Census of Agriculture. Table 3–18 supplies information about migrant and  
 18 temporary farm labor within 50 mi (80 km) of WF3. According to the 2012 Census,  
 19 approximately 3,350 farm workers were hired to work for less than 150 days and were  
 20 employed on 1,047 farms within 50 mi (80 km) of WF3. The Parish with the highest number of  
 21 temporary farm workers (561) on 195 farms was Tangipahoa Parish, Louisiana (NASS 2014).

1 **Table 3–18. Migrant Farm Workers and Temporary Farm Labor in Parishes Located within**  
 2 **50 mi (80 km) of WF3 (2012)**

Parish <sup>(a)</sup>	Number of Farms with Hired Farm Labor <sup>(b)</sup>	Number of Farms Hiring Workers for Less Than 150 Days <sup>(b)</sup>	Number of Farm Workers Working for Less Than 150 Days <sup>(b)</sup>	Number of Farms Reporting Migrant Farm Labor <sup>(b)</sup>
<b>Louisiana</b>				
Ascension	49	34	158	6
Assumption	51	34	182	14
East Baton Rouge	101	82	167	0
Iberia	108	75	482	20
Iberville	69	37	216	13
<b>Jefferson</b>	<b>16</b>	<b>7</b>	<b>(c)</b>	<b>0</b>
Lafourche	83	65	199	10
Livingston	82	74	(D)	3
Orleans	7	7	(D)	0
Plaquemines	55	45	130	5
St. Bernard	24	18	(c)	0
<b>St. Charles</b>	<b>10</b>	<b>8</b>	<b>(c)</b>	<b>0</b>
St. Helena	92	76	190	1
St. James	31	25	106	12
St. John the Baptist	5	4	(c)	2
St. Martin	100	72	235	22
St. Mary	45	28	250	19
St. Tammany	163	112	249	16
Tangipahoa	257	195	561	9
Terrebonne	56	26	120	7
West Baton Rouge	37	23	104	5
<b>Total</b>	<b>1,441</b>	<b>1,047</b>	<b>3,349</b>	<b>164</b>

(a) Parishes within 50 mi (80 km) of WF3 with at least one block group located within the 50-mi (80-km) radius.

(b) Table 7. Hired farm Labor – Workers and Payroll: 2012.

(c) Withheld to avoid disclosing data for individual farms.

Note: ROI parishes are in bold italics.

Source: 2012 Census of Agriculture – Parish Data (NASS 2014)

3 A total of 164 farms, in the 50-mi (80-km) radius of the WF3 reported hiring approximately  
 4 1,400 migrant workers in the 2012 Census. St. Martin Parish had the highest number of farms  
 5 (22) reporting migrant farm labor (154 workers) (NASS 2014).

### 1 3.10.3 Housing and Community Services

2 This section presents information regarding housing and local public services, including  
3 education and water supply.

#### 4 3.10.3.1 Housing

5 Table 3–19 lists the total number of occupied and vacant housing units, vacancy rates, and  
6 median value in the ROI. Based on USCB’s 2011–2015 American Community Survey 5-year  
7 estimates (USCB 2017e), there were approximately 209,000 housing units in the ROI, of which  
8 over 186,000 were occupied. The median values of owner-occupied housing units in the ROI  
9 range from \$172,700 in Jefferson Parish to \$184,300 in St. Charles Parish. The vacancy rate  
10 also varied slightly between the two parishes, from 2.0 percent in St. Charles Parish to  
11 2.1 percent in Jefferson Parish (USCB 2017e).

12 **Table 3–19. Housing in the WF3 ROI (2011–2015, 5-year Estimate)**

	St. Charles	Jefferson	ROI
Total housing units	20,209	189,163	209,372
Occupied housing units	18,383	168,104	186,487
Total vacant housing units	1,826	21,059	22,885
Percent total vacant	9.0	11.1	10.9
Owner occupied units	14,886	103,991	118,877
Median value (dollars)	184,300	172,700	174,153
Owner vacancy rate (percent)	2.0	2.1	2.1
Renter occupied units	3,497	64,113	67,610
Median rent (dollars/month)	896	900	900
Rental vacancy rate (percent)	8.5	9.3	9.3

Source: USCB 2017e

#### 13 3.10.3.2 Education

14 St. Charles Parish has 1 public school district of which there are a total of 15 schools. During  
15 the 2015–2016 school year, approximately 9,500 students were enrolled (NCES 2016b).

#### 16 3.10.3.3 Public Water Supply

17 The St. Charles Parish Waterworks Department is the service provider for Parish residents and  
18 relies on the Mississippi River as its water source. It also provides potable water to WF3. As  
19 shown in Table 3–20, demand on the East Bank services is currently at approximately  
20 31 percent of capacity. The West Bank Water District demand is currently at 41.1 percent of  
21 capacity. The East Bank system was recently upgraded and there are currently no plans to  
22 expand the West Bank system (Entergy 2016a).

23 The Jefferson Parish Water Department is also organized into East Bank and West Bank  
24 districts, and the Mississippi River is the water source. The East Bank water district serves a  
25 population of 243,782. Demand is currently at approximately 41 percent of capacity. The West  
26 Bank district serves a population of 188,770, and demand is at 35.7 percent of capacity.  
27 Population in the Parish has declined since 2000 and consumption is expected to remain  
28 relatively steady in the near future (Entergy 2016a).

## Affected Environment

1 Table 3–20 lists the largest public water suppliers in St. Charles Parish and Jefferson Parish  
 2 and provides water source and population served for those suppliers. Currently, there is excess  
 3 capacity in the major public water systems.

4 **Table 3–20. Public Water Supply Systems in St. Charles Parish and Jefferson Parish**

Public Water System	Source	Design Capacity (mgd)	Average Production (mgd)	Demand (percent of capacity)	Population Served <sup>(a)</sup>
<b>St. Charles Parish</b>					
St. Charles Water District East Bank (New Sarpy)	Surface water	13	4	30.7	29,517
St. Charles Water District West Bank (Luling)	Surface water	9	3.7	41.1	31,485
<b>Jefferson Parish</b>					
Jefferson Water Department East Bank Complex	Surface water	87	35.3	40.6	243,782
Jefferson Water Department West Bank Complex	Surface water	61	21.8	35.7	188,770

(a) Safe Drinking Water Search for the State of Louisiana (EPA 2017).

Sources: Entergy 2016a; EPA 2015

### 5 **3.10.4 Tax Revenues**

6 Entergy pays annual property taxes to St. Charles Parish based on the assessed value of WF3.  
 7 The State of Louisiana calculates a total entity or unit value for regulated utilities in the State,  
 8 including Entergy Louisiana, LLC, and does not value WF3 separately. Entergy Louisiana, LLC  
 9 property in Louisiana was assessed at approximately \$558 million in 2015 (LTC 2015, page 9).  
 10 The 2015 taxable assessed value of Entergy Louisiana, LLC property allocated to St. Charles  
 11 Parish was approximately \$183.6 million dollars (SCP 2016b, page 154). Entergy Louisiana,  
 12 LLC does not receive separate tax invoices from St. Charles Parish for power plants. In 2015,  
 13 Entergy Louisiana, LLC paid approximately \$22.4 million in property taxes to St. Charles Parish  
 14 (Table 3–21).

15 Total property tax revenues for St. Charles Parish, including Parish and local taxes, were  
 16 approximately \$147.4 million in 2015. The two largest programs receiving Parish funds were  
 17 school maintenance at approximately \$52 million, with total school taxes equaling approximately  
 18 \$70 million, and law enforcement at approximately \$22 million, with total law enforcement  
 19 equaling approximately \$27 million. (LTC 2015, page 76) In 2015, Entergy Louisiana, LLC  
 20 payments to St. Charles Parish in property taxes represented roughly 15 percent of the total  
 21 Parish property tax revenues. Entergy Louisiana, LLC anticipates that the company's assessed  
 22 value and tax rates will continue to fluctuate; however, Entergy Louisiana, LLC does not expect  
 23 these changes to be notable or significant changes to future property tax payments.

24 Other than property taxes, no other significant payments are made by Entergy Louisiana, LLC to  
 25 St. Charles Parish on behalf of WF3.

**Table 3–21. Entergy Louisiana, LLC Property Tax Payments, 2010–2015**

Year	Entergy Louisiana, LLC Property Taxes (in millions of dollars)	St. Charles Parish Revenues (in millions of dollars)	Percent of Parish Revenue
2010	21.4	116.5	18
2011	21.4	125.9	17
2012	20.7	131.4	16
2013	20.5	136.5	15
2014	20.8	142.9	15
2015	22.4	147.4	15

Source: Entergy 2016a, Entergy 2016b

**3.10.5 Local Transportation**

The primary access to WF3 is from state route Louisiana-18 (LA-18) on the north side of the power plant. LA-3127 has the heaviest east-west traffic within a 6-mi (9.7-km) radius of WF3. The LA-18 traffic counts taken at locations east and southeast of WF3 in St. Charles Parish have been slowly rising, whereas counts taken northwest of the plant in St. John the Baptist Parish have decreased. LA-3142, located east of the plant, is a predominantly north-south collector road and carries the greatest amount of traffic, linking LA-3127 to LA-18 (Entergy 2016a).

Table 3–22 lists state roads near WF3 and Louisiana Department of Transportation & Development (LaDOTD) average annual daily traffic (AADT) volumes. The AADT values represent traffic volumes for a 24-hour period factored by both day of week and month of year.

**Table 3–22. Louisiana State Routes in the Vicinity of WF3: 2016 Average Annual Daily Traffic Count**

Roadway and Location	Mile Marker	Average Annual Daily Traffic (AADT) and Average Daily Traffic (ADT)
<b>LA-18</b>		
Northwest of LA-3141 (St. John the Baptist)	43.14	1,274 <sup>(a)</sup>
East of LA-3142 (St. Charles)	51.12	4,069
Southeast of LA-3160 (St. Charles)	52.57	6,968
<b>LA-3127</b>		
Northwest of LA-3141 (St. John the Baptist)	29.18	6,938 <sup>(a)</sup>
West of LA-3141 (St. Charles)	32.16	7,359
Southeast of LA-3160 (St. Charles)	39.15	7,079
LA-3141, West of WF3 (St. Charles)	0.56	2,004
LA-3142, Southeast of WF3 (St. Charles)	0.80	8,253
LA-3160, Southeast of WF3 (St. Charles)	0.31	3,128

<sup>(a)</sup> AADT represents traffic volume in 2014

Source: LaDOTD 2017

1 **3.11 Human Health**

2 **3.11.1 Radiological Exposure and Risk**

3 As required by NRC regulation 10 CFR 20.1101, Entergy has a radiation protection program  
4 designed to protect onsite personnel, including employees, contractor employees, visitors, and  
5 offsite members of the public from radiation and radioactive material generated at WF3.

6 The radiation protection program is extensive and includes, but is not limited to the following:

- 7 • organization and administration (i.e., a Radiation Protection Manager who is  
8 responsible for the program and having trained and qualified workers);
- 9 • implementing procedures;
- 10 • an ALARA program to minimize dose to workers and members of the public;
- 11 • a dosimetry program (i.e., measure radiation dose of plant workers);
- 12 • Radiological Controls (i.e., protective clothing, shielding, filters, respiratory  
13 equipment, and individual work permits with specific radiological requirements);
- 14 • radiation area entry and exit controls (i.e., locked or barricaded doors, interlocks,  
15 local and remote alarms, personnel contamination monitoring stations);
- 16 • posting of radiation hazards (i.e., signs and notices alerting plant personnel of  
17 potential hazards);
- 18 • record keeping and reporting (i.e., documentation of worker dose and radiation  
19 survey data);
- 20 • radiation safety training (i.e., classroom training and use of mockups to simulate  
21 complex work assignments);
- 22 • radioactive effluent monitoring management (i.e., control and monitor radioactive  
23 liquid and gaseous effluents released into the environment);
- 24 • radioactive environmental monitoring (i.e., sampling and analysis of environmental  
25 media, such as air, water, vegetation, food crops, direct radiation, and milk to  
26 measure the levels of radioactive material in the environment that may impact human  
27 health); and
- 28 • radiological waste management (i.e., control, monitor, process, and dispose of  
29 radioactive solid waste).

30 Regarding the radiation exposure to WF3 personnel, the NRC staff reviewed the data contained  
31 in NUREG-0713, *Occupational Radiation Exposure at Commercial Nuclear Power Reactors  
32 and Other Facilities 2014: Forty-Seventh Annual Report* (Volume 36) (NRC 2016). This report,  
33 which was the most recent available at the time of this review, summarizes the occupational  
34 exposure data through 2014 that are maintained in the NRC's Radiation Exposure Information  
35 and Reporting System database. Nuclear power plants are required by 10 CFR 20.2206 to  
36 report their occupational exposure data to the NRC annually.

37 NUREG-0713 calculates a 3-year average collective dose per reactor for all nuclear power  
38 reactors licensed by the NRC. The 3-year average collective dose is one of the metrics that the  
39 NRC uses in the Reactor Oversight Process to evaluate the applicant's ALARA program.  
40 Collective dose is the sum of the individual doses received by workers at a facility licensed to  
41 use radioactive material over a 1-year time period. There are no NRC or EPA standards for

1 collective dose. Based on the data for operating PWRs like those at WF3, the average annual  
 2 collective dose per reactor was 48 person-rem. In comparison, WF3 had a reported annual  
 3 collective dose per reactor of 111 person-rem.

4 In addition, as reported in NUREG–0713, for 2014, no worker at WF3 received an annual dose  
 5 greater than 1.0 rem (0.01 sievert (Sv)), which is less than half of the NRC occupational dose  
 6 limit of 5.0 rem (0.05 Sv) in 10 CFR 20.1201.

### 7 **3.11.2 Chemical Hazards**

8 State and Federal environmental agencies regulate the use, storage, and discharge of  
 9 chemicals, biocides, and sanitary wastes and minor chemical spills. Chemical hazards to plant  
 10 workers resulting from continued operations associated with license renewal are expected to be  
 11 minimized by the licensee implementing good industrial hygiene practices as required by  
 12 permits and Federal and state regulations. Plant discharges of these chemical and sanitary  
 13 wastes are monitored and controlled as part of the plant's LPDES permit process to minimize  
 14 impacts to the public and the environment. In addition, proposed changes in the use of cooling  
 15 water treatment chemicals would require review by the plant's LPDES permit-issuing authority  
 16 and possible modification of the existing LPDES permit LA0007374, including examination of  
 17 the human health effects of the change.

18 Entergy controls the use, storage, and discharge of chemicals and sanitary wastes at WF3 in  
 19 accordance with its chemical control procedures and site-specific chemical spill prevention  
 20 plans. Chemical wastes are controlled and managed in accordance with Entergy's waste  
 21 management procedure. These plant procedures and plans are designed to prevent and  
 22 minimize the potential for a chemical or hazardous waste release that could impact workers,  
 23 members of the public, and the environment (Entergy 2016a).

### 24 **3.11.3 Microbiological Hazards**

25 Thermal effluents associated with nuclear plants that discharge to a river, such as WF3, have  
 26 the potential to promote the growth of certain thermophilic microorganisms linked to adverse  
 27 human health effects. Microorganisms of particular concern include several types of bacteria  
 28 (*Legionella* spp., *Salmonella* spp., *Shigella* spp., and *Pseudomonas aeruginosa*) and the  
 29 free-living amoeba *Naegleria fowleri*.

30 The public can be exposed to the thermophilic microorganisms *Salmonella*, *Shigella*,  
 31 *P. aeruginosa*, and *N. fowleri* during swimming, boating, or other recreational uses of  
 32 freshwater. If a nuclear plant's thermal effluent enhances the growth of thermophilic  
 33 microorganisms, recreational users could experience an elevated risk of exposure when using  
 34 waters near the plant's discharge. Nuclear plant workers can be exposed to *Legionella* spp.  
 35 when performing maintenance activities on plant cooling systems if workers inhale cooling water  
 36 vapors because vapors are often within the optimum temperature range for *Legionella* growth.

#### 37 Thermophilic Microorganisms of Concern

38 *Salmonella typhimurium* and *S. enteritidis* are two species of enteric bacteria that cause  
 39 salmonellosis, a disease more common in summer than winter (CDC 2015a). Salmonellosis is  
 40 transmitted through contact with contaminated human or animal feces and may be spread  
 41 through water transmission or contact with food or infected animals (CDC 2015a). These  
 42 bacteria grow at temperatures ranging from 77 to 113 °F (25 to 45 °C), have an optimal growth  
 43 temperature around human body temperature (98.6 °F (37 °C)), and can survive extreme  
 44 temperatures as low as 41 °F (5 °C) and as high as 122 °F (50 °C) (Oscar 2009). Research  
 45 studies examining the persistence of *Salmonella* spp. outside of a host found that the bacteria

## Affected Environment

1 can survive for several months in water and in aquatic sediments (Moore et al. 2003). From  
2 1990–2016, the annual number of reported *Salmonella* spp. cases within the State of Louisiana  
3 has ranged from 531 to 1,548, for an average of 1,000 cases per year (LDH undated). CDC  
4 data indicate that no outbreaks or cases of waterborne *Salmonella* infection from recreational  
5 waters have occurred in the United States from 2002 through 2016 (CDC 2015a, 2016a). From  
6 2006 to 2016, all CDC-reported salmonellosis outbreaks have been caused by contaminated  
7 produce, meats, or prepared foods or through contact with contaminated animals (CDC 2015a,  
8 2016a).

9 Shigellosis infections are caused by the transmission of *Shigella* spp. from person to person  
10 through contaminated feces and unhygienic handling of food. Like salmonellosis, infections are  
11 more common in summer than in winter (CDC 2015b). The bacteria grow at temperatures  
12 between 77 and 99 °F (25 and 37 °C) and can survive temperatures as low as 41 °F (5 °C)  
13 (PHAC 2010). From 1990–2016, the annual number of reported *Shigella* spp. cases within the  
14 State of Louisiana has ranged from 128 to 645, for an average of 367 cases per year  
15 (LDH undated). CDC reports (2002, 2004, 2006, 2008, 2011) indicate that less than a dozen  
16 shigellosis outbreaks have been attributed to lakes, reservoirs, and other recreational waters in  
17 the past 10 available data years (1999 through 2008).

18 *Pseudomonas aeruginosa* can be found in soil, hospital respirators, water, and sewage and on  
19 the skin of healthy individuals. It is most commonly linked to infections transmitted in healthcare  
20 settings. Infections from exposure to *P. aeruginosa* in water can lead to development of mild  
21 respiratory illnesses in healthy people (CDC 2014). These bacteria have an optimal growth  
22 temperature of 98.6 °F (37 °C) and can survive in temperatures as high as 107.6 °F (42 °C)  
23 (Todar 2004). Louisiana Department of Health (undated) did not report any cases of  
24 *Pseudomonas aeruginosa* from 1990 through 2016.

25 The free-living amoeba *Naegleria fowleri* prefers warm freshwater habitats and is the causative  
26 agent of human primary amoebic meningoencephalitis. Infections occur when *N. fowleri*  
27 penetrate the nasal tissue through direct contact with water in warm lakes, rivers, or hot springs  
28 and migrate to the brain tissues (CDC 2015c). This free-swimming amoeba species is rarely  
29 found in water temperatures below 95 °F (35 °C), and infections rarely occur at those  
30 temperatures (Tyndall et al. 1989). The *N. fowleri*-caused disease, primary amoebic  
31 meningoencephalitis (PAM), is rare in the United States. Between 1962 through 2015,  
32 CDC (2016c) confirmed an average of seven cases of PAM annually. During this 53-year  
33 period, four cases total have been reported in Louisiana (CDC 2016c). Louisiana Office of  
34 Public Health (2013) determined that the most recent cases, two cases in 2011 and one case in  
35 2013, were due to contaminated drinking water. No cases of PAM in Louisiana have ever been  
36 attributed to the Mississippi River or recreational surface water use (Entergy 2016b).

37 *Legionella* spp. infections result in legionellosis (e.g., Legionnaires' disease), which manifests  
38 as a dangerous form of pneumonia or an influenza-like illness. Legionellosis outbreaks are  
39 often associated with complex water system houses inside buildings or structures, such as  
40 cooling towers (CDC 2016b). *Legionella* spp. thrive in aquatic environments as intracellular  
41 parasites of protozoa and are only infectious in humans through inhalation contact from an  
42 environmental source (CDC 2016b). Stagnant water between 95 and 115 °F (35 and 46 °C)  
43 tends to promote growth in *Legionella* spp., although the bacteria can grow at temperatures as  
44 low as 68 °F (20 °C) and as high as 122 °F (50 °C) (OSHA 1999). From 1990–2016, the annual  
45 number of reported *Legionella* spp. cases within the State of Louisiana has ranged from 1 to 61,  
46 for an average of 15 cases per year (LDH undated).

### 1 **3.11.4 Electromagnetic Fields**

2 Based on the GEIS, the Commission found that electric shock resulting from direct access to  
3 energized conductors or from induced charges in metallic structures has not been found to be a  
4 problem at most operating plants and generally is not expected to be a problem during the  
5 license renewal term. However, a site-specific review is required to determine the significance  
6 of the electric shock potential along the portions of the transmission lines that are within the  
7 scope of this SEIS.

8 In the GEIS, the NRC found that without a review of the conformance of each nuclear plant  
9 transmission line with National Electrical Safety Code<sup>®</sup> (NESC<sup>®</sup>) criteria, it was not possible to  
10 determine the significance of the electric shock potential (IEEE 2002). Evaluation of individual  
11 plant transmission lines is necessary because the issue of electric shock safety was not  
12 addressed in the licensing process for some plants. For other plants, land use in the vicinity of  
13 transmission lines may have changed, or power distribution companies may have chosen to  
14 upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an  
15 assessment of the impact of the proposed action on the potential shock hazard from the  
16 transmission lines if the transmission lines that were constructed for the specific purpose of  
17 connecting the plant to the transmission system do not meet the recommendations of the NESC  
18 for preventing electric shock from induced currents. The NRC uses the NESC criteria and the  
19 applicant's adherence to those criteria during the current operating license as its baseline to  
20 assess the potential human health impact of the induced current from an applicant's  
21 transmission lines. As discussed in the GEIS, the issue of electric shock is of small significance  
22 for transmission lines operated in adherence with the NESC criteria.

23 As discussed in Section 3.1.6.5, transmission lines within the scope of the NRC's license  
24 renewal environmental review are limited to those transmission lines that connect the nuclear  
25 plant to the substation where electricity is fed into the regional distribution system and  
26 transmission lines that supply power to the nuclear plant from the grid (NRC 2013a).

27 As indicated by Entergy in its ER, no offsite transmission lines are in-scope for the  
28 environmental review for license renewal. The only transmission lines in-scope for license  
29 renewal are on site; the lines from the WF3 switching station to the WF3 switchyard  
30 (Entergy 2016a). Therefore, there is no potential shock hazard to offsite members of the public  
31 from these transmission lines. As discussed in Section 3.11.5, WF3 maintains an occupational  
32 safety program in accordance with the Occupational Safety & Health Administration (OSHA)  
33 regulations for its workers, which includes protection from acute electric shock.

### 34 **3.11.5 Other Hazards**

35 Two additional human health issues are addressed in this section: (1) physical occupational  
36 hazards and (2) electric shock hazards.

37 Nuclear power plants are industrial facilities that have many of the typical occupational hazards  
38 found at any other electric power generation utility. Workers at or around nuclear power plants  
39 would be involved in some electrical work, electric power line maintenance, repair work, and  
40 maintenance activities and exposed to some potentially hazardous physical conditions  
41 (e.g., falls, excessive heat, cold, noise, electric shock, and pressure).

42 OSHA is responsible for developing and enforcing workplace safety regulations. It was created  
43 by the Occupational Safety and Health Act of 1970, as amended (29 U.S.C. 651 et seq.), which  
44 was enacted to safeguard the health of workers. With specific regard to nuclear power plants,  
45 plant conditions that result in an occupational risk, but do not affect the safety of licensed  
46 radioactive materials, are under the statutory authority of OSHA rather than the NRC as set

1 forth in a Memorandum of Understanding (53 FR 43950) between the NRC and OSHA.  
2 Occupational hazards are reduced when workers adhere to safety standards and use  
3 appropriate protective equipment; however, fatalities and injuries from accidents may still occur.  
4 WF3 maintains an occupational safety program in accordance with OSHA's regulations for its  
5 workers (Entergy 2016a).

### 6 **3.12 Environmental Justice**

7 Under Executive Order (EO) 12898 (59 FR 7629), Federal agencies are responsible for  
8 identifying and addressing, as appropriate, disproportionately high and adverse human health  
9 and environmental impacts on minority and low-income populations. Independent agencies,  
10 such as the NRC, are not bound by the terms of EO 12898 but are, as stated in  
11 paragraph 6-604 of the EO, "requested to comply with the provisions of [the] order." In 2004,  
12 the Commission issued a *Policy Statement on the Treatment of Environmental Justice Matters*  
13 *in NRC Regulatory and Licensing Actions* (69 FR 52040), which states, "The Commission is  
14 committed to the general goals set forth in EO 12898, and strives to meet those goals as part of  
15 its NEPA review process."

16 The Council on Environmental Quality (CEQ) provides the following information in  
17 *Environmental Justice: Guidance Under the National Environmental Policy Act* (CEQ 1997):

#### 18 **Disproportionately High and Adverse Human Health Effects.**

19 Adverse health effects are measured in risks and rates that could result in latent cancer  
20 fatalities, as well as other fatal or nonfatal adverse impacts on human health. Adverse  
21 health effects may include bodily impairment, infirmity, illness, or death.  
22 Disproportionately high and adverse human health effects occur when the risk or rate  
23 of exposure to an environmental hazard for a minority or low-income population is  
24 significant (as employed by NEPA) and appreciably exceeds the risk or exposure rate  
25 for the general population or for another appropriate comparison group (CEQ 1997).

#### 26 **Disproportionately High and Adverse Environmental Effects.**

27 A disproportionately high environmental impact that is significant (as employed by  
28 NEPA) refers to an impact or risk of an impact on the natural or physical environment  
29 in a low-income or minority community that appreciably exceeds the environmental  
30 impact on the larger community. Such effects may include ecological, cultural, human  
31 health, economic, or social impacts. An adverse environmental impact is an impact  
32 that is determined to be both harmful and significant (as employed by NEPA). In  
33 assessing cultural and aesthetic environmental impacts, impacts that uniquely affect  
34 geographically dislocated or dispersed minority or low-income populations or American  
35 Indian tribes are considered (CEQ 1997).

36 The environmental justice analysis assesses the potential for disproportionately high and  
37 adverse human health or environmental effects on minority and low-income populations that  
38 could result from the operation of WF3 during the renewal term. In assessing the impacts, the  
39 following definitions of minority individuals and populations and low-income population were  
40 used (CEQ 1997):

#### 41 **3.12.1 Minority Individuals**

42 Individuals who identify themselves as members of the following population groups: Hispanic or  
43 Latino, American Indian or Alaska Native, Asian, Black or African American, Native Hawaiian or

1 Other Pacific Islander, or two or more races, meaning individuals who identified themselves on  
2 a Census form as being a member of two or more races, for example, White and Asian.

### 3 **3.12.2 Minority Populations**

4 Minority populations are identified when (1) the minority population of an affected area exceeds  
5 50 percent or (2) the minority population percentage of the affected area is meaningfully greater  
6 than the minority population percentage in the general population or other appropriate unit of  
7 geographic analysis.

### 8 **3.12.3 Low-income Population**

9 Low-income populations in an affected area are identified with the annual statistical poverty  
10 thresholds from the Census Bureau's Current Population Reports, Series P60, on Income and  
11 Poverty.

#### 12 Minority Population

13 According to the USCB's 2010 Census data, approximately 40 percent of the population  
14 residing within a 50-mi (80-km) radius of WF3 identified themselves as minority individuals. The  
15 largest minority groups were Black or African American (approximately 29 percent) and  
16 Hispanic, Latino, or Spanish origin of any race (approximately 6 percent) (USCB 2017).

17 According to 2010 Census data, minority populations in the socioeconomic ROI (St. Charles  
18 and Jefferson Parishes) comprised approximately 43 percent of the total two-parish population  
19 (see Table 3-15). Figure 3-14 shows predominantly minority population block groups, using  
20 2010 Census data for race and ethnicity, within a 50-mi (80-km) radius of WF3. According to  
21 the USCB's 2011-2015 American Community Survey 5-Year Estimates, since 2010 minority  
22 populations in the ROI increased by approximately 8,200 persons and now comprise 44 percent  
23 of the ROI population (see Table 3-16).

24 Census block groups were considered minority population block groups if the percentage of the  
25 minority population within any block group exceeded the percent of the minority population  
26 within the 50-mi (80-km) radius of WF3. A minority population exists if the percentage of the  
27 minority population within the block group is meaningfully greater than the minority population  
28 percentage in the 50-mi (80-km) radius.

29 As shown in Figure 3-14, minority population block groups (race and ethnicity) are clustered  
30 east and west of WF3 in New Orleans, Vacherie, and Donaldsonville, Louisiana. Based on this  
31 analysis, WF3 is located in a minority population block group.

#### 32 Low-Income Population

33 According to the USCB's 2010-2014 American Community Survey (ACS) data, approximately  
34 18 percent of individuals residing within a 50-mi (80-km) radius of WF3 were identified as living  
35 below the Federal poverty threshold in 2014 (USCB 2017). The 2014 Federal poverty threshold  
36 was \$24,230 for a family of four.

37 According to the USCB's 2011-2015 American Community Survey 5-Year Estimates,  
38 15.2 percent of families and 19.8 percent of people in Louisiana were living below the Federal  
39 poverty threshold and the median household and per capita incomes for Louisiana were  
40 \$45,047 and \$24,981, respectively (USCB 2017). In the socioeconomic ROI (St. Charles and  
41 Jefferson parishes), people living in St. Charles Parish have higher median household and per  
42 capita incomes (\$59,990 and \$27,247, respectively) than the state averages, with fewer families  
43 and people (8.8 percent and 11.8 percent, respectively) living below the poverty level. In

## Affected Environment


1 addition, people living in Jefferson Parish also have higher median household and per capita  
2 incomes (\$47,947 and \$27,127, respectively) than the state averages, with 13.0 percent of  
3 families and 16.8 percent of persons living below the official poverty level (USCB 2017).

4 Figure 3–15 shows the location of predominantly low-income population block groups within a  
5 50-mi (80-km) radius of WF3. Census block groups were considered low-income population  
6 block groups if the percentage of individuals living below the Federal poverty threshold within  
7 any block group exceeded the percent of the individuals living below the Federal poverty  
8 threshold within the 50-mi (80-km) radius of WF3.

9 As shown in Figure 3–15, low-income population block groups are clustered east and west of  
10 WF3 in New Orleans and Donaldsonville, Louisiana. Based on this analysis, WF3 is located in  
11 a low-income population block group.

1  
2

**Figure 3–14. 2010 Census Minority Block Groups Within a 50-mi (80-km) Radius of WF3**




3  
4

Source: USCB 2017

1  
2

**Figure 3–15. 2010 Census Low-Income Block Groups Within a 50-mi (80-km) Radius of WF3**



3  
4

Source: USCB 2017

5 **3.13 Waste Management and Pollution Prevention**

6 **3.13.1 Radioactive Waste**

7 As discussed in Section 3.1.4, WF3 uses liquid, gaseous, and solid waste processing systems  
 8 to collect and treat, as needed, radioactive materials produced as a byproduct of plant  
 9 operations. Radioactive materials in liquid and gaseous effluents are reduced before being  
 10 released into the environment so that the resultant dose to members of the public from these

1 effluents is well within NRC and EPA dose standards. Radionuclides that can be efficiently  
2 removed from the liquid and gaseous effluents before release are converted to a solid waste  
3 form for disposal in a licensed disposal facility.

#### 4 **3.13.2 Nonradioactive Waste**

5 Waste minimization and pollution prevention are important elements of operations at all nuclear  
6 power plants. Licensees are required to consider pollution prevention measures as dictated by  
7 the Pollution Prevention Act (Public Law 101-508) and Resource Conservation and Recovery  
8 Act of 1976, as amended (Public Law 94-580) (NRC 2013).

9 As described in Section 3.1.5, WF3 has a nonradioactive waste management program to handle  
10 nonradioactive waste in accordance with Federal, State, and corporate regulations and  
11 procedures. WF3 has waste minimization measures in place, as verified during the site visit the  
12 NRC staff conducted in July 2016. This program includes measures such as material control,  
13 process control, waste management, recycling, and feedback, thereby effecting waste  
14 reduction.

15 WF3 has an SWPPP that identifies potential sources of pollution that may affect the quality of  
16 storm water discharges from permitted outfalls. The SWPPP also describes BMPs used to  
17 reduce pollutants in storm water discharges to assure compliance with the site's LPDES permit.

18 WF3 also has an SPCC plan to monitor areas within the site that have the potential to discharge  
19 oil into or upon navigable waters, as per regulations in 40 CFR Part 112. The SPCC plan  
20 identifies and describes the procedures, materials, equipment, and facilities utilized at the  
21 station to minimize the frequency and severity of oil spills.

22 WF3 is subject to the reporting requirements of 40 CFR Part 110 for the discharge of oil, as  
23 pursuant to Section 311(b)(4) of the Federal Water Pollution Control Act. Discharges of oil in  
24 such quantities that may be harmful to the public health or welfare or the environment have to  
25 be reported to the National Response Center. No oil releases from 2010 through June 2016  
26 have triggered the reporting requirements in 40 CFR Part 110. (Entergy 2016a, 2016b).

#### 27 **3.14 References**

28 10 CFR Part 20. *Code of Federal Regulations*, Title 10, Energy, Part 20, "Standards for  
29 protection against radiation."

30 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, "Domestic licensing of  
31 production and utilization facilities."

32 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental  
33 protection regulations for domestic licensing and related regulatory functions."

34 10 CFR Part 61. *Code of Federal Regulations*, Title 10, Energy, Part 61, "Licensing  
35 requirements for land disposal of radioactive waste."

36 10 CFR Part 71. *Code of Federal Regulations*, Title 10, Energy, Part 71, "Packaging and  
37 transportation of radioactive material."

38 10 CFR Part 72. *Code of Federal Regulations*, Title 10, Energy, Part 72, "Licensing  
39 requirements for the independent storage of spent nuclear fuel, high-level radioactive waste,  
40 and reactor related Greater than Class C waste."

41 15 CFR Part 930. *Code of Federal Regulations*, Title 15, Commerce and Foreign Trade,  
42 Part 930, "Federal consistency with approved coastal management programs."

## Affected Environment

- 1 40 CFR Part 50. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 50,  
2 “National primary and secondary ambient air quality standards.”
- 3 40 CFR Part 51. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 51,  
4 “Requirements for preparation, adoption, and submittal of implementation plans.”
- 5 40 CFR Part 81. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 81,  
6 “Designation of areas for air quality planning purposes.”
- 7 40 CFR Part 112. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 112,  
8 “Oil pollution prevention.”
- 9 40 CFR Part 131. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 131,  
10 “Water quality standards.”
- 11 40 CFR Part 190. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 190,  
12 “Environmental radiation protection standards for nuclear power operations.”
- 13 49 CFR Parts 171–178. *Code of Federal Regulations*, Title 49, Transportation, Subchapter C—  
14 Hazardous Materials Regulations and “Specifications for packagings.”
- 15 50 CFR Part 402. *Code of Federal Regulations*, Title 50, Wildlife and Fisheries, Part 402,  
16 “Interagency cooperation—Endangered Species Act of 1973, as amended.”
- 17 41 FR 41914. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
18 determination of critical habitat for American crocodile, California condor, Indiana bat, and  
19 Florida manatee. *Federal Register* 41(187):41914–41916. September 24, 1976.
- 20 42 FR 47840. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
21 final rule; correction and augmentation of published rulemaking. *Federal Register* 42(184):  
22 47840-47845. September 22, 1977.
- 23 55 FR 36641. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
24 determination of endangered status for the pallid sturgeon. *Federal Register* 55(173):  
25 36641-36647. September 6, 1990.
- 26 56 FR 49653. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
27 threatened status for the gulf sturgeon. *Federal Register* 56(189):49653–49658.  
28 September 30, 1991.
- 29 59 FR 7629. Executive Order No. 12898. “Federal actions to address environmental justice in  
30 minority populations and low-income populations.” *Federal Register* 59(32):7629–7634.  
31 February 16, 1994.
- 32 68 FR 13370. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
33 designation of critical habitat for the gulf sturgeon; final rule. *Federal Register* 68(189):  
34 13370–13495. March 19, 2003.
- 35 69 FR 52040. U.S. Nuclear Regulatory Commission. “Policy statement on the treatment of  
36 environmental justice matters in NRC regulatory and licensing actions.” *Federal Register*  
37 69(163):52040–52048. August 24, 2004.
- 38 70 FR 39104. Environmental Protection Agency. 2005. Regional Haze Regulations and  
39 Guidelines for Best Available Retrofit Technology (BART) Determinations. *Federal Register*  
40 70(128):39104–39172. July 6, 2005.
- 41 74 FR 56260. Environmental Protection Agency. 2009. Mandatory Reporting of Greenhouse  
42 Gases.” *Federal Register* 74(209):56260-56519. October 30, 2009.

- 1 75 FR 31514. U.S. Environmental Protection Agency. 2010. "Prevention of Significant  
2 Deterioration and Title V Greenhouse Gas Tailoring Rule." *Federal Register* 75(106):31514–  
3 31608. June 3, 2010.
- 4 81 FR 999. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
5 12-month finding on a petition to downlist the West Indian manatee and proposed rule to  
6 reclassify the West Indian manatee as threatened. *Federal Register* 81(5):999–1026.  
7 January 8, 2016.
- 8 82 FR 16668. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;  
9 Reclassification of the West Indian manatee from endangered to threatened. *Federal*  
10 *Register* 82(64):16668–16704. April 5, 2017.
- 11 Alexander JS, Wilson RC, Green WR. 2012. A brief History and Summary of the Effects of  
12 River Engineering and Dams on the Mississippi River System and Delta. Reston, VA: USGS  
13 Circular 1375. Available at <<http://pubs.usgs.gov/circ/1375/>> (accessed 25 October 2016).
- 14 [APA] American Planning Association. 2016. The Geology of New Orleans – Implications for  
15 Planners. August 31, 2016. Available at  
16 <<http://www.nogs.org/Content/pdf/TheGeologyofNewOrleans2016.pdf>> accessed  
17 (12 December 2016).
- 18 [AEC] U.S. Atomic Energy Commission. 1973. Final Environmental Statement Related to  
19 Construction of Waterford Steam Electric Station, Unit 3. Washington, DC: AEC. March 1973.  
20 287 p. Agencywide Documents Access and Management System (ADAMS) Accession  
21 No. ML16204A314.[ACOE]. U.S. Army Corps of Engineers. Undated. Bonnet Carre Spillway  
22 Fishing. Available at <[http://www.mvn.usace.army.mil/Portals/56/docs/  
23 Recreation/BCS/Brochures/BCSFishBrochure.pdf](http://www.mvn.usace.army.mil/Portals/56/docs/Recreation/BCS/Brochures/BCSFishBrochure.pdf)> (accessed 8 November 2016).
- 24 Baker JA, Killgore KJ, Kasul RL. 1991. Aquatic habitats and fish communities in the lower  
25 Mississippi River. *Reviews in Aquatic Science* 3:313–356.
- 26 [BGEPA] Bald and Golden Eagle Protection Act. 16 USC §668 et seq.
- 27 Brown AV, Brown KB, Jackson DC, Pierson WK. 2005. The lower Mississippi River and its  
28 tributaries. In Benke AC, Cushing CE, editors. *Rivers of North America*. New York, Academic  
29 Press.
- 30 [BLS] U.S. Bureau of Labor Statistics. 2017. "Local Area Unemployment Statistics." Available  
31 at <<http://www.bls.gov/data/>> (accessed May 2017).
- 32 Clean Air Act of 1970. 42 U.S.C. §7401 et seq.
- 33 [CZMA] Coastal Zone Management Act of 1972. 16 U.S.C. §1451 et seq.
- 34 [CEQ] Council on Environmental Quality. 1997. Environmental Justice: Guidance under the  
35 National Environmental Policy Act. Available at  
36 <[http://www.epa.gov/oecaerth/environmentaljustice/resources/policy/ej\\_guidance\\_nepa\\_ceq129  
37 7.pdf](http://www.epa.gov/oecaerth/environmentaljustice/resources/policy/ej_guidance_nepa_ceq1297.pdf)>.
- 38 [CHC] Center for Hearing and Communication. Undated. "Common Environmental Noise  
39 Levels Factsheet." Available at <[http://chchearing.org/noise/common-environmental-noise-  
40 levels/](http://chchearing.org/noise/common-environmental-noise-levels/)> (accessed 3 November 2016).
- 41 [CDC] Centers for Disease Control and Prevention. 2002. "Surveillance for Waterborne  
42 Disease Outbreaks—United States, 1999–2000." *Morbidity and Mortality Weekly Report*  
43 51(8):1–28. November 22, 2002. Available at  
44 <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5108a1.htm>> (accessed 14 December 2016).

## Affected Environment

- 1 [CDC] Centers for Disease Control and Prevention. 2004. "Surveillance for Waterborne  
2 Disease Outbreaks and Other Health Events Associated with Recreational Water—United  
3 States, 2001–2002." *Morbidity and Mortality Weekly Report* 53(8):1–22. October 22, 2004.  
4 Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5308a1.htm>> (accessed  
5 14 December 2016).
- 6 [CDC] Centers for Disease Control and Prevention. 2006. "Surveillance for Waterborne  
7 Disease and Outbreaks and Other Health Events Associated with Recreational Water—United  
8 States, 2003–2004." *Morbidity and Mortality Weekly Report* 55(12):1–24. December 22, 2006.  
9 Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5512a1.htm>> (accessed  
10 14 December 2016).
- 11 [CDC] Centers for Disease Control and Prevention. 2008. "Surveillance for Waterborne  
12 Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility  
13 Associated—United States, 2005–2006." *Morbidity and Mortality Weekly Report* 57(9):1–29.  
14 September 9, 2008. Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5709a1.htm>>  
15 (accessed 14 December 2016).
- 16 [CDC] Centers for Disease Control and Prevention. 2011. "Surveillance for Waterborne  
17 Disease Outbreaks and Other Health Events Associated with Recreational Water—United  
18 States, 2007–2008." *Morbidity and Mortality Weekly Report* 60(12):1–32. September 23, 2011.  
19 Available at <[http://www.cdc.gov/mmwr/preview/mmwrhtml/ss6012a1.htm?s\\_cid=ss6012a1\\_w](http://www.cdc.gov/mmwr/preview/mmwrhtml/ss6012a1.htm?s_cid=ss6012a1_w)>  
20 (accessed 14 December 2016).
- 21 [CDC] Centers for Disease Control and Prevention. 2014. "Pseudomonas aeruginosa in  
22 Healthcare Settings—HAI." May 7, 2014. Available at  
23 <<http://www.cdc.gov/hai/organisms/pseudomonas.html>> (accessed 2 March 2016).
- 24 [CDC] Centers for Disease Control and Prevention. 2015a. "Technical Information on  
25 Salmonella." Updated March 9, 2015. Available at  
26 <<http://www.cdc.gov/salmonella/general/technical.html>> (accessed 12 December 2016).
- 27 [CDC] Centers for Disease Control and Prevention. 2015b. "Shigellosis." August 5, 2015.  
28 Available at <<http://www.cdc.gov/shigella/index.html>> (accessed 2 March 2016).
- 29 [CDC] Centers for Disease Control and Prevention. 2015c. "Pathogen and Environment—  
30 Naegleria fowleri." December 7, 2015. Available at  
31 <<http://www.cdc.gov/parasites/naegleria/pathogen.html>> (accessed 2 March 2016).
- 32 [CDC] Centers for Disease Control and Prevention. 2016a. "Reports of Salmonella Outbreak  
33 Investigations." Updated November 28, 2016. Available at  
34 <<https://www.cdc.gov/salmonella/outbreaks-2016.html>> (accessed 12 December 2016).
- 35 [CDC] Centers for Disease Control and Prevention. 2016b. "Legionella: Home Page—  
36 Legionnaires Disease and Pontiac Fever." January 15, 2016. Available at  
37 <<http://www.cdc.gov/legionella/index.html>> (accessed 2 March 2016).
- 38 [CDC] Centers for Disease Control and Prevention. 2016c. "Naegleria fowleri—Sources of  
39 Infection—Number of Case-reports of Primary Amebic Meningoencephalitis by State of  
40 Exposure: United States, 1962–2015." April 22, 2016. Available at  
41 <<http://www.cdc.gov/parasites/naegleria/state-map.html>> (accessed 14 December 2016).
- 42 [DOI] U.S. Department of the Interior, National Park Service. 2017. National Register of  
43 Historic Places: Research. Available at <<http://www.nps.gov/nr/research/>> (accessed  
44 10 March 2017).
- 45 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.

- 1 [ENERCON] ENERCON Services, Inc. 2014. Threatened and Endangered Species Survey,  
2 Waterford Steam Electric Station, Unit 3. Oklahoma City, OK. December 30, 2014. ADAMS  
3 Accession No. ML17037D250.
- 4 [ENSR] ENSR International. 2005. Proposal for Information Collection, Entergy Louisiana, Inc.,  
5 Waterford 1 & 2 Plant. Document Number 10785-001. June 2005. 133 p. ADAMS Accession  
6 No. ML17034A323.
- 7 [ENSR] ENSR Corporation. 2007. Impingement Mortality and Entrainment Characterization  
8 Study (IMECS) Entergy—Waterford 3. December 2007. ADAMS Accession  
9 No. ML12157A426.
- 10 [Entergy] Entergy Louisiana, LLC. 2004. Standby Plans during Air Pollution Alerts, Warnings or  
11 Emergencies. ADAMS Accession No. ML17023A268.
- 12 [Entergy] Entergy Louisiana, LLC. 2007. Waterford 3 LPDES Permit LA0007374 Stormwater  
13 Pollution Prevention Plan. Revision 1. December 17, 2007. ADAMS Accession  
14 No. ML17037D315.
- 15 [Entergy] Entergy Louisiana, LLC. 2008. Annual Radioactive Effluent Release Report –  
16 2007 Waterford Steam Electric Station, Unit 3 (Waterford 3) Docket No. 50-382, License  
17 No. NPF-38. April 30, 2008. ADAMS Accession No. ML081230373.
- 18 [Entergy] Entergy Louisiana, LLC. 2009. Annual Radioactive Effluent Release Report –  
19 2008 Waterford Steam Electric Station, Unit 3 (Waterford 3) Docket No. 50-382, License  
20 No. NPF-38. April 30, 2009. ADAMS Accession No. ML091250182.
- 21 [Entergy] Entergy Louisiana, LLC. 2010. Annual Radioactive Effluent Release Report –  
22 2009 Waterford Steam Electric Station, Unit 3 (Waterford 3) Docket No. 50-382, License  
23 No. NPF-38. April 30, 2010. ADAMS Accession No. ML101241056.
- 24 [Entergy] Entergy Louisiana, LLC. 2011. Annual Radioactive Effluent Release Report,  
25 January 1, 2010–December 31, 2010, Waterford 3 SES Entergy Operations, Inc., Docket  
26 Number 50-382, License Number NPF-38. April 9, 2011. ADAMS Accession  
27 No. ML11122A023.
- 28 [Entergy] Entergy Operations, Inc. 2012a. Waterford Steam Electric Station, Unit 3,  
29 2011 Annual Radiological Effluent Release Report. Killona, LA: Entergy Nuclear.  
30 April 30, 2012. ADAMS Accession No. ML12122A017.
- 31 [Entergy] Entergy Operations, Inc. 2012b. Waterford Steam Electric Station, Unit 3,  
32 2011 Annual Radiological Environmental Operating Report. Killona, LA: Entergy Nuclear.  
33 April 30, 2012. ADAMS Accession No. ML12122A016.
- 34 [Entergy] Entergy Operations, Inc. 2013a. Annual Radiological Effluent Release Report –  
35 2012, Waterford Steam Electric Station, Unit 3 (Waterford 3), Docket No. 50-382, License  
36 No. NPF-38. April 30, 2013. ADAMS Accession No. ML13123A031.
- 37 [Entergy] Entergy Operations, Inc. 2013b. Waterford Steam Electric Station, Unit 3,  
38 2012 Annual Radiological Environmental Operating Report. Killona, LA: Entergy Nuclear.  
39 April 30, 2013. ADAMS Accession No. ML13123A030.
- 40 [Entergy] Entergy Louisiana, LLC and Entergy Operations, Inc. 2014a. Updated Final Safety  
41 Analysis Report (UFSAR). Killona, LA: Entergy Operations. Revision 308. November 2014.  
42 ADAMS Accession No. ML16088A325.

## Affected Environment

- 1 [Entergy] Entergy Operations, Inc. 2014b. Waterford Steam Electric Station, Unit 3,  
2 2013 Annual Radiological Effluent Release Report. Killona, LA: Entergy Nuclear.  
3 April 29, 2014. ADAMS Accession No. ML14120A217.
- 4 [Entergy] Entergy Operations, Inc. 2014c. Waterford Steam Electric Station, Unit 3,  
5 2013 Annual Radiological Environmental Operating Report. Killona, LA: Entergy Nuclear.  
6 April 28, 2014. ADAMS Accession No. ML14120A312.
- 7 [Entergy] Entergy Operations, Inc. 2015a. Offsite Dose Calculation Manual (ODCM).  
8 Revision 306. Killona, LA: Entergy Nuclear. UNT-005-014. March 2015. ADAMS Accession  
9 No. ML16132A511.
- 10 [Entergy] Entergy Operations, Inc. 2015b. Waterford Steam Electric Station, Unit 3,  
11 2014 Annual Radiological Effluent Release Report. Killona, LA: Entergy Nuclear.  
12 April 29, 2015. ADAMS Accession No. ML15124A594.
- 13 [Entergy] Entergy Operations, Inc. 2015c. Waterford Steam Electric Station, Unit 3,  
14 2014 Annual Radiological Environmental Operating Report. Killona, LA: Entergy Nuclear.  
15 April 29, 2015. ADAMS Accession No. ML15124A010.
- 16 [Entergy] Entergy Louisiana, LLC. 2015d. Letter from R. Buckley, Entergy, to J. Harris,  
17 Louisiana Department of Natural Resources. Subject: Waterford Steam Electric Station, Unit 3,  
18 Coastal Zone Consistency Determination. April 9, 2015. In Entergy 2016ER (p. E-2).
- 19 [Entergy] Entergy Louisiana, LLC. 2015e. Flood Hazard Reevaluation Report Waterford Steam  
20 Electric Station, Unit 3 (Waterford 3). July 21, 2015. ADAMS Accession No. ML15204A321.
- 21 [Entergy] Entergy Operations, Inc. 2015f. Letter from M. R. Chisum, Site Vice President,  
22 Waterford 3, to Louisiana Department of Environmental Quality, Office of Environmental  
23 Services. Subject: Application for Renewal of LPDES Permit and Request for Waiver for Early  
24 Submittal of 122.21(r) Impingement and Entrainment Characterization Data. March 30, 2015.  
25 ADAMS Accession No. ML17037D290.
- 26 [Entergy] Entergy Louisiana, LLC and Entergy Operations, Inc. 2016a. Appendix E,  
27 Applicant's Environmental Report, Operating License Renewal Stage, Waterford Steam Electric  
28 Station, Unit 3. Killona, LA: Entergy Operations. March 2016. ADAMS Accession  
29 Nos. ML16088A326, ML16088A327, ML16088A328, ML16088A329, ML16088A333, and  
30 ML16088A335.
- 31 [Entergy] Entergy Louisiana, LLC. 2016b (RAI). Letter from M.R. Chisum, Waterford 3 Site  
32 Vice President, Entergy, to NRC Document Control Desk. Responses to Request for Additional  
33 Information for Environmental Review Regarding the License Renewal Application for Waterford  
34 Steam Electric Station, Unit 3 (Waterford 3). November 23, 2016. ADAMS Accession  
35 No. ML16328A414.
- 36 [Entergy] Entergy Operations, Inc. 2016c. Waterford Steam Electric Station, Unit 3,  
37 2015 Annual Radiological Environmental Operating Report. Killona, LA: Entergy Nuclear.  
38 April 25, 2016. ADAMS Accession No. ML16132A515.
- 39 [Entergy] Entergy Operations, Inc. 2016d. Waterford Steam Electric Station, Unit 3,  
40 2015 Annual Radiological Effluent Release Report. Killona, LA: Entergy Nuclear.  
41 April 25, 2016. ADAMS Accession No. ML16132A509.
- 42 [EPA] U.S. Environmental Protection Agency. 1974. Information on Levels of Environmental  
43 Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety.  
44 Available at <<https://www.epa.gov/nscep>> (accessed 8 November 2016).

- 1 [EPA] U.S. Environmental Protection Agency. 1981. Noise Effects Handbook: A Desk  
2 Reference to Health and Welfare Effects of Noise. Washington, DC: Office of Noise Abatement  
3 and Control. October 1979, Revised July 1981.
- 4 [EPA] U.S. Environmental Protection Agency. 2014. 2014 National Emissions Inventory (NEI)  
5 Data. Available at <[https://www.epa.gov/air-emissions-inventories/2014-national-emissions-  
7 inventory-nei-data](https://www.epa.gov/air-emissions-inventories/2014-national-emissions-<br/>6 inventory-nei-data)> (accessed 9 November 2016).
- 7 [EPA] U.S. Environmental Protection Agency. 2016a. NAAQS Table. Available at  
8 <<https://www.epa.gov/criteria-air-pollutants/naaqs-table>> (accessed 3 November 2016)
- 9 [EPA] U.S. Environmental Protection Agency. 2016b. Summary of the Noise Control Act.  
10 Available at <<https://www.epa.gov/laws-regulations/summary-noise-control-act>> (accessed  
11 3 November 2016).
- 12 [EPA] U.S. Environmental Protection Agency. 2016c. “Surf Your Watershed, Lower  
13 Mississippi-New Orleans Watershed – 08090100.” Page updated 7/12/16. Available at  
14 <[https://cfpub.epa.gov/surf/huc.cfm?huc\\_code=08090100](https://cfpub.epa.gov/surf/huc.cfm?huc_code=08090100)> (accessed 12 July 2016).
- 15 [EPA] U.S. Environmental Protection Agency. 2016d. “NPDES State Program Information,  
16 State Program Authority.” Page updated February 9, 2016. Available at  
17 <<https://www.epa.gov/npdes/npdes-state-program-information>> (accessed 5 December 2016).
- 18 [EPA] U.S. Environmental Protection Agency. 2016e. “Enforcement and Compliance History  
19 Online.” [Detailed Facility Report, Entergy Louisiana LLC – Waterford 3 Steam Electric Station,  
20 CWA Enforcement and Compliance.] Available at <[https://echo.epa.gov/detailed-facility-  
22 report?fid=110002042414#pane3110002042414](https://echo.epa.gov/detailed-facility-<br/>21 report?fid=110002042414#pane3110002042414)> (accessed 6 December 2016).
- 22 [EPA] U.S. Environmental Protection Agency. 2017. “Safe Drinking Water Information System  
23 (SDWIS),” Parish Search— St. Charles and Jefferson Parishes, Louisiana. Available at  
24 <<http://www.epa.gov/enviro/facts/sdwis/search.html>> (accessed May 2017).
- 25 [Espey, Huston & Associates] Espey, Huston, & Associates, Inc. 1977. Annual Data Report,  
26 Waterford Power Station, Units 1 and 2, Screen Impingement Studies, February 1976 through  
27 January 1977. Prepared for Louisiana Power and Light Company. May 6, 1977. 46 p.  
28 ADAMS Accession No. ML17037C948.
- 29 [FEMA] Federal Emergency Management Agency. 1992. Flood Insurance Rate Map,  
30 St. Charles Parish, Louisiana (Unincorporated Areas). Oakton, VA: FEMA Map Service Center.  
31 Map Number 2201600125C. June 16, 1992. Available at <<https://msc.fema.gov/portal/>>  
32 (accessed 5 December 2016).
- 33 Federal Water Pollution Control Act (Clean Water Act) of 1972, as amended.  
34 33 U.S.C. §1251 et seq.
- 35 FishNet. 2014. FishNet2, Search FishNet. Available at <<http://www.fishnet2.net>> (accessed  
36 8 November 2016).
- 37 FTN Associates Ltd. 2014. Entergy Waterford-3 Groundwater Monitoring Program Five-Year  
38 Review. June 3, 2014. ADAMS Accession No. ML17037D055.
- 39 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 2009.  
40 Gulf Sturgeon (*Acipenser oxyrinchus desotoi*) 5-Year Review: Summary and Evaluation.  
41 September 2009. 49 p. Available at <[https://ecos.fws.gov/docs/five\\_year\\_review/doc2620.pdf](https://ecos.fws.gov/docs/five_year_review/doc2620.pdf)>  
42 (accessed September 1, 2016).

## Affected Environment

- 1 [FWS] U.S. Fish and Wildlife Service. 2013. Biological Opinion for Channel Improvement  
2 Program, Mississippi River and Tributaries Project, Lower Mississippi River.  
3 December 12, 2013. Available at  
4 <<https://www.fws.gov/mississippi/ pdf/LMRBiologicalOpinion.pdf>> (accessed  
5 1 September 2016).
- 6 [FWS] U.S. Fish and Wildlife Service. 2014. Revised Recovery Plan for the Pallid Sturgeon  
7 (Scaphirhynchus albus). Prepared by the Pallid Sturgeon Recovery Coordinator.  
8 January 2014. 126 p. Available at  
9 <[https://ecos.fws.gov/docs/recovery\\_plan/Pallid%20Sturgeon%20Recovery%20Plan%20First%  
10 20Revision%20signed%20version%20012914\\_3.pdf](https://ecos.fws.gov/docs/recovery_plan/Pallid%20Sturgeon%20Recovery%20Plan%20First%20Revision%20signed%20version%20012914_3.pdf)> (accessed 1 September 2016).
- 11 [FWS] U.S. Fish and Wildlife Service. 2017. Letter from FWS to NRC. Subject: Waterford  
12 Steam Electric Station Unit 3, Updated list of threatened and endangered species that may  
13 occur in your proposed project location, and/or may be affected by your proposed project.  
14 Consultation Code: 04EL1000-2016-SLI-0334. April 13, 2017. ADAMS Accession  
15 No. ML17103A180.
- 16 Griffith, JM. 2003. Hydrogeologic Framework of Southeastern Louisiana, Louisiana  
17 Department of Transportation and Development, Water Resources Technical Report No. 72.  
18 2003. Available at <<http://la.water.usgs.gov/publications/pdfs/TR72.pdf>> (accessed  
19 November 29, 2016).
- 20 Harrison, AB, Morse JC. 2012. The Macroinvertebrate Fauna of the Mississippi River.  
21 Transactions of the American Entomological Society, Vol. 138, Nos. 1 and 2, p. 55–72.
- 22 Hoover JJ, George SG, Killgore KJ. 2007. Diet of shovelnose sturgeon and pallid sturgeon in  
23 the free-flowing Mississippi River. *Journal of Applied Ichthyology* 23:494–499.
- 24 [HUD] U.S. Department of Housing and Urban Development. 2014. Noise Abatement and  
25 Control. Available at <[https://www.hudexchange.info/programs/environmental-review/noise-  
26 abatement-and-control/](https://www.hudexchange.info/programs/environmental-review/noise-abatement-and-control/)> (accessed 3 November 2016).
- 27 [IEEE] Institute of Electrical and Electronics Engineers. 2002. National Electrical Safety Code.  
28 Available at <<http://standards.ieee.org/about/nesc/>> (accessed 17 June 2015).
- 29 [ILIT] Independent Levee Investigation Team. 2006. Investigation of the Performance of the  
30 New Orleans Flood Protection Systems in Hurricane Katrina on August 29, 2005, Final Report.  
31 July 31, 2006. Available at <<http://www.ce.berkeley.edu/projects/neworleans/>> accessed  
32 (28 October 2016).
- 33 Jones CE, An K, Blom RG, Kent JD, Ivins ER, Bekaert D. 2016. Anthropogenic and geologic  
34 influences on subsidence in the vicinity of New Orleans, Louisiana, *Journal of Geophysical*  
35 *Research*, Solid Earth, 121, p. 3867–3887 doi: Article 10.1002/2015JB02636 May15, 2016,  
36 Available at  
37 <[http://onlinelibrary.wiley.com/doi/10.1002/2015JB02636/abstract;jsessionid=294C4A511AA3  
38 C9A1ECD5D9CF4E858865.f01t04](http://onlinelibrary.wiley.com/doi/10.1002/2015JB02636/abstract;jsessionid=294C4A511AA3C9A1ECD5D9CF4E858865.f01t04)> (accessed 31 October 2016).
- 39 Kammerer JC. 1990. “Largest Rivers in the United States.” Reston, VA: U.S. Department of  
40 the Interior, U.S. Geological Survey. Open File Report 87-242. Revised May 1990. Available  
41 at <<https://pubs.usgs.gov/of/1987/ofr87-242/pdf/ofr87242.pdf>> (accessed 8 July 2016).
- 42 [LBJWC] Lady Bird Johnson Wildlife Flower Center, University of Texas at Austin. 2016. Native  
43 Plant Database: Western Umbrella Sedge. Available at  
44 <[http://www.wildflower.org/plants/result.php?id\\_plant=FUS1](http://www.wildflower.org/plants/result.php?id_plant=FUS1)> (accessed 31 August 2016).

- 1 Lorenz OT, O'Connel MTI. 2011. Establishment and post-hurricane survival of the non-native  
2 Rio Grance cichlid (*Herichthys cyanoguttatus*) in the greater New Orleans metropolitan area.  
3 *Southeastern Naturalist* 10(4):673–686.
- 4 LAC 33:IX.23. Louisiana Administrative Code, Title 33, Environmental Quality, Part IX, Water  
5 Quality, Subpart 2, The Louisiana Pollutant Discharge Elimination System (LPDES) Program,  
6 Chapter 23, Definitions and General LPDES Program Requirements. State of Louisiana  
7 Division of Administration. Available at <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>>  
8 (accessed 5 December 2016).
- 9 LAC 33:IX.1111. Louisiana Administrative Code, Title 33, Environmental Quality, Part IX, Water  
10 Quality, Subpart 1, Water Pollution Control, Chapter 11, Surface Water Quality Standards,  
11 Section 1111, "Water Use Designations." State of Louisiana Division of Administration.  
12 Available at <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>> (accessed 5 December 2016).
- 13 LAC 33:III.23.5. Louisiana Administrative Code, Title 33, Environmental Quality, Part III, Air,  
14 Chapter 5, Permit Procedures. State of Louisiana, Division of Administration. Available at  
15 <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>> (accessed 5 December 2016).
- 16 LAC 33:III.23.2113. Louisiana Administrative Code, Title 33, Environmental Quality, Part III, Air,  
17 Chapter 21, Control of Emission of Organic Compounds, Subchapter A, General, Section 2113,  
18 Housekeeping. State of Louisiana, Division of Administration. Available at  
19 <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>> (accessed 5 December 2016).
- 20 LAC 33:III.5611. Louisiana Administrative Code, Title 33, Environmental Quality, Part III, Air,  
21 Chapter 56, Prevention of Air Pollution Emergency Episode, Section 5611, Standby Plans to be  
22 Submitted When Requested by the Administrative Authority. State of Louisiana, Division of  
23 Administration. Available at <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>> (accessed  
24 5 December 2016).
- 25 LAC 33:VII. Louisiana Administrative Code, Title 33, Environmental Quality, Part VII,  
26 Environmental Quality: Solid Waste. LAC 33:VII. State of Louisiana, Division of Administration.  
27 Available at <<http://www.doa.la.gov/Pages/osr/lac/LAC-33.aspx>> (accessed 23 October 2017).
- 28 LAC 51:XXVII. Louisiana Administrative Code, Title 51, Public Health-Sanitary Code,  
29 Part XXVII, Management of Refuse, Infectious Waste, Medical Waste, and Potentially Infectious  
30 Biomedical Waste LAC 51:XXVII. Available at  
31 <<http://www.doa.la.gov/Pages/osr/lac/books.aspx>> (accessed 23 October 2017).
- 32 [LDEQ] Louisiana Department of Environmental Quality. 2004. Permit modification,  
33 Waterford III, Entergy Operations, Inc. Killona, St. Charles Parish. ADAMS Accession  
34 No. ML17023A268.
- 35 [LDEQ] Louisiana Department of Environmental Quality. 2014. Final 2014 Louisiana Water  
36 Quality Inventory: Integrated Report, Fulfilling Requirements of the Federal Clean Water Act,  
37 Sections 305(b) and 303(d). Baton Rouge, LA: Department of Environmental Quality.  
38 September 2014. EPA revisions dated July 28, 2015. Available at  
39 <[http://www.deq.louisiana.gov/portal/DIVISIONS/WaterPermits/WaterQualityStandardsAssessm  
40 ent/WaterQualityInventorySection305b/2014IntegratedReport.aspx](http://www.deq.louisiana.gov/portal/DIVISIONS/WaterPermits/WaterQualityStandardsAssessm<br/>40 ent/WaterQualityInventorySection305b/2014IntegratedReport.aspx)> (accessed  
41 25 October 2016).

## Affected Environment

- 1 [LDEQ] Louisiana Department of Environmental Quality. 2015a. Letter from S. Guilliams,  
2 Administrator, Water Permit Division, to K.M. Dowell, Entergy Services, Inc. RE: Entergy  
3 Operations, Inc. – Waterford Steam Electric Station Unit 3 Water Quality Certification.  
4 January 30, 2015. In: Appendix E, Applicant’s Environmental Report, Operating License  
5 Renewal Stage, Waterford Steam Electric Station, Unit 3. [Attachment A]. ADAMS Accession  
6 No. ML16088A335.
- 7 [LDEQ] Louisiana Department of Environmental Quality. 2015b. Letter from N. Larsen,  
8 Environmental Project Specialist 3, Permits Application Administrative Review Group, to  
9 M. Chisum, Site Vice President, Entergy Operations, Inc. RE: Waterford 3 Steam Electric  
10 Station Administrative Completeness Determination. April 15, 2015. ADAMS Accession  
11 No. ML17037D302.
- 12 [LDEQ] Louisiana Department of Environmental Quality. 2016. “Final 2014 Louisiana Water  
13 Quality Integrated Report (305(b)/303(d)).” Page updated July 29, 2015. Available at  
14 <[http://www.deq.louisiana.gov/portal/DIVISIONS/WaterPermits/WaterQualityStandardsAssessm  
16 ent/WaterQualityInventorySection305b/2014IntegratedReport.aspx](http://www.deq.louisiana.gov/portal/DIVISIONS/WaterPermits/WaterQualityStandardsAssessm<br/>15 ent/WaterQualityInventorySection305b/2014IntegratedReport.aspx)> (accessed  
17 5 December 2016).
- 18 [LDEQ] Louisiana Department of Environmental Quality. 2017. Permit No. LA0007374, AI  
19 No.: 35260, Water Discharge Permit, Entergy Operations, Waterford 3 Steam Electric Station.  
20 Baton Rouge, LA: Office of Environmental Services. Issued 1 August 2017. Effective date  
21 1 October 2017. Available at  
22 <<http://edms.deq.louisiana.gov/app/doc/view.aspx?doc=10769669&ob=yes&child=yes>>  
(accessed 10 October 2017).
- 23 [LDH] Louisiana Department of Health. Undated. “Annual Infectious Disease Surveillance  
24 Reports.” Available at <<http://new.dhh.louisiana.gov/index.cfm/page/536>> (accessed  
25 14 December 2016).
- 26 [LDNR] Louisiana Department of Natural Resources. 2013. Coastal Use  
27 Authorization/Consistency Determination. RE: P20130941, ENTERGY – WATERFORD 3.  
28 Office of Coastal Management. July 19, 2013. ADAMS Accession No. ML17038A260.  
29 [Env-RAI SW-11 Package.]
- 30 [LDNR] Louisiana Department of Natural Resources. 2015. Letter from D. Haydel, LDNR, to  
31 R. Buckley, Entergy. RE: C20150075, Coastal Zone Consistency, Entergy Louisiana, LLC and  
32 Entergy Operations, Inc., Nuclear Regulatory Commission, Federal License or Permit, Renewal  
33 of the operating license for the Waterford Steam Electric Station, Unit 3, through  
34 December 18, 2044, St. Charles Parish, Louisiana. April 14, 2015. In Entergy 2016ER  
35 (p. E-17).
- 36 [LDNR] Louisiana Department of Natural Resources. 2016. “Surface Water Management  
37 Program.” No page date. Available at  
38 <<http://www.dnr.louisiana.gov/index.cfm?md=pagebuilder&tmp=home&pid=92>> (accessed  
39 5 December 2016).
- 40 [LADOTD] Louisiana Department of Transportation & Development. 2017. “Estimated Annual  
41 Average Daily Traffic Count.” Available at <<http://wwwapps.dotd.la.gov/engineering/tatv/>>  
42 (accessed May 2017).

- 1 [LDWF] Louisiana Department of Wildlife and Fisheries. 2013. Letter from K. Balkum, Biologist,  
2 Program Manager, to K. Morgan, Administrator, Louisiana Department of Natural Resources,  
3 Office of Coastal Management. RE: Application Number: P20130941, Applicant:  
4 Entergy-Waterford-3. July 9, 2013. ADAMS Accession No. ML17038A277.  
5 [Env-RAI SW-11 Package.]
- 6 [LDWF] Louisiana Department of Wildlife and Fisheries. 2015. 2013–2014 Annual Report.  
7 Baton Rouge, LA. Available at  
8 <[http://www.wlf.louisiana.gov/sites/default/files/pdf/publication/39247-2013-2014-annual-](http://www.wlf.louisiana.gov/sites/default/files/pdf/publication/39247-2013-2014-annual-report/2013-2014_annual_report.pdf)  
9 [report/2013-2014\\_annual\\_report.pdf](http://www.wlf.louisiana.gov/sites/default/files/pdf/publication/39247-2013-2014-annual-report/2013-2014_annual_report.pdf)> (accessed 1 December 2016).
- 10 [LDWF] Louisiana Department of Wildlife and Fisheries. Undated. Rare Animals of Louisiana:  
11 Paddlefish (*Polyodon spathula*). Available at  
12 <[http://www.wlf.louisiana.gov/sites/default/files/pdf/fact\\_sheet\\_animal/32190-](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_animal/32190-Polyodon%20spathula/polyodon_spathula.pdf)  
13 [Polyodon%20spathula/polyodon\\_spathula.pdf](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_animal/32190-Polyodon%20spathula/polyodon_spathula.pdf)> (accessed 7 November 2016).
- 14 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016a. “Maurepas Swamp WMA.”  
15 Available at <<http://www.wlf.louisiana.gov/wma/2791>> (accessed 16 May 2016).
- 16 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016b. “Salvador/Timken WMA.”  
17 Available at <<http://www.wlf.louisiana.gov/wma/2765>> (accessed 16 May 2016).
- 18 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016c. “Rare Animals of Louisiana:  
19 Bald Eagle.” Available at  
20 <[http://www.wlf.louisiana.gov/sites/default/files/pdf/fact\\_sheet\\_animal/32259-](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_animal/32259-Haliaeetus%20leucocephalus/haliaeetus_leucocephalus.pdf)  
21 [Haliaeetus%20leucocephalus/haliaeetus\\_leucocephalus.pdf](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_animal/32259-Haliaeetus%20leucocephalus/haliaeetus_leucocephalus.pdf)> (accessed 31 August 2016).
- 22 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016d. “Rare Plants of Louisiana:  
23 *Ceratopteris pteridoides* – Floating Antler-fern, Water Fern Family (Parkeriaceae).” Available at  
24 <[http://www.wlf.louisiana.gov/sites/default/files/pdf/fact\\_sheet\\_plant/31761-](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_plant/31761-Ceratopteris%20pteridoides/ceratopteris_pteridoides.pdf)  
25 [Ceratopteris%20pteridoides/ceratopteris\\_pteridoides.pdf](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_plant/31761-Ceratopteris%20pteridoides/ceratopteris_pteridoides.pdf)> (accessed 31 August 2016).
- 26 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016e. “Rare Plants of Louisiana:  
27 *Mimulus ringens* – Square-stemmed Monkey Flower, Figwort Family (Scrophulariaceae).”  
28 Available at <[http://www.wlf.louisiana.gov/sites/default/files/pdf/fact\\_sheet\\_plant/31996-](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_plant/31996-Mimulus%20ringens/mimulus_ringens.pdf)  
29 [Mimulus%20ringens/mimulus\\_ringens.pdf](http://www.wlf.louisiana.gov/sites/default/files/pdf/fact_sheet_plant/31996-Mimulus%20ringens/mimulus_ringens.pdf)> (accessed 31 August 2016).
- 30 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016f. Species by Parish List.  
31 Available at <<http://www.wlf.louisiana.gov/wildlife/species-parish-list>> (accessed 7 July 2016).
- 32 [LGS] Louisiana Geological Survey. 2001. Earthquakes in Louisiana, Public Information Series  
33 No. 7. June 2001. Available at <<http://www.lgs.lsu.edu/deploy/uploads/7earthquakes.pdf>>  
34 (accessed 19 October 2016).
- 35 [LNHP] Louisiana Natural Heritage Program. 2016. Species by Parish List: St. Charles Parish.  
36 Available at <[http://www.wlf.louisiana.gov/wildlife/species-parish-list?tid=256&type\\_1=All](http://www.wlf.louisiana.gov/wildlife/species-parish-list?tid=256&type_1=All)>  
37 (accessed 31 August 2016).
- 38 [LOCD] Louisiana Office of Cultural Development. 2011. Our Places, Our Heritage: A Plan for  
39 Historic Preservation and Archaeological Conservation in Louisiana, 2011–2015. Available at  
40 <[http://www.crt.state.la.us/Assets/OCD/hp/SHPO/SHPO\\_Jan\\_2011.pdf](http://www.crt.state.la.us/Assets/OCD/hp/SHPO/SHPO_Jan_2011.pdf)> (accessed  
41 13 February 2017).
- 42 [LOCD] Louisiana Office of Cultural Development. 2017. Division of Historic Preservation –  
43 National Register. Available at <[http://www.crt.state.la.us/cultural-development/historic-](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)  
44 [preservation/national-register/index](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)> (accessed 13 February 2017).

## Affected Environment

- 1 Louisiana Office of Public Health. 2013. Meningo-Encephalitis Due to Free Living Amebas  
2 Annual Report. Available at <[http://new.dhh.louisiana.gov/assets/oph/Center-PHCH/Center-  
3 CH/infectious-epi/Annals/AmebaFreeLivingEncephalitis\\_LalDAnnual.pdf](http://new.dhh.louisiana.gov/assets/oph/Center-PHCH/Center-CH/infectious-epi/Annals/AmebaFreeLivingEncephalitis_LalDAnnual.pdf)> (accessed  
4 14 December 2016).
- 5 [LTC] Louisiana Tax Commission. 2015. "Louisiana Tax Commission Annual Report 2015."  
6 Available at <[http://www.latax.state.la.us/Menu\\_AnnualReports/UploadedFiles/](http://www.latax.state.la.us/Menu_AnnualReports/UploadedFiles/)> (accessed  
7 May 2017).
- 8 [MSA] Magnuson–Stevens Fishery Conservation and Management Reauthorization Act of 2006,  
9 as amended. 16 U.S.C. §§1801–1884.
- 10 [MMPA] Marine Mammal Protection Act of 1972, as amended. 16 U.S.C. §1361 et seq.
- 11 McFarland DG, Nelson LS, Grodowitz MJ, Smart RM, Owens CS. 2004. *Salvinia molesta*  
12 D.S. Mitchell (Giant Salvinia) in the United States: A review of species ecology and approaches  
13 to management. ERDC/EL SR-04-2. Jacksonville, Fla.: U.S. Army Corps of Engineers Aquatic  
14 Plant Control Research Program.
- 15 [MODNR] Missouri Department of Natural Resources. 2014. The New Madrid Seismic Zone,  
16 Division of Geology and Land Survey Fact Sheet Number 26. February 2014. Available at  
17 <<http://www.dnr.mo.gov/pubs/pub2465.pdf>> (accessed 27 October 2014).
- 18 Moore BC, Martinez E, Gay JM, Rice DH. 2003. Survival of *Salmonella enterica* in freshwater  
19 and sediments and transmission by the aquatic midge *Chironomus tentans* (Chironomidae:  
20 Diptera). *Applied and Environmental Microbiology* 69(8):4556–4560.
- 21 [NASS] National Agricultural Statistics Service, U.S. Department of Agriculture. 2014.  
22 "2012 Census of Agriculture," Volume 1, Chapter 2, Parish Level, Table 7. "Hired Farm Labor –  
23 Workers and Payroll: 2012." 2012 Census of Agriculture, Volume 1 Chapter 2, Parish Level  
24 Data for Louisiana. May 2, 2014. Last modified: 5/16/2017. Available at  
25 <[http://www.agcensus.usda.gov/Publications/2012/Full\\_Report/Census\\_by\\_State/](http://www.agcensus.usda.gov/Publications/2012/Full_Report/Census_by_State/)> (accessed  
26 May 2017).
- 27 [NCES] National Center for Education Statistics. 2016a. "College Navigator." U.S. Department  
28 of Education, Washington, D.C. College and university student population within 50 miles of  
29 ZIP code 70057. Released July 2016. Available at  
30 <<http://nces.ed.gov/collegenavigator/default.aspx>> (accessed May 2017).
- 31 [NCES] National Center for Education Statistics. 2016b. St. Charles Parish Public School  
32 Districts. 2014–2015, 2015–2016 school years. Available at  
33 <<http://nces.ed.gov/ccd/districtsearch/>> (accessed May 2017).
- 34 [NCDC] National Climatic Data Center. 2010. 2010 Local Climatological Data Annual Summary  
35 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
36 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 14 December 2016).
- 37 [NCDC] National Climatic Data Center. 2011. 2011 Local Climatological Data Annual Summary  
38 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
39 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 28 June 2016).
- 40 [NCDC] National Climatic Data Center. 2012. 2012 Local Climatological Data Annual Summary  
41 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
42 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 28 June 2016).
- 43 [NCDC] National Climatic Data Center. 2013. 2013 Local Climatological Data Annual Summary  
44 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
45 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 28 June 2016).

- 1 [NCDC] National Climatic Data Center. 2014. 2014 Local Climatological Data Annual Summary  
2 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
3 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 28 June 2016).
- 4 [NCDC] National Climatic Data Center. 2015. 2015 Local Climatological Data Annual Summary  
5 with Comparative Data, New Orleans, Louisiana (KMSY). Available at  
6 <<http://www.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 28 June 2016).
- 7 [NCDC] National Climatic Data Center. 2016a. Storm Events Database for St. Charles Parish,  
8 Louisiana. Available at <<http://www.ncdc.noaa.gov/stormevents/>> (accessed  
9 3 November 2016).
- 10 [NCDC] National Climatic Data Center. 2016b. Storm Events Database, 8/28/2005 Hurricane  
11 Event Details. Available at <<http://www.ncdc.noaa.gov/stormevents/>> (accessed  
12 3 November 2016)
- 13 [NHEERL] National Health and Environmental Effects Research Laboratory, U.S. Environmental  
14 Protection Agency. 2011. Level III Ecoregions of the Continental United States: Washington,  
15 DC, scale 1:10,000,000. Available at  
16 <[http://training.fws.gov/courses/csp/csp3200/resources/documents/Eco\\_Level\\_III.pdf](http://training.fws.gov/courses/csp/csp3200/resources/documents/Eco_Level_III.pdf)>  
17 (accessed 17 May 2016).
- 18 [NOAA] National Oceanic and Atmospheric Administration. 2013. Regional Climate Trends and  
19 Scenarios for the U.S. National Climate Assessment, Part 2. Climate of the Southeast U.S.  
20 NOAA Technical Report NESDIS 142-2.
- 21 [NRR] Natural Resource Report. 2010. Federal Land Managers' Air Quality Related Values  
22 Work Group (FLAG). NPS/NRPC/NRR-2010/232. Available at  
23 <[https://www.nature.nps.gov/air/Pubs/pdf/flag/FLAG\\_2010.pdf](https://www.nature.nps.gov/air/Pubs/pdf/flag/FLAG_2010.pdf)> (accessed 27 December 2016).
- 24 [Nature Conservancy] The Nature Conservancy. "Mississippi Species: Gulf Sturgeon."  
25 Available at <[http://www.nature.org/ourinitiatives/regions/northamerica/unitedstates/  
26 mississippi/explore/gulf-sturgeon-species-profile.xml](http://www.nature.org/ourinitiatives/regions/northamerica/unitedstates/mississippi/explore/gulf-sturgeon-species-profile.xml)> (accessed 1 September 2016).
- 27 NatureServe. 2015. NatureServe Explorer: An online encyclopedia of life [web application].  
28 Version 7.1. NatureServe, Arlington, VA. Last Updated October 2015. Available at  
29 <<http://explorer.natureserve.org/servlet/NatureServe?searchName=Polyodon%20spathula>>  
30 (accessed 7 November 2016).
- 31 Nico L, Maynard E, Schofield PJ, Cannister M, Larson J, Fusaro A, Neilson M. 2016. Cyprinus  
32 carpio. USGS Nonindigenous Aquatic Species Database. Gainesville, FL. Last updated  
33 15 July 2015. Available at <<https://nas.er.usgs.gov/queries/factsheet.aspx?speciesID=4>>  
34 (accessed 8 November 2016).
- 35 Neuman RW, Butler NW. 1993. Louisiana Prehistory. Louisiana Archaeological Survey and  
36 Antiquities Commission. Second Edition. Available at  
37 <<http://www.crt.state.la.us/dataprojects/archaeology/virtualbooks/LAPREHIS/LAPRE.HTM>>  
38 (accessed 15 February 2017).
- 39 [NEI] Nuclear Energy Institute. 2007. Industry Ground Water Protection Initiative – Final  
40 Guidance Document. Washington, DC: NEI. NEI 07-07. August 2007. ADAMS Accession  
41 No. ML072600295.
- 42 [NRC] U.S. Nuclear Regulatory Commission. 1981. Final Environmental Statement Related to  
43 the Operation of Waterford Steam Electric Station, Unit No. 3. NUREG-0779. September 1981.  
44 ADAMS Accession No. ML16095A114.

## Affected Environment

- 1 [NRC] U.S. Nuclear Regulatory Commission. 1996. Generic Environmental Impact Statement.  
2 for License Renewal of Nuclear Plants, Final Report. Washington, DC: NRC. NUREG–1437,  
3 Volumes 1 and 2. May 31, 1996. 1,204 p. ADAMS Accession Nos. ML040690705 and  
4 ML040690738.
- 5 [NRC] U.S. Nuclear Regulatory Commission. 2005a. Event Notification Report for  
6 September 9, 2005, Event Numbers 41954. Available at <[http://www.nrc.gov/reading-rm/doc-](http://www.nrc.gov/reading-rm/doc-collections/event-status/event/2005/20050909en.html)  
7 [collections/event-status/event/2005/20050909en.html](http://www.nrc.gov/reading-rm/doc-collections/event-status/event/2005/20050909en.html)> (accessed 3 November 2016).
- 8 [NRC] US Nuclear Regulatory Commission. 2005b. Statement Submitted by the United States  
9 Nuclear Regulatory Commission to the Committee on Environment and Public Works United  
10 States Senate for the Hurricane Katrina Hearing. Available at <[http://www.nrc.gov/reading-](http://www.nrc.gov/reading-rm/doc-collections/congress-docs/congress-testimony/2005/katrina-testimony.pdf)  
11 [rm/doc-collections/congress-docs/congress-testimony/2005/katrina-testimony.pdf](http://www.nrc.gov/reading-rm/doc-collections/congress-docs/congress-testimony/2005/katrina-testimony.pdf)> (accessed  
12 3 November 2016).
- 13 [NRC] U.S. Nuclear Regulatory Commission. 2012. Request for Information Pursuant to Title  
14 10 of the *Code of Federal Regulations* 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3,  
15 of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident.  
16 Washington, DC: NRC. March 12, 2012. ADAMS Accession No. ML12053A340.
- 17 [NRC] U.S. Nuclear Regulatory Commission. 2013. *Generic Environmental Impact Statement*  
18 *for License Renewal of Nuclear Plants*. Washington, DC: Office of Nuclear Reactor Regulation.  
19 NUREG-1437, Revision 1, Volumes 1, 2, and 3. June 2013. ADAMS Accession  
20 Nos. ML13106A241, ML13106A242, and ML13106A244.
- 21 [NRC] U.S. Nuclear Regulatory Commission. 2014. Probabilistic Seismic Hazard Analysis:  
22 Background Information. May 20, 2014. ADAMS Accession No. ML14140A648.
- 23 [NRC] U.S. Nuclear Regulatory Commission. 2016. Occupational Radiation Exposure at  
24 Commercial Nuclear Power Reactors and Other Facilities 2014: Forty-Seventh Annual Report.  
25 Washington, DC: NRC. NUREG–0713, Volume 36. April 2016. ADAMS Accession  
26 No. ML16112A230.
- 27 [OSH Act] Occupational Safety and Health Act of 1970, as amended. 29 U.S.C. §651 et seq.
- 28 Oscar TP. 2009. Predictive model for survival and growth of *Salmonella typhimurium* DT104  
29 on chicken skin during temperature abuse. *Journal of Food Protection* 72(2):304–314.
- 30 [OSHA] Occupational Safety and Health Administration. 1999. OSHA Technical Manual  
31 (OTM). Section III: Chapter 7, “Legionnaires’ Disease.” Available at  
32 <[https://www.osha.gov/dts/osta/otm/otm\\_iii/otm\\_iii\\_7.html](https://www.osha.gov/dts/osta/otm/otm_iii/otm_iii_7.html)> (accessed 2 March 2016).
- 33 Prakken LB. 2009. Groundwater Resources in the New Orleans Area, 2008, State of Louisiana  
34 Department of Transportation and Development, Office of Public Works, Hurricane Flood  
35 Protection and Intermodal Transportation Water Resources Programs; Water Resources  
36 Technical Report No. 80. 2009. Available at  
37 <<http://la.water.usgs.gov/publications/pdfs/TR80.pdf>> (accessed 2 November 2016).
- 38 [PHAC] Public Health Agency of Canada. 2010. *Shigella* spp.—Pathogen Safety Data Sheets.  
39 September 2010. Available at <[http://www.phac-aspc.gc.ca/lab-bio/res/psds-ftss/shigella-](http://www.phac-aspc.gc.ca/lab-bio/res/psds-ftss/shigella-eng.php)  
40 [eng.php](http://www.phac-aspc.gc.ca/lab-bio/res/psds-ftss/shigella-eng.php)> (accessed 2 March 2016).
- 41 Reed D, Wilson L. 2004. Coast 2050: A New Approach to Restoration of Louisiana Coastal  
42 Wetlands, Physical Geography, V.H. Winston and Son, Inc. p. 4–21. 2004. Available at  
43 <<http://labs.uno.edu/restoration/Reed%20and%20Wilson%202050.pdf>> (accessed  
44 31 October 2016).

- 1 [SCP] St. Charles Parish, Louisiana – Code of Ordinances, Chapter 24 – Noise. Undated.  
2 Available at  
3 <[https://www.municode.com/library/la/st\\_charles\\_parish/codes/code\\_of\\_ordinances?nodeId=PTIIPACO\\_CH24NO](https://www.municode.com/library/la/st_charles_parish/codes/code_of_ordinances?nodeId=PTIIPACO_CH24NO)> (accessed 27 December 2016).  
4
- 5 [SCP] St. Charles Parish. 2011. St. Charles Parish 2030 Comprehensive Plan. Volume 1:  
6 Policy Document. Adopted June 20, 2011. 209 p. Available at  
7 <<http://stcharlesftp.com/publicinfo/compplan.pdf>> (accessed 16 May 2016).  
8
- 9 St. Charles Parish. 2015. Hazard Mitigation Plan. Prepared by Providence for St. Charles  
10 Parish, LA. January 2015. Available at <<http://stcharlesparish-la.gov/departments/emergency-preparedness>> (accessed 5 December 2016).  
11
- 12 [SCP] St. Charles Parish. 2016a. “About Waterworks.” Available at <<http://stcharlesparish-la.gov/departments/waterworks/about-waterworks>> (accessed 8 July 2016).  
13
- 14 [SCP] St. Charles Parish. 2016b. “Comprehensive Annual Financial Report for the Fiscal Year  
15 Ended December 31, 2015.” Available at  
16 <<http://www.stcharlesgov.net/departments/finance/financial-statements-audits>> (accessed  
17 May 2017).  
18
- 19 Sharitz RR, Mitsch WJ. 1993. “Southern floodplain forests,” p. 311–372. In Martin WH,  
20 Boyce SG, Echternacht AC, editors. Biodiversity of the Southeastern United States, Lowland  
21 Terrestrial Communities. John Wiley and Sons: New York, NY.  
22
- 23 Steam Control Commission. 1972. Letter from R.A. Lafleur, Executive Secretary, to Louisiana  
24 Power and Light Company. RE: Letter of certification. June 21, 1972. In: Appendix E,  
25 Applicant’s Environmental Report, Operating License Renewal Stage, Waterford Steam Electric  
26 Station, Unit 3. [Attachment A]. ADAMS Accession No. ML16088A335.  
27
- 28 Todar K. 2004. Pseudomonas. Available at  
29 <<http://textbookofbacteriology.net/pseudomonas.html>> (accessed 2 March 2016).  
30
- 31 Toft JD, Simenstad CA, Cordell JR, Grimaldo LF. 2003. The effects of introduced water  
32 hyacinth on habitat structure, invertebrate assemblages, and fish diets.  
33 *Estuaries* 26(3):746–758.  
34
- 35 Tomaszewski, DJ. 2003a. Ground-Water Resources Along the Lower Mississippi River,  
36 Southeastern Louisiana, State of Louisiana Department of Transportation and Development,  
37 Office of Public Works and Intermodal Public Works and Water Resources Division; Water  
38 Resources Technical Report No. 69. 2003. Available at  
39 <<http://la.water.usgs.gov/publications/pdfs/TR69.pdf>> (accessed 2 November 2016).  
40
- 41 Tomaszewski, DJ. 2003b. Plate 2: The Altitude of Top, Extent and Thickness, and Distribution  
42 of Freshwater in Gramercy Aquifer, Lower Mississippi River Area in Southeastern Louisiana  
43 Ground-Water Resources Along the Lower Mississippi River, Southeastern Louisiana, State of  
44 Louisiana Department of Transportation and Development, Office of Public Works and  
45 Intermodal Public Works and Water Resources Division; Water Resources Technical Report  
46 No. 69. 2003. Available at <<http://la.water.usgs.gov/publications/pdfs/TR69Plate2.pdf>>  
47 (accessed 2 November 2016).  
48

## Affected Environment

- 1 Tomaszewski DJ. 2003c. Plate 3: The Altitude of Top, Extent and Thickness, and Distribution  
2 of Freshwater in Norco Aquifer, Lower Mississippi River Area in Southeastern Louisiana  
3 Ground-Water Resources Along the Lower Mississippi River, Southeastern Louisiana, State of  
4 Louisiana Department of Transportation and Development, Office of Public Works and  
5 Intermodal Public Works and Water Resources Division; Water Resources Technical Report  
6 No. 69. 2003. Available at <<http://la.water.usgs.gov/publications/pdfs/TR69Plate3.pdf>>  
7 (accessed 2 November 2016).
- 8 Tomaszewski DJ. 2003d. Plate 4: The Altitude of Top, Extent and Thickness, and Distribution  
9 of Freshwater in Gonzales-New Orleans Aquifer, Lower Mississippi River Area in Southeastern  
10 Louisiana Ground-Water Resources Along the Lower Mississippi River, Southeastern Louisiana,  
11 State of Louisiana Department of Transportation and Development, Office of Public Works and  
12 Intermodal Public Works and Water Resources Division; Water Resources Technical Report  
13 No. 69. 2003. Available at <<http://la.water.usgs.gov/publications/pdfs/TR69Plate4.pdf>>  
14 (accessed 2 November 2016).
- 15 Tyndall RL, Ironside KS, Metler PL, Tan EL, Hazen TC, Fliermans CB. 1989. Effect of thermal  
16 additions on the density and distribution of thermophilic amoebae and pathogenic *Naegleria*  
17 *fowleri* in a newly created cooling lake. *Applied and Environmental Microbiology* 55(3):722–732.
- 18 [USACE] U.S. Army Corps of Engineers. 1972. Department of the Army Permit, LMNOD-SP  
19 (Mississippi River) 796. Re: Install and maintain intake and discharge structure, protective  
20 dolphins, and appurtenant works. Issued to Louisiana Power and Light Co. U.S. Army Corps of  
21 Engineers, New Orleans District. Issued July 7, 1972. ADAMS Accession No. ML17038A264.  
22 [Env-RAI SW-11 Package.]
- 23 [USACE] U.S. Army Corps of Engineers. 2013. Letter from A. Powell, Operations Manager,  
24 Completed Works, New Orleans District, to J. Dantin, President, Board of Commissioners,  
25 LaFourche Basin Levee District. RE: Application for a Department of the Army permit dated  
26 July 15, 2013, from Entergy – Waterford 3. September 19, 2013. ADAMS Accession  
27 No. ML17038A273. [Env-RAI SW-11 Package.]
- 28 [USACE] United States Army Corps of Engineers. 2016a. “The Mississippi River.” (Flood  
29 Control Plan). New Orleans District. No page date. Available at  
30 <[http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Mississippi-River-](http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Mississippi-River-Tributaries/)  
31 [Tributaries/](http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Mississippi-River-Tributaries/)> (accessed 8 July 2016).
- 32 [USACE] United States Army Corps of Engineers. 2016b. “Bonnet Carre' Spillway Overview.”  
33 New Orleans District. No page date. Available at  
34 <[http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Bonnet-Carre-](http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Bonnet-Carre-Spillway-Overview/)  
35 [Spillway-Overview/](http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Bonnet-Carre-Spillway-Overview/)> (accessed 5 December 2016).
- 36 [USACE] United States Army Corps of Engineers. 2016c. “An Overview of the Mississippi  
37 River’s Saltwater Wedge.” New Orleans District. No page date. Available at  
38 <[http://www2.mvn.usace.army.mil/eng/saltwater/wedge\\_overview.asp](http://www2.mvn.usace.army.mil/eng/saltwater/wedge_overview.asp)> (accessed  
39 5 December 2016).
- 40 [USCB] U.S. Census Bureau. 2017a. American FactFinder, Table DP03 – “Selected Economic  
41 Characteristics,” 2011–2015, 5-Year Estimates for St. Charles and Jefferson Parishes.  
42 Available at <<http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>>  
43 (accessed May 2017).

- 1 [USCB] U.S. Census Bureau. 2017b. 1970–2010 Decennial Census: 1900 to 1990;  
2 “Table DP-1 – Profile of General Demographic Characteristics: 2000,” and American  
3 FactFinder, Table DP-1, “Profile of General Population and Housing Characteristics: 2010,  
4 2010 Demographic Profile Data” for St. Charles and Jefferson Parishes. Available at  
5 <http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t> (accessed  
6 May 2017).
- 7 [USCB] U.S. Census Bureau. 2017c. American FactFinder, “2011–2015 American Community  
8 Survey 5-Year Estimates,” Table DP05 – “ACS Demographic and Housing Estimates” for  
9 St. Charles and Jefferson Parishes. Available at  
10 <http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t> (accessed  
11 May 2017).
- 12 [USCB] U.S. Census Bureau. 2017d. American FactFinder, “2011–2015 American Community  
13 Survey 5-Year Estimates,” Table B25001 – “Housing Units” and Table B25004 – “Vacancy  
14 Status” for parishes within 50-mile radius of WF3. Available at  
15 <http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t> (accessed  
16 May 2017).
- 17 [USCB] U.S. Census Bureau. 2017e. “American FactFinder, “2011–2015 American Community  
18 Survey 5-Year Estimates,” Table DP04 – Selected Housing Characteristics” for St. Charles and  
19 Jefferson Parishes. Available at  
20 <http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t> (accessed  
21 May 2017).
- 22 [USCB] U.S. Census Bureau. 2017f. American FactFinder, Table DP-1, “Profile of General  
23 Population and Housing Characteristics: 2010, 2010 Demographic Profile Data.” American  
24 Fact Finder, “2011–2015 American Community Survey 5-Year Estimates,” Table DP05 – “ACS  
25 Demographic and Housing Estimates” and Table DP03 – “Selected Economic Characteristics.”  
26 Available at <http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>  
27 (accessed March 2017).
- 28 [USCG] U.S. Coast Guard. 1996. Approval for Private Aids to Navigation, CG-2554. RE: Mark  
29 Ends of New Dock and Dolphins; Protect Intake Structure. Issued December 11, 1972; revised  
30 August 29, 1996. ADAMS Accession No. ML17038A280.
- 31 [USGS] U.S. Geological Survey. 2016a. USGS Water-Year Summary 2015, 07374525  
32 Mississippi River at Belle Chasse, LA. Available at  
33 [http://waterdata.usgs.gov/nwis/wys\\_rpt/?site\\_no=07374525&agency\\_cd=USGS](http://waterdata.usgs.gov/nwis/wys_rpt/?site_no=07374525&agency_cd=USGS) (accessed  
34 5 December 2016).
- 35 [USGS] U.S. Geological Survey. 2016b. USGS Water-Year Summary 2015, 07374000  
36 Mississippi River at Baton Rouge, LA. Available at  
37 [http://waterdata.usgs.gov/nwis/wys\\_rpt/?site\\_no=07374000&agency\\_cd=USGS](http://waterdata.usgs.gov/nwis/wys_rpt/?site_no=07374000&agency_cd=USGS) (accessed  
38 5 December 2016).
- 39 [USDA] U.S. Department of Agriculture. 2014. 2012 Census of Agriculture: Louisiana State  
40 and Parish Data. Volume 1, Geographic Area Series, Part 18. Issued May 2014. Available at  
41 [https://www.agcensus.usda.gov/Publications/2012/Full\\_Report/Volume\\_1\\_Chapter\\_2\\_County  
42 Level/Louisiana/lav1.pdf](https://www.agcensus.usda.gov/Publications/2012/Full_Report/Volume_1_Chapter_2_County_Level/Louisiana/lav1.pdf) (accessed 16 May 2016).
- 43 [USDA] U.S. Department of Agriculture. 2016. Custom Soil Resource Report for St. Charles  
44 Parish, Louisiana, Waterford. National Resources Conservation Service. 2016. Available at  
45 <http://websoilsurvey.nrcs.usda.gov/app/WebSoilSurvey.aspx> (accessed 4 October 2016).

## Affected Environment

- 1 [UGA] University of Georgia. 2016. Status of Invasives for Louisiana. Available at  
2 <[http://www.eddmaps.org/tools/statereport.cfm?id=us\\_la](http://www.eddmaps.org/tools/statereport.cfm?id=us_la)> (accessed 31 August 2016).
- 3 Van Kooten G. 2005. Disturbances in the Delta: Understanding New Orleans' Geology, Calvin  
4 College, Spark, Winter 2005. Available at <[https://www.calvin.edu/publications/spark/  
5 2005/winter/neworleans2.htm](https://www.calvin.edu/publications/spark/2005/winter/neworleans2.htm)> (accessed 31 October 2016).
- 6 Weakley A, Dinerstein E, Snodgrass R, Wolfe K. 2016. "Mississippi Lowland Forests."  
7 Available at <<http://www.worldwildlife.org/ecoregions/na0409>> (accessed 18 May 2016).
- 8 Wiken E, Nava FJ, Griffith G. 2011. North American Terrestrial Ecoregions—Level III.  
9 Montreal, Canada: Commission for Environmental Cooperation. Available at  
10 <[http://www3.cec.org/islandora/en/item/10415-north-american-terrestrial-ecoregionslevel-iii-  
11 en.pdf](http://www3.cec.org/islandora/en/item/10415-north-american-terrestrial-ecoregionslevel-iii-<br/>11 en.pdf)> (accessed 18 May 2016).
- 12 White VE, Prakken LB. 2015. Water Resources of St. Charles Parish, Louisiana. Baton  
13 Rouge, LA: U.S. Geological Survey, Lower Mississippi-Gulf Water Science Center.  
14 Fact Sheet 2014–3118. February 2015. Available at  
15 <<https://pubs.usgs.gov/fs/2014/3118/pdf/fs2014-3118.pdf>> (accessed 5 December 2016).
- 16 Yuill B, Lavoie D, Reed DJ. 2009. Understanding Subsidence Processes in Coastal Louisiana,  
17 *Journal of Coastal Research* SI(54):23–36. West Palm Beach (FL), ISSN 0749-0208.  
18 Fall 2009. Available at <<http://www.jcronline.org/doi/pdf/10.2112/SI54-012.1>> (accessed  
19 1 November 2016).

## 1     **4.0 ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS**

### 2     **4.1 Introduction**

3     In license renewal environmental reviews, the U.S. Nuclear Regulatory Commission (NRC)  
4     considers the environmental consequences of the proposed action (i.e., continued reactor  
5     operations), the no-action alternative (i.e., not renewing the operating license), and the  
6     environmental consequences of various alternatives for replacing the nuclear power plant's  
7     generating capacity. In plant-specific environmental reviews, the NRC compares the  
8     environmental impacts of license renewal with those of the no-action alternative and  
9     replacement power alternatives to determine whether the adverse environmental impacts of  
10    license renewal are not so great that it would be unreasonable to preserve the option of license  
11    renewal for energy-planning decisionmakers.

12    In this chapter, the NRC evaluates the environmental consequences of the proposed action  
13    (i.e., license renewal of Waterford 3 (WF3)), including the (1) impacts associated with continued  
14    operations similar to those that have occurred during the current license term, (2) impacts of  
15    various alternatives to the proposed action, (3) impacts from the termination of nuclear power  
16    plant operations and decommissioning after the license renewal term (with emphasis on the  
17    incremental effect caused by an additional 20 years of reactor operation), (4) impacts  
18    associated with the uranium fuel cycle, (5) impacts of postulated accidents (design-basis  
19    accidents (DBAs) and severe accidents), (6) cumulative impacts of the proposed action, and  
20    (7) resource commitments associated with the proposed action, including unavoidable adverse  
21    impacts, the relationship between short-term use and long-term productivity, and irreversible  
22    and irretrievable commitment of resources. The NRC also considers new and potentially  
23    significant information on environmental issues related to the impacts of operation during the  
24    renewal term.

25    NUREG–1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*  
26    (*GEIS*) (NRC 1996, 1999, 2013d), identifies 78 issues to be evaluated in the license renewal  
27    environmental review process. This supplemental environmental impact statement (SEIS)  
28    supplements the information provided in the GEIS. Generic issues (Category 1) rely on the  
29    analysis presented in the GEIS, unless otherwise noted. Applicable site-specific issues  
30    (Category 2) have been analyzed for WF3 and assigned a significance level of SMALL,  
31    MODERATE, or LARGE. Section 1.4 of this SEIS provides an explanation of the criteria for  
32    Category 1 and Category 2 issues, as well as the definitions of SMALL, MODERATE, and  
33    LARGE. Resource-specific impact significance level definitions are provided where applicable.

### 34    **4.2 Land Use and Visual Resources**

35    This section describes the potential impacts of the proposed action (license renewal) and  
36    alternatives to the proposed action on land use and visual resources.

#### 37    **4.2.1 Proposed Action**

38    Section 3.2 of this supplemental environmental impact statement (SEIS) describes land use  
39    and visual resources in the vicinity of the WF3 site. The four generic (Category 1) issues that  
40    apply to land use and visual resources during the proposed license renewal period appear in  
41    Table 4–1. The GEIS (NRC 2013a) discusses these issues in Section 4.2.1. The GEIS does  
42    not identify any site-specific (Category 2) land use or visual resource issues.

## Environmental Consequences and Mitigating Actions

1 The NRC staff did not identify any new and significant information related to the generic  
2 (Category 1) land use and visual resource issues during the review of the applicant's  
3 Environmental Report (ER) (Entergy 2016a), the site audit, or the scoping process. Therefore,  
4 the NRC expects no impacts associated with these issues beyond those discussed in the GEIS.  
5 The GEIS concludes that the impact level for each of these issues is SMALL.

6 **Table 4–1. Land Use and Visual Resource Issues**

Issue	GEIS Section	Category
<b>Land Use</b>		
Onsite land use	4.2.1.1	1
Offsite land use	4.2.1.1	1
Offsite land use in transmission line right-of-ways (ROWs) <sup>(a)</sup>	4.2.1.1	N/A <sup>(b)</sup>
<b>Visual Resources</b>		
Aesthetic impacts	4.2.1.2	1

<sup>(a)</sup> This issue applies only to the in-scope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

<sup>(b)</sup> As described in Section 3.1.6, all in-scope transmission lines subject to the evaluation of environmental impacts for license renewal are located within the WF3 site property boundary. Therefore, this issue does not apply to WF3 license renewal.

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51, NRC 2013a

### 7 **4.2.2 No-Action Alternative**

#### 8 **4.2.2.1 Land Use**

9 If WF3 were to shut down, the impacts to land use would remain similar to those during  
10 operations. Temporary buildings and staging or laydown areas may be required during large  
11 component and structure dismantling. WF3 is likely to have sufficient space within previously  
12 disturbed areas for these needs; therefore, no additional land would need to be disturbed that  
13 would result in changes to current land uses. The GEIS (NRC 2013a) notes that land use  
14 impacts could occur in other areas beyond the immediate nuclear plant site as a result of the  
15 no-action alternative if new power plants are needed to replace lost capacity. The NRC staff  
16 concludes that the no-action alternative is unlikely to noticeably alter or have more than minor  
17 effects on land use. Thus, the NRC staff concludes that the impacts of the no-action alternative  
18 on land use during the proposed license renewal term would be SMALL.

#### 19 **4.2.2.2 Visual Resources**

20 If WF3 were to shut down, visual resources impacts would remain similar to those experienced  
21 during operations. The reactor auxiliary building, which creates the largest visual impact, would  
22 eventually be dismantled, which would reduce the already SMALL impacts to visual resources  
23 that would occur during the proposed license renewal term. Thus, the NRC staff concludes that  
24 the impacts of the no-action alternative on visual resources would be SMALL.

### 1 **4.2.3 New Nuclear Alternative**

#### 2 *4.2.3.1 Land Use*

3 The new nuclear alternative assumes that Entergy would build a new nuclear facility on the  
4 Entergy property but outside the existing WF3 and Waterford 1, 2, and 4 footprints. The facility  
5 would require an estimated 230 ac (93 ha) of land, all of which Entergy already owns.  
6 Additional offsite land would be required for uranium mining, although this impact would result in  
7 no net change in land use impacts from those that would be associated with the proposed WF3  
8 license renewal.

9 During construction, the use of the existing site would maximize availability of existing  
10 infrastructure, and Entergy (2016a) states that a new nuclear plant could be sited within the  
11 Entergy property footprint while meeting levee setback restrictions and avoiding wetlands.  
12 Because Entergy (2016a) would site the plant on property that is already zoned for heavy  
13 industrial use and that has been previously disturbed, impacts to wetlands and other site land  
14 uses would be minimal and likely unnoticeable. Accordingly, the NRC staff concludes that  
15 construction impacts would be SMALL. Operation of a new nuclear facility would incur impacts  
16 similar to those assessed for the proposed WF3 license renewal, which the NRC concludes, in  
17 Section 4.2.1, would be SMALL. The NRC staff concludes that impacts of constructing and  
18 operating a new nuclear alternative on land use would be SMALL.

#### 19 *4.2.3.2 Visual Resources*

20 Construction would require clearing, excavation, and the use of construction equipment, all of  
21 which may be visible off site. However, because the Entergy property is already an  
22 industrial-use site and is situated in a highly-industrialized area, these temporary visual impacts  
23 would be minimal in the context of the area's existing aesthetics. Depending on the exact  
24 location of the new nuclear alternative within the Entergy property, construction likely would be  
25 partially visible to individuals traveling along LA-18, LA-628, LA-3127 and the Mississippi River;  
26 from the nearest residences, which lie approximately 0.9 mi (1.4 km) from the site; and from  
27 Killona and Montz Parks, each of which are 1 mi (0.8 km) from the site. Construction of the new  
28 nuclear alternative would not be visible from any sensitive viewing areas, such as cultural  
29 resources or historic properties. Given the highly industrialized nature of the surrounding area,  
30 any visible construction machinery and activities would blend into the adjacent skyline. Painting  
31 auxiliary structures, ducts, pipes, and tanks blue-gray, as Entergy has done at WF3, would  
32 enable these features to blend into the concrete of the principle structures and further reduce  
33 any visual impacts. During operation, visual impacts would be similar in type and magnitude to  
34 those discussed for the proposed WF3 license renewal, which the NRC staff concludes, in  
35 Section 4.2.1, would be SMALL. New cooling towers and their associated plumes would be the  
36 most obvious visual impact and would likely be visible farther from the site than other buildings  
37 and infrastructure. Because of their height, the cooling towers may require aircraft warning  
38 lights, which would be visible at night. However, as previously discussed, the new nuclear plant  
39 would be located in a heavily industrialized area where tall structures and visible plumes already  
40 exist. The NRC staff concludes that impacts of constructing and operating a new nuclear  
41 alternative on visual resources would be SMALL.

### 42 **4.2.4 Supercritical Pulverized Coal Alternative**

#### 43 *4.2.4.1 Land Use*

44 The supercritical pulverized coal (SCPC) alternative assumes that Entergy would build a new  
45 SCPC facility at an existing power plant site within the Southeast Electric Reliability Corporation  
46 (SERC) region of Louisiana. The facility would be equipped with carbon capture and storage

## Environmental Consequences and Mitigating Actions

1 technology, mechanical draft cooling towers, and it would require an estimated 120 ac (49 ha) of  
2 land. The existing transmission line infrastructure would be sufficient to support the plant;  
3 however, additional offsite land would be required for coal mining and waste disposal.

4 During construction, the use of an existing power plant site would maximize availability of  
5 existing infrastructure. However, depending on the size of the acquired site, previously  
6 undisturbed or non-industrial areas may be cleared, graded, and converted or otherwise  
7 disturbed. Thus, construction impacts on land uses could range from SMALL, if the chosen site  
8 has enough previously disturbed industrial-use land to accommodate the new SCPC plant, to  
9 MODERATE if additional non-industrial areas are cleared and converted to industrial use.

10 Operation would not result in additional land use impacts on the chosen SCPC site. However,  
11 offsite land uses could be altered as a result of coal mining and waste disposal if affected lands  
12 were not already used for these purposes. Entergy (2016a) estimates that land requirements  
13 for coal mining and waste disposal could range from 1,350 to 30,700 ac (550 to 12,400 ha)  
14 during the life of the SCPC plant. Although some of this impact would be offset by the  
15 elimination of land required for uranium mining, the broad range in required land could result in  
16 impacts ranging from SMALL to MODERATE.

17 The NRC staff concludes that impacts of constructing and operating an SCPC alternative on  
18 land use would be SMALL to MODERATE.

### 19 4.2.4.2 *Visual Resources*

20 Construction would require clearing, excavation, and the use of construction equipment, all of  
21 which may be visible off site. However, because the SCPC plant would be sited on an existing  
22 power plant site, these temporary visual impacts would be minimal in the context of the area's  
23 existing aesthetics. During operation, exhaust stacks and cooling tower plumes likely would be  
24 visible off site, and some structures may require aircraft warning lights that would be visible at  
25 night. Such impacts would be similar to those already present, given that the SCPC plant would  
26 be located on an existing power plant site; however, exact impacts would vary depending on the  
27 topography of the area and the height of existing power plant structures. Accordingly, the NRC  
28 staff concludes that impacts of constructing and operating an SCPC alternative on visual  
29 resources could range from SMALL to MODERATE because of the uncertainty regarding the  
30 exact location of the alternative and the corresponding sensitivity of the surrounding viewshed.

### 31 4.2.5 **Natural Gas Combined-Cycle Alternative**

#### 32 4.2.5.1 *Land Use*

33 The natural gas combined-cycle (NGCC) alternative assumes that Entergy would build a new  
34 NGCC facility on its existing property. The facility would require an estimated 60 ac (24 ha) of  
35 land and would be sited on previously disturbed land. Some infrastructure upgrades could be  
36 required as well as construction of a new or upgraded pipeline.

37 During construction, the use of the existing site would maximize the availability of the existing  
38 infrastructure, and Entergy (2016a) states that it could site a new NGCC plant on previously  
39 disturbed land. Because Entergy (2016a) would site the plant on property that is already zoned  
40 for heavy industrial use and that has been previously disturbed, impacts to wetlands and other  
41 site land uses would be minimal and likely unnoticeable. Construction of a new gas pipeline  
42 segment with an associated right-of-way (ROW) would be required to connect the NGCC plant  
43 to an existing pipeline approximately 6 to 7 mi (10 to 11 km) to the south (Entergy 2016a).  
44 Collocating the new pipeline in an existing ROW could minimize land use impacts. Accordingly,  
45 the NRC staff concludes that construction impacts would be SMALL.

1 Operation would not result in additional land use impacts on the Entergy property. However,  
2 offsite land uses could be altered as a result of natural gas wells and collection stations if  
3 affected lands were not already used for these purposes. Entergy (2016a) estimates that offsite  
4 land requirements for a natural gas well field could require up to 4,920 ac (1,990 ha) of land.  
5 However, because of the abundance of natural gas being transported from the Northeast United  
6 States through the TETCO pipeline to the Gulf area, Entergy (2016a) does not anticipate that  
7 the use of offsite land would be required if a new NGCC plant were constructed. Thus, impacts  
8 on land use during operation would be SMALL.

9 The NRC staff concludes that impacts of constructing and operating an NGCC alternative on  
10 land use would be SMALL.

#### 11 4.2.5.2 *Visual Resources*

12 Visual impacts would be similar to those described in Section 4.2.3.2 for the new nuclear  
13 alternative, which would also be sited on the Entergy property. During operation, exhaust  
14 stacks would be visible, as well as new cooling towers and their associated plumes. Some  
15 structures may require aircraft warning lights that would be visible at night. However, as  
16 previously discussed, the new NGCC plant would be located in a heavily industrialized area  
17 where tall structures and visible plumes already exist. The NRC staff concludes that the  
18 impacts of constructing and operating an NGCC alternative on visual resources would be  
19 SMALL.

### 20 4.2.6 **Combination Alternative (NGCC, Biomass, and Demand-Side Management)**

#### 21 4.2.6.1 *Land Use*

22 The combination alternative assumes that Entergy would build a new NGCC facility and four  
23 biomass units on its existing property. The facilities would require a total of 90 ac (36 ha) of  
24 land (30 ac (12 ha) for the NGCC component and 60 ac (24 ha) for the biomass component).  
25 Some infrastructure upgrades could be required as well as construction of a new or upgraded  
26 pipeline. As with the NGCC alternative, offsite land is unlikely to be affected because of the  
27 availability of natural gas in the Gulf area through the TETCO pipeline. Additional offsite land  
28 for the biomass component is not anticipated for fuel feedstock, but it could be required for  
29 storing, loading, and transporting biomass fuel materials. The demand-side management  
30 (DSM) component would be implemented through energy efficiency and DSM programs across  
31 the Entergy service area.

32 Because the NGCC and biomass components of this alternative also would be sited on the  
33 Entergy property, construction of these components would have similar impacts as those  
34 described for the new nuclear alternative and NGCC alternative in Sections 4.2.3.1 and 4.2.5.1,  
35 respectively. DSM would not require any form of construction, and would, therefore have no  
36 construction-type impacts. Accordingly, construction impacts associated with the combination  
37 alternative would be SMALL.

38 Operation of the NGCC and biomass components would not result in additional land use  
39 impacts on the Entergy property. The NGCC component would not require additional offsite  
40 land use. Although the biomass component would require offsite land use for the cultivation of  
41 energy crops (fuel), land use impacts associated with the production of crops is already  
42 occurring and would be the same regardless of whether crops are used as feedstock for  
43 electricity generation, for food, or for some other purpose. DSM would not involve operational  
44 impacts. Thus, operational impacts resulting from the combination alternative would be SMALL.

45 The NRC staff concludes that the overall impacts of implementing the combination alternative  
46 on land use would be SMALL.

1 4.2.6.2 *Visual Resources*

2 Visual resource impacts for the NGCC and biomass components of the combination alternative  
 3 would be similar to those described for the NGCC alternative in Section 4.2.5.2, because they  
 4 would be sited on the same property and would involve similar types of buildings and  
 5 infrastructure. Both would use cooling towers to dissipate waste heat and some structures may  
 6 require aircraft warning lights that would be visible at night. However, as previously discussed,  
 7 the Entergy property is located in a heavily industrialized area where tall structures and visible  
 8 cooling tower plumes already exist. Therefore, visual impacts of these components of the  
 9 combination alternative would be SMALL. No visual impacts would be associated with the DSM  
 10 component. Therefore, the NRC staff concludes that the overall impacts of implementing the  
 11 combination alternative on visual resources would be SMALL.

12 **4.3 Air Quality and Noise**

13 This section describes the potential impacts of the proposed action (license renewal) and  
 14 alternatives to the proposed action on air quality and noise conditions.

15 **4.3.1 Proposed Action**

16 4.3.1.1 *Air Quality*

17 Section 3.3 describes the meteorological, air quality, and noise conditions in the vicinity of WF3.  
 18 Two Category 1 air quality issues are applicable to WF3: (1) air quality impacts (all plants) and  
 19 (2) air quality effects of transmission lines (Table 4–2). There are no Category 2 issues for air  
 20 quality. The Category 1 issue, air quality effects of transmission lines, considers the production  
 21 of ozone and oxides of nitrogen. The GEIS found that minute and insignificant amounts of  
 22 ozone and nitrogen oxides (NO<sub>x</sub>) are generated during the transmission of power to the nuclear  
 23 plant from the grid. The Category 1 issue, air quality impacts (all plants), considers the air  
 24 quality impacts from continued operation and refurbishment associated with license renewal.

25 **Table 4–2. Air Quality and Noise**

Issue	GEIS Section	Category
Air quality impacts (all plants)	4.3.1.1	1
Air quality effects of transmission lines	4.3.1.1	1
Noise impacts	4.3.1.2	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

26 The NRC staff did not identify any new and significant information during the review of Entergy's  
 27 ER (Entergy 2016a), the site audit, the scoping process, or responses to requests for additional  
 28 information (RAIs). As a result, the NRC did not identify any information or impacts related to  
 29 these issues that would change the conclusions presented in the GEIS. Therefore, there are no  
 30 impacts related to these issues beyond those discussed in the GEIS. The GEIS concludes that  
 31 the impact level for each of these issues is SMALL.

32 4.3.1.2 *Noise*

33 One Category 1 noise issue is applicable to WF3: noise impacts (Table 4–2). The 1996 GEIS  
 34 (NRC 1996) concluded that noise was not a problem at operating plants and was not expected  
 35 to be a problem at any nuclear plant during the license renewal term. The GEIS (NRC 2013a)  
 36 did not identify new information that would alter this conclusion; therefore, impacts are expected

1 to be SMALL. The NRC staff did not identify any new and significant information during the  
 2 review of Entergy’s ER (Entergy 2016a), the site audit, the scoping process, or responses to  
 3 RAls (Entergy 2016b). As a result, the NRC did not identify any information or impacts related  
 4 to this issue that would change the conclusions presented in the GEIS. Therefore, there are no  
 5 impacts related to this issue beyond those discussed in the GEIS. The GEIS concludes that the  
 6 impact level for this issue is SMALL.

7 **4.3.2 No-Action Alternative**

8 **4.3.2.1 Air Quality**

9 The no-action alternative represents a decision by the NRC not to renew the operating license  
 10 of a nuclear power plant beyond the current operating license term. At some point, all nuclear  
 11 plants will terminate operations and undergo decommissioning. The impacts from  
 12 decommissioning are considered in NUREG-0586, *Final Generic Environmental Impact*  
 13 *Statement on Decommissioning of Nuclear Facilities*. Therefore, the scope of impacts  
 14 considered under the no-action alternative includes the immediate impacts resulting from  
 15 activities at WF3 that would occur between plant shutdown and the beginning of  
 16 decommissioning (i.e., activities and actions necessary to cease operation of WF3). An  
 17 evaluation of the air quality impacts from replacement baseload power generation is provided in  
 18 Sections 4.3.3 through 4.3.6 below.

19 Under the no-action alternative, when the plant stops operating, there would be a reduction in  
 20 air pollutant emissions from activities related to plant operation, such as the use of combustion  
 21 sources (e.g., diesel generators, boilers) and vehicle traffic. Activity from these air emission  
 22 sources would not cease, but emissions would be lower. Therefore, if emissions decrease, the  
 23 impact on air quality from the shutdown of WF3 would be SMALL.

24 **4.3.2.2 Noise**

25 When the plant stops operating, there will be a reduction in noise from activities related to plant  
 26 operation, including the turbine generator, onsite gun range, and vehicle traffic (e.g., workers,  
 27 deliveries). As activity from noise sources is reduced, the impact on ambient noise levels is  
 28 expected to be less than current operations of WF3; therefore, impacts would be SMALL.

29 **4.3.3 New Nuclear Alternative**

30 **4.3.3.1 Air Quality**

31 As discussed in Section 2.2.2.1, the new nuclear alternative would consist of a gross capacity of  
 32 1,333 MWe and a capacity factor of 90 percent (1,200 MWe net). This alternative would be  
 33 located within a portion of the land on the approximately 3,600-ac (1,400-ha) Entergy Louisiana,  
 34 LLC property. Therefore, the new nuclear alternative would be located in St. Charles parish,  
 35 which is designated attainment for all National Ambient Air Quality Standards (NAAQS).

36 Construction of the new nuclear plant would result in temporary impacts on local air quality. Air  
 37 emissions would be intermittent and would vary based on the level and duration of a specific  
 38 activity throughout the construction phase. During the construction phase, the primary sources  
 39 of air emissions would be engine exhaust and fugitive dust emissions. Engine exhaust  
 40 emissions would be from heavy construction equipment and commuter, delivery, and support  
 41 vehicular traffic traveling within, to, and from the facility. Fugitive dust emissions would be from  
 42 soil disturbances by heavy construction equipment (e.g., earthmoving, excavating, and  
 43 bulldozing); vehicle traffic on unpaved surfaces; concrete batch plant operations; and, to a  
 44 lesser extent, wind erosion. Various mitigation techniques and best management practices

## Environmental Consequences and Mitigating Actions

1 (BMPs) (e.g., watering disturbed areas, reducing equipment idle times, and the use of ultra-low  
2 sulfur diesel fuel) could be used to minimize air emissions and reduce fugitive dust. Air  
3 emissions include criteria pollutants (particulate matter, nitrogen oxides, carbon monoxide, and  
4 sulfur dioxide), volatile organic compounds (VOCs), hazardous air pollutants (HAPs), and  
5 greenhouse gases (GHGs). Small quantities of VOCs and HAPs emissions would be released  
6 from equipment refueling; organic solvents used in cleaning, onsite storage, and the use of  
7 petroleum-based fuels; onsite maintenance of the heavy construction equipment; and certain  
8 painting and other construction-finishing activities. Construction lead times for nuclear plants  
9 are anticipated to be 7 years (NRC 2013b). Because air emissions from construction activities  
10 would be limited, local, and temporary, the NRC staff concludes that the associated air quality  
11 impacts from construction of a new nuclear alternative would be SMALL.

12 Operation of a new nuclear generating plant would result in air emissions similar in magnitude to  
13 those of WF3. Nuclear power plants do not burn fossil fuels to generate electricity. Sources of  
14 air emissions will include stationary combustion sources (e.g., diesel generators and auxiliary  
15 boilers); mechanical-draft cooling towers; and mobile sources (e.g., worker vehicles, onsite  
16 heavy equipment, and support vehicles). In general, most stationary combustion sources at a  
17 nuclear power plant operate only for limited periods, often for periodic maintenance testing.  
18 A new nuclear power plant would have to secure a permit from the Louisiana Department of  
19 Environmental Quality (LDEQ) for air pollutants emitted from sources (e.g., criteria pollutants,  
20 VOCs, HAPs, and GHGs) associated with its operations. The NRC staff expects the air  
21 emissions for combustion sources from a new nuclear plant to be similar to those currently  
22 being emitted from WF3 (see Section 3.2), and additional particulate matter emissions would  
23 result from operation of mechanical-draft cooling towers. However, as discussed in NRC  
24 2013a, air quality impacts from cooling tower operations have been small. Therefore, emissions  
25 are expected to fall far below the threshold for major sources (100 tons (91 MT) per year) and  
26 the threshold for mandatory GHG reporting (27,558 tons (25,000 MT) per year of carbon dioxide  
27 equivalents (CO<sub>2eq</sub>). Air emissions from operation of a new nuclear alternative are not expected  
28 to contribute to NAAQS violations. The NRC staff concludes that the impacts of operation of a  
29 new nuclear alternative on air quality would be SMALL.

### 30 4.3.3.2 *Noise*

31 As discussed in Section 3.2.2, St. Charles Parish has a noise ordinance that sets maximum  
32 permissible sound levels based on the receiving land use category (e.g., residential,  
33 commercial, industrial). For designated residential zones, the maximum sound limits received  
34 range from 50 decibels on the A-weighted scale (dBA) from 7 a.m.–10 p.m. and 45 dBA from  
35 10 p.m.–7 a.m. The St. Charles Parish noise ordinance does not set a maximum permissible  
36 sound level for areas zoned as industrial. The site location of the new nuclear alternative  
37 (within the 3,600-ac (1,400-ha) Entergy Louisiana, LLC property) has been designated as a  
38 heavy manufacturing zoning district. While the layout and exact location of a new nuclear plant  
39 may differ from WF3, the distance from primary noise sources to nearby residents is expected  
40 to be similar (i.e., approximately 0.9 mi (1.4 km) away).

41 Construction of a new nuclear power plant is similar to that of other large industrial projects and  
42 involves many noise-generating activities. In general, noise emissions vary with each phase of  
43 construction, depending on the level of activity, the mix of construction equipment for each  
44 phase, and site-specific conditions. Several factors, including source-receptor configuration,  
45 land cover, meteorological conditions (e.g., temperature, relative humidity, and vertical profiles  
46 of wind and temperature), and screening (e.g., topography, and natural or manmade barriers),  
47 affect noise propagation to receptors. Typical construction equipment, such as dump trucks,  
48 loaders, bulldozers, graders, scrapers, air compressors, generators, and mobile cranes, would  
49 be used, and pile-driving and blasting activities would take place during construction of a new

1 nuclear power plant. Other noise sources include commuter, delivery, and support vehicular  
2 traffic traveling within, to, and from the facility. These offsite noise sources would be intermittent  
3 and short-term, occurring during certain hours of the day (shift changes).

4 During the construction phase, a variety of construction equipment would be used for varying  
5 durations. Noise levels from construction equipment at 50 ft (15 m) distance typically are in the  
6 85- to 100-dBA range (DoT 2006); however, noise levels attenuate rapidly with distance. For  
7 instance, at a 0.9-mi (1.4-km) distance from construction equipment with a sound strength of  
8 85 dBA, noise levels drop 45 dBA (GSU 2016). Noise abatement and controls can be  
9 incorporated to reduce noise impacts. Based on the temporary nature of construction activities,  
10 the location of this facility is an existing zoned industrial area, consideration of noise attenuation  
11 from the construction site to residences, and good noise control practices, the NRC staff  
12 concludes that the potential noise impacts of construction activities from a new nuclear  
13 alternative would be SMALL.

14 During the operation phase, noise sources from the new nuclear power plant would include the  
15 cooling tower; transformers; turbines; other auxiliary equipment, such as standby generators or  
16 auxiliary boilers; and vehicular traffic (e.g., commuting, delivery, and support). Noise levels  
17 during operation of a new nuclear alternative would be similar to existing conditions, as noise  
18 sources would be similar to operation of WF3 and from surrounding industrial facilities.  
19 Therefore, noise impacts from operation of a new nuclear alternative would be SMALL.

#### 20 **4.3.4 SCPC Alternative**

##### 21 *4.3.4.1 Air Quality*

22 As discussed in Section 2.2.2.2, the SCPC alternative would consist of two 706-MWe units with  
23 a capacity factor of 85 percent each (i.e., 600 MWe net for each unit). The units would be  
24 collocated at an existing power plant site within the SERC region of Louisiana. Within the State  
25 of Louisiana, the only designated nonattainment areas for NAAQS are five parishes in the  
26 southeastern region of Louisiana for ozone. Therefore, the SCPC alternative could be located  
27 within a designated nonattainment area for ozone.

28 Construction of the SCPC plant would result in temporary impacts on local air quality. Activities  
29 such as earthmoving and vehicular traffic generate fugitive dust. In addition, emissions from  
30 these activities would contain various air pollutants, including carbon monoxide, oxides of  
31 nitrogen, oxides of sulfur, and PM, VOCs, and various GHGs. Air emissions would be  
32 intermittent and vary based on the level and duration of a specific activity throughout the  
33 construction phase. Construction lead times for coal plants are approximately 4 to 5 years  
34 (IEA/OECD/NEA 2005; NREL 2006). Various mitigation techniques could be used to minimize  
35 air emissions and reduce fugitive dust. Because air emissions from construction activities would  
36 be limited, local, and temporary, the NRC staff concludes that the associated air quality impacts  
37 from construction would be SMALL.

38 Operation of the SCPC plant would result in significant emissions of certain criteria pollutants  
39 (including nitrogen oxides, sulfur oxides, and particulate matter) and mercury. Air emissions for  
40 the SCPC alternative were estimated using emission factors developed by the U.S. Department  
41 of Energy's (DOE's) National Energy Technology Laboratory (NETL) (NETL 2010) for an SCPC  
42 that is equipped with low nitrogen oxide burners and over-fire air to control nitrogen oxides, wet  
43 limestone forced-oxidation scrubbers to control sulfur dioxide, and a monoethanolamine based

## Environmental Consequences and Mitigating Actions

1 solvent process to remove carbon dioxide from the flue gas. The resulting estimated SCPC  
2 emissions are as follows:

- 3 • sulfur dioxide (SO<sub>2</sub>)—190 tons (170 MT) per year,
- 4 • nitrogen oxides (NO<sub>x</sub>)—5,600 tons (5,060 MT) per year,
- 5 • particulate matter (PM<sub>10</sub>)—1,060 tons (960 MT) per year,
- 6 • carbon monoxide (CO) —126 tons (114 MT) per year,
- 7 • mercury (Hg)—0.10 tons (0.08 MT) per year, and
- 8 • carbon dioxide equivalent (CO<sub>2e</sub>)—1.8 million tons (1.6 million MT) per year.

9 Operation of the mechanical-draft cooling tower also will result in additional particulate matter  
10 emissions above those presented above. Additional emissions also will be associated with  
11 worker vehicles commuting to and from the plant.

12 A new SCPC plant would qualify as a major-emitting industrial facility and would be subject to a  
13 New Source Review (NSR) under the Clean Air Act of 1970, as amended (CAA)  
14 (42 U.S.C. 7651 et seq.), to ensure that air emissions are minimized and that the local air quality  
15 is not substantially degraded. Additionally, various Federal and State regulations aimed at  
16 controlling air pollution would affect an SCPC alternative, including:

- 17 • standards of performance for electric utility steam generating units set forth in  
18 40 CFR Part 60 Subpart Da;
- 19 • visibility protection regulatory requirements, including review of the new sources that  
20 may affect visibility in any Federal Class I area, set forth in 40 CFR Part 51,  
21 Subpart P, 40 CFR 51.307;
- 22 • CAA Title IV reduction requirements for sulfur oxides and nitrogen oxides, which are  
23 the main precursors of acid rain and the major causes of reduced visibility. Title IV  
24 establishes maximum sulfur oxide and nitrogen oxide emission rates from existing  
25 plants and a system of sulfur oxide emission allowances that can be used, sold, or  
26 saved for future use by new plants;
- 27 • the Cross-State Air Pollution Rule in Volume 76 of the *Federal Register* (FR),  
28 p. 48208 (76 FR 48208), requires power plants in Louisiana to reduce nitrogen oxide  
29 emissions to assist in attaining the ozone NAAQS;
- 30 • continuous monitoring requirements of sulfur dioxide and nitrogen oxides as  
31 specified in 40 CFR Part 75;
- 32 • continuous monitoring requirements for carbon dioxide, as specified in  
33 40 CFR Part 75;
- 34 • mandatory GHG reporting regulations for major sources (74 FR 56260); major sources  
35 are defined as those sources emitting more than 25,000 MT per year of all GHGs;
- 36 • permitting requirements for GHG emissions under the prevention of significant  
37 deterioration (PSD) and Title V Federal permit programs of the CAA (77 FR 41051);  
38 operating permits issued to major sources of GHG under the PSD or Title V permit  
39 programs must contain provisions requiring the use of best available control  
40 technology to limit the emissions of GHGs, if those sources would be subject to PSD  
41 or Title V permitting requirements because of their non-GHG pollutant emission

1 potentials and if their estimated GHG emissions are at least 75,000 tons per year of  
 2 CO<sub>2e</sub>; and

- 3 • the Mercury and Air Toxics Standards final rule (77 FR 9304), which sets standards  
 4 for emissions of heavy metals (i.e., mercury, arsenic, chromium, and nickel) and acid  
 5 gases (i.e., hydrochloric acid and hydrofluoric acid) from coal utility steam generating  
 6 units.

7 As a result of the significant criteria air emissions (nitrogen oxides and particulate matter) and  
 8 GHG emissions, the NRC staff concludes that the air quality impacts associated with operation  
 9 of an SCPC alternative would be MODERATE.

10 **4.3.4.2 Noise**

11 Construction vehicles and equipment associated with the construction of an SCPC plant and  
 12 commuter, delivery, and support vehicular traffic traveling within, to, and from the construction  
 13 site would generate noise. Noise sources and levels would be similar to those discussed under  
 14 Section 4.3.3.2 above. The distance to noise sensitive receptors is unknown since the SCPC  
 15 alternative would be constructed at an existing power plant site anywhere within the SERC  
 16 region of Louisiana. However, both onsite and offsite noise sources would be intermittent and  
 17 short-term, lasting only through the duration of plant construction. Additionally, noise abatement  
 18 and controls can be incorporated to reduce noise impacts. Based on the temporary nature of  
 19 construction activities and good noise control practices, the NRC staff concludes that the  
 20 potential noise impacts of construction activities from an SCPC alternative would be SMALL.

21 Operation of an SCPC alternative would introduce continuous mechanical sources of noise that  
 22 could be audible off site. Onsite noise sources from operation of an SCPC alternative will  
 23 include mechanical draft cooling towers, transformers, turbines, pumps, boilers, compressors,  
 24 and other auxiliary equipment. The distance to noise sensitive receptors is unknown because  
 25 the SCPC alternative would be constructed at an existing power plant site anywhere within the  
 26 SERC region of Louisiana. Offsite noise sources associated with operation of the SCPC  
 27 alternative will include employee and delivery vehicle traffic and delivery of coal. However,  
 28 offsite noise sources would be intermittent, and because the SCPC alternative would be located  
 29 adjacent to an existing rail line or waterway, noise levels from coal delivery would be similar to  
 30 current conditions. Therefore, noise impacts from operation of an SCPC alternative would be  
 31 SMALL.

32 **4.3.5 NGCC Alternative**

33 **4.3.5.1 Air Quality**

34 The NGCC alternative would consist of two 690 MWe units with a capacity factor of 87 percent  
 35 (i.e., 600 MWe net for each unit). The NGCC alternative would be located within a portion of the  
 36 land on the approximately 3,600-ac (1,400-ha) Entergy Louisiana, LLC property. Therefore, the  
 37 NGCC alternative would be located in St. Charles Parish, which is designated attainment for all  
 38 NAAQS.

39 Construction of an NGCC power plant would be similar to that of other large industrial projects.  
 40 Construction of an NGCC power plant would result in the release of various criteria pollutants  
 41 (particulate matter, NO<sub>x</sub>, CO, and SO<sub>2</sub>), VOCs, HAPs, and GHGs from the operation of internal  
 42 combustion engines in construction vehicles, equipment, delivery vehicles, and vehicles used by  
 43 the commuting construction workforce. In addition, onsite soil disturbance activities such as  
 44 earthmoving and material handling would generate fugitive dust. Releases of VOCs also will  
 45 result from the onsite storage and dispensing of vehicle and equipment fuels. Air emissions  
 46 would be intermittent and vary based on the level and duration of a specific activity throughout

## Environmental Consequences and Mitigating Actions

1 the construction phase. Gas-fired power plants are constructed relatively quickly; construction  
2 lead times for NGCC plants are approximately 2 to 3 years (IEA/OECD/NEA 2005). Impacts  
3 would be localized, intermittent, and short-lived, and adherence to well-developed and  
4 well-understood construction BMPs would mitigate such impacts. Therefore, the NRC staff  
5 concludes that construction-related impacts on air quality from an NGCC alternative would be of  
6 relatively short duration and would be SMALL.

7 Operation of an NGCC alternative would result in emissions of criteria pollutants and GHGs.  
8 The sources of air emissions during operation include gas turbines through heat recovery steam  
9 generator stacks and mechanical-draft cooling towers. Emissions for the NGCC alternative  
10 were estimated using emission factors developed by DOE's NETL (NETL 2012). Assuming a  
11 total gross capacity of 1,380 MW and a capacity factor of 0.87, the NRC staff estimates the  
12 following air emissions for an NGCC alternative plant:

- 13 • sulfur oxides—16 tons (14 metric tons (MT)) per year,
- 14 • nitrogen oxides—405 tons (368 MT) per year,
- 15 • carbon monoxide—40 tons (37 MT) per year,
- 16 • PM<sub>10</sub>—5 tons (4 MT) per year, and
- 17 • carbon dioxide equivalents (CO<sub>2eq</sub>)—5.2 million tons (4.7 million MT) per year.

18 Operation of the mechanical-draft cooling tower also will result in additional particulate matter  
19 emissions above those presented above. Additional emissions also will be associated with  
20 worker vehicles commuting to and from the plant.

21 A new NGCC plant would qualify as a major-emitting industrial facility and would be subject to  
22 an NSR under the CAA of 1970, as amended (42 U.S.C. 7651 et seq.), to ensure that air  
23 emissions are minimized and that the local air quality is not substantially degraded.  
24 Additionally, various Federal and State regulations aimed at controlling air pollution would affect  
25 an NGCC alternative including:

- 26 • standards of performance for stationary combustion turbines set forth in  
27 Subpart KKKK of 40 CFR Part 60;
- 28 • 40 CFR, Part 51, Subpart P, 40 CFR 51.307 contains the visibility protection  
29 regulatory requirements, including review of the new sources that may affect visibility  
30 in any Federal Class I area;
- 31 • CAA (42 U.S.C. 7651 et seq.) Title IV reduction requirements for sulfur oxides and  
32 nitrogen oxides, which are the main precursors of acid rain and the major causes of  
33 reduced visibility. Title IV establishes maximum sulfur oxide and nitrogen oxide  
34 emission rates from existing plants and a system of sulfur oxide emission allowances  
35 that can be used, sold, or saved for future use by new plants;
- 36 • the Cross-State Air Pollution Rule (76 FR 48208) requires power plants in Louisiana  
37 to reduce nitrogen oxide emissions to assist in attaining the ozone NAAQS;
- 38 • continuous monitoring requirements of sulfur dioxide, nitrogen oxides, and carbon  
39 dioxide as specified in 40 CFR Part 75;
- 40 • mandatory GHG reporting regulations for major sources (74 FR 56260); major  
41 sources are defined as those sources emitting more than 25,000 MT per year of all  
42 GHGs; and

- 1 • permitting requirements for GHG emissions under the PSD and Title V Federal  
 2 permit programs of the CAA (77 FR 41051); operating permits issued to major  
 3 sources of GHGs under the PSD or Title V permit programs must contain provisions  
 4 requiring the use of best available control technology to limit the emissions of GHGs,  
 5 if those sources would be subject to PSD or Title V permitting requirements because  
 6 of their non-GHG pollutant emission potentials and if their estimated GHG emissions  
 7 are at least 75,000 tons per year of CO<sub>2e</sub>.

8 Based on the air emission estimates, nitrogen oxide and GHG emissions would be noticeable  
 9 and significant. Carbon dioxide emissions would be much larger than the threshold in the  
 10 U.S. Environmental Protection Agency’s (EPA’s) GHG Tailoring Rule, and nitrogen oxide  
 11 emissions would exceed the threshold for major sources subject to Title V permitting. The NRC  
 12 staff concludes that the overall air quality impacts associated with operation of an NGCC  
 13 alternative would be SMALL to MODERATE.

14 **4.3.5.2 Noise**

15 The NGCC alternative would be located within the 3,600-ac (1,400-ha) Entergy Louisiana, LLC  
 16 property in St. Charles Parish. Although the layout and exact location of a new NGCC plant  
 17 may differ from WF3, the distance from primary noise sources to nearby residents is expected  
 18 to be similar and, therefore, approximately 0.9 mi (1.4 km) away.

19 Construction of an NGCC plant is similar to that of other large industrial projects. Typical  
 20 construction equipment, such as dump trucks, loaders, bulldozers, graders, scrapers, air  
 21 compressors, generators, and mobile cranes, would be used, and pile-driving and blasting  
 22 activities would take place during the construction of an NGCC plant. However, as discussed  
 23 under Section 4.3.3.2., noise levels from construction equipment attenuate rapidly with distance  
 24 and the NRC staff does not anticipate that noise levels would be noticeable to nearby residents.  
 25 Other noise sources include commuter, delivery, and support vehicular traffic traveling within, to,  
 26 and from the facility. These offsite noise sources would be intermittent and short-term,  
 27 occurring during certain hours of the day (shift changes). Therefore, based on the temporary  
 28 nature of construction activities, the location of this facility in an existing zoned industrial area,  
 29 consideration of noise attenuation from the construction site to residences, and good noise  
 30 control practices, the NRC staff concludes that the potential noise impacts of construction  
 31 activities from a new NGCC alternative would be SMALL.

32 During the operation phase, noise sources from an NGCC alternative would include cooling  
 33 towers, transformers, and pumps. Offsite noise source will include vehicular traffic  
 34 (e.g., commuting, delivery, and support), pipelines, and gas compressor stations. However,  
 35 noise levels during operation of an NGCC alternative would be similar to existing conditions  
 36 because noise sources would be similar to operation of Waterford 1, 2, and WF3 and from  
 37 surrounding industrial facilities. Therefore, the noise impacts from operation of an NGCC  
 38 alternative would be SMALL.

39 **4.3.6 Combination Alternative (NGCC, Biomass, and DSM)**

40 **4.3.6.1 Air Quality**

41 The combination alternative consists of an NGCC unit with gross capacity of 690 MWe  
 42 (600 MWe net), four biomass-fired units with a gross capacity of 48 MWe (40 MWe net) each,  
 43 and DSM programs to achieve 1,200 MWe in energy savings. The NGCC unit and biomass-  
 44 fired units would be located on the approximately 3,600-ac (1,400-ha) Entergy Louisiana, LLC  
 45 property. Therefore, the NGCC unit and biomass-fired units would be located in St. Charles

## Environmental Consequences and Mitigating Actions

1 Parish, which is designated attainment for all NAAQS. Potential air quality impacts would result  
2 primarily from the NGCC and biomass-fired portions of this combination alternative.

3 Air emissions associated with the construction of the NGCC and biomass portions of the  
4 combination alternative are similar to that of other large industrial projects and, as previously  
5 discussed, for the new nuclear, SCPC, and NGCC alternatives above. Gas-fired and  
6 biomass-fired power plants are constructed relatively quickly; construction lead times for NGCC  
7 plants are approximately 2 to 3 years and 2 years for biomass-fired plants  
8 (IEA/OECD/NEA 2005; IRENA 2012). Construction activities would cause some temporary  
9 impacts to air quality from dust generation during operation of the earthmoving and  
10 material-handling equipment and exhaust emissions from worker vehicles and construction  
11 equipment. These emissions include criteria pollutants, VOCs, GHGs, and small amounts of  
12 HAPs. However, these impacts would be localized, intermittent, and short-lived, and adherence  
13 to well-developed and well-understood construction BMPs would mitigate such impacts. The  
14 NRC staff concludes that construction-related impacts on air quality from the NGCC portion and  
15 biomass portion of the combination alternative would be SMALL.

16 Air emissions associated with the operation of the NGCC portion of the combination alternative  
17 are similar to those associated with the NGCC alternative in Section 4.3.5.1; however, these  
18 emissions are reduced proportionally because the electricity output of the NGCC unit is  
19 50 percent of the NGCC alternative. The NRC staff estimates the following air emissions for a  
20 690 MWe gross capacity NGCC unit:

- 21 • sulfur oxides—8 tons (7 metric tons (MT)) per year,
- 22 • nitrogen oxides—200 tons (184 MT) per year,
- 23 • carbon monoxide—20 tons (18 MT) per year,
- 24 • PM<sub>10</sub>—2 tons (2 MT) per year, and
- 25 • carbon dioxide equivalents (CO<sub>2eq</sub>)—2.6 million tons (2.4 million MT) per year.

26 Operation of the mechanical-draft cooling tower also will result in additional particulate matter  
27 emissions above those presented above. Additional emissions also will be associated with  
28 worker vehicles commuting to and from the plant.

29 Operation of biomass-fired units will result in emissions from the conversion of the fuel  
30 feedstock (crops, forest and crop residue, wood waste, and municipal solid waste) into a  
31 gaseous product that will primarily consist of carbon monoxide and carbon dioxide. Nitrogen  
32 oxides and sulfur oxides emissions from biomass-fired units are lower than the equivalent  
33 fossil-fueled plants. Emissions from biomass-fired plants depend on the type of biomass  
34 feedstock and gasification technology (Ciferno and Marano 2002; NREL 2003). The NRC staff  
35 estimates the following emissions for operation of four biomass-fired units with a gross capacity  
36 of 48 MWe each, based on emission factors developed by the National Renewable Energy  
37 Laboratory (NREL 1997):

- 38 • sulfur oxides—85 tons (76 metric tons (MT)) per year,
- 39 • nitrogen oxides—1,680 tons (1,530 MT) per year,
- 40 • carbon monoxide—8,700 tons (7,860 MT) per year,
- 41 • PM<sub>10</sub>—420 tons (380 MT) per year, and
- 42 • carbon dioxide equivalents (CO<sub>2eq</sub>)—2.5 million tons (2.2 million MT) per year.

1 A new NGCC plant and biomass-fired units would qualify as major-emitting industrial facilities  
 2 and would be subject to an NSR and the Federal and State regulations aimed at controlling air  
 3 pollution discussed under Section 4.3.5.1 for the NGCC alternative.

4 Based on the air emission estimates, nitrogen oxide, carbon monoxide, and GHG emissions  
 5 would be noticeable and significant. Carbon dioxide emissions would be much larger than the  
 6 threshold in EPA's GHG Tailoring Rule, and nitrogen oxide emissions would exceed the  
 7 threshold for major sources subject to Title V permitting requirement. The NRC staff concludes  
 8 that the overall air quality impacts associated with operation of the combination alternative  
 9 would be MODERATE.

10 **4.3.6.2 Noise**

11 As discussed in Section 3.2.2, St. Charles Parish has a noise ordinance that sets maximum  
 12 permissible sound levels based on the receiving land use category (e.g., residential,  
 13 commercial, industrial). For designated residential zones, the maximum sound limits received  
 14 range from 50 dBA from 7 a.m.–10 p.m. and 45 dBA from 10 p.m.–7 a.m. The St. Charles  
 15 Parish noise ordinance does not set maximum permissible sound levels for areas zoned as  
 16 industrial. The site location of the new combination alternative (within the 3,600-ac (1,400-ha)  
 17 Entergy Louisiana, LLC property) has been designated as a heavy manufacturing zoning  
 18 district. While the layout and exact location of NGGC and biomass facilities may differ from  
 19 WF3, the distance from primary noise sources to nearby residents is expected to be similar  
 20 (i.e., approximately 0.9 mi (1.4 km) away). The NRC staff does not anticipate noise impacts  
 21 from the DSM component of this combination alternative.

22 The construction-related noise sources for the NGCC portion of the combination alternative  
 23 would be similar to those for construction of the NGCC alternative discussed in Section 4.3.5.2.  
 24 Consequently, the NRC staff concludes that construction-related noise associated with the  
 25 NGCC portion of the combination alternative would be SMALL.

26 The construction-related noise sources for the biomass portion of the combination alternative  
 27 would be similar to that of other large industrial projects. Typical construction equipment would  
 28 be used, and pile-driving and blasting activities would take place. Noise levels from  
 29 construction equipment would be similar to those discussed in Section 4.3.3.2, however, given  
 30 the existing industrial facilities in the vicinity and noise attenuation from the construction site to  
 31 residences, the NRC staff concludes that noise levels from construction of a biomass-fired  
 32 facility would not be noticeable. Additional noise sources would include commuter, delivery, and  
 33 support vehicular traffic traveling within, to, and from the construction site. These offsite noise  
 34 sources would be intermittent and short-term, occurring during certain hours of the day  
 35 (shift changes). Therefore, the noise impacts from construction of a biomass-fired facility would  
 36 be SMALL.

37 Noise sources from operation of the NGCC and biomass portions of the combination alternative  
 38 would include cooling towers, steam generators, turbines, biomass incinerators, and pumps.  
 39 Offsite noise sources will include vehicular traffic, pipelines, and gas compressor stations.  
 40 However, noise levels during operation of the NGCC and biomass portions of this combination  
 41 alternative would be similar to existing conditions associated with noise from the operation of  
 42 Waterford 1, 2, and WF3 and from surrounding industrial facilities. Additionally, the nearest  
 43 residents will be approximately 0.9 mi (1.4 km) away from operation of the NGCC and biomass  
 44 facilities. Given the noise environment associated with the existing industrial facilities and  
 45 distance to nearest residents, the NRC staff does not anticipate that noise from operation of the  
 46 NGCC and biomass portions of the combination facility would be noticeable. Therefore, noise  
 47 impacts from operation of the NGCC and biomass portions of the combination alternative would  
 48 be SMALL.

1 **4.4 Geologic Environment**

2 This section describes the potential impacts of the proposed action (license renewal) and  
3 alternatives to the proposed action on geologic and soil resources.

4 **4.4.1 Proposed Action**

5 Table 4–3 identifies issues related to geology and soils that are applicable to the WF3 site  
6 during the renewal term. Section 3.4 describes the local and regional geologic environment of  
7 the WF3 site.

8 **Table 4–3. Geology and Soils Issues**

Issue	GEIS Section	Category
Geology and Soils	4.4.1	1

Table source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

9 The NRC staff did not identify any new and significant information associated with the  
10 Category 1 geology and soils issue identified in Table 4–3 during the review of the applicant’s  
11 ER (Entergy 2016a), the site audit, the scoping process, or the evaluation of other available  
12 information. As a result, no information or impacts related to this issue were identified that  
13 would change the conclusions presented in the GEIS (NRC 2013a). For this issue, the GEIS  
14 concludes that the impacts are SMALL. It is expected that there would be no incremental  
15 impacts related to this Category 1 issue during the renewal term beyond those discussed in  
16 the GEIS.

17 **4.4.2 No-Action Alternative**

18 There would not be any impacts to the geology and soils at the WF3 site with shutdown of the  
19 facility. With the shutdown of the facility, no additional land would be disturbed. Therefore,  
20 impacts for this alternative would be SMALL.

21 **4.4.3 New Nuclear Alternative**

22 For the new nuclear alternative, the impacts on geology and soil resources would occur during  
23 construction and no additional land would be disturbed during operations. During construction,  
24 sources of aggregate material, such as crushed stone and sand and gravel, would be required  
25 to construct buildings, foundations, roads, and parking lots. The NRC staff presumes that these  
26 resources would likely be obtained from commercial suppliers using local or regional sources.  
27 Land clearing during construction and installation of power plant structures and impervious  
28 surfaces would expose soils to erosion and alter surface drainage. BMPs would be  
29 implemented in accordance with applicable permitting requirements so as to reduce soil  
30 erosion. These practices would include the use of sediment fencing, staked hay bales, check  
31 dams, sediment ponds, and riprap aprons at construction and laydown yard entrances,  
32 mulching and geotextile matting of disturbed areas, and rapid reseeding of temporarily disturbed  
33 areas. Removed soils and any excavated materials would be stored on site for redistribution,  
34 such as for backfill at the end of construction. Construction impacts would be temporary and  
35 localized. Therefore, the impacts of this alternative on geology and soils resources would be  
36 SMALL.

1 **4.4.4 SCPC Alternative**

2 For the SCPC alternative, the staff expects that impacts on geology and soils resources would  
 3 be of the same type but less than those described for the new nuclear alternative because of  
 4 the smaller land area disturbed and less extensive excavation work that would be required.  
 5 Therefore, the impact of this alternative on geology and soils resources would be SMALL.

6 **4.4.5 NGCC Alternative**

7 For the NGCC alternative, the staff expects that impacts on geology and soils resources would  
 8 be of the same type as those described for the new nuclear alternative. However, direct  
 9 impacts would be less than both the new nuclear and SCPC alternatives because of the smaller  
 10 land area excavated and disturbed for facility construction. Therefore, the impact of this  
 11 alternative on geology and soils resources would be SMALL.

12 **4.4.6 Combination Alternative (NGCC, Biomass, and DSM)**

13 For the NGCC and biomass components of this alternative, the staff expects that impacts on  
 14 geology and soils would be of the same type as those described for the new nuclear alternative,  
 15 with direct impacts less than those of the other alternatives because of the much smaller land  
 16 areas excavated and disturbed. DSM would reduce the need for electrical power.  
 17 Consequently, there should not be any impacts on geology and soils from this component.  
 18 Therefore, the impact of this alternative on geology and soil resources would be SMALL.

19 **4.5 Water Resources**

20 This section describes the potential impacts of the proposed action (license renewal) and  
 21 alternatives to the proposed action on surface water and groundwater resources.

22 **4.5.1 Proposed Action**

23 *4.5.1.1 Surface Water Resources*

24 The Category 1 (generic) surface water use and quality issues applicable to WF3 are discussed  
 25 in the following sections and listed in Table 4–4. There are no plant-specific Category 2 surface  
 26 water use and quality issues applicable to WF3 because WF3 uses a once-through cooling  
 27 system and does not utilize cooling ponds or cooling towers using makeup water from a river for  
 28 condenser cooling purposes. Surface water resources-related aspects and conditions relevant  
 29 to the WF3 site are described in Section 3.5.1.

30 **Table 4–4. Surface Water Resources Issues**

<b>Issue</b>	<b>GEIS Section</b>	<b>Category</b>
Surface water use and quality (noncooling system impacts)	4.5.1.1	1
Altered current patterns at intake and discharge structures	4.5.1.1	1
Scouring caused by discharged cooling water	4.5.1.1	1
Discharge of metals in cooling system effluents	4.5.1.1	1
Discharge of biocides, sanitary wastes, and minor chemical spills	4.5.1.1	1
Effects of dredging on surface water quality	4.5.1.1	1
Temperature effects on sediment transport capacity	4.5.1.1	1

Sources: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

## Environmental Consequences and Mitigating Actions

### 1 Generic Surface Water Resources

2 The NRC staff did not identify any new and significant information associated with the  
3 Category 1 surface water issues identified in Table 4–4 during the review of the applicant’s ER  
4 (Entergy 2016a), the applicant’s response to NRC’s request for additional information, the  
5 scoping process, or the evaluation of other available information as documented in  
6 Section 3.5.1. As a result, no information or impacts related to these issues were identified that  
7 would change the conclusions presented in the GEIS (NRC 2013a). For these issues, the GEIS  
8 concludes that the impacts are SMALL. It is expected that there would be no incremental  
9 impacts related to these Category 1 issues during the license renewal term beyond those  
10 discussed in the GEIS; therefore, the impacts associated with these issues are SMALL.

### 11 4.5.1.2 *Groundwater Resources*

12 Table 4–5 identifies issues related to groundwater that are applicable to WF3 during the license  
13 renewal term. Section 3.5.2 describes groundwater resources at the WF3 site.

14 **Table 4–5. Groundwater Issues**

Issue	GEIS Section	Category
Groundwater contamination and use (noncooling system impacts)	4.5.1.2	1
Groundwater use conflicts (plants that withdraw less than 100 gpm)	4.5.1.2	1
Groundwater quality degradation resulting from water withdrawals	4.5.1.2	1
Radionuclides released to groundwater	4.5.1.2	2

Source: Table B-1 in Appendix B, Subpart A to 10 CFR Part 51

15 The NRC staff did not identify any new and significant information associated with the  
16 Category 1 groundwater issues identified in Table 4–5 during the review of the applicant’s ER  
17 (Entergy 2016), the site audit, the scoping process, or the evaluation of other available  
18 information. As a result, no information or impacts related to these issues were identified that  
19 would change the conclusions presented in the GEIS (NRC 2013a). For these issues, the GEIS  
20 concludes that the impacts are SMALL. Therefore, it is expected that there would be no  
21 incremental impacts related to these Category 1 issues during the renewal term beyond those  
22 discussed in the GEIS.

23 The one Category 2 issue (see Table 4–5) related to groundwater during the renewal term is  
24 discussed in the following text.

### 25 Radionuclides Released to Groundwater

26 This issue looks at potential contamination of groundwater from the release of radioactive  
27 liquids from plant systems into the environment. Section 3.5.2.3 describes WF3 site  
28 groundwater quality. In evaluating the potential impacts on groundwater quality associated with  
29 license renewal, the NRC staff uses, as its baseline, the existing groundwater conditions as  
30 described in Section 3.5.2.3. These baseline conditions encompass the existing quality of  
31 groundwater potentially affected by continued operations (as compared to relevant State or EPA  
32 primary drinking water standards), as well as the current and potential onsite and offsite uses  
33 and users of groundwater for drinking and other purposes. The baseline also considers other  
34 downgradient or in-aquifer uses and users of groundwater.

1 Radionuclide contamination from WF3 operations has not been detected in groundwater  
2 beneath the WF3 site. Present and future WF3 operations are not expected to impact the  
3 quality of groundwater in any aquifers that are a current or potential future source of water for  
4 offsite users. Therefore, the NRC staff concludes that the impacts on groundwater use and  
5 quality during the WF3 license renewal term would be SMALL.

#### 6 **4.5.2 No-Action Alternative**

##### 7 *4.5.2.1 Surface Water Resources*

8 Surface water withdrawals and the rate of consumptive water use would greatly decrease and  
9 would eventually cease after WF3 is shutdown. Wastewater discharges would be reduced  
10 considerably. As a result, shutdown would reduce the overall impacts on surface water use and  
11 quality. Stormwater runoff would continue to be discharged from the plant site to ditches and  
12 receiving waters. Overall, the impact of this alternative on surface water resources would  
13 remain SMALL.

##### 14 *4.5.2.2 Groundwater Resources*

15 With the cessation of operations, there should be no groundwater consumption and little or no  
16 impacts on groundwater quality. Therefore, the impact of this alternative on groundwater  
17 resources would remain SMALL.

#### 18 **4.5.3 New Nuclear Alternative**

##### 19 *4.5.3.1 Surface Water Resources*

20 Impacts from construction activities on surface water resources associated with the new nuclear  
21 alternative could be appreciable because of the land area required for new nuclear units (see  
22 Table 2–1 in Chapter 2) on the 3,600 ac (1,400 ha) Entergy Louisiana, LLC property where  
23 WF3 is located. Construction activities might alter surface water drainage features, such as  
24 canals, within the construction footprints, including any wetland areas. Deep excavation work  
25 for the nuclear island, extensive site clearing, and a large laydown area for facility construction  
26 could directly and indirectly impact the water quality of affected water bodies.

27 Construction activities may cause temporary impacts to surface water quality by increased  
28 sediment loading and from any pollutants in stormwater runoff from disturbed areas and  
29 excavations, from spills and leaks from construction equipment, and from any dredge-and-fill  
30 activities. These sources could potentially affect downstream surface water quality. However,  
31 site construction activities would have to be conducted under an LDEQ-issued Louisiana  
32 Pollutant Discharge Elimination System (LPDES) general permit for stormwater discharges from  
33 large construction sites (i.e., 5 ac (2 ha) or more) (LAC 33:IX.2515; LDEQ 2016). The general  
34 permit requires the development and implementation of a stormwater pollution prevention plan  
35 (SWPPP) including use of appropriate BMPs for waste management, water discharge,  
36 stormwater pollution prevention, soil erosion control, site-stabilization techniques, and spill  
37 prevention practices to prevent or minimize any surface water quality impacts during  
38 construction. To the maximum extent possible, after being refurbished, the existing WF3  
39 surface water intake and discharge infrastructure would be used. This would largely eliminate  
40 the impacts associated with the construction of new surface water intake and discharge  
41 structures. Dredge-and-fill operations would be conducted under a permit from the U.S. Army  
42 Corps of Engineers (USACE) and State-equivalent permits requiring the implementation of  
43 applicable BMPs to minimize associated impacts.

## Environmental Consequences and Mitigating Actions

1 To support construction, water would be required for potable and sanitary use by the  
2 construction workforce and for concrete production, equipment washdown, dust suppression,  
3 soil compaction, and other miscellaneous uses. In its ER, Entergy (2016a) assumes that there  
4 would be no direct use of surface water during construction because water could be obtained  
5 from the municipal water utility (i.e., St. Charles Parish via a service connection) and possibly  
6 trucked to the point of use from the local utility, as necessary. Alternatively, water could be  
7 obtained from surface water or local groundwater.

8 The NRC staff estimates that extensive groundwater dewatering of deep excavations could be  
9 necessary within the Entergy Louisiana, LLC property. Dewatering would not be expected to  
10 impact offsite surface water bodies, and water pumped from excavations would be managed  
11 and discharged in accordance with LDEQ requirements and would not be expected to affect  
12 offsite surface water quality.

13 For operations, the staff assumes that the new nuclear power plant would utilize mechanical  
14 draft cooling towers operating in a closed-cycle configuration (see Table 2–1 in Chapter 2).  
15 Nuclear power plants using closed-cycle cooling systems with cooling towers withdraw  
16 substantially less surface water for condenser cooling than a plant using a once-through system  
17 like WF3, although the relative percentage of consumptive water use is greater in closed-cycle  
18 plants because of evaporative and drift losses during cooling tower operation (NRC 2013a).

19 Under this alternative, total surface water withdrawals for operation of the AP1000 facility would  
20 be a small fraction of that required for a similarly sized plant using once-through cooling, such  
21 as WF3 (which averages 1,029 mgd (1,593 cfs; 45.0 m<sup>3</sup>/s)). However, consumptive water use  
22 would be about 130 percent greater because of evaporative losses and drift from closed-cycle  
23 cooling. This consumptive use is, nonetheless, negligible compared to the flow of the  
24 Mississippi River near the Entergy Louisiana, LLC property, as discussed in Section 3.5.1.1.

25 Surface water withdrawals would be subject to any applicable State water appropriation and  
26 registration requirements (see Section 3.5.1.2).

27 The volume of circulating cooling water and comingled wastewater discharged to surface waters  
28 during facility operations under this alternative would be much less than for a plant with a  
29 once-through cooling system like WF3, due to the substantial reduction in circulating cooling  
30 water flow. In addition, closed-cycle cooling systems typically require chemical treatment.  
31 Specifically, biocides are commonly used in cooling towers to control biofouling, in addition to  
32 other chemical additives for corrosion control in plant systems (NRC 2013a). Other chemical  
33 additives also may be needed to prevent scale buildup or corrosion in the closed-cycle system.  
34 Use of a closed-cycled condenser cooling system would substantially increase the usage of  
35 biocides and other additives relative to a once-through plant. These additives then would be  
36 present in the cooling tower blowdown discharged to receiving waters, such as the Mississippi  
37 River, under this alternative.

38 Nevertheless, any chemical additions would be accounted for in the operation and permitting of  
39 liquid effluents from the new nuclear alternative. All effluent discharges would be subject to  
40 LPDES permit requirements for the discharge of wastewater and industrial stormwater to waters  
41 of the United States. As for WF3, it is likely that sanitary effluent would be discharge to the  
42 St. Charles Parish Department of Public Works and Wastewater for treatment.

43 To prevent and respond to accidental nonnuclear releases to surface waters, operations would  
44 also be conducted in accordance with a spill prevention, control, and countermeasures plan;  
45 storm water pollution prevention plan; or equivalent plans and associated BMPs and  
46 procedures.

1 Based on this analysis, the NRC staff concludes that the overall impacts on surface water  
2 resources from construction and operations under the new nuclear alternative would be SMALL.

3 **4.5.3.2 Groundwater Resources**

4 For the new nuclear alternative, the staff assumed that construction water might be obtained  
5 from onsite groundwater or from the local water utility. In addition, because of the shallow depth  
6 to groundwater beneath the site, there is likely to be a need for groundwater dewatering during  
7 excavation and construction. Pumped groundwater removed from excavations would be  
8 discharged in accordance with appropriate State and local permits.

9 During operations, the NRC staff assumes that potable water would be obtained from the local  
10 water utility (St. Charles Parish) currently serving the WF3 site. During both construction and  
11 operation, any groundwater withdrawals would be subject to applicable State water  
12 appropriation and registration requirements. The application of BMPs in accordance with a  
13 State-issued Louisiana Pollutant Discharge Elimination System (LPDES) general permit,  
14 including an appropriate waste management, water discharge, stormwater pollution prevention  
15 plan (SWPPP), and spill prevention practices, would prevent or minimize groundwater quality  
16 impacts during construction. During operation, effluent discharges would be subject to LPDES  
17 permit requirements for the discharge of wastewater and industrial stormwater as described in  
18 Section 4.5.3.1. Therefore, the impact of this alternative on groundwater resources would be  
19 SMALL.

20 **4.5.4 SCPC Alternative**

21 **4.5.4.1 Surface Water Resources**

22 Impacts on surface water resources from construction activities associated with the SCPC  
23 alternative would be expected to be similar to but somewhat less than those under the new  
24 nuclear alternative. This is attributable to less land required for construction of the power block  
25 (see Table 2–1 in Chapter 2). The SCPC plant would be located at an alternative site within the  
26 SERC region of Louisiana. Otherwise, the same assumptions for construction and operations  
27 as described in Section 4.5.3.1 also apply to this alternative, except as noted.

28 Similar to the new nuclear alternative, some temporary impacts to surface water quality may  
29 result from increased sediment loading and from pollutants in stormwater runoff from disturbed  
30 areas and from excavation and dredge-and-fill activities, as previously described in  
31 Section 4.5.3.1 for the new nuclear alternative. There also would be the potential for hydrologic  
32 and water quality impacts to occur from the extension or refurbishment of rail spurs, or the  
33 construction or refurbishment of barge facilities, to transport coal to the site location.  
34 Nevertheless, as described in Section 4.5.3.1 for the new nuclear alternative, water quality  
35 impacts would be minimized by application of BMPs and compliance with an LDEQ-issued  
36 LPDES general permit. The NRC staff also assumes that any existing intake and discharge  
37 infrastructure at an alternative site location would be refurbished to maximize the use of existing  
38 facilities. Dredge-and-fill operations would be conducted under a permit from USACE and  
39 State-equivalent permits requiring the implementation of applicable BMPs to minimize  
40 associated impacts.

41 To support operations of a SCPC plant, the staff assumes that the new facility would utilize a  
42 closed-cycle cooling system with mechanical-draft cooling towers. The SCPC alternative facility  
43 would require more makeup water for operations than the new nuclear alternative but with  
44 similar consumptive water use (see Table 2–1 in Chapter 2). As with the new nuclear  
45 alternative, total operational surface water withdrawals for the SCPC alternative would be a  
46 small fraction of that required for a plant with a once-through cooling system such as WF3.

## Environmental Consequences and Mitigating Actions

1 All effluent discharges would be subject to LPDES permit requirements for the discharge of  
2 wastewater and industrial stormwater to waters of the United States, as previously discussed for  
3 the new nuclear alternative. Additionally, management of runoff and leachate from coal and ash  
4 storage facilities would require additional regulatory oversight and would present an additional  
5 risk to surface water resources.

6 For this alternative, based on the potential for additional hydrologic alteration and potential  
7 water quality impacts from coal and ash handling and management and higher makeup water  
8 demand for operations, the NRC staff concludes that impacts on surface water resources from  
9 construction and operations under the SCPC alternative would range from SMALL to  
10 MODERATE.

### 11 4.5.4.2 *Groundwater Resources*

12 For the SCPC alternative, the staff expects the impacts on groundwater use and quality would  
13 be of the same type and similar to, but less than those described for the new nuclear alternative.  
14 Therefore, the impact of this alternative on groundwater resources would be SMALL.

## 15 4.5.5 **NGCC Alternative**

### 16 4.5.5.1 *Surface Water Resources*

17 A new NGCC plant would be sited on the Entergy Louisiana, LLC property and in proximity to  
18 the existing WF3 site. The facility would use available site infrastructure after necessary  
19 refurbishment. The facility footprint would be smaller than that for the facilities that would be  
20 constructed under either the new nuclear or SCPC alternatives (see Table 2–1 in Chapter 2).  
21 An additional 85 ac (34 ha) would be needed for a right-of-way to connect with existing natural  
22 gas supply lines south of the site. Nevertheless, the NRC staff expects that direct impacts on  
23 surface water resources from construction activities associated with the NGCC alternative would  
24 be much smaller than those under either the new nuclear or SCPC alternatives because less  
25 extensive excavation and earthwork would be required. Otherwise, the same assumptions for  
26 construction and operations as described in Sections 4.5.3.1 and 4.5.4.1 also apply to this  
27 alternative, except as noted.

28 Some temporary impacts to surface water quality may result from construction activities, as  
29 previously described in Section 4.5.3.1 for the new nuclear alternative. Further, depending on  
30 the path of new gas pipelines to service the NGCC plant, some stream or canal crossings or  
31 sub-crossings could be necessary. However, because of the short-term nature of any required  
32 dredge-and-fill operations and stream-crossing activities, the hydrologic alterations and  
33 sedimentation would be localized, and water-quality impacts would be temporary and would  
34 cease after construction has been completed and the site has been stabilized. The use of  
35 modern pipeline construction techniques, such as horizontal directional drilling, would further  
36 minimize the potential for hydrologic and water quality impacts. In addition, all potential water  
37 quality impacts would be minimized by the application of BMPs and through compliance with  
38 LDEQ-issued NPDES permits for construction. Any dredge-and-fill operations would be  
39 conducted under a permit from the USACE and State-equivalent permits requiring the  
40 implementation of applicable BMPs to minimize associated impacts.

41 For onsite facility operations, cooling water demand and consumptive water use for a twin-unit  
42 NGCC plant, utilizing mechanical-draft cooling towers operating in a closed-cycle configuration,  
43 would be substantially less than for the facilities under the new nuclear and SCPC alternatives.  
44 Consumptive water use under the NGCC alternative would be reduced by about 70 percent as  
45 compared to the new nuclear and SCPC alternatives (see Table 2–1 in Chapter 2).

1 Discharge of cooling water return flow and other effluents to surface waters would be  
 2 substantially less under this alternative relative to the new nuclear and SCPC alternatives.  
 3 All surface water discharges under the NGCC alternative would be subject to LPDES permit  
 4 requirements for the discharge of wastewater and industrial stormwater to waters of the United  
 5 States (see Section 4.5.3.1).

6 For the NGCC alternative, the NRC staff concludes that the overall impacts on surface water  
 7 resources from construction and operations would be SMALL.

8 **4.5.5.2 Groundwater Resources**

9 For the NGCC alternative, the staff expects the impacts on groundwater use and quality would  
 10 be of the same type as those described for the new nuclear alternative, but direct impacts would  
 11 be much less than those associated with either the new nuclear or SCPC alternatives.  
 12 Therefore, the impact of this alternative on groundwater resources would be SMALL.

13 **4.5.6 Combination Alternative (NGCC, Biomass, and DSM)**

14 **4.5.6.1 Surface Water Resources**

15 The NGCC and biomass facility components of the combination component would be sited  
 16 within the 3,600 ac (1,400 ha) Entergy Louisiana, LLC property and in proximity to the WF3 site.  
 17 Access to and reuse of portions of the existing WF3 site will allow for the use of available  
 18 infrastructure (after necessary refurbishment), including the WF3 intake and discharge  
 19 structures. This would reduce construction-related impacts on water resources. Otherwise, the  
 20 same general assumptions for construction and operations as described in Section 4.5.5.1 also  
 21 apply to this alternative, except as noted.

22 For construction and operation of the NGCC component, potential water resources impacts  
 23 would be reduced by approximately half compared with the NGCC alternative. This is because  
 24 the NGCC plant would be scaled back to a single 600-MWe unit (net capacity), as further  
 25 described in Table 2–1 in Chapter 2.

26 The four biomass-fueled units that would be built under this alternative would occupy a small  
 27 area of land (see Table 2–1 in Chapter 2). Temporary impacts to surface water quality may  
 28 result from facility construction from increased sediment loading and from any pollutants in  
 29 stormwater runoff from disturbed areas and excavations, from spills and leaks from construction  
 30 equipment, and from any dredge-and-fill activities. However, site construction activities would  
 31 have to be conducted under an LDEQ-issued LPDES general permit for stormwater discharges  
 32 from large construction sites, which requires the development and implementation of a SWPPP  
 33 and use of appropriate BMPs to prevent or minimize any surface water quality impacts during  
 34 construction (see Section 4.5.3.1). Any necessary dredge-and-fill operations would be  
 35 conducted under a permit from the USACE and State-equivalent permits.

36 As for the other replacement power alternatives and technology components, the NRC staff  
 37 assumes that the four biomass-fueled power units would be equipped with mechanical draft  
 38 cooling towers for closed-cycle cooling. Makeup water demand and consumptive water use for  
 39 operation of these units would be similar to but somewhat greater than that for the NGCC  
 40 component of this alternative (see Table 2-1 in Chapter 2). In summary, the total operational  
 41 makeup water demand and associated consumptive water use for the combination alternative  
 42 would be similar to but somewhat greater than under the NGCC alternative but substantially  
 43 less than (by about 70 percent) that projected for the new nuclear and SCPC alternatives.  
 44 Implementation of the DSM component of this combination alternative would not be expected to  
 45 result in incremental impacts on surface water use and quality that are greater than those  
 46 described in Sections 4.5.3.1, 4.5.4.1, and 4.5.5.1. In consideration of this information, the NRC

## Environmental Consequences and Mitigating Actions

1 staff concludes that the impacts on surface water resources from construction and operations  
2 under the combination alternative would be SMALL.

### 3 4.5.6.2 Groundwater Resources

4 For the NGCC and biomass components of this alternative, the staff expects impacts on  
5 groundwater use and quality would be of the same type as those described for the new nuclear  
6 alternative, with direct impacts less than those of the other alternatives because of the much  
7 smaller land areas affected. DSM would reduce the need for electrical power. Consequently,  
8 there should not be any incremental impacts on groundwater use and quality from this  
9 component. Therefore, the impact of this alternative on groundwater resources would be  
10 SMALL.

## 11 4.6 Terrestrial Resources

12 This section describes the potential impacts of the proposed action (license renewal) and  
13 alternatives to the proposed action on terrestrial resources.

### 14 4.6.1 Proposed Action

15 Section 3.6 of this SEIS describes terrestrial resources on and in the vicinity of the WF3 site.  
16 The generic (Category 1) and site-specific (Category 2) issues that apply to terrestrial resources  
17 during the proposed license renewal period appear in Table 4–6. The GEIS (NRC 2013a)  
18 discusses these issues in Section 4.6.1.1.

19 **Table 4–6. Terrestrial Resource Issues**

Issue	GEIS Section	Category
Effects on terrestrial resources (noncooling system impacts)	4.6.1.1	2
Exposure of terrestrial organisms to radionuclides	4.6.1.1	1
Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds)	4.6.1.1	1
Cooling tower impacts on vegetation (plants with cooling towers)	4.6.1.1	N/A <sup>(a)</sup>
Bird collisions with plant structures and transmission lines <sup>(b)</sup>	4.6.1.1	1
Water use conflicts with terrestrial resources (plants with cooling ponds or cooling towers using makeup water from a river)	4.6.1.1	N/A <sup>(a)</sup>
Transmission line ROW management impacts on terrestrial resources <sup>(b)</sup>	4.6.1.1	1
Electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock) <sup>(b)</sup>	4.6.1.1	1

<sup>(a)</sup> This issue does not apply because WF3 does not have cooling towers or a cooling pond.

<sup>(b)</sup> This issue applies only to the in-scope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

#### 20 4.6.1.1 Generic Terrestrial Resource Issues

21 The NRC staff did not identify any new and significant information associated with the generic  
22 (Category 1) terrestrial resource issues listed in Table 4–6 during the staff's review of the

1 applicant’s ER (Entergy 2016a), the site audit, or the scoping process. As a result, the NRC  
 2 staff expects no impacts associated with these issues beyond those discussed in the GEIS.  
 3 The GEIS concludes that the impact level for each of these issues is SMALL.

4 **4.6.1.2 Effects on Terrestrial Resources (Noncooling System Impacts)**

5 In the GEIS (NRC 2013a), the NRC staff determined that noncooling system effects on  
 6 terrestrial resources is a Category 2 issue (see Table 4–6) that requires site-specific evaluation  
 7 during each license renewal review. According to the GEIS, noncooling system impacts can  
 8 include those impacts that result from landscape maintenance activities, stormwater  
 9 management, elevated noise levels, and other ongoing operations and maintenance activities  
 10 that would occur during the renewal period and that could affect terrestrial resources on and  
 11 near a plant site.

12 **Landscape Maintenance Activities**

13 Entergy’s landscape maintenance practices primarily consist of grass cutting and weed control  
 14 within developed or previously disturbed areas of the site. Transmission line ROWs cover  
 15 approximately 8 ac (3.2 ha) of the Entergy (2016a) property. Although vegetation is sparse in  
 16 these areas because the lines cross the WF3 industrial area, Entergy (2016a) spot applies  
 17 herbicide treatments on a 2-year cycle to control undesirable brush and woody vegetation.  
 18 Herbicide application volumes typically range from 10 to 25 gallons per bush acre, and all  
 19 chemicals are applied according to label directions and manufacturer recommendations by  
 20 licensed companies with qualified applicators (Entergy 2016a). Leased agricultural land is  
 21 maintained by the leasee in accordance with the standing lease. Approximately 66 percent  
 22 (2,345 ac (949 ha)) of the Entergy property remains as undeveloped, uncultivated natural areas  
 23 (see Table 3–A in Section 3.6.3). Entergy (2016a) does not actively maintain these areas and  
 24 has no plans to disturb any undeveloped areas as part of the proposed license renewal.

25 **Stormwater Management**

26 WF3 discharges stormwater to the Mississippi River through 13 outfalls, which are permitted  
 27 under the site’s LPDES permit No. LA0007374 (LDEQ 2017). The LPDES permit ensures that  
 28 discharges to the river from WF3’s operations do not impair Mississippi River water quality.  
 29 Additionally, the LPDES permit requires Entergy to maintain an SWPPP, which identifies  
 30 potential sources of pollutants that could affect stormwater discharges and that identifies BMPs  
 31 Entergy uses to reduce pollutants in stormwater discharges to ensure compliance with  
 32 applicable conditions of the permit. The BMPs include procedures to minimize and respond to  
 33 spills and leaks, handle industrial materials and wastes that can be readily mobilized by contact  
 34 with stormwater, and minimize erosion and sedimentation, among others. Entergy further  
 35 monitors areas with potential for spills of oil or other regulated substances under its Spill  
 36 Prevention Control and Countermeasures Plan. Collectively, these measures ensure that the  
 37 effects to terrestrial resources from pollutants carried by stormwater would be small during the  
 38 proposed license renewal term.

39 **Noise**

40 The GEIS (NRC 2013a) indicates that elevated noise levels could be a noncooling system  
 41 impact to terrestrial resources. However, the GEIS also concludes that generic noise impacts  
 42 would be SMALL because noise levels would remain well below regulatory guidelines for offsite  
 43 receptors during continued operations and refurbishment associated with license renewal. The  
 44 NRC staff did not identify any information during its review that would indicate that noise  
 45 impacts to terrestrial resources at WF3 would be unique or require separate analysis.

## Environmental Consequences and Mitigating Actions

### 1 Other Operations and Maintenance Activities

2 Operational and maintenance activities that Entergy (2016a) might undertake during the license  
3 renewal term include maintenance and repair of plant infrastructure, such as roadways, piping  
4 installations, fencing, and other security structures. These activities would likely be confined to  
5 previously disturbed areas of the site. Entergy (2016a) anticipates no refurbishment during the  
6 license renewal period.

7 Entergy (2016a) maintains procedures to ensure that environmentally sensitive areas are  
8 adequately accounted for and protected during operational and maintenance activities and  
9 project planning. The procedures direct Entergy personnel to obtain appropriate local, State,  
10 and/or Federal permits before beginning work; implement BMPs to protect wetlands, natural  
11 heritage areas, and sensitive ecosystems; and consult the appropriate agencies wherever  
12 Federally or State-listed species may be affected. Additionally, WF3's Environmental Protection  
13 Plan contained in Appendix B of the facility operating license requires Entergy to prepare an  
14 environmental evaluation for any construction or operational activities that may significantly  
15 affect the environment (NRC 1985). If such an evaluation indicates that an activity involves an  
16 unreviewed environmental question, the Environmental Protection Plan requires Entergy to  
17 obtain approval from the NRC before performing the activity (NRC 1985). The renewed license,  
18 if issued, would include an Environmental Protection Plan with identical or similar requirements.

### 19 Conclusion

20 Based on the NRC staff's independent review, the staff concludes that the landscape  
21 maintenance activities, stormwater management, elevated noise levels, and other ongoing  
22 operations and maintenance activities that Entergy might undertake during the renewal term  
23 would primarily be confined to disturbed areas of the Entergy property. These activities would  
24 neither have noticeable effects on terrestrial resources nor would they destabilize any important  
25 attribute of the terrestrial resources on or in the vicinity of WF3. The NRC staff concludes that  
26 noncooling system impacts on terrestrial resources during the license renewal term would be  
27 SMALL.

### 28 **4.6.2 No-Action Alternative**

29 Under the no-action alternative, WF3 would shut down. Under this alternative, the impacts to  
30 terrestrial ecology would remain similar to those during operations. Temporary buildings and  
31 staging or laydown areas may be required during large component and structure dismantling.  
32 WF3 is likely to have sufficient space within previously disturbed areas for these needs;  
33 therefore, no additional land disturbances would occur on previously undisturbed land. Adjacent  
34 lands may experience temporary increases in erosional runoff, dust, or noise, but these impacts  
35 could be minimized with the implementation of standard BMPs (NRC 2002). The GEIS  
36 (NRC 2013a) notes that terrestrial resource impacts could occur in other areas beyond the  
37 immediate nuclear plant site as a result of the no-action alternative if new power plants are  
38 needed to replace lost capacity. The NRC staff concludes that the no-action alternative is  
39 unlikely to noticeably alter or have more than minor effects on terrestrial resources. Thus, the  
40 NRC staff concludes that the impacts of the no-action alternative on terrestrial resources during  
41 the proposed license renewal term would be SMALL.

### 42 **4.6.3 New Nuclear Alternative**

43 The new nuclear alternative assumes that Entergy would build a new nuclear facility on the  
44 Entergy property but outside the existing WF3 and Waterford 1, 2, and 4 footprints. The facility  
45 would require an estimated 230 ac (93 ha) of land, all of which Entergy already owns.

1 Additional offsite land would be required for uranium mining, although this impact would result in  
2 no net change in land use impacts from those that would be associated with the proposed  
3 license renewal of WF3.

4 During construction, the use of the existing site would maximize availability of existing  
5 infrastructure, and Entergy (2016a) states that a new nuclear plant could be sited within the  
6 Entergy property footprint while meeting levee setback restrictions and avoiding wetlands.  
7 Because Entergy (2016a) would site the plant on property already zoned for heavy industrial  
8 use and that has been previously disturbed, impacts to wetlands and other terrestrial habitats  
9 would be minimal. Clearing of some plant communities within the construction footprint likely  
10 would occur. Wildlife in these areas would be displaced but could relocate to neighboring  
11 natural areas. Entergy (2016a) would implement BMPs to control erosion, sedimentation, and  
12 fugitive dust. Because wildlife on the Entergy property are likely already acclimated to industrial  
13 noises, additional noise associated with construction would be unlikely to create additional  
14 disturbances or impacts. Overall, due to the industrialized nature of the proposed site and the  
15 low likelihood for wetlands or other previously undisturbed habitats to be affected, construction  
16 impacts would be SMALL.

17 During operation, impacts would be similar in type and magnitude to those assessed in  
18 Section 4.6.1 for continued operation of WF3 under the proposed renewal term, which the NRC  
19 staff determined would be SMALL. Additional impacts associated with cooling tower operation  
20 could include bird collisions with the towers and salt drift, fogging, or increased humidity that  
21 could affect adjacent vegetation. However, the GEIS (NRC 2013a) determined that such  
22 impacts are SMALL for all nuclear plants. The NRC staff concludes that impacts of constructing  
23 and operating a new nuclear alternative on terrestrial resources would be SMALL.

#### 24 **4.6.4 SCPC Alternative**

25 The SCPC alternative assumes that Entergy would build a new SCPC facility at an existing  
26 power plant site within the SERC region of Louisiana. The facility would be equipped with  
27 carbon capture and storage technology, mechanical draft cooling towers, and it would require  
28 an estimated 120 ac (49 ha) of land. The existing transmission line infrastructure would be  
29 sufficient to support the plant; however, additional offsite land would be required for coal mining  
30 and waste disposal.

31 During construction, the use of an existing power plant site would maximize availability of  
32 existing infrastructure. However, depending on the size of the acquired site, previously  
33 undisturbed or non-industrial areas may be cleared, graded, and converted or otherwise  
34 disturbed. Thus, construction impacts on terrestrial habitats would vary depending on whether  
35 the chosen site has enough previously disturbed industrial-use land to accommodate the new  
36 SCPC plant or whether additional non-industrial or natural areas would be cleared and  
37 converted. Clearing of plant communities within the construction footprint would likely occur.  
38 Wildlife in these areas would be displaced, but they could relocate to neighboring natural areas.  
39 Nonetheless, terrestrial species could experience habitat loss or fragmentation, loss of food  
40 resources, and altered behavior due to noise and other construction-related disturbances.  
41 Erosion and sedimentation from clearing, leveling, and excavating land could affect adjacent  
42 riparian and wetland habitats, if present, although implementation of appropriate BMPs would  
43 minimize these effects. The exact magnitude of impacts to terrestrial resources would vary  
44 based on the chosen location of the SCPC plant and on the amount and types of undisturbed  
45 habitat that would be affected by construction of the alternative. Therefore, construction  
46 impacts could range from SMALL to MODERATE.

## Environmental Consequences and Mitigating Actions

1 The GEIS (NRC 2013a) concludes that impacts to terrestrial resources from operation of fossil  
2 energy alternatives would essentially be similar to those from continued operations of a nuclear  
3 facility. Unique impacts would include air emissions of GHGs, which can have far-reaching  
4 consequences because they contribute to climate change. The effects of climate change on  
5 terrestrial resources are discussed in Section 4.15.3.2. In the WF3 region, these effects may  
6 include migratory mis-synchronizations; loss of coastal, riparian, and wetland terrestrial habitats  
7 to sea level rise and storm surges; and increased susceptibility to insect infestations and  
8 pathogens, among others. Although operation of the SCPC alternative may contribute to  
9 noticeable impacts, such as those resulting from climate change, the incremental contribution of  
10 the SCPC alternative to such impacts is unlikely to destabilize any important attribute of the  
11 terrestrial environment and, therefore, would be SMALL to MODERATE.

12 The NRC staff concludes that impacts of constructing and operating an SCPC alternative on  
13 terrestrial resources would be SMALL to MODERATE.

### 14 **4.6.5 NGCC Alternative**

15 The NGCC alternative assumes that Entergy would build a new NGCC facility on its existing  
16 property. The facility would require an estimated 60 ac (24 ha) of land and would be sited on  
17 previously disturbed land. Some infrastructure upgrades could be required as well as  
18 construction of a new or upgraded pipeline.

19 During construction, the use of the existing site would maximize availability of existing  
20 infrastructure, and Entergy (2016a) states that it could site a new NGCC plant on previously  
21 disturbed land. Because Entergy (2016a) would site the plant on property already zoned for  
22 heavy industrial use and that has been previously disturbed, impacts to wetlands and other site  
23 land uses would be minimal and likely unnoticeable. Construction of a new gas pipeline  
24 segment with an associated ROW would be required to connect the NGCC plant to an existing  
25 pipeline approximately 6 to 7 mi (10 to 11 km) to the south (Entergy 2016a). Collocating the  
26 new pipeline in an existing ROW could minimize land use impacts. Clearing of some plant  
27 communities within the construction footprint likely would occur. Wildlife in these areas would  
28 be displaced, but they could relocate to neighboring natural areas. Entergy (2016a) would  
29 implement BMPs to control erosion, sedimentation, and fugitive dust. Because wildlife on the  
30 Entergy property are likely already acclimated to industrial noises, additional noise associated  
31 with construction would be unlikely to create additional disturbances or impacts. Overall,  
32 because of the industrialized nature of the proposed site and the low likelihood for wetlands or  
33 other previously undisturbed habitats to be affected, construction impacts would be SMALL.

34 The GEIS (NRC 2013a) concludes that impacts to terrestrial resources from operation of fossil  
35 energy alternatives would essentially be similar to those from continued operations of a nuclear  
36 facility. Unique impacts would include air emissions of GHGs, which can have far-reaching  
37 consequences because they contribute to climate change. The effects of climate change on  
38 terrestrial resources are discussed in Section 4.15.3.2. In the WF3 region, these effects may  
39 include migratory mis-synchronizations; loss of coastal, riparian, and wetland terrestrial habitats  
40 to sea level rise and storm surges; and increased susceptibility to insect infestations and  
41 pathogens, among others. Although operation of the NGCC alternative may contribute to  
42 noticeable impacts, such as those resulting from climate change, the incremental contribution of  
43 the NGCC alternative to such impacts is unlikely to destabilize any important attribute of the  
44 terrestrial environment and, therefore, would be SMALL to MODERATE.

45 The NRC staff concludes that impacts of constructing and operating an NGCC alternative on  
46 terrestrial resources would be SMALL during construction and SMALL to MODERATE during  
47 operation.

#### 1    **4.6.6    Combination Alternative (NGCC, Biomass, and DSM)**

2    The combination alternative assumes that Entergy would build a new NGCC facility and four  
3    biomass units on its existing property. The facilities would require a total of 90 ac (36 ha) of  
4    land (30 ac (12 ha) for the NGCC component and 60 ac (24 ha) for the biomass component).  
5    Some infrastructure upgrades could be required, as well as construction of a new or upgraded  
6    pipeline. As with the NGCC alternative, offsite land is unlikely to be affected because of the  
7    availability of natural gas in the Gulf area through the TETCO pipeline. Additional offsite land  
8    for the biomass component is not anticipated for fuel feedstock but could be required for storing,  
9    loading, and transporting biomass fuel materials. The DSM component would be implemented  
10   through energy efficiency and DSM programs across the Entergy service area.

11   Because the NGCC and biomass components of this alternative also would be sited on the  
12   Entergy property, construction of these components would have similar impacts as those  
13   described for the NGCC alternative in Section 4.6.5. DSM would not require any form of  
14   construction, and would, therefore, have no construction-type impacts. Accordingly,  
15   construction impacts associated with the combination alternative would be SMALL.

16   Operation of the NGCC component of the combination alternative would have similar impacts to  
17   those described for the NGCC alternative in Section 4.6.5. Although air emissions for the  
18   NGCC component would be roughly half of those that would result from the NGCC alternative  
19   because the NGCC component of the combination alternative would produce roughly half the  
20   energy as the NGCC alternative, the biomass component also would result in air emissions.  
21   These emissions would include GHGs, which can have far-reaching consequences because  
22   they contribute to climate change. The effects of climate change on terrestrial resources are  
23   discussed in Section 4.15.3.2. In the WF3 region, these effects may include migratory mis-  
24   synchronizations; loss of coastal, riparian, and wetland terrestrial habitats to sea level rise and  
25   storm surges; and increased susceptibility to insect infestations and pathogens, among others.  
26   Although operation of the NGCC and biomass components of this alternative may contribute to  
27   noticeable impacts, such as those resulting from climate change, the incremental contribution of  
28   these components to such impacts is unlikely to destabilize any important attribute of the  
29   terrestrial environment and, therefore, would be SMALL to MODERATE. DSM would not  
30   involve operational impacts.

31   The NRC staff concludes that the overall impacts of implementing the combination alternative  
32   on terrestrial resources would be SMALL to MODERATE.

#### 33    **4.7    Aquatic Resources**

34   This section describes the potential impacts of the proposed action (license renewal) and  
35   alternatives to the proposed action on aquatic resources.

##### 36    **4.7.1    Proposed Action**

37   Section 3.1.3 describes the WF3 cooling and auxiliary water systems, and Section 3.7 describes  
38   the aquatic resources of interest. Table 4–7 identifies the generic (Category 1) and site-specific  
39   (Category 2) issues that apply to aquatic resources at WF3 during the proposed license renewal  
40   period.

1

**Table 4–7. Aquatic Resource Issues**

<b>Issue</b>	<b>GEIS Section</b>	<b>Category</b>
<b>All plants</b>		
Entrainment of phytoplankton and zooplankton	4.6.1.2	1
Infrequently reported thermal impacts	4.6.1.2	1
Effects of cooling water discharge on dissolved oxygen, gas supersaturation, and eutrophication	4.6.1.2	1
Effects of nonradiological contaminants on aquatic organisms	4.6.1.2	1
Exposure of aquatic organisms to radionuclides	4.6.1.2	1
Effects of dredging on aquatic organisms	4.6.1.2	1
Effects on aquatic resources (noncooling system impacts)	4.6.1.2	1
Impacts of transmission line ROW management on aquatic resources <sup>(a)</sup>	4.6.1.2	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.6.1.2	1
<b>Plants with once-through cooling systems or cooling ponds</b>		
Impingement and entrainment of aquatic organisms	4.6.1.2	2
Thermal impacts on aquatic organisms	4.6.1.2	2

<sup>(a)</sup> This issue applies only to the in-scope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

2 **4.7.1.1 Generic GEIS Issues**

3 The NRC staff did not identify any new and significant information associated with the  
 4 Category 1 aquatic resource issues identified in Table 4–7 during the review of the applicant’s  
 5 ER, aquatic surveys and studies performed at WF3 and in the Mississippi River, and available  
 6 scientific literature; the site audit; and Federal and State agency and public comments received  
 7 during the scoping process. As a result, no information or impacts related to these issues were  
 8 identified that would change the conclusions presented in the GEIS (NRC 2013a). For these  
 9 issues, the GEIS concludes that the impacts are SMALL. The NRC staff does not expect  
 10 incremental impacts related to these Category 1 issues during the renewal term beyond those  
 11 discussed in the GEIS; therefore, the impacts associated with these issues are SMALL.

12 **4.7.1.2 Impingement and Entrainment of Aquatic Organisms**

13 In the GEIS (NRC 2013a), the NRC determined that impingement and entrainment of aquatic  
 14 organisms is a Category 2 issue (see Table 4–7) that requires a site-specific evaluation during  
 15 each license renewal review for plants with once-through cooling systems, such as WF3.

16 Impingement is the entrapment of all life stages of fish and shellfish on the outer part of an  
 17 intake structure or against a screening device during periods of water withdrawal  
 18 (40 CFR 125.83). Impingement can kill organisms immediately or contribute to a slower death  
 19 resulting from exhaustion, suffocation, injury, and other physical stresses. The potential for  
 20 injury or death is generally related to the amount of time an organism is impinged, its  
 21 susceptibility to injury, and the physical characteristics of the screen washing and fish return  
 22 system (if present).

1 Entrainment is the incorporation of all life stages of fish and shellfish with intake water flow  
2 entering and passing through a cooling-water intake structure and into a circulating water  
3 system (40 CFR 125.83). Organisms susceptible to entrainment are generally of a smaller size  
4 than those susceptible to impingement and include ichthyoplankton (fish eggs and larvae), larval  
5 stages of shellfish and other macroinvertebrates, zooplankton, and phytoplankton. Entrained  
6 organisms may experience physical trauma and stress, pressure changes, excess heat, and  
7 exposure to chemicals, all of which may result in injury or death (Mayhew et al. 2000).

8 A particular species can be subject to both impingement and entrainment if some individual fish  
9 are impinged on screens while others pass through the screens and are entrained. For  
10 instance, adults could be impinged while larvae could be entrained, if they are small enough to  
11 pass through the intake screen openings.

12 At WF3, aquatic organisms that inhabit the Mississippi River may be impinged when cooling  
13 water is drawn from the river through an intake structure. Organisms entrained by passing  
14 through the intake system and into the WF3 cooling water system are subject to mechanical,  
15 thermal, and toxic stresses that make survival unlikely.

16 This section’s analysis uses a retrospective assessment of the present and past impacts to the  
17 aquatic ecosystem resulting from WF3 operation in order to provide a prospective assessment  
18 for the future impacts over the proposed license renewal term (i.e., through 2044). In addition,  
19 the NRC staff used a modified weight-of-evidence (WOE) approach to evaluate the effects of  
20 impingement and entrainment on the aquatic resources in the Mississippi River. The NRC staff  
21 chose this approach because EPA recommends a WOE approach for ecological risk  
22 assessment (EPA 1998). The WOE approach is a useful tool because of the complex nature of  
23 assessing risk (or impact). The NRC has used this approach in other evaluations of the effects  
24 of nuclear power plant cooling systems on aquatic communities (e.g., NRC 2010, 2013,  
25 2015a, 2015b, 2016h). Menzie et al. (1996) defines WOE as “...the process by which multiple  
26 measurement endpoints are related to an assessment endpoint to evaluate whether significant  
27 risk of harm is posed to the environment.” In the present WOE approach, the NRC staff  
28 examined four lines of evidence (LOE) to determine if operation of WF3 is contributing to  
29 adverse impacts on aquatic resources in the Mississippi River. The lines of evidence are as  
30 follows:

LOE	Description
1	Results of impingement studies
2	Results of entrainment studies
3	Temporal differences in fish populations in the Mississippi River
4	Consideration of engineered designs and operational controls that affect impingement and entrainment rates

31 LOE 1: Impingement Studies

32 To estimate impingement rates at WF3, Entergy conducted an impingement study at  
33 Waterford 1 and 2 and extrapolated the impingement data to estimate impingement rates at  
34 WF3. The results of the two impingement studies conducted at Waterford 1 and 2, Entergy’s  
35 method of extrapolation to estimate impingement at WF3, and the uncertainties related to this  
36 approach are described below.

37 Entergy, its predecessors, and its contractors conducted two impingement studies at  
38 Waterford 1 and 2: an historical study from 1976 through 1977, and a more recent study from


## Environmental Consequences and Mitigating Actions

1 2006 through 2007. From February 1976 and January 1977, Espey, Huston and Associates,  
2 Inc. (1977) collected biweekly impingement samples within set 24-hour collection periods.  
3 Espey, Huston and Associates, Inc. (1977) collected samples in the sluiceway of the intake  
4 structure within three baskets lined with hardware cloth that had 0.25-inch (in.) (0.64-cm) to  
5 0.5-in. (1.3-cm) mesh openings.

6 Espey, Huston and Associates, Inc. (1977) collected a total of 49 species: 46 fish species and  
7 3 invertebrate species. The majority of impinged individuals were juveniles (less than  
8 25 millimeters (mm) (1 in.)). Commonly collected shellfish and fish species included river  
9 shrimp (*Macrobrachium chione*; 49.7 percent relative abundance of individuals collected), blue  
10 catfish (*Ictalurus furcatus*; 20.3 percent), threadfin shad (*Dorosoma petenense*; 10.5 percent),  
11 bay anchovy (*Anchoa mitchilli*; 6 percent) freshwater drum (*Aplodinotus grunniens*; 4.5 percent),  
12 gizzard shad (*Dorosoma cepedianum*; 2.9 percent), skipjack herring (*Alosa chrysochions*;  
13 2.4 percent), and channel catfish (*Ictalurus punctatus*; 2.1 percent) (Figure 4-1). No other  
14 species comprised more than 1 percent of the relative abundance of individuals collected.  
15 Entergy estimated an impingement rate of 4.22 organisms per 10,000 m<sup>3</sup> of withdrawn water by  
16 dividing the number of individuals impinged over a 24-hour period by the amount of water  
17 withdrawn within the time period and multiplying the result by 10,000 to get an impingement rate  
18 per 10,000 m<sup>3</sup>.

19 In 2006, ENSR (2007) conducted a similar impingement study at Waterford 1 and 2. From  
20 September 2006 through August 2007, ENSR (2007) collected biweekly impingement samples  
21 within set 24-hour collection periods. ENSR (2007) collected samples in the sluiceway of the  
22 intake structure with nets constructed of 0.375-in. (0.95-cm) mesh openings. A total of 32 fish  
23 and shellfish species were collected during the study. The most commonly impinged shellfish  
24 and fish were similar to the species collected in the 1976-1977 study and included river shrimp  
25 (58.4 percent relative abundance of individuals collected), threadfin shad (14 percent), grass  
26 shrimp (*Palaemonetes kadiakensis*; 9.3 percent) channel catfish (5.2 percent), blue catfish  
27 (4.7 percent), freshwater drum (3.3 percent), bay anchovy (1.4 percent), gizzard shad  
28 (0.7 percent), and skipjack herring (0.3 percent) (Figure 4-1). Applying the same approach as  
29 in the 1977 study to estimate impingement rates, ENSR (2007) estimated an impingement rate  
30 of 16.16 individuals per 10,000 m<sup>3</sup>. ENSR (2007) attributed the increased impingement rate,  
31 from 4.22 to 16.16 organisms per 10,000 m<sup>3</sup>, to interannual variation for ambient populations of  
32 fish near Waterford 1 and 2. ENSR (2007) noted that other variables often correlated with fish  
33 population size; such as river flows, water temperature, and spawning conditions, showed  
34 considerable interannual variation. The lack of other impingement studies or long-term  
35 population studies at WF3 prevented the NRC staff from examining what variables may have  
36 contributed to higher impingement rates and interannual changes in impingement rates.

1 **Figure 4–1. Relative Abundance of Commonly Impinged Species during the 1976-1977**  
 2 **and 2006-2007 Studies at Waterford 1 and 2**



3  
 4 Source: ENSR (2007)

5 ENSR (2007) estimated annual impingement at WF3 by multiplying the impingement rate  
 6 calculated during the 2006–2007 study at Waterford 1 and 2 (16.16 organisms per 10,000 m<sup>3</sup> of  
 7 withdrawn water) by the annual withdrawal rate at WF3. This calculation resulted in an estimate  
 8 of 3,472,951 organisms per year. ENSR (2007) and Entergy (2016a and 2016b) determined  
 9 that the impingement rate calculated at Waterford 1 and 2 was representative of the  
 10 impingement rate at WF3, given the close proximity of the facilities, similar habitat near both  
 11 intake structures, and the similar technologies to reduce impingement at both structures. In  
 12 addition, anecdotal impingement observations at Waterford 1 and 2 and WF3 confirmed similar  
 13 commonly impinged species at both intakes (ENSR 2007). Entergy used the data from  
 14 Waterford 1 and 2 in part based on a remanded 2004 version of the EPA Phase II Cooling  
 15 Water Intake Rule (Phase II Rule; 79 FR 48300). The remanded proposed rule in  
 16 40 CFR 125.95 stated that a facility may use existing data if it can demonstrate the extent to  
 17 which the data are representative of current conditions and if the data were collected using  
 18 appropriate quality assurance/quality control procedures (LDEQ 2006). The LDEQ reviewed  
 19 Entergy’s approach to using data collected at Waterford 1 and 2 and determined that this  
 20 approach is reasonable, given that similar species would be expected to occur at both sites  
 21 because of the proximity to and the similar habitat at the two intakes (NRC 2016a).

22 The NRC staff acknowledges that there is uncertainty related to Entergy’s approach for  
 23 estimating impingement at WF3 because of several assumptions incorporated within Entergy’s  
 24 calculations. One source of uncertainty is whether the aquatic community is similar near the  
 25 intakes at Waterford 1 and 2 and at WF3. No long-term studies have been conducted to  
 26 compare the fish and shellfish populations between the two intakes. As described above,  
 27 although the aquatic communities are likely similar based on the similar habitat (e.g., same  
 28 average water velocity in the channel of the Mississippi River) and proximity of the two intakes  
 29 to one another (2,100 ft (640 m) apart), small differences in habitat (e.g., different river  
 30 bathymetry, availability of nearby habitat structure, water temperature, and river bed substrates)  
 31 can influence population dynamics.

## Environmental Consequences and Mitigating Actions

1 Another source of uncertainty is interannual variation. The two impingement studies at  
 2 Waterford 1 and 2 demonstrated that impingement rates vary seasonally and annually.  
 3 Additional impingement studies would provide a more complete assessment of the full range in  
 4 interannual variation. Given that Entergy applied the higher impingement rate (16.16 versus  
 5 4.22 organisms per 10,000 m<sup>3</sup>) to extrapolate impingement at WF3, the current estimate at WF3  
 6 is likely conservative and represents years when impingement is average to high.

7 ENSR's (2007) impingement estimates for WF3 also assume that organisms are equally as  
 8 likely to be impinged at Waterford 1 and 2 as at WF3. Several engineered and operational  
 9 factors influence impingement likelihood, including:

- 10 • approach and through-screen velocity,
- 11 • size and type of traveling screens,
- 12 • intake location, and
- 13 • other engineered features to reduce impingement mortality, such as fish returns.

14 The approach and through-screen velocity can affect impingement rates because a lower  
 15 approach velocity allows fish to swim away from the intake structure and prevent impingement.  
 16 A fish often can avoid impingement if its swimming speed is faster than the approach velocity at  
 17 the traveling screen. Both the approach velocity at the river and through-screen velocity at  
 18 Waterford 1 and 2 and at WF3 are similar and vary from approximately 1 to 2 feet per second  
 19 (fps) (0.3 to 0.6 m/s). (see Table 4–8). The approach velocity at WF3 is lower (1 fps (0.3 m/s))  
 20 than at Waterford 1 and 2 (1.5 fps (0.46 m/s)), which indicates that some fish might be able to  
 21 avoid impingement more often at WF3.

22 Both the Waterford 1 and 2 and the WF3 intakes include conventional traveling screens with  
 23 relatively similar screen size. (see Table 4–8). The screen panels at Waterford 1 and 2 have a  
 24 0.25-in. (0.64-cm) mesh. Before 2016, screen panes at WF3 were made of stainless steel  
 25 mesh, with 90 percent covered in 0.25-in. (0.64-cm) mesh and 10 percent covered in 0.375-in.  
 26 (0.95-cm) mesh. In 2016, Entergy installed new MultiDisc screens made of polyethylene and  
 27 that have a mesh size of 0.375 in. (0.94 cm) (Entergy 2016b). The polyethylene material  
 28 potentially could increase survivability of some impinged species, although the slightly larger  
 29 mesh size also could potentially increase entrainment rates (McLaren and Tuttle 2000).

30 The location of the intake also varies between the two sites, given that Waterford 1 and 2 is  
 31 upriver of WF3 and the intakes draw from different depths within the water column. (see Table  
 32 4–8). NRC (1981) predicted that less catfish and drum would be impinged at WF3 as compared  
 33 to Waterford 1 and 2 because the WF3 intake will draw from a larger portion of the water  
 34 column, including higher water levels.

35

**Table 4–8. Plant Intake Characteristics**

<b>Intake Characteristic</b>	<b>Waterford 1 and 2</b>	<b>WF3</b>
<b>Velocity</b>		
approach at river end	0.95 to 1.5 fps	1.09 to 1.78 fps
approach at screen	1.5 fps	1.0 fps
through screen	1.3 to 2.0 fps	1.06 to 1.82 fps
<b>Traveling Screens</b>		
mesh size <sup>a</sup>	0.25 in.	0.25 in. to 0.375 in.

Intake Characteristic	Waterford 1 and 2	WF3
<b>Location</b>		
distance offshore	150 ft	162 ft
depth below surface	28 to 36 ft	1 to 35 ft
hydraulic zone of influence	262 sq ft	659 sq ft

<sup>(a)</sup> In 2016, Entergy installed new MultiDisc screens with a mesh size of 0.375 in. (0.94 cm) (Entergy 2016b). Prior to 2016, 90 percent of the screen panels were a 0.25-in. (0.64-cm) mesh and 10 percent were at 0.375-in. (0.95-cm) mesh.

Sources: LP&L 1978; Entergy 2016b

1 ENSR (2005a) estimated that the fish handling return system at Waterford 1 and 2 reduces  
 2 impingement mortality by 15 percent. WF3's intake does not contain a fish return system,  
 3 although a fish handling system currently in place may reduce impingement mortality  
 4 (ENSR 2005b, 2007). Entergy (2016b) noted that the intake structure potentially could be  
 5 equipped with a fish return system during the period of extended operations. However, when  
 6 evaluating the impacts to fish for this SEIS, the NRC staff did not assume that a fish return  
 7 system would be in place, given that Entergy has not committed to add one.

8 *Conclusion*

9 Commonly impinged species include river shrimp, threadfin shad, grass shrimp, channel catfish,  
 10 blue catfish, freshwater drum, bay anchovy, gizzard shad, and skipjack herring. None of the  
 11 commonly impinged species are rare, threatened, or endangered. To determine whether the  
 12 estimated impingement rates are having a noticeable effect on aquatic biota, the NRC staff  
 13 would need to examine this LOE in conjunction with population-level studies to determine  
 14 whether impingement has resulted in a noticeable decline or other measurable impacts on  
 15 aquatic biota. The NRC staff performs this population analysis in LOE 3.

16 The NRC staff acknowledges that there is uncertainty related to Entergy's approach to estimate  
 17 impingement at WF3, given that Entergy extrapolated impingement rates based on studies  
 18 conducted at Waterford 1 and 2. Furthermore, impingement data focuses on common species;  
 19 therefore, it does not allow the NRC staff to examine impingement rates for rare or less common  
 20 species, which generally are more sensitive to environmental changes.

21 LOE 2: Entrainment Studies

22 Entergy has not collected entrainment data at Waterford 1 or 2, or WF3. In its impingement  
 23 mortality and entrainment characterization study, ENSR (2005b, 2007) stated that because the  
 24 facility's design intake flow is less than 5 percent of the mean annual flow of the Mississippi  
 25 River, this exempted the facility from conducting an entrainment characterization study. The  
 26 exemption was based on a previous draft of the Phase II Rule, which has since been remanded.  
 27 Under the 2014 final Phase II Rule, an intake flow of 5 percent or less of the mean annual flow  
 28 does not exempt an existing facility from characterizing entrainment (79 FR 48300).

29 Given the lack of entrainment data collection at WF3, the NRC staff conducted a qualitative  
 30 assessment for the potential impacts to the aquatic community from entrainment at WF3. As  
 31 described in Section 3.7.2.2, Louisiana Power & Light (LP&L) (1978) found low levels of fish  
 32 eggs and larvae (ichthyoplankton) during its preoperational study near WF3 from 1974 through  
 33 1976. Commonly collected families and taxa included Clupeidae or herrings (threadfin shad,  
 34 gizzard shad, and skipjack herring); Cyprinidae or minnow family (carp, chubs, minnows, and  
 35 shiners); Ictaluridae or catfish family, including blue and channel catfish larvae; Centrarchidae or

## Environmental Consequences and Mitigating Actions

1 sunfish family (sunfish, bass, and crappies) and Sciaenidae (freshwater drum) (LP&L 1978,  
2 NRC 1981). However, no ichthyofaunal data have been collected within the vicinity of WF3  
3 since the plant began operations in 1985 (ENSR 2007, Entergy 2016b).

4 The area immediately surrounding the intake structure does not provide suitable habitat for most  
5 fish eggs and larvae that occur near WF3 (Baker et al. 1991; ENSR 2007; LDEQ 2010). For  
6 example, the intake structure is located approximately 162 ft (49 m) from the shoreline within  
7 fast-flowing water (average flow of 3.65 ft/sec (1.11 m/s)), with a high suspended sediment load,  
8 and limited food availability for eggs and larvae (e.g., restricted phytoplankton and periphyton  
9 growth) (ENSR 2005b; 2007). Most fish in the Lower Mississippi River spawn in shallow or  
10 sheltered areas, smaller streams, backwaters or floodplains, and in areas with aquatic  
11 vegetation or gravel and sand bottoms. Few eggs that are spawned upriver would reach WF3  
12 because all but one of the commonly occurring species near WF3 have demersal eggs, which  
13 sink to the river bed floor. Based on the results of preoperational ichthyoplankton studies, low  
14 levels of eggs and larvae occur near WF3 (LP&L 1978; NRC 1981).

15 One method for estimating entrainment is to calculate the percent of flow that is withdrawn by  
16 the cooling water system (EPA 2002; Entergy 2016a). This method assumes that planktonic  
17 organisms are equally distributed throughout the waterbody, and therefore, the percent of water  
18 withdrawn is the same as the percent of planktonic organisms entrained. This assumption  
19 appears to be reasonable for the Lower Mississippi River near WF3, given that preoperational  
20 studies from 1974–1976 reported a fairly homogeneous distribution of fish eggs and larvae near  
21 WF3 (LP&L 1978). ENSR (2007) estimated that WF3 withdraws 0.48 percent of the flow in the  
22 Mississippi River. Based on the assumption that eggs and larvae are evenly distributed, WF3  
23 would entrain less than 0.5 percent of the free-flowing eggs and larvae. Furthermore, most  
24 species near WF3 spawn in the spring, when flows are high and a smaller fraction of the river  
25 water would be withdrawn for WF3 cooling (NRC 1981). In addition, all but one of the  
26 commonly occurring species near WF3 have demersal eggs, which sink to the river bed, and  
27 would be less likely to be entrained within the intake within the mid to upper portions of the  
28 water column (NRC 1981). Given that the WF3 intake is located in an area that does not  
29 provide suitable spawning habitat for most fish species, and preoperational studies did not find  
30 important spatial differences of ichthyoplankton near WF3, it is reasonable to assume that  
31 entrainment would be 0.5 percent or less for most fish species in the Lower Mississippi River.

### 32 *Conclusion*

33 No ichthyofaunal studies have occurred near WF3 in the past 30 years, and no entrainment  
34 studies have been conducted at Waterford 1 or 2, or WF3. The NRC conducted a qualitative  
35 analysis and determined that entrainment of fish eggs and larvae is not likely to noticeably affect  
36 important attributes of the aquatic community near WF3 because of the lack of suitable  
37 spawning habitat near WF3, low ichthyoplankton densities near WF3, and because WF3  
38 withdraws less than 0.5 percent of the average flow in the Mississippi River.

### 39 LOE 3: Temporal Trends in Fish Populations in the Mississippi River

40 Impingement and entrainment from the withdrawal of makeup water from the Mississippi River  
41 have removed individuals from the river ecosystem since WF3 began operating in 1985. Over  
42 this period of time, the aquatic community may have changed in a number of ways, including  
43 species richness (the number of species present), species composition (the kinds of species  
44 present), and species evenness (the relative abundance of species). This LOE compares fish  
45 populations before and during operations to determine whether changes have occurred and if  
46 such changes can be attributed to WF3 operations. If impingement and entrainment were to  
47 affect fish within the vicinity of WF3, fish abundances and species richness likely would be lower  
48 post-operation as compared to before operations.

1 In the section below, the NRC staff makes general characterizations of fish populations during  
 2 preoperational and operational surveys. However, differences between time periods could  
 3 occur for multiple reasons, including variations in sampling equipment, the frequency and timing  
 4 of sampling events, and sampling locations. Furthermore, the lack of consistently repeated  
 5 sampling prevented the NRC staff from conducting statistical analyses on the changes in fish  
 6 populations over time. Therefore, the trends presented below describe general patterns in fish  
 7 populations that have not been tested for statistical significance.

8 As described in Section 3.7, relatively few long-term fish surveys have occurred in the Lower  
 9 Mississippi River. Available species occurrence data included the following studies:

- 10 • Entergy’s preoperational sampling near WF3 (1973–1980),
- 11 • Entergy’s impingement study at Waterford 1 and 2 (1976–1977),
- 12 • Entergy’s impingement study at Waterford 1 and 2 (2006–2007), and
- 13 • local aquatic surveys compiled within the FishNet database that occurred in 1953,  
 14 1982, 1997, 1998, and 2000.

15 Given the different methodologies, sampling locations, sampling protocols, and equipment  
 16 among these studies, it would be inappropriate to combine the data from the various surveys to  
 17 conduct statistical analyses. In addition, some of the surveys only recorded the presence or  
 18 absence of the species, rather than the abundance found within each survey. Therefore, the  
 19 NRC staff examined the presence or absence of the most commonly impinged species during  
 20 three time periods: 1953, 1973–1982, and 1997–2007 (Table 4–9).

21 The fish survey data indicate that all commonly impinged species were present before  
 22 operations, in 1985, as well as after 20 to 30 years of operations, from 1997–2007. The  
 23 continued presence of the most commonly impinged species suggests that the aquatic  
 24 community surrounding WF3 has not substantially changed since WF3 operations began.  
 25 General observations from local fisheries biologists also suggest that the community structure  
 26 within the Lower Mississippi near WF3 has not substantially changed since operations began  
 27 in 1985 (ENSR 2007). However, the NRC staff notes that the presence and absence data in  
 28 Table 4–9 focus on common species and, therefore, do not allow the NRC staff to examine  
 29 changes over time for rare or less common species, which generally are more sensitive to  
 30 environmental changes. In addition, the data also limit the NRC staff from examining whether  
 31 the population sizes of the most common species have changed over time.

32 **Table 4–9. Occurrence Patterns in the Lower Mississippi River near WF3 for Species**  
 33 **Comprising More than 1 Percent of the 1976–1977 and 2006–2007 Impingement Studies**

Species	Common Name	Survey Year(s)		
		1953 <sup>(a)</sup>	1973–1982 <sup>(b)</sup>	1997–2007 <sup>(c)</sup>
<b>Clupeidae</b>				
<i>Alosa chrysochloris</i>	skipjack herring	X	X	X
<i>Dorosoma cepedianum</i>	gizzard shad		X	X
<i>Dorosoma petenense</i>	threadfin shad	X	X	X
<b>Engraulidae</b>				
<i>Anchoa mitchilli</i>	bay anchovy		X	X
<i>Ictalurus furcatus</i>	blue catfish	X	X	X
<i>Ictalurus punctatus</i>	channel catfish		X	X

## Environmental Consequences and Mitigating Actions

Species	Common Name	Survey Year(s)		
		1953 <sup>(a)</sup>	1973–1982 <sup>(b)</sup>	1997–2007 <sup>(c)</sup>
<b>Sciaenidae</b>				
<i>Aplodinotus grunniens</i>	freshwater drum	X	X	X
<p><sup>(a)</sup> FishNet 2014: Survey conducted by R.D. Suttkus &amp; Webb in 1953 in Mississippi River by the U.S. Bonnet Carre Spillway.</p> <p><sup>(b)</sup> LP&amp;L 1978, ENSR 2007: Aquatic sampling within the vicinity of WF3 from 1973–1980; Commonly impinged species at Waterford 1 and 2 in 1976–1977.</p> <p>FishNet 2014: Survey conducted by E.B. Pebbles &amp; D.L. Rome in 1982 in Mississippi River by the U.S. Bonnet Carre Spillway.</p> <p><sup>(c)</sup> ENSR 2007: Impinged species at Waterford 1 and 2 during 2006–2007 surveys.</p> <p>FishNet 2014: Surveys conducted by Atwood and Walsh in 1997, Atwood in 1998, and Atwood and Walsh in 2000 in the Mississippi River by Little Rock Ferry (river mile (RM) 125.3).</p>				
Sources: LP&L 1978; ENSR 2007; FishNet 2014				

1 ENSR (2007) reported similar relative abundances for commonly impinged fish species in both  
 2 the 1976–1977 and 2006–2007 studies (Figure 4–1). Anecdotal evidence by plant operators  
 3 also confirmed that commonly impinged species have remained the same over time  
 4 (ENSR 2007). The similar relative abundance of impinged fish species collected before and  
 5 during operations also suggests that the aquatic community near WF3 has not changed  
 6 significantly since operations began. The NRC staff notes that the impingement data focus on  
 7 common species and, therefore, do not allow the NRC staff to examine changes over time for  
 8 rare or less common species, which generally are more sensitive to environmental changes.

### 9 *Conclusion*

10 In LOE 3, the NRC staff looked at the presence and absence of the most commonly impinged  
 11 species within aquatic surveys near WF3. The fish survey data indicate that all commonly  
 12 impinged species were present before operations, in 1985, and after 20 to 30 years of  
 13 operations, from 1997–2007. In addition, fish species that comprised 1 percent or more of  
 14 impingement collections in the 1976–1977 study had a similar relative abundance in the  
 15 2006–2007 study. The continued presence and relative abundance of the mostly commonly  
 16 impinged species suggest that the aquatic community surrounding WF3 has not substantially  
 17 changed since WF3 operations began. Therefore, the NRC staff concludes that impingement  
 18 and entrainment are not having a noticeable impact on fish populations in the Mississippi River  
 19 near WF3.

20 The NRC staff acknowledges that the above analysis includes a large degree of uncertainty  
 21 because the best available population studies do not include repeated sampling at control sites  
 22 and non-control sites both before and during operations. Such data would have allowed the  
 23 NRC staff to statistically examine changes in fish populations over time, including changes in  
 24 population size. Given that such a dataset does not exist, the NRC staff based its analysis on  
 25 the best available information, which was limited to presence and absence data during three  
 26 time periods. Additionally, the available data focus on common species, and do not allow the  
 27 NRC staff to examine population changes for rare or less common species, which generally are  
 28 more sensitive to environmental changes.

#### 1 LOE 4: Engineered Design and Operational Controls

2 In August 2014, EPA published a final rule establishing requirements under Section 316(b) of  
 3 the CWA for cooling-water intake structures at existing facilities (Phase II Rule; 79 FR 48300).  
 4 The final Phase II Rule indicates that two basic approaches can reduce impingement and  
 5 entrainment mortality: (1) flow reduction and (2) including technologies into the cooling-water  
 6 intake design that gently exclude organisms or collect and return organisms without harm to the  
 7 water body. The EPA also notes that two additional approaches can reduce impingement and  
 8 entrainment; however, these technologies may not be available to all facilities. The two  
 9 additional approaches are: relocating the facility's intake to a less biologically rich area in a  
 10 water body and reducing the intake velocity. The WF3 intake structure on the Mississippi River  
 11 incorporates several of these approaches.

#### 12 *Location of Intake in Less Biologically Rich Area*

13 Location of the intake system is a design factor that can affect impingement and entrainment  
 14 because locating intake systems in areas with high biological productivity or sensitive biota can  
 15 negatively affect aquatic life (EPA 2004). As discussed in Section 3.7, the location of the intake  
 16 structure within deep, fast-flowing water (approximately 162 ft (49 m) from the shoreline and an  
 17 average flow of 3.65 ft/sec (1.11 m/s); ENSR 2005b) suggests that the area immediately  
 18 surrounding the intake does not provide suitable habitat for fish eggs and larvae  
 19 (Baker et al. 1991; ENSR 2007; LDEQ 2010). Furthermore, this area is not as biologically rich  
 20 as compared to shallow areas along the shoreline that provide more complex habitat structure,  
 21 such as vegetation. In addition, the intake location experiences high levels of floating debris,  
 22 high suspended sediment load, shifting riverbed, and low levels of prey (e.g., zooplankton and  
 23 phytoplankton), which also makes the location less suitable for juvenile and adult fish and  
 24 shellfish (ENSR 2007; LDEQ 2010). Entergy (2007) estimated that the offshore location, in  
 25 combination with the fish handling system, reduces impingement mortality by at least 94 percent  
 26 as compared to a hypothetical intake located along the shoreline, which has substantially  
 27 greater biological richness.

#### 28 *Flow Reduction*

29 Reducing the amount of water withdrawn for cooling purposes from a water body reduces the  
 30 number of aquatic organisms that are drawn through the intake structure and subject to  
 31 impingement or entrainment. WF3 uses a once-through system, which generally withdraws and  
 32 discharges more cooling water than closed-cycle systems that recirculate water before  
 33 discharge into the source waterbody (NRC 2013a). Entergy (2016a) determined that the plant  
 34 design intake flow is 1,555.2 million gallons per day (mgd) or 2,406 cubic feet per second (cfs),  
 35 which would withdraw approximately 0.48 percent of the river's mean annual flow. Although the  
 36 intake flow is not reduced given the once-through technology, the relatively low withdrawal rate  
 37 compared to the river's mean annual flow indicates that only a small portion of aquatic  
 38 organisms within the Lower Mississippi River would be exposed to potential impingement or  
 39 entrainment at WF3.

#### 40 *Technologies That Exclude or Collect and Return Organisms*

41 The WF3 cooling system contains technologies that help exclude organisms from becoming  
 42 impinged or entrained. Water enters the river screen house through an intake bay equipped  
 43 with trash racks and 0.25-in (0.64-cm) to 0.375-in (0.95-cm) mesh travelling screens, which  
 44 prevent debris and aquatic biota from entering the system (ENSR 2005b; Entergy 2016a,  
 45 2016b). The EPA indicates that, ideally, traveling screens would be used with a fish handling  
 46 and return system (79 FR 48300). WF3's intake does not contain a fish return system, although  
 47 a fish handling system currently in place may reduce impingement mortality (ENSR 2005b,

## Environmental Consequences and Mitigating Actions

1 2007). Entergy (2016b) noted that the intake structure potentially could be equipped with a fish  
2 return system during the period of extended operations, although no plans are in place to install  
3 such a system. In addition, the intake velocity (discussed below) should allow some fish to  
4 swim away and escape impingement.

### 5 *Intake Flow*

6 Water velocity associated with the intake structure greatly influences the rate of impingement  
7 and entrainment. The higher the approach velocity, through-screen velocity, or both, the greater  
8 the number of organisms that will be impinged or entrained. At an approach velocity of  
9 0.5 fps (0.15 m/s) or less, most fish can swim away and escape from the intake current  
10 (79 FR 48300). The approach velocity at WF3 ranges from 1.0 to 1.78 fps (0.33 to 0.54 m/s)  
11 (LP&L 1978; Entergy 2016b), which is greater than that recommended by EPA for protection of  
12 aquatic organisms and could contribute to impingement and entrainment effects.

### 13 *Best Technology Available*

14 In 1991, LDEQ issued WF3's LPDES permit (No. LA0007374). Within the 1991 permit, LDEQ  
15 approved the intake structure as being the best technology available (BTA) in accordance with  
16 Section 316(b) of the Clean Water Act.

17 The LDEQ (2010) issued Entergy's most recent LPDES permit in 2010. At that time,  
18 LDEQ (2010) evaluated the BTA based on the standards set in a July 6, 2004, Phase II Rule  
19 that was rescinded on July 9, 2007. The 2010 LPDES permit states that a "repromulgated  
20 regulation will supersede any requirements contained in the permit." Based on the BTA  
21 standards described in the rescinded 2004 Phase II Rule, LDEQ (2010) determined that WF3's  
22 cooling-water intake system represents the BTA based on the following factors:

- 23 • The offshore location of the intake minimizes fish and shellfish from entering the  
24 intake because of the conditions of the Mississippi River channel (i.e., high velocity,  
25 increased debris, shifting river bed, lack of habitat/vegetation, and reduction of food  
26 sources).
- 27 • The skimmer wall prevents swimming organisms from entering the intake.

28 In August 2014, the EPA published the final Phase II Rule, including applicable regulations for  
29 cooling water intake systems at existing power plants and the schedule for implementation  
30 (79 FR 48300). In 2017, LDEQ issued a renewed LPDES permit for WF3 (see discussion in  
31 Section 3.1.2.3). The 2017 LPDES permit did not determine whether it is compliant with the  
32 final Phase II Rule because Entergy requested and LDEQ granted an alternative schedule for  
33 Entergy to submit the information required under the final Phase II Rule (see 40 CFR 122.21(r)).  
34 LDEQ (2017) further stated that Entergy shall submit this information with the renewal  
35 application for the next permit cycle. Therefore, the NRC staff assumes that if the 2022 LPDES  
36 permit is renewed and issued, the renewed LPDES permit would comply with the final 2014  
37 Phase II Rule to minimize impingement and entrainment impacts.

### 38 *Conclusion*

39 For LOE 4, the NRC staff examined engineering and operation controls currently in place, as  
40 well as engineering and operational controls that LDEQ has evaluated as part of its review of  
41 WF3's LPDES permit. Although some engineered and operational controls currently in place  
42 may reduce impingement (e.g., placement of the intake system 162 ft (49 m) from the shoreline  
43 with relatively lower biological productivity) or entrainment (e.g., traveling screens), the  
44 withdrawal rates associated with a once-through cooling system, the lack of a fish return  
45 system, and the through-screen velocity may contribute to adverse impingement and  
46 entrainment effects.

1 Overall Impingement and Entrainment Conclusion

2 The NRC staff reviewed four LOEs to examine the impacts from impingement and entrainment  
3 on the aquatic resources near WF3. In LOE 1, the NRC staff determined that commonly  
4 impinged species include river shrimp, threadfin shad, grass shrimp, channel catfish, blue  
5 catfish, freshwater drum, bay anchovy, gizzard shad, and skipjack herring. In LOE 3, the NRC  
6 staff reviewed available population studies for these commonly impinged species. The NRC  
7 staff found that these species were present before operations, in 1985, as well as after 20 to  
8 30 years of operations, from 1997–2007. In addition, commonly impinged fish species had a  
9 similar relative abundance in the 1976–1977 impingement study as compared to the 2006–2007  
10 study. The continued presence and relative abundance of the commonly impinged species  
11 suggests that the aquatic community surrounding WF3 has not substantially changed as a result  
12 of impingement since WF3 operations began.

13 In LOE 2, the NRC staff reviewed preoperational ichthyofaunal studies. No ichthyofaunal  
14 studies have occurred near WF3 in the past 30 years and no entrainment studies have been  
15 conducted at Waterford 1, 2, or WF3. In its qualitative assessment of entrainment impacts, the  
16 NRC staff concluded that entrainment of fish eggs and larvae is not likely to noticeably affect  
17 important attributes of the aquatic community near WF3 because of the lack of suitable  
18 spawning habitat near WF3, because eggs that are produced upstream are likely to sink and not  
19 likely to drift within the water column towards WF3, because preoperational studies recorded  
20 low egg and larvae density near WF3, and because a very small portion of eggs and larvae  
21 would be entrained given that WF3 withdraws less than 0.5 percent of the average flow in the  
22 Mississippi River. In addition, in LOE 3, the NRC staff determined that the continued presence  
23 of common species suggests that the aquatic community surrounding WF3 has not substantially  
24 changed as a result of impingement and entrainment since WF3 operations began.

25 For LOE 4, the NRC staff examined engineering and operation controls currently in place, as  
26 well as engineering and operational controls that LDEQ has evaluated as part of its review of  
27 WF3's LPDES permit. While some engineered and operational controls currently in place may  
28 reduce impingement (e.g., placement of the intake system 162 ft (49 m) from the shoreline with  
29 relatively lower biological productivity) or entrainment (e.g., traveling screens), the withdrawal  
30 rates associated with a once-through cooling system, the lack of a fish return system, and the  
31 approach and through-screen velocity may contribute to adverse impingement and entrainment  
32 effects.

33 Based on the above analysis, the NRC staff concludes that the impingement and entrainment  
34 impacts to aquatic resources in the Lower Mississippi River would be SMALL because such  
35 effects during the proposed license renewal period would not be detectable or would be so  
36 minor as to neither destabilize nor noticeably alter any important attribute of the aquatic  
37 community near WF3 based on the following:

- 38 • the location of the intake system within an area of relatively lower biological  
39 productivity for eggs, larvae, juvenile and adult fish and shellfish;
- 40 • the continued presence and relative abundance of the mostly commonly impinged  
41 species both before and after 20 to 30 years of operations;
- 42 • the very small portion of eggs and larvae that would be entrained given that WF3  
43 withdraws less than 0.5 percent of the average flow in the Mississippi River; and
- 44 • the traveling screens to exclude eggs and larvae.

45 The NRC staff acknowledges that the above analysis includes a large degree of uncertainty  
46 because of limited available studies and field data. Impingement estimates are extrapolated

## Environmental Consequences and Mitigating Actions

1 from studies conducted at an upriver facility (Waterford 1 and 2). As described in additional  
2 detail above, the analysis assumes that the same aquatic biota occur at both locations and that  
3 the differences in the intakes structures and operational procedures do not affect impingement  
4 rates. The NRC staff did not identify any entrainment studies at Waterford 1, 2, and WF3, and  
5 therefore conducted a qualitative analysis. In addition, the NRC staff did not identify any  
6 long-term aquatic population studies that included abundance measures for aquatic species.  
7 The NRC staff based its population change analysis on the best available information, which  
8 focused on presence and absence data of common species. While the available studies  
9 provided sufficient information for the NRC staff to evaluate impacts to the general aquatic  
10 community near WF3, the available studies did not allow the NRC staff to examine population  
11 changes for rare or less common species, which generally are more sensitive to environmental  
12 changes.

### 13 4.7.1.3 *Thermal Impacts on Aquatic Organisms*

14 In the GEIS (NRC 2013a), the NRC determined that thermal impacts on aquatic organisms are  
15 a Category 2 issue (see Table 4–7) for plants with once-through cooling systems, such as WF3,  
16 which requires a site-specific evaluation during each license renewal review.

17 The discharge of heated water into the Mississippi River can cause lethal and sublethal effects  
18 on resident fish, influence food web characteristics and structure, and increase susceptibility to  
19 diseases and parasites. The potential for harm associated with the discharge of heated water  
20 into streams, rivers, bays, and estuaries became known during the early 1960s. The number of  
21 new power generating facilities constructed with once-through cooling systems resulted in the  
22 definition of waste heat as a pollutant in the Federal Water Pollution Control Act of 1965  
23 (subsequently amended and commonly known as the CWA). Waste heat discharges can  
24 directly kill sensitive aquatic organisms if the duration and extent of the organism's exposure  
25 exceeds its upper thermal tolerance limit. Indirect effects associated with exposure to nonlethal  
26 temperatures can result in disruptions or changes to spawning behavior, accelerated or  
27 diminished growth rates of early life stages, or changes in growth or survival in response to  
28 changes to food web dynamics or predator/prey interactions. Indirect effects also can occur if  
29 the presence of a thermal plume restricts or blocks a species' migratory pattern during a critical  
30 life stage or results in avoidance behavior that affects species' viability or increases the  
31 likelihood of predation. In addition, thermal discharges can alter aquatic communities indirectly  
32 by increasing the incidence of disease or parasitism and changing the concentration of  
33 dissolved gas (NRC 2013a).

34 Consistent with the analyses in Section 4.7.1.2, this section's analysis uses a retrospective  
35 assessment of the present and past impacts to the aquatic ecosystem resulting from WF3  
36 operation in order to provide a prospective assessment for the future impacts over the proposed  
37 license renewal term (i.e., through 2044). The NRC staff used a modified WOE approach to  
38 evaluate thermal impacts on the aquatic resources in the Mississippi near WF3. The NRC staff  
39 examined three lines of evidence as follows:

LOE	Description
1	Regulatory and administrative controls on thermal effluents
2	Thermal plume models and analyses
3	Thermal exposure and tolerance for aquatic biota

1 LOE 1: Regulatory and Administrative Controls

2 The Louisiana Administrative Code (LAC) and the WF3 LPDES permit (LDEQ 2010) impose  
3 regulatory controls on WF3's thermal effluent that ensure impacts on the aquatic environment  
4 are reduced or mitigated.

5 Title 33, *Environmental Regulatory Code*, Section 1113, "Criteria," states that the biological and  
6 community structure and function in State waters shall be maintained, protected, and restored,  
7 except where not attainable and feasible as defined in LAC 33:IX.1109. Specifically, the LAC  
8 contains stipulations pertaining to effluent temperature as well as mixing zones and zones of  
9 initial dilution to protect aquatic biota. The following limitations and requirements included in  
10 Section 1113 pertain to effluent temperature and serve to protect aquatic biota from the effects  
11 of such effluents.

12           The maximum temperature rise shall not exceed 2.8 °C (5 °F) above ambient receiving  
13           water body temperatures.

14           Water temperature in rivers shall at no time exceed 32.2 °C (90 °F), except on a  
15           case-by-case basis to allow for the effects of natural conditions such as unusually hot  
16           and/or dry weather.

17 Section 1115 limits the mixing zone to 100 cfs (2.8 m<sup>3</sup>/s) or one-third of the flow, whichever is  
18 greater, for the Mississippi River (e.g., streams in which the lowest average discharge over a  
19 period of one week with a recurrence interval of 10 years ("7Q10 flow") is greater than 100 cfs  
20 (2.8 m<sup>3</sup>/s)).

21 WF3's initial LPDES permit limited the thermal effluent to 110 °F (43 °C) and 8.5×10<sup>9</sup> BTU/hour.  
22 In 1998, LDEQ raised the temperature and heat limits to 118 °F (48 °C) and 9.5×10<sup>9</sup> BTU/hour  
23 based on Entergy's request associated with a power uprate at WF3. The LDEQ (2010) issued  
24 Entergy's most recent LPDES permit in 2010, which retained the temperature and heat limits at  
25 118 °F (48 °C) and 9.5×10<sup>9</sup> BTU/hour. In issuing the LPDES permit, LDEQ (2010) determined  
26 that the temperature and heat limit would assure that the discharge meets all State water quality  
27 standards.

28 As described in Section 3.5.1.3, on March 30, 2015, Entergy submitted a permit renewal  
29 application for WF3 (Entergy 2015b). On April 15, 2015, LDEQ acknowledged receipt of WF3's  
30 LPDES permit renewal application and determined that the application is administratively  
31 complete (LDEQ 2015). Therefore, Entergy's LPDES 2010 permit for WF3 operations remains  
32 valid and in effect (i.e., administratively continued) in accordance with LAC 33:IX.2321. The  
33 NRC staff assumes that if the LPDES permit is renewed and issued, the renewed LPDES permit  
34 would assure that the discharge meets all State water quality standards and that LDEQ would  
35 consider any environmental changes in the river since 1998.

36 The NRC staff reviewed the results of recorded maximum daily discharge temperatures as  
37 reported in Entergy's discharge monitoring reports for the past 2.5 years (2014 through 2016)  
38 (Entergy 2016b). Based on the NRC's staff review and Entergy's responses to the NRC's RAIs,  
39 Entergy has received no notices of violation associated with LPDES permitted discharges  
40 during the 2014 through 2016 time period (see Section 3.5.1). In addition, the actual discharge  
41 temperature typically was several degrees lower than the thermal limit during this time period.  
42 From January 2014 through June 2016, the daily maximum discharge temperature was typically  
43 105 °F (40.6 °C) to 111 °F (43 °C) during the warmest months, May through October  
44 (Entergy 2016b).

## Environmental Consequences and Mitigating Actions

### 1 *LOE 1 Conclusion*

2 For LOE 1, the NRC staff examined regulatory and administrative controls currently in place as  
3 part of WF3's LPDES permit. WF3's thermal effluent is currently limited by WF3's  
4 administratively continued LPDES permit to a maximum temperature of 118 °F (47.8 °C). LDEQ  
5 set the LPDES temperature limits in accordance with LAC's maximum temperature rise and  
6 mixing zone limits. In the past 3 years, Entergy received no notices of violations. The NRC  
7 depends on the State to enforce the regulatory controls in place at WF3 and effectively ensure  
8 that any environmental effects to Mississippi River aquatic communities are not detectable or  
9 are so minor as to neither destabilize nor noticeably alter the community.

### 10 LOE 2: Thermal Plume Models and Analyses

11 LP&L initially modeled the predicted WF3 thermal plume in its 316(a) Demonstration Study  
12 (LP&L 1979) and in its ER for the WF3 Operating License (LP&L 1978). These analyses  
13 estimated the combined thermal plumes from four nearby plants, including Waterford 1, 2, and  
14 WF3, as well as Little Gypsy, which is located across the Mississippi River from WF3. The  
15 model predicted that thermal plume size changed depending on season and increased as flow  
16 decreased whereby the thermal plume was widest and deepest under the lowest flow  
17 conditions. Under extreme low-flow river conditions (2,800 m<sup>3</sup>/s (100,000 cfs)), LP&L  
18 determined that a thermal plume with at least a 2.8 °C (5 °F) increase in temperature would  
19 cover a maximum of 15 percent of a cross-sectional area of the river. Under typical low-flow  
20 river conditions (5,600 m<sup>3</sup>/s (200,000 cfs)), LP&L determined that a thermal plume with at least  
21 a 2.8 °C (5 °F) increase in temperature would cover about 6.6 percent of a cross-sectional area  
22 of the river.

23 LP&L (1978) also estimated the zone of passage (temperature increase less than 2 °C (3.6 °F))  
24 under average seasonal river conditions when all four plants would be operating. The zone of  
25 passage was largest in spring (96.6 percent) when flows generally were highest and smallest in  
26 winter (90 percent) when flow tends to decrease.

27 In its 316(a) Demonstration Study, LP&L (1978) concluded that the area near the WF3  
28 discharge structure has a low potential for thermal discharge impacts. This conclusion was  
29 primarily based on the following: (1) no unique shellfish, fish, or wildlife occur near WF3, and  
30 (2) the thermal plume would be limited to a small portion of the river's cross-sectional area,  
31 leaving sufficient space for aquatic biota to travel through a zone of passage or a brief period of  
32 exposure to higher temperatures.

33 The NRC staff (1981) conducted an independent analysis of the WF3 thermal plume, based on  
34 typical low-flow conditions (5,600 m<sup>3</sup>/s (200,000 cfs)). Low-flow conditions occur approximately  
35 once every 6.7 years and flows are higher 85 percent of the time (LP&L 1978). The NRC staff's  
36 (1981) analysis indicated that the thermal plume would be slightly deeper and more extended in  
37 length than LP&L predicted. Specifically, the NRC staff predicted that thermal plume with a  
38 2.8 °C (5 °F) increase would cover about 7.3 percent of the river's cross-sectional area (rather  
39 than 4.2 percent as LP&L estimated). Despite the slightly larger thermal plume estimate, the  
40 NRC (1981) concluded that the mixing zone was well below Louisiana's Water Quality Criteria  
41 and no adverse impact would be expected to aquatic biota due to the large zone of passage  
42 (with minimal to no increased temperatures), the relatively short exposure time to organisms  
43 that pass through the thermal plume (approximately 1 hour or less), the absence of rare species  
44 near WF3, and the relatively low biological richness near WF3.

45 In 1998, LDEQ evaluated the WF3 thermal plume based on Entergy's request to increase the  
46 temperature and heat discharge limits for a power uprate. Entergy's application requested that  
47 the LPDES permit discharge limits be increased from 110 °F (43 °C) and 8.5×10<sup>9</sup> BTU/hour to

1 118 °F (48 °C) and  $9.5 \times 10^9$  BTU/hour or removed entirely (LDEQ 1998). LDEQ (1998)  
2 estimated that under power uprate conditions, aquatic organisms would be able to avoid the  
3 thermal plume of four operating plants (Waterford 1, 2, WF3, and Little Gypsy) through a zone  
4 of passage that included 96 to 81 percent of the river's cross-sectional area, depending on  
5 operating and flow conditions.

6 As described above in LOE 1, Entergy submitted an application to renew its LPDES on  
7 March 30, 2015. The NRC staff assumes that if the LPDES permit is renewed and issued, the  
8 renewed LPDES permit would assure that the discharge meets all State water quality standards  
9 and that LDEQ would consider any environmental changes in the river since 1998, such as  
10 increases in temperature from climate change.

### 11 *LOE 2 Conclusion*

12 For LOE 2, the NRC staff examined available thermal plume analyses and models. All models  
13 showed that the thermal plume increased in size and temperature during low-flow conditions. In  
14 its most recent thermal analysis, LDEQ (1998) estimated that aquatic organisms would be able  
15 to avoid the thermal plume of four operating plants (Waterford 1, 2, WF3, and Little Gypsy)  
16 through a zone of passage that included 96 to 81 percent of the river's cross-sectional area,  
17 depending on operating and flow conditions. Based on this LOE, the NRC staff concludes that  
18 impacts would not be detectable or would be so minor as to neither destabilize nor noticeably  
19 alter the community due to the large zone of passage (with minimal to no increased  
20 temperatures) and the relatively short exposure time to organisms that pass through the thermal  
21 plume (approximately 1 hour or less).

### 22 LOE 3: Thermal Exposure and Tolerance for Aquatic Biota

23 Aquatic organisms may be able to avoid the thermal plume by swimming within the zone of  
24 passage. However, some organisms, especially those that float or are weak swimmers, may  
25 not be able to avoid the plume. The NRC staff (1981) estimated that travel time through the  
26 thermal plumes would be limited to approximately 1 hour. Potential thermal stress to biota that  
27 would not be able to swim away to avoid the thermal plume (e.g., plankton or benthic sessile  
28 invertebrates, as well as biota that could swim away to avoid the thermal plume (e.g., fish,  
29 shrimp, and crabs) are discussed below.

30 Plankton that drift or weakly swim, including fish eggs and larvae, could be exposed to portions  
31 of the thermal plume. The increase in temperature within the plume would be beyond optimum  
32 levels for most fish eggs and larvae during warmer months (LP&L 1978; NRC 1981). However,  
33 given the relatively large zone of passage, only a small portion of fish eggs and larvae would  
34 pass through the thermal plume and experience thermal stress. In addition, the exposure time  
35 would be relatively brief (approximately 1 hour), and would not necessarily result in mortality for  
36 all plankton, especially during colder seasons and higher flows, when the plume is cooler and  
37 smaller. In addition, the NRC staff (1981) did not predict adverse impacts to plankton in part  
38 because the habitat near WF3 is not ideal for eggs and larvae and preoperational studies found  
39 low density of eggs and larvae near WF3.

40 Benthic sessile invertebrates are not mobile and, therefore, would be unable to move in order to  
41 avoid the thermal plume. LP&L (1979) determined that the thermal plume with a 3.6 °F (2 °C)  
42 isotherm would not reach the river bottom during average seasonal flow or typical low-flow  
43 conditions. Portions of the plume may, however, reach submerged river banks where sessile  
44 invertebrates can attach to woody or hard structures. In addition, the plume may reach the river  
45 bed bottom during extreme low-flow conditions. If sessile organisms are exposed to the thermal  
46 plume during warmer months (May through October), such biota may experience thermal stress  
47 such as reduced fecundity, increased susceptibility to diseases, and mortality. However,

## Environmental Consequences and Mitigating Actions

1 impacts are not expected to noticeably alter sessile invertebrate communities near WF3,  
2 because of the intermittent occurrence of thermal plumes that would reach sessile communities,  
3 because the plume would not exceed thermal tolerance levels during cooler months, and  
4 because few sessile invertebrates occur near WF3 due to the poor habitat conditions (fast water  
5 flow, shifting river bed, and low density of food sources).

6 Mobile organisms (e.g., fish and shrimp) may be able to swim away to avoid the thermal plume.  
7 The majority of fish near WF3 are warm-water fish that are seasonally adapted to relatively high  
8 temperatures and, therefore, have relatively high levels of thermal tolerances. For example, the  
9 thermal tolerance for juvenile gizzard shad, striped mullet, catfish, and freshwater drum is 36 °C  
10 (96 °F) or greater (NRC 1981). River shrimp, which is the most commonly impinged species,  
11 has an upper temperature tolerance of about 30 °C (86 °F) in a 24-hour period. From  
12 January 2014 through June 2016, the thermal plume was generally below 30 °C (86 °F) during  
13 the months of November through April, and thermal stress during these months is not expected  
14 (Entergy 2016b). From May through October, some fish and shrimp would experience thermal  
15 stress if river temperatures exceed 36 °C (96 °F) and biota are unable to avoid the plume. This  
16 condition would rarely occur given that LDEQ (1998) estimated that the river surface  
17 temperature would only exceed 36 °C (96 °F) 2.5 percent of the time. In addition, travel time  
18 through the plume would be 1 hour or less, depending on the swimming speeds of the  
19 organisms. Therefore, fish and shrimp would rarely be exposed to thermally stressful conditions  
20 due to the large available zone of passage, the infrequent occurrence of thermally stressful  
21 thermal plume temperatures, and the small amount of time (less than 1 hour) that biota would  
22 spend swimming through the thermal plume.

### 23 *LOE 3 Conclusion*

24 For LOE 3, the NRC reviewed the time and frequency that biota would be exposed to the  
25 thermal plume and evaluated the ecological impacts based on thermal thresholds and potential  
26 avoidance behaviors. Plankton would likely be thermally stressed when exposed to the thermal  
27 plume. However, the impacts would be minor given the large zone of passage, the small  
28 portion of plankton that would be exposed to the thermal plume, and the short exposure time  
29 while drifting through the plume (1 hour or less). Although benthic sessile organisms would not  
30 be able to move to avoid or travel through the thermal plume, impacts would be minimal  
31 because the thermal plume would rarely reach the river bed floor and because few sessile  
32 invertebrates occur near WF3 due to the poor habitat conditions. Fish and shrimp populations  
33 may experience minor exposures to the thermal plume, but impacts are not likely to noticeably  
34 alter these communities because biota could avoid the plume and swim through the large zone  
35 of passage, the swim time through the thermal plume would be short (1 hour or less), the  
36 thermal plume would not exceed thermal tolerance during cooler portions of the year, and the  
37 plume would only occasionally exceed thermal tolerances during limited periods of time during  
38 part of the year (May through October).

### 39 Summary of Thermal Impacts Conclusion

40 In LOE 1, the NRC staff reviewed State regulations and specific temperature limits within  
41 Entergy's most recent LPDES permit. WF3's thermal effluent is currently limited to 118 °F  
42 (47.8 °C), which LDEQ set to ensure that the Mississippi River would meet all State Water  
43 Quality Standards.

44 In LOE 2, the NRC reviewed various thermal models and analyses to determine the extent and  
45 intensity of the thermal plume under a variety of operational and environmental conditions. All  
46 models showed that the thermal plume increased in size and temperature during low-flow  
47 conditions. In its most recent thermal analysis, LDEQ (1998) estimated that aquatic organisms  
48 would be able to avoid the thermal plume of four operating plants (Waterford 1 and 2, WF3, and

1 Little Gypsy) through a zone of passage that includes 96 to 81 percent of the river cross section  
2 depending on operating and flow conditions.

3 For LOE 3, the NRC reviewed the time and frequency that biota would be exposed to the  
4 thermal plume and evaluated the ecological impacts based on thermal thresholds and potential  
5 avoidance behaviors. The NRC staff determined that impacts to aquatic biota would be minor  
6 based on the following:

- 7 • a large zone of passage would be available for mobile biota to travel through;
- 8 • a small portion of drifting or weakly swimming biota (e.g., fish eggs and larvae) would  
9 be exposed to the thermal plume;
- 10 • exposure times while moving through the thermal plume would be limited to 1 hour or  
11 less;
- 12 • the thermal plume would not exceed thermal tolerances for many biota, especially  
13 during cooler portions of the year;
- 14 • the thermal plume would rarely reach sessile invertebrates on the river bed floor; and
- 15 • few eggs, larvae, and sessile invertebrates occur near WF3 due to the poor habitat  
16 conditions.

17 Based on the above analysis, the NRC staff concludes that the thermal impacts to aquatic  
18 resources in the Lower Mississippi River would be SMALL because such effects during the  
19 proposed license renewal period would not be detectable or would be so minor that they would  
20 neither destabilize nor noticeably alter any important attribute of the aquatic community near  
21 WF3.

#### 22 4.7.1.4 Mitigation

23 ENSR (2005b) evaluated various technologies and operational measures to reduce  
24 impingement and entrainment at WF3 in a 316(b) Proposal for Information Collection (PIC) that  
25 Entergy submitted to LDEQ. The PIC (ENSR 2005b) considers technological changes,  
26 including modifications to the traveling screens (dual flow screens, Ristroph screens, fine mesh  
27 traveling screens, and angled and modular inclined screens), fixed screens (wedgewire  
28 screens, perforated pipes, barrier nets, an aquatic filter barrier system, and porous dams/leaky  
29 dikes), a submerged offshore intake structure, and fish diversion and avoidance measures  
30 (louvers and bar racks, velocity cap, strobe lights, acoustic deterrent, bubbles, and chains).  
31 ENSR (2005b) also considered operational measures in the PIC, such as more frequent rotation  
32 of the traveling water screens and flow reduction (variable speed pumps, evaporative cooling  
33 towers, and dry cooling).

34 The NRC staff notes that Entergy's PIC was written before publication of the final  
35 2014 Phase II Rule (79 FR 48300). In 2015, Entergy submitted an application to renew its  
36 LPDES permit (Entergy 2016b). LDEQ has not yet renewed the LPDES permit, and therefore,  
37 has not yet evaluated whether and what mitigation measures would be required for compliance  
38 with the current Phase II Rule. Entergy (2016b) stated that technological and operational  
39 measures evaluated within the 316(b) PIC would be the mostly like type of mitigation measures  
40 imposed by LDEQ if it determined that additional modifications are necessary to achieve the  
41 BTA standards described in the final 2014 Phase II Rule.

1 **4.7.2 No-Action Alternative**

2 If WF3 were to cease operating, impacts to aquatic ecology would decrease or stop following  
3 reactor shutdown. Some withdrawal of water from the Mississippi River would continue during  
4 the shutdown period as the fuel is cooled, although the amount of water withdrawn would  
5 decrease over time. The reduced demand for cooling water would substantially decrease the  
6 effects of impingement, entrainment, and thermal effluents. These effects likely would stop  
7 following the removal of fuel from the reactor core and shutdown of the spent fuel pool. Given  
8 the small area of the thermal plume in the Mississippi River under normal operating conditions  
9 (0.48 percent), effects from cold shock are unlikely.

10 Thus, the NRC staff concludes that the impacts of the no-action alternative on aquatic resources  
11 during the proposed license renewal term would be SMALL.

12 **4.7.3 New Nuclear Alternative**

13 Construction of a new nuclear alternative would occur at the Entergy Louisiana, LLC property,  
14 which currently includes Waterford 1, 2, 4, and WF3. Entergy would likely use existing onsite  
15 infrastructure, such as transmission lines, the intake structure, and the discharge structure,  
16 although some modifications may be necessary (Entergy 2016a). Construction activities for the  
17 new unit and mechanical-draft cooling towers could degrade water quality of nearby  
18 waterbodies, such as ephemeral drainage ditches or the Mississippi River through erosion and  
19 sedimentation; result in loss of habitat through wetland filling; or result in direct mortality of  
20 aquatic organisms from dredging or other in-water work. Because of the relatively short-term  
21 nature of construction activities, degradation of habitat quality likely would be relatively localized  
22 and temporary. Loss of habitat could be minimized by siting the plant far from onsite wetlands  
23 and other onsite aquatic resources, as well as using the existing intake and discharge  
24 structures, transmission lines, roads, parking areas, and other infrastructure. Appropriate  
25 permits would ensure that water quality impacts would be addressed through mitigation or  
26 BMPs, as stipulated in the permits. The USACE and LDEQ would oversee applicable  
27 permitting, including a CWA Section 404 permit, Section 401 certification, and Section 402(p)  
28 National Pollutant Discharge Elimination System (NPDES) general stormwater permit. Because  
29 of the short-term nature of the construction activities, use of existing infrastructure, and required  
30 BMPs, the hydrological alterations to aquatic habitats and direct impacts to aquatic resources  
31 would be minimal.

32 Operational impacts would include those described in the GEIS (NRC 2013a) for a power plant  
33 using cooling towers. Therefore impingement, entrainment, thermal effects, and other impacts  
34 described for aquatic resources also would be SMALL. Water use conflicts with aquatic  
35 resources would not be likely given that the new unit would withdraw less than 0.5 percent of  
36 the flow in the Mississippi River.

37 The NRC staff concludes that the impacts to aquatic resources from construction and operation  
38 of a new nuclear alternative would be SMALL.

39 **4.7.4 SCPC Alternative**

40 Construction of an SCPC alternative would occur at another existing power plant site within the  
41 SERC region of Louisiana. The GEIS (NRC 2013a) indicates that the impacts of new power  
42 plant construction on ecological resources would be qualitatively similar to those described  
43 above for construction of a new nuclear plant. Thus, those impacts discussed under the new  
44 nuclear alternative would apply during the construction phase. Such construction impacts would  
45 be SMALL if the new unit is built in a manner and location that avoids aquatic habitats and

1 minimizes habitat degradation through the use of existing infrastructure and implementation of  
2 BMPs. However, construction impacts could be MODERATE if the new unit or its associated  
3 infrastructure (such as new intake and discharge structures) result in direct mortality of aquatic  
4 organisms or noticeably degrade aquatic habitats.

5 Operation of the SCPC alternative would require less cooling water than WF3 because the plant  
6 would operate with a closed-cycle system. Accordingly, impingement, entrainment, and thermal  
7 effects on aquatic resources likely would be smaller than for continued operation of WF3,  
8 although the exact magnitude would depend upon the water body and the specific aquatic  
9 communities present. Chemical discharges from the cooling system would be similar to those  
10 at WF3. Operation would require coal deliveries, cleaning, and storage, which would require  
11 periodic dredging (if coal is delivered by barge); create dust, sedimentation, and turbidity; and  
12 introduce trace elements and minerals into the water. Air emissions from the SCPC units would  
13 include small amounts of sulfur dioxide, particulates, and mercury that would settle on water  
14 bodies or be introduced into the water from soil erosion. If the SCPC plant were located on the  
15 same water body (the Mississippi River) in the vicinity of the WF3 site, overall operational  
16 impacts would be less than for the continued operation of WF3 because of the reduced  
17 impingement, entrainment, and thermal effects. However, without knowing the location of the  
18 SCPC plant, the associated water body, aquatic species, and their interactions within the  
19 ecosystem, the NRC staff cannot assume that overall impacts of operation of an SCPC plant  
20 would be less than those for the continued operation of WF3. Thus, impacts could range from  
21 SMALL to MODERATE.

22 The NRC staff concludes that the impacts to aquatic resources from construction of an SCPC  
23 plant would be SMALL and the impacts from operation would be SMALL to MODERATE.

#### 24 **4.7.5 NGCC Alternative**

25 Construction of an NGCC alternative would occur at the Entergy Louisiana, LLC site. The GEIS  
26 (NRC 2013a) indicates that the impacts of new power plant construction on ecological  
27 resources would be qualitatively similar. Thus, those impacts discussed under the new nuclear  
28 alternative would apply during the construction phase. Construction of new pipelines, if  
29 necessary, could impact previously undisturbed habitats. This impact would vary depending on  
30 the location of the plant and would be more likely to impact terrestrial resources than aquatic  
31 resources. Because the NGCC alternative would be built at the Entergy Louisiana, LLC site,  
32 new pipelines could be collocated in existing corridors and existing infrastructure could be used  
33 to reduce impacts. Overall, construction impacts would be SMALL.

34 Operation of the NGCC alternative cooling system would be qualitatively similar to the SCPC  
35 alternative but would result in smaller impacts because the NGCC alternative would consume  
36 about half as much cooling water. Air emissions from the NGCC units would include nitrogen  
37 oxide, carbon dioxide, and particulates that would settle on water bodies or be introduced into  
38 the water from soil erosion. Given that the NGCC plant would be located on the same water  
39 body (the Mississippi River) as WF3, overall operational impacts would be less than for the  
40 continued operation of WF3, because of the reduced impingement, entrainment, and thermal  
41 effects, which were determined in Section 4.7.1.2 to be SMALL for aquatic resources in the  
42 Lower Mississippi River.

43 The NRC staff concludes that the impacts to aquatic resources from construction and operation  
44 of an NGCC plant would be SMALL.

1 **4.7.6 Combination Alternative (NGCC, Biomass, and DSM)**

2 The NGCC and biomass portion of this alternative would be located at the Entergy Louisiana,  
3 LLC site. Construction impacts would be qualitatively similar to those discussed for the NGCC  
4 alternative but would require slightly more land (60 ac (24 ha) for the NGCC alternative and  
5 90 ac (36 ha) for the combination alternative). Entergy likely would be able to construct both  
6 facilities on site while avoiding sensitive aquatic habitats, given that a sufficient amount of  
7 disturbed land is available on the site to avoid construction within wetlands (Entergy 2016a).  
8 Degradation of habitat quality from construction activities likely would be relatively localized and  
9 temporary because of the relatively short-term nature of construction activities and required  
10 BMPs.

11 Operation of the NGCC and biomass portion of the combination alternative would withdraw  
12 slightly more water than the NGCC alternative (8.3 mgd (32,000 m<sup>3</sup>/d) versus 9.5 mgd  
13 (36,000 m<sup>3</sup>/d)). Impacts to aquatic resources from water withdrawal and discharge likely would  
14 not noticeably impact important attributes of aquatic resources given that the intake and  
15 discharge structures are located in an area of low biological richness, water withdrawal would  
16 be less than 1 percent of the flow of the Mississippi River, and the State would limit the  
17 temperature and chemical composition of discharged water through an LPDES permit.

18 The DSM portions of the alternative, which account for approximately 37 percent of the  
19 alternative's power generation, would not require any new construction nor require additional  
20 cooling or consumptive water use during operation. Thus, impacts to aquatic resources from  
21 this portion of the alternative would be negligible.

22 Based on the minimal impacts to aquatic resources, the NRC staff concludes that the impacts  
23 on aquatic resources from the combination alternative would be SMALL.

24 **4.8 Special Status Species and Habitats**

25 This section describes the potential impacts of the proposed action (license renewal) and  
26 alternatives to the proposed action on special status species and habitats.

27 **4.8.1 Proposed Action**

28 Section 3.8 of this SEIS describes the special status species and habitats that have the  
29 potential to be affected by the proposed action. The discussion of species and habitats  
30 protected under the Endangered Species Act of 1973 (16 U.S.C. §1531) (ESA) in Section 3.8  
31 includes a description of the action area as defined by the ESA section 7 regulations at  
32 50 CFR 402.02. The action area encompasses all areas that would be directly or indirectly  
33 affected by the proposed WF3 license renewal.

34 Table 4–10 lists the one Category 2 issue related to special status species and habitats  
35 identified in the GEIS (NRC 2013a). Appendix C.1 contains information on the NRC staff's ESA  
36 section 7 consultation with the U.S. Fish and Wildlife Service (FWS) and National Marine  
37 Fisheries Service (NMFS) for the proposed action.

1

**Table 4–10. Special Status Species and Habitat Issues**

Issue	GEIS Section	Category
Threatened, endangered, and protected species, critical habitat and essential fish habitat	4.6.1.3	2

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

2 **4.8.1.1 Species and Habitats under the U.S. Fish and Wildlife Service’s Jurisdiction**

3 Section 3.8 considers whether three Federally listed species under the FWS’s jurisdiction occur  
 4 in the action area based on each species’ habitat requirements, life history, occurrence records,  
 5 and other available information. In that section, the NRC staff concludes that the only listed  
 6 species that may occur in the action area is the pallid sturgeon (*Scaphirhynchus albus*). The  
 7 remaining two species, the Atlantic sturgeon gulf subspecies (*Acipenser oxyrinchus desotoi*)  
 8 and West Indian manatee (*Trichechus manatus*), are unlikely to occur in the action area based  
 9 on habitat requirements or available surveys and studies of the WF3 action area. Accordingly,  
 10 the NRC staff concludes that the proposed action would have no effect on the Atlantic sturgeon  
 11 gulf subspecies or West Indian manatee as identified in Table 4–11 below. The NRC staff also  
 12 concludes in Section 3.8 that no proposed species, candidate species, or critical habitat  
 13 (proposed or designated) occurs in the action area. Therefore, the proposed action would have  
 14 no effect on proposed species, candidate species, or critical habitat. The NRC staff separately  
 15 analyzes the potential impacts of the proposed license renewal on the pallid sturgeon below.

16 **Table 4–11. Effect Determinations for Federally Listed Species under FWS’s Jurisdiction**

Species	Common Name	Federal Status <sup>(a)</sup>	ESA Effect Determination
<i>Acipenser oxyrinchus desotoi</i>	Atlantic sturgeon gulf subspecies	FT	no effect
<i>Scaphirhynchus albus</i>	pallid sturgeon	FE	not likely to adversely affect
<i>Trichechus manatus</i>	West Indian manatee	FE	no effect

<sup>(a)</sup> FE = Federally endangered under the Endangered Species Act of 1973, as amended (ESA); FT = Federally threatened under the ESA

17 **Pallid Sturgeon (*Scaphirhynchus albus*)**

18 In Section 3.8, the NRC staff concludes that the pallid sturgeon may occur in the action area  
 19 based on FWS data from the Lower Mississippi River, data from studies conducted at other  
 20 Lower Mississippi River energy generating facilities, and the results of a 2008 Endangered  
 21 Species Act of 1973, as amended (ESA) (16 U.S.C. 1531 et seq.), section 7 consultation  
 22 between the USACE and the FWS related to an emergency opening on the Bonnet Carre  
 23 Spillway.

24 As stated in Chapter 1, the proposed action would allow WF3 to continue to operate  
 25 through 2044. During the proposed license renewal term, pallid sturgeon in the action area  
 26 could experience the following effects: (1) entrainment, (2) impingement, (3) thermal effects,  
 27 (4) exposure to radionuclides and other contaminants, and (5) reduction in available prey due to

## Environmental Consequences and Mitigating Actions

1 impingement and entrainment or thermal impacts to prey species. These impacts are described  
2 below in terms of direct, indirect, interrelated, and interdependent effects.

### 3 *Direct Effects*

#### 4 Entrainment

5 Entrainment is the incorporation of all life stages of fish and shellfish with intake water flow  
6 entering and passing through a cooling-water intake structure and into a circulating water intake  
7 structure (40 CFR 125.83). Section 4.7.1.2 addresses the effects of entrainment and  
8 impingement collectively for all Mississippi River aquatic organisms. In that section, the NRC  
9 staff concludes that the impacts of impingement and entrainment on aquatic resources would be  
10 SMALL over the course of the proposed license renewal term.

11 Pallid sturgeon are unlikely to be subject to entrainment at WF3. Organisms susceptible to  
12 entrainment generally include ichthyoplankton (fish eggs and larvae), larval stages of shellfish  
13 and other macroinvertebrates, zooplankton, and phytoplankton. Because pallid sturgeon are  
14 not currently known to spawn in the Mississippi River main channel (FWS and NMFS 2009),  
15 eggs and larvae would not occur in the action area. Additionally, pallid sturgeon eggs are  
16 demersal and adhesive, and therefore would not be expected to drift downstream from any  
17 upstream spawning grounds. ENSR (2007) also has found that ichthyoplankton densities for all  
18 species in the region of the Mississippi River in which WF3 is located are very low. For these  
19 reasons, the NRC staff does not expect pallid sturgeon eggs and larvae to be entrained into the  
20 WF3 cooling-water intake system. Therefore, entrainment would not affect pallid sturgeon  
21 during the proposed license renewal term.

#### 22 Impingement

23 Impingement is the entrapment of all life stages of fish and shellfish on the outer part of an  
24 intake structure or against a screening device during periods of water withdrawal  
25 (40 CFR 125.83). Because juvenile and adult pallid sturgeon have been collected in the Lower  
26 Mississippi River, it is possible that individuals are susceptible to impingement at WF3. To  
27 evaluate this impact, the NRC staff considered pallid sturgeon swimming speeds, historical  
28 impingement records at other Lower Mississippi River energy generating facilities, and past  
29 FWS reviews associated with Entergy's request for the FWS to review its license renewal  
30 application (LRA) and with LDEQ's WF3 LPDES permit renewal.

31 An important factor that influences a species' ability to avoid impingement into a cooling-water  
32 intake structure is its swimming speed. In a swimming stamina test of hatchery-reared juvenile  
33 pallid sturgeon at Gavins Point National Fish Hatchery in South Dakota, Adams et al. (1999)  
34 observed maximum sustained swimming speed with no fatigue after 480 minutes of 25 cm/sec  
35 (9.8 in./sec) for juveniles of 17.0 to 20.5 cm (6.7 to 8.1 in.) fork length (FL) and 10 cm/sec  
36 (3.9 in./sec) for juveniles of 13.0 to 16.8 cm (5.1 to 6.6 in.) FL. Burst speeds, which are the  
37 highest speeds attained by fish and are used to capture prey, avoid predators, or negotiate  
38 short-term fast currents, were measured for the two groups at 55 to 70 and 40 to 70 cm/sec  
39 (22 to 28 and 16 to 28 in./sec), respectively. Notably, juvenile pallid sturgeon in this study  
40 demonstrated a higher capacity for burst swimming than had been demonstrated in studies of  
41 other sturgeon species. Because of the various swimming behaviors observed during the study,  
42 Adams et al. (1999) concluded that observed swimming speeds do not solely represent  
43 steady-state swimming speeds. Similar to other lotic, benthic fish, pallid sturgeon juveniles  
44 were able to use their pectoral fins and overall body morphology to maintain station against  
45 velocity without swimming (Adams et al. 1999).

46 Impingement of healthy juvenile pallid sturgeon can reasonably be assumed to occur in  
47 situations where a facility's intake velocity is higher than juvenile burst swimming speeds. Burst

1 swimming speeds are an appropriate comparison because juveniles likely would navigate the  
 2 draw of an intake current similar to short-term fast currents that individuals would encounter  
 3 while migrating through long stretches of a river. Thus, juvenile pallid sturgeon are most likely  
 4 to be susceptible to impingement at facilities with intake velocities greater than 70 cm/sec  
 5 (28 in./sec), and smaller or weaker individuals also would be susceptible to impingement at  
 6 facilities with intake velocities as low as 40 cm/sec (22 in./sec).

7 WF3's approach velocity ranges from 1.09 to 1.78 fps (33 to 55 cm/sec; 13.08 to 21.36 in./sec).  
 8 With these approach velocities, juveniles of greater than 17 cm (6.7 in.) FL would likely be able  
 9 to avoid impingement into the WF3 cooling system based on observed burst speeds in Adams  
 10 et al.'s (1999) study. Smaller juveniles of less than 16.8 cm (6.6 in.) FL, however, may not be  
 11 able to avoid the intake when the intake velocity is greater than or equal to 1.3 fps (40 cm/sec;  
 12 16 in./sec). These individuals could be susceptible to impingement. Additionally, individuals  
 13 within the larger FL range could exhibit slower burst swimming speeds if weakened, injured, or  
 14 diseased, which could increase susceptibility to impingement.

15 No impingement studies have been conducted at WF3 to verify the above assumptions  
 16 regarding juvenile susceptibility to impingement. Therefore, the NRC staff reviewed  
 17 impingement data from other Lower Mississippi River energy generating facilities, including data  
 18 from Waterford 1 and 2, which lies just upriver of WF3.

19 Like WF3, Waterford 1 and 2 have an offshore intake structure that withdraws water from the  
 20 main stem of the Mississippi River within fast flowing water that has relatively low densities of  
 21 ichthyoplankton (ENSR 2007). Waterford 1 and 2's approach velocity is slightly lower than WF3  
 22 and varies from 0.95 to 1.5 fps (29.0 to 45.7 cm/sec; 11.4 to 18 in./sec). Therefore, based on  
 23 the above discussion of swimming speeds, juveniles of less than 16.8 cm (6.6 in.) FL could be  
 24 occasionally impinged when the facility is drawing water at the upper end of the velocity range  
 25 (1.3 to 1.5 fps; 40 to 45.7 cm/sec; 16 to 18 in./sec). Larger but weakened, injured, or diseased  
 26 juveniles also could be impinged. To validate these assumptions, the NRC staff reviewed two  
 27 Waterford 1 and 2 impingement studies, which were conducted in 1976–1977 and 2006–2007.

28 From February 1976 through January 1977, Espey, Huston & Associates collected 24 biweekly  
 29 impingement samples at set 24-hour intervals in the sluiceway of the Waterford 1 and 2 intake  
 30 structure with baskets that collected biota and debris following travel screen washing and  
 31 clearing. Section 4.7.1.2 describes the study's methods in detail. Out of 22,123 individuals of  
 32 46 fish and 3 invertebrate species, Espey, Huston & Associates (1977) collected 2 juvenile  
 33 pallid sturgeon. The first juvenile was collected during the May 18–19, 1976, sample period.  
 34 The individual was 42 cm (16.5 in.) standard length (SL) and 211.8 g (0.47 lbs). The second  
 35 was collected during the July 27–28, 1976, sample period. The individual was 28.3 cm  
 36 (11.1 in.) SL and 66.4 g (0.15 lbs). While a clear comparison cannot be made because Espey,  
 37 Huston & Associates (1978) recorded SL and not FL, the SLs indicate that these individuals  
 38 were likely of FLs greater than 17 cm (6.7 in.). However, the study qualitatively noted that  
 39 physical injury to ray-finned fish, including shredding and abrading of the soft rays, was  
 40 common, and that spines were sometimes broken. Thus, the two collected juveniles may have  
 41 been weakened or injured, which may have accounted for their impingement despite their  
 42 larger size.

43 Beginning in 2006, ENSR (2007) conducted a similar impingement study at Waterford 1 and 2.  
 44 ENSR collected biweekly samples within set 24-hour collection periods from September 2006  
 45 through August 2007. As with the previous study, biological samples were collected in the  
 46 sluiceway with baskets. ENSR collected 18,608 individuals of 32 fish and shellfish species  
 47 during the study. ENSR (2007) did not collect any pallid sturgeon during the study.

## Environmental Consequences and Mitigating Actions

1 In addition to data from Waterford 1 and 2, Espey, Huston & Associates conducted impingement  
2 and entrainment sampling at three of the five units at Willow Glenn Power Station from  
3 January 1975 through January 1976. This facility lies approximately 71 RM (114 Rkm)  
4 upstream of WF3 at RM 201 (Rkm 323), and like WF3, it has an offshore intake structure in the  
5 main stem of the Mississippi River within fast flowing water with low densities of  
6 ichthyoplankton. ENSR (2005) summarizes the Willow Glen study and reports that  
7 impingement rates during the study were relatively low with 126,000 organisms per year  
8 estimated to be impinged with all five units in operation. One juvenile pallid sturgeon was  
9 impinged over the course of the study. Because the original study was unavailable for NRC  
10 staff review, the intake velocities and the size of the impinged juvenile are unknown.

11 Unlike juveniles, adult pallid sturgeon are expected to have sufficient swimming ability to avoid  
12 impingement. The NRC staff did not identify any impingement studies on the Lower Mississippi  
13 River that reported collections of adult pallid sturgeon. Accordingly, the NRC staff believes that  
14 adult pallid sturgeon are unlikely to be susceptible to impingement at WF3.

15 In 2015 and 2016, the FWS reviewed the potential impacts of continued operation of the WF3  
16 cooling-water intake system upon two occasions: following Entergy's request for comments on  
17 the WF3 LRA and during LDEQ's review of Entergy's LPDES permit renewal application.

18 On May 28, 2015, Entergy (2016a) requested the FWS's review of the WF3 LRA. The FWS  
19 replied on June 26, 2015, and stated that the project had been reviewed for effects to Federally  
20 listed species under its jurisdiction and currently protected by the ESA, and that the proposed  
21 license renewal would have no effect on those species (Entergy 2016a). On March 1, 2016, the  
22 LDEQ submitted a copy of Entergy's LPDES permit renewal application to the FWS for its  
23 review in accordance with the biological opinion associated with the final CWA 316(b) Rule for  
24 Existing Facilities (LDEQ 2016). The FWS replied on March 31, 2016, stating that the renewal  
25 of the permit is not likely to adversely affect resources under its jurisdiction, including the pallid  
26 sturgeon, and that the FWS's finding fulfilled the requirements under section 7(a)(2) of the ESA.  
27 The FWS's responses to Entergy and to LDEQ indicate that the FWS does not expect continued  
28 operation of WF3 to result in impingement of pallid sturgeon individuals (FWS 2016).

29 Based on the above review of pallid sturgeon swimming speeds, historical impingement records  
30 at other Lower Mississippi River energy generating facilities, and past FWS reviews of effects to  
31 Federally listed species associated with Entergy's request for the FWS to review its LRA and  
32 with LDEQ's WF3 LPDES permit renewal, the NRC staff concludes that the risk of pallid  
33 sturgeon impingement during the license renewal term is a discountable impact because it is  
34 extremely unlikely to occur.

### 35 Thermal Effects

36 North American sturgeon species generally prefer cooler waters and most prefer and perform  
37 optimally at water temperatures of 25 °C (77 °F) or less (Blevins 2011). Activity and growth of  
38 young sturgeon generally increases with temperature until an optimal temperature, usually  
39 below 25 °C (77 °F), is reached (Blevins 2011). Eggs and larval stages likely are more sensitive  
40 to high temperatures than juveniles and adults, which can find refuge in microhabitats with  
41 cooler water. In a study of 1,000 juvenile shovelnose sturgeon in the upper Missouri River,  
42 Kapperman et al. (2009) found that temperature tolerances range from 10.0 to 30.0 °C (50  
43 to 86 °F) with optimal growth occurring at 22.0 °C (71.6 °F). However, available literature  
44 suggests that pallid sturgeon likely tolerate higher water temperatures than shovelnose and  
45 other sturgeon species. For instance, data from a small bioenergetics model study of pallid  
46 sturgeon on the Lower Missouri River indicate that 25 to 28 °C (77 to 82.4 °F) is the optimal  
47 temperature range for feeding and growth (Chipps et al. 2010). Temperatures from 30 to 33 °C  
48 (86 to 91.4 °F) appear to be stressful, while temperatures above 33 °C (91.4 °F) begin to result

1 in death (Chipps et al. 2010). At 33 °C (91.4 °F), 4-day survival of pallid sturgeon individuals  
2 was 83 percent, whereas at 35 °C (95 °F), all fish lost equilibrium within 30 seconds, and all  
3 individuals died within 2 hours (Chipps et al. 2010).

4 Within the action area, Mississippi River surface water temperatures fluctuate seasonally with  
5 the lowest temperatures typically occurring in January and the highest temperatures typically  
6 occurring in August. In a 2006–2007 impingement study conducted at Waterford 1 and 2,  
7 ENSR (2007) recorded temperatures between 6.4 °C (43.5 °F) and 32.7 °C (90.9 °F). The WF3  
8 thermal plume also varies with season. Generally, the WF3 thermal plume increases as flow  
9 decreases, such that the thermal plume is largest under low-flow conditions. The NRC staff  
10 (1981) conducted an independent analysis of the WF3 thermal plume based on typical low-flow  
11 conditions (5,600 m<sup>3</sup>/sec (200,000 cfs)), which occur approximately once every 6.7 years.  
12 The NRC staff (1981) found that the 2.8 °C (5 °F) thermal plume isotherm would cover about  
13 7.3 percent of the river's cross-section area. Since that time, the LDEQ has increased the  
14 allowable effluent discharge temperature limit in the WF3 LPDES permit from 110 °F (43 °C) to  
15 118 °F (48 °C). Under the 118 °F (48 °C) limit, the LDEQ estimates a zone of passage of  
16 81 percent of the cross-sectional river area assuming conservative assumptions, such as  
17 extreme low flow and all four plants (WF3, Waterford 1 and 2, and Little Gypsy Power Plant)  
18 operating. Section 4.7.1.3 describes the WF3 thermal plume and associated LPDES permit  
19 limitations on thermal effluent in more detail.

20 In Section 4.7.1.3, the NRC staff concludes that although fish populations may experience minor  
21 exposures to the thermal plume, impacts are not likely to noticeably alter these communities  
22 because (1) biota could avoid the plume and swim through the large zone of passage, (2) swim  
23 time through the thermal plume would be short (1 hour or less), (3) the thermal plume would not  
24 exceed thermal tolerance during cooler portions of the year, and (4) the plume would only  
25 exceed thermal tolerances during limited periods of time during part of the year (May through  
26 October). Similarly, pallid sturgeon juveniles and adults are not expected to be measurably  
27 affected by the WF3 thermal plume for the reasons listed above. While individuals may exhibit  
28 altered behavior to avoid the thermal plume, effects are unlikely to reach the scale of a take  
29 and, therefore, would be insignificant. Pallid sturgeon eggs and larvae do not occur in the  
30 action area, and therefore, would be unaffected. Additionally, the FWS (2016) determined that  
31 renewal of the WF3 LPDES permit, which authorizes heated discharge and sets corresponding  
32 temperature limitations, is not likely to adversely affect pallid sturgeon. Accordingly, the NRC  
33 staff concludes that thermal effects on pallid sturgeon during the proposed license renewal term  
34 represent an insignificant impact.

#### 35 Exposure to Radionuclides and Other Contaminants

36 The NRC staff (2013a) determined in the GEIS that exposure to radionuclides would be of  
37 SMALL significance for aquatic resources because exposure would be well below EPA  
38 guidelines developed to protect aquatic biota. The GEIS also concludes that the effects of  
39 nonradiological contaminants on aquatic organisms would be SMALL because BMPs and  
40 discharge limitations contained in applicable State-issued NPDES permits would minimize the  
41 potential for impacts to aquatic resources. In Section 4.7 of this SEIS, the NRC staff did not  
42 identify any new and significant information that would call into question these conclusions'  
43 applicability to the proposed WF3 license renewal. Therefore, exposure of aquatic organisms to  
44 radionuclides and nonradiological contaminants during the license renewal term would not be  
45 detectable or would be so minor as to neither destabilize nor noticeably alter any important  
46 attribute of the aquatic environment.

47 In biological opinions associated with the continued operation of two other nuclear power plants,  
48 the NMFS (2013, 2014) determined that measurable exposure of sturgeon (Atlantic (*Acipenser*

## Environmental Consequences and Mitigating Actions

1 *oxyrinchus oxyrinchus*) and shortnose (*A. brevirostrum*) sturgeons) to radionuclides and other  
2 contaminants resulting from continued operation of a nuclear power plant would be extremely  
3 unlikely and, therefore, represented an insignificant and discountable impact.

4 The NRC staff did not identify any scientific studies or other information indicating that pallid  
5 sturgeon could experience measurable adverse effects from the minimal discharges of  
6 radionuclides and other contaminants that would occur during the proposed WF3 license  
7 renewal period. Based on the above information, the NRC staff finds that exposure to  
8 radionuclides and other contaminants during the proposed license renewal period represents a  
9 discountable impact because it would not be able to be meaningfully detected, measured, or  
10 evaluated and insignificant because exposure would never reach the scale where a take would  
11 occur.

### 12 Reduction in Available Prey due to Impingement and Entrainment or Thermal Impacts

13 The diet of pallid sturgeon changes with age and is described in Section 3.8. Section 4.7  
14 addresses impingement and entrainment of aquatic resources near WF3. The most commonly  
15 impinged species that are potential prey for pallid sturgeon are three clupids: threadfin shad,  
16 freshwater drum, and skipjack herring. However, the NRC staff concludes in Section 4.7 that  
17 the continued presence and relative abundance of the most commonly impinged species  
18 suggest that the aquatic community surrounding WF3 has not substantially changed as a result  
19 of impingement since WF3 operations began. The NRC staff qualitatively assesses entrainment  
20 in Section 4.7 and concludes that it is not likely to noticeably affect important attributes of the  
21 aquatic community near WF3 because of the lack of suitable spawning habitat near WF3,  
22 among other factors. Overall, the NRC staff concludes that impingement and entrainment  
23 impacts would be SMALL and would not be detectable or are so minor as to neither destabilize  
24 nor noticeably alter the aquatic community. The NRC staff also concludes in Section 4.7 that  
25 thermal impacts on aquatic resources would be SMALL during the proposed license renewal  
26 term. Accordingly, because WF3 operations do not result in detectable impingement and  
27 entrainment or thermal impacts on the aquatic community, any small reductions in available  
28 prey that could result in effects on pallid sturgeon through the food web would not be able to be  
29 meaningfully measured, detected, or evaluated, and, therefore, would be a discountable impact.

### 30 *Indirect Effects*

31 Under the ESA, indirect effects are those caused by the proposed action that are later in time,  
32 but are still reasonably certain to occur (50 CFR 402.02). The NRC staff did not identify any  
33 indirect effects associated with the proposed action that could affect the pallid sturgeon.  
34 Termination of WF3 operations and associated decommissioning of each reactor would occur  
35 eventually regardless of license renewal. Although the proposed license renewal would delay  
36 the date of reactor shutdown, it would not significantly alter decommissioning impacts. Future  
37 effects to pallid sturgeon associated with decommissioning of WF3 at the end of the proposed  
38 license renewal term would be addressed through section 7 consultation, if needed, at the time  
39 of decommissioning.

### 40 *Interrelated and Interdependent Effects*

41 Interrelated actions are those actions that are part of a larger action and that depend on the  
42 larger action for their justification (50 CFR 402.02). Interdependent actions are those actions  
43 that have no independent utility apart from the proposed action (50 CFR 402.02). The NRC  
44 staff has not identified any information that would indicate that there would be any interrelated or  
45 interdependent actions associated with the proposed license renewal that might affect the pallid  
46 sturgeon.

### 1 *Summary of Effects*

2 The NRC staff finds that entrainment of pallid sturgeon into the WF3 intake during the proposed  
3 license renewal term is unlikely because the species is not currently known to spawn in the  
4 Mississippi River main channel. Although impingement of juveniles and adults is possible, the  
5 NRC staff concludes that this impact is unlikely and discountable because pallid sturgeon  
6 impingement has been relatively rare at other Lower Mississippi River energy generating  
7 facilities and because the FWS previously determined in March 2016 that the WF3 LPDES  
8 permit renewal, which authorizes continued withdrawal and discharge of cooling water, is not  
9 likely to adversely affect pallid sturgeon. Although pallid sturgeon individuals may exhibit  
10 altered behavior to avoid the WF3 thermal plume, thermal impacts would never reach the scale  
11 where a take would occur and, therefore, would be insignificant. Some reductions in available  
12 prey due to impingement and entrainment or thermal effects could occur during the proposed  
13 license renewal term, but these impacts would be discountable because the NRC staff  
14 determined in Section 4.7 that impacts on aquatic organisms from impingement, entrainment,  
15 and thermal effluent would be SMALL.

### 16 *Conclusion*

17 Based on the foregoing assessment, the NRC staff concludes that the proposed WF3 license  
18 renewal *may affect, but is not likely to adversely affect* the pallid sturgeon. In a letter dated  
19 November 20, 2017, the FWS (2017) concurred with this determination. The FWS's  
20 concurrence documents that the NRC staff has fulfilled its ESA section 7(a)(2) obligations with  
21 respect to the proposed WF3 license renewal. The staff's consultation with FWS is further  
22 described in Appendix C of this SEIS.

### 23 *4.8.1.2 Species and Habitats under the NMFS's Jurisdiction*

24 As discussed in Section 3.8, no Federally listed species or critical habitats under NMFS's  
25 jurisdiction occur within the action area. Thus, the NRC staff concludes that the proposed  
26 action would have no effect on Federally listed species or habitats under NMFS's jurisdiction.

### 27 *4.8.1.3 Cumulative Effects*

28 The ESA regulations at 50 CFR 402.12(f)(4) direct Federal agencies to consider cumulative  
29 effects as part of the proposed action effects analysis. Under the ESA, cumulative effects are  
30 defined as "those effects of future State or private activities, not involving Federal activities, that  
31 are reasonably certain to occur within the action area of the Federal action subject to  
32 consultation" (50 CFR 402.02). Unlike the National Environmental Policy Act of 1969, as  
33 amended (NEPA) (42 U.S.C. 4321), definition of cumulative impacts (see Section 4.16),  
34 cumulative effects under the ESA do not include past actions or other Federal actions requiring  
35 separate ESA section 7 consultation. When formulating biological opinions under formal  
36 section 7 consultation, the FWS and NMFS (1998) consider cumulative effects when  
37 determining the likelihood of jeopardy or adverse modification. Therefore, consideration of  
38 cumulative effects under the ESA is necessary only if listed species will be adversely affected  
39 by the proposed action and formal section 7 consultation is necessary (FWS 2014). Because  
40 the NRC staff concluded earlier in this section that the proposed license renewal is not likely to  
41 adversely affect the pallid sturgeon and that it would have no effect on all other Federally listed  
42 species and on critical habitat, consideration of cumulative effects is not necessary.  
43 Additionally, the NRC staff did not identify any actions within the action area that meet the  
44 definition of cumulative effects under the ESA.

1 **4.8.1.4 Reporting Requirements**

2 If in the future, a Federally listed species is observed on the WF3 site, the NRC has measures  
3 in place to ensure that NRC staff would be appropriately notified so that the NRC staff could  
4 determine the appropriate course of action, such as possibly reinitiating section 7 consultation  
5 under the ESA at that time. WF3's operating license, Appendix B, "Environmental Protection  
6 Plan," Section 4.1, "Unusual or Important Environmental Events" (NRC 1985) requires Entergy  
7 to report to the NRC within 24 hours any mortality or unusual occurrence of a species protected  
8 by the ESA on the WF3 site. Additionally, the NRC's regulations containing notification  
9 requirements require that operating nuclear power reactors report to the NRC within 4 hours  
10 "any event or situation, related to...protection of the environment, for which a news release is  
11 planned or notification to other government agencies has been or will be made" (10 CFR  
12 50.72(b)(2)(xi)). Such notifications include reports regarding Federally listed species, as  
13 described in Section 3.2.12 of NUREG-1022, *Event Report Guidelines: 10 CFR 50.72 and*  
14 *50.73* (NRC 2013c).

15 **4.8.1.5 Species and Habitats Protected Under the Magnuson-Stevens Act**

16 As discussed in Section 3.8, NMFS has not designated essential fish habitat (EFH) pursuant to  
17 the Magnuson-Stevens Fishery Conservation and Management Act, as amended (MSA)  
18 (16 U.S.C. 1801-1884), in the Mississippi River. The NRC staff contacted the NMFS on  
19 July 26, 2016, to confirm that NMFS did not have any additional concerns pertaining to EFH,  
20 such as effects of the proposed license renewal on EFH prey species (NRC 2016b, 2016c).  
21 The NMFS confirmed that the NRC is not required to consult under the MSA because there is  
22 no EFH in the Mississippi River within the vicinity of WF3. Regarding prey species, the NMFS  
23 stated that although some EFH prey species occur in the Mississippi River, the level of  
24 impingement and entrainment of these species is not expected to be of concern. Thus, the  
25 NRC staff concludes that the proposed action would have no effect on EFH.

26 **4.8.2 No-Action Alternative**

27 Under the no-action alternative, WF3 would shut down. Federally listed species and designated  
28 critical habitat can be affected not only by operation of nuclear power plants but also by  
29 activities during shutdown. The ESA action area for the no-action alternative most likely would  
30 be the same or similar to the action area described in Section 3.8. The plant would require  
31 substantially less cooling water and thermal effluent; therefore, potential impacts to aquatic  
32 species and habitats would be reduced, although the plant would still require some cooling  
33 water for some time. Changes in land use and other shutdown activities might affect terrestrial  
34 species differently than under continued operation.

35 The no-action alternative likely would have less effects on Federally listed species in the action  
36 area than would the proposed action. However, the NRC staff would assess the need for ESA  
37 consultation upon plant shutdown. The ESA forbids "take" of a listed species, where "take"  
38 means "harass, harm, pursue, hunt, shoot, wound, kill, trap, capture, or collect, or attempt to  
39 engage in any such conduct." In the case of a take, ESA section 7 could require that the NRC  
40 initiate consultation with the FWS or NMFS. The implementing regulations at 50 CFR 402.16  
41 also direct Federal agencies to reinitiate consultation in circumstances where (a) the incidental  
42 take limit in a biological opinion is exceeded, (b) new information reveals effects to Federally  
43 listed species or designated critical habitats that were not previously considered, (c) the action  
44 is modified in a manner that causes effects not previously considered, or (d) new species are  
45 listed or new critical habitat is designated that may be affected by the action. An ESA section 7  
46 consultation could identify impacts on Federally listed species or critical habitat, require  
47 monitoring and mitigation to minimize such impacts, and provide a level of exempted takes.

1 Regulations and guidance regarding the ESA section 7 consultation process are provided in  
2 50 CFR Part 402 and in the Endangered Species Consultation Handbook (FWS and  
3 NMFS 1998).

4 The effects on ESA-listed aquatic species likely would be smaller than the effects under  
5 continued operation but would depend on the listed species and habitats present when the  
6 alternative is implemented. The types and magnitudes of adverse impacts to terrestrial  
7 ESA-listed species would depend on the shutdown activities and the listed species and habitats  
8 present when the alternative is implemented; therefore, the NRC cannot forecast a particular  
9 level of impact for this alternative.

#### 10 **4.8.3 New Nuclear Alternative**

11 This alternative entails shutdown of WF3 and construction of a new nuclear alternative on the  
12 Entergy property. Section 4.8.2 discusses ESA considerations for the shutdown of WF3.

13 If a new nuclear plant were to be built on the Entergy property, the ESA action area might be  
14 different, and the activities and structures associated with the site would be different from those  
15 described for the proposed license renewal. Because the NRC would remain the licensing  
16 agency under this alternative, the ESA would require the NRC to initiate consultation with the  
17 FWS, as applicable, before construction to consider whether the construction and operation of  
18 the new nuclear plant would affect any Federally listed species or adversely modify or destroy  
19 designated critical habitat.

20 The type of impacts on ESA-listed species likely would be similar to those described for  
21 terrestrial and aquatic resources in Sections 4.6 and 4.7. However, the magnitude of such  
22 impacts could be larger than that for terrestrial and aquatic resources because ESA-listed  
23 species are rare and more sensitive to environmental stressors. Because the magnitude of  
24 adverse impacts to ESA-listed species would depend on the site layout, plant design, operation,  
25 and the listed species and habitats potentially present in the action area when the alternative is  
26 implemented, the NRC cannot forecast a particular level of impact for this alternative related to  
27 Federally listed species and critical habitats.

28 As described in Sections 3.8.2 and 4.8.1.2, the NMFS has not designated EFH in the  
29 Mississippi River. Given that the new nuclear alternative would be built on the Entergy property,  
30 it is likely that the new nuclear alternative would have no effect on EFH. However, future  
31 changes in EFH designations or regulations could require the NRC to consult with NMFS  
32 regarding impacts to EFH at the time this alternative is implemented. Therefore, the NRC  
33 cannot forecast a particular level of impact for this alternative related to EFH.

#### 34 **4.8.4 SCPC Alternative**

35 This alternative entails shutdown of WF3 and construction of a new SCPC alternative at an  
36 existing power plant site within the SERC region of Louisiana. Section 4.8.2 discusses ESA  
37 considerations for the shutdown of WF3.

38 Unlike license renewal or the new nuclear alternative, the NRC does not license SCPC facilities;  
39 therefore, the NRC would not be responsible for initiating section 7 consultation if listed species  
40 or habitats might be adversely affected under this alternative. The facilities themselves would  
41 be responsible for protecting listed species because the ESA forbids take of a listed species for  
42 both Federal and non-Federal entities.

43 Impacts to listed species and critical habitats would vary depending on the chosen site, the  
44 action area associated with the site, and the species present in that action area. The type of

## Environmental Consequences and Mitigating Actions

1 impacts on ESA-listed species would likely be similar to those described for terrestrial and  
2 aquatic resources in Sections 4.6 and 4.7. However, the magnitude of such impacts could be  
3 larger than that for terrestrial and aquatic resources because ESA-listed species are rare and  
4 more sensitive to environmental stressors. Because the magnitude of adverse impacts to  
5 ESA-listed species would depend on the site layout, plant design, operation, and species and  
6 habitats listed when the alternative is implemented, the NRC cannot forecast a particular level of  
7 impact for this alternative related to Federally listed species and critical habitats.

8 Similarly, effects to EFH would depend on the specific site chosen, whether NMFS has  
9 designated EFH in the vicinity of that site, and the design and operational parameters of the  
10 SCPC plant's cooling system. Further, EFH consultation under the MSA is only required of  
11 Federal agencies, and, as such, would only require consultation with the NMFS if the SCPC  
12 plant siting, construction, or permitting involved a Federal agency nexus. Accordingly, the NRC  
13 cannot forecast a particular level of impact for this alternative related to EFH.

### 14 **4.8.5 NGCC Alternative**

15 This alternative entails shutdown of WF3 and construction of a new NGCC facility on the  
16 Entergy property. Section 4.8.2 discusses ESA considerations for the shutdown of WF3.

17 Unlike license renewal or the new nuclear alternative, the NRC does not license NGCC  
18 facilities; therefore, the NRC would not be responsible for initiating section 7 consultation if listed  
19 species or habitats might be adversely affected under this alternative. The facilities themselves  
20 would be responsible for protecting listed species because the ESA forbids take of a listed  
21 species for both Federal and non-Federal entities.

22 If the NGCC alternative were to be built on the Entergy property, the ESA action area might be  
23 different, and the activities and structures associated with the site would be different from those  
24 described for the proposed license renewal. The type of impacts on ESA-listed species would  
25 likely be similar to those described for terrestrial and aquatic resources in Sections 4.6 and 4.7.  
26 However, the magnitude of such impacts could be larger than that for terrestrial and aquatic  
27 resources because ESA-listed species are rare and more sensitive to environmental stressors.  
28 Because the magnitude of adverse impacts to ESA-listed species would depend on the site  
29 layout, plant design, operation, and species and habitats listed when the alternative is  
30 implemented, the NRC cannot forecast a particular level of impact for this alternative related to  
31 Federally listed species and critical habitats.

32 As described in Sections 3.8.2 and 4.8.1.2, the NMFS has not designated EFH in the  
33 Mississippi River. Given that the NGCC alternative would be built on the Entergy property, it is  
34 likely that the NGCC alternative would have no effect on EFH. However, EFH consultation  
35 under the MSA is only required of Federal agencies, and, as such, would only require  
36 consultation with the NMFS if the NGCC plant siting, construction, or permitting involved a  
37 Federal agency nexus. Accordingly, the NRC cannot forecast a particular level of impact for this  
38 alternative related to EFH.

### 39 **4.8.6 Combination Alternative (NGCC, Biomass, and DSM)**

40 This alternative entails shutdown of WF3 and construction and operation of a new NGCC plant  
41 and biomass plant on the Entergy property as well as DSM. Section 4.8.2 discusses ESA  
42 considerations for the shutdown of WF3.

43 Unlike license renewal or the new nuclear alternative, the NRC does not license NGCC or  
44 biomass facilities and is not involved in energy planning or decisionmaking, such as  
45 implementation of DSM; therefore, the NRC would not be responsible for initiating section 7

1 consultation if listed species or habitats might be adversely affected under this alternative. The  
 2 facilities themselves would be responsible for protecting listed species because the ESA forbids  
 3 take of a listed species for both Federal and non-Federal entities.

4 If new NGCC and biomass plants were to be built on the Entergy property, the ESA action area  
 5 might be different, and the activities and structures associated with the site would be different  
 6 from those described for the proposed license renewal. The type of impacts on ESA-listed  
 7 species would likely be similar to those described for terrestrial and aquatic resources in  
 8 Sections 4.6 and 4.7. However, the magnitude of such impacts could be larger than that for  
 9 terrestrial and aquatic resources because ESA-listed species are rare and more sensitive to  
 10 environmental stressors. Because the magnitude of adverse impacts to ESA-listed species  
 11 would depend on the site layout, plant design, operation, and species and habitats listed when  
 12 the alternative is implemented, the NRC cannot forecast a particular level of impact for this  
 13 alternative related to Federally listed species and critical habitats.

14 As described in Sections 3.8.2 and 4.8.1.2, the NMFS has not designated EFH in the  
 15 Mississippi River. Given that the NGCC and biomass alternative would be built on the Entergy  
 16 property, it is likely that the combination alternative of NGCC, biomass, and DSM would have no  
 17 effect on EFH. However, EFH consultation under the MSA is only required of Federal agencies,  
 18 and, as such, would only require consultation with the NMFS if the NGCC and biomass plant  
 19 siting, construction, or permitting involved a Federal agency nexus. Accordingly, the NRC  
 20 cannot forecast a particular level of impact for this alternative related to EFH.

21 **4.9 Historic and Cultural Resources**

22 **4.9.1 Proposed Action**

23 The historic and cultural resource issue applicable to WF3 during the license renewal term is  
 24 listed in Table 4–12. Section 3.9 of this SEIS describes the historic and cultural resources that  
 25 have the potential to be affected by the proposed action.

26 **Table 4–12. Historic and Cultural Resources Issue**

Issue	GEIS Section	Category
Historic and cultural resources	4.7.1	2

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

27 The National Historic Preservation Act of 1966, as amended (NHPA)  
 28 (54 U.S.C. 300101 et seq.), requires Federal agencies to consider the effects of their  
 29 undertakings on historic properties, and renewing the operating license of a nuclear power plant  
 30 is an undertaking that could potentially affect historic properties. Historic properties are defined  
 31 as resources included on, or eligible for inclusion on, the National Register of Historic Places  
 32 (NRHP). The criteria for eligibility are listed in 36 CFR 60.4 and include (1) association with  
 33 significant events in history, (2) association with the lives of persons significant in the past,  
 34 (3) embodiment of distinctive characteristics of type, period, or construction, and (4) sites or  
 35 places that have yielded, or are likely to yield, important information.

36 The historic preservation review process (Section 106 of the NHPA) is outlined in regulations  
 37 issued by the Advisory Council on Historic Preservation in 36 CFR Part 800.

## Environmental Consequences and Mitigating Actions

1 In accordance with NHPA provisions, the NRC is required to make a reasonable effort to identify  
2 historic properties included in, or eligible for, inclusion in the NRHP in the area of potential effect  
3 (APE). The APE for a license renewal action includes the power plant site, the transmission  
4 lines up to the first substation, and immediate environs that may be affected by the license  
5 renewal decision and land disturbing activities associated with continued reactor operations  
6 during the license renewal term.

7 If historic properties are present within the APE, the NRC is required to contact the State  
8 Historic Preservation Officer (SHPO), assess the potential impact, and resolve any possible  
9 adverse effects of the undertaking (license renewal) on historic properties. In addition, the NRC  
10 is required to notify the SHPO if historic properties would not be affected by license renewal or if  
11 no historic properties are present. In Louisiana, SHPO responsibilities are shared between the  
12 Division of Historic Preservation and the Division of Archaeology (LOCD 2011, 2017).

### 13 Consultation

14 In accordance with 36 CFR 800.8(c), on June 2, 2016, the NRC initiated written consultation  
15 with the following Federally recognized Tribes (NRC 2016d, see Appendix C.):

- 16 • Chitimacha Tribe of Louisiana,
- 17 • Coushatta Tribe of Louisiana,
- 18 • Jena Band of Choctaw Indians, and
- 19 • Tunica-Biloxi Tribe of Louisiana.

20 The NRC also initiated consultations with the Louisiana SHPO (on June 3, 2016) and the  
21 Advisory Council on Historic Preservation (on June 6, 2016) (NRC 2016e, 2016f).

22 In these letters, the NRC provided information about the proposed action, defined the APE, and  
23 indicated that the NHPA review would be integrated with the NEPA process, in accordance with  
24 36 CFR 800.8(c). The NRC invited participation in the identification and possible decisions  
25 concerning historic properties and also invited participation in the scoping process. To date, the  
26 NRC has received no comments from these Tribes and organizations specific to WF3 license  
27 renewal. However, the Louisiana SHPO previously reviewed the draft Phase 1A Literature  
28 Review and Archeological Sensitivity Assessment commissioned by Entergy in support of its  
29 LRA, and concurred that operation of WF3 during the license renewal term would have no effect  
30 on known historic properties (Entergy 2016a; LOCD 2015). Similarly, the Coushatta Tribe of  
31 Louisiana and the Jena Band of Choctaw Indians previously indicated in correspondence to  
32 Entergy that the proposed action would result in “no historical properties affected” and “no  
33 adverse effect,” respectively (Entergy 2016a).

### 34 Findings

35 As described in Section 3.9, there are 42 known historic and cultural resources located within  
36 the WF3 APE, including 10 historic properties that are either listed on, or are considered eligible  
37 for listing on, the NRHP. Entergy has both fleet-wide and site-specific administrative controls in  
38 place to manage and protect cultural resources. Entergy’s fleet-wide cultural resource  
39 protection plan requires that appropriate reviews, investigations, and consultations are  
40 completed before performing ground-disturbing activities in undisturbed or cultural  
41 resource-sensitive areas. Although training on this plan is not compulsory, all Entergy  
42 employees are required to adhere to the instructions contained in the procedure.

43 Entergy has also established a separate cultural resources protection plan in coordination with  
44 the Louisiana SHPO to help ensure historic and cultural resources specific to WF3 are  
45 considered before ground-disturbing activities. This plan is incorporated by reference in the

1 WF3 Environmental Protection Plan and includes provisions to protect areas on the property  
 2 determined to be NRHP-eligible, including those associated with the former Waterford  
 3 Plantation. It also identifies the protocols to be followed should cultural resources be discovered  
 4 during ground-disturbing activities. However, Entergy does not anticipate that any physical  
 5 changes or ground-disturbing activities would be required to support license renewal of WF3  
 6 (Entergy 2016a).

7 Based on (1) the location of NRHP-eligible historic properties within the APE, (2) tribal input,  
 8 (3) Entergy’s cultural resource protection plans, (4) the fact that no license renewal-related  
 9 physical changes or ground-disturbing activities would occur, (5) SHPO input, and (6) cultural  
 10 resource assessment, license renewal would not adversely affect any known historic properties  
 11 (36 CFR 800.4(d)(1)). Entergy could reduce the risk of potential impacts to historic and cultural  
 12 resources located on or near the WF3 site by ensuring workers engaged in planning and  
 13 executing ground-disturbing activities are trained on the applicable cultural resource  
 14 protection plans.

15 **4.9.2 No-Action Alternative**

16 Not renewing the operating licenses and terminating reactor operations would have no  
 17 immediate effect on historic properties and cultural resources at WF3. As stated in the  
 18 decommissioning GEIS, impacts to cultural resources would be SMALL at nuclear plants where  
 19 decommissioning activities would only occur within existing industrial site boundaries. Impacts  
 20 cannot be predicted generically if decommissioning activities would occur outside of the  
 21 previously disturbed industrial site boundaries, because impacts depend on site-specific  
 22 conditions. In these instances, impacts could only be determined through site-specific analysis  
 23 (NRC 2002b).

24 In addition, 10 CFR 50.82 requires power reactor licensees to submit a post-shutdown  
 25 decommissioning activities report (PSDAR) to the NRC. The PSDAR provides a description of  
 26 planned decommissioning activities at the nuclear plant. Until the PSDAR is submitted, the  
 27 NRC cannot determine whether land disturbance would occur outside the existing industrial site  
 28 boundary after the nuclear plant is shut down.

29 **4.9.3 New Nuclear Alternative**

30 This alternative assumes that a new nuclear power plant would be built on the Entergy  
 31 Louisiana, LLC property separate from the existing Waterford 1, 2, 4, and WF3. The new  
 32 nuclear plant would require an estimated 230 ac (93 ha) of land for the power plant. The  
 33 potential for impacts on historic and cultural resources from the construction and operation of a  
 34 new nuclear power plant would vary depending on the specific location chosen within the  
 35 Entergy Louisiana, LLC property. Use of previously disturbed areas of the Entergy, LLC  
 36 property known to not contain historic and cultural resources would be maximized, and areas of  
 37 greatest cultural sensitivity avoided. Undisturbed areas of the property that could potentially be  
 38 affected by the construction and operation of a new nuclear power plant would need to be  
 39 surveyed to identify and record historic and cultural resources. Any resources found in these  
 40 surveys would need to be evaluated for eligibility on the NRHP, and mitigation of adverse  
 41 effects would need to be addressed if eligible resources were encountered. Visual impacts on  
 42 significant cultural resources, such as the viewsheds of historic properties near the proposed  
 43 nuclear power plant site, also would need to be assessed and evaluated.

44 The new nuclear plant would be located in a heavily industrialized area where tall structures and  
 45 visible plumes already exist. Given the preference to site the power plant on previously  
 46 disturbed land and given that no major infrastructure upgrades would be necessary, avoidance

1 of significant historic and cultural resources would be possible and could be managed  
2 effectively. Therefore, construction and operation of a new nuclear power plant on the Entergy,  
3 LLC property would not adversely affect known historic and cultural resources.

#### 4 **4.9.4 Super-Critical Pulverized Coal Alternative**

5 The SCPC alternative assumes that Entergy would build a new SCPC facility at an existing  
6 power plant site within the SERC region of Louisiana. The facility would require an estimated  
7 120 ac (49 ha) of land for major permanent facilities, as well as additional land for coal mining  
8 and waste disposal. Land areas potentially affected by the construction and operation of a new  
9 SCPC power plant would need to be surveyed to identify and record historic and cultural  
10 resources if the proposed action involves a Federal undertaking under NHPA. However,  
11 previously disturbed industrial areas at an existing power plant site would not likely contain  
12 intact historic and cultural resources. Any cultural resources and archaeological sites  
13 discovered during surveys should be evaluated for eligibility on the NRHP, and adverse effects  
14 should be addressed if eligible resources are encountered. Existing sensitive archaeological  
15 sites and historic properties should be avoided during site selection. Visual impacts to historic  
16 properties, such as historic viewsheds, should also be avoided or mitigated.

17 The extent of impact on historic and cultural resources would depend on the resource richness  
18 of the land acquired for an SCPC power plant. Exhaust stacks and cooling tower plumes  
19 associated with a new SCPC plant also would likely be visible off site. Avoidance of historic and  
20 cultural resources may not be possible but could be effectively managed under current laws and  
21 regulations. However, this determination would depend on the specific location, plant design,  
22 and operational characteristics of the new SCPC power plant. Therefore, it cannot be  
23 determined whether this alternative would result in adverse impacts to historic properties.

#### 24 **4.9.5 NGCC Alternative**

25 This alternative assumes that a new NGCC power plant would be built on the Entergy  
26 Louisiana, LLC property separate from the existing Waterford 1, 2, 4, and WF3. The new  
27 NGCC plant would require an estimated 60 ac (24 ha) of land for the power plant. Some  
28 infrastructure upgrades could be required, as well as construction of a new or upgraded  
29 pipeline.

30 Impacts from the construction and operation of a new NGCC plant would be similar to, but less  
31 than, the impacts described for the new nuclear alternative. Given the preference to site the  
32 power plant on previously disturbed land and given that no major infrastructure upgrades would  
33 be necessary, avoidance of significant historic and cultural resources would be possible and  
34 could be managed effectively. Therefore, construction and operation of a new NGCC power  
35 plant on the Entergy, LLC property would not adversely affect known historic and cultural  
36 resources.

#### 37 **4.9.6 Combination Alternative (NGCC, Biomass, and Demand Side Management)**

38 The combination alternative assumes that Entergy would build a new NGCC facility and four  
39 new biomass units on its existing property. The facilities would require a total of 90 ac (36 ha)  
40 of land for the NGCC and biomass components). Some infrastructure upgrades could be  
41 required, as well as construction of a new or upgraded pipeline. Additional offsite land for the  
42 biomass component is not anticipated for fuel feedstock but could be required for storing,  
43 loading, and transporting biomass fuel materials. The DSM component would be implemented  
44 through energy efficiency and DSM programs across the Entergy service area.

1 Impacts from the construction and operation of the NGCC and biomass components of this  
 2 alternative would be similar to, but less than, the impacts described for the new nuclear  
 3 alternative. Given the preference to site the power plant on previously disturbed land and given  
 4 that no major infrastructure upgrades would be necessary, avoidance of significant historic and  
 5 cultural resources would be possible and could be managed effectively. Activities associated  
 6 with the DSM component of this alternative would not have any direct impact on historic and  
 7 cultural resources. Therefore, construction and operation of the combination alternative on the  
 8 Entergy, LLC property would not adversely affect known historic and cultural resources.

9 **4.10 Socioeconomics**

10 **4.10.1 Proposed Action**

11 Socioeconomic effects of ongoing reactor operations at WF3 have become well established as  
 12 regional socioeconomic conditions have adjusted to the presence of the nuclear power plant.  
 13 These conditions are described in Section 3.10. Any changes in employment and tax revenue  
 14 caused by license renewal and any associated refurbishment activities could have a direct and  
 15 indirect impact on community services and housing demand, as well as traffic volumes in the  
 16 communities around a nuclear power plant.

17 Socioeconomic NEPA issues from Table B–1 in Appendix B to Subpart A of 10 CFR Part 51,  
 18 applicable to the license renewal of WF3, are listed in Table 4–13. The review conducted for  
 19 the 2013 GEIS revision did not identify any Category 2 socioeconomic NEPA issues  
 20 (NRC 2013a).

21 **Table 4–13. Socioeconomic NEPA Issues**

Issues	GEIS Sections	Category
Employment and income, recreation and tourism	4.8.1.1	1
Tax revenues	4.8.1.2	1
Community services and education	4.8.1.3	1
Population and housing	4.8.1.4	1
Transportation	4.8.1.5	1

Source: Table B–1 in Appendix B, Subpart A of 10 CFR Part 51; NRC 2013a

22 The site-specific socioeconomic impact analysis for the license renewal of WF3 included a  
 23 review of the Entergy ER (Entergy 2016a), scoping comments, other information records, and a  
 24 data-gathering site visit to WF3. The review found no new and significant socioeconomic  
 25 impact information that would exceed the predicted socioeconomic impacts evaluated in the  
 26 GEIS, nor any additional socioeconomic NEPA issues beyond those listed in Table B–1.

27 In addition, Entergy has indicated in its ER that they have no plans to add non-outage workers  
 28 during the license renewal term and that increased maintenance and inspection activities could  
 29 be managed using the current workforce (Entergy 2016a). Consequently, people living in the  
 30 vicinity of WF3 would not experience any changes in socioeconomic conditions during the  
 31 license renewal term beyond what is currently being experienced. Therefore, the impact of  
 32 continued reactor operations during the license renewal term would not exceed the  
 33 socioeconomic impacts predicted in the GEIS. For these issues, the GEIS predicted that the  
 34 impacts would be SMALL for all nuclear plants.

1 **4.10.2 No-Action Alternative**

2 *4.10.2.1 Socioeconomics*

3 Not renewing the operating license and terminating reactor operations would have a noticeable  
4 impact on socioeconomic conditions in the parishes and communities near WF3. The loss of  
5 jobs, income, and tax revenue would have an immediate socioeconomic impact. As jobs are  
6 eliminated, some, but not all, of the 641 WF3 workers would begin to leave. Employment and  
7 income from the buying and selling of goods and services needed to operate and maintain the  
8 nuclear power plant also would be reduced. The loss of tax revenue could result in the  
9 reduction or elimination of some public and educational services.

10 If WF3 workers and their families move out of the region, increased housing vacancies and  
11 decreased demand likely would cause housing prices to fall. Socioeconomic impacts from the  
12 termination of reactor operations would be concentrated in St. Charles and Jefferson Parishes  
13 and the communities most reliant on income from nuclear plant operations, because the  
14 majority of WF3 workers reside in these two parishes. However, the socioeconomic impact  
15 from the loss of jobs, income, and tax revenue, may be less noticeable in some communities  
16 because of the amount of time required for decommissioning. The socioeconomic impacts from  
17 not renewing the operating license and terminating reactor operations at WF3 would, depending  
18 on the jurisdiction, range from SMALL to MODERATE.

19 *4.10.2.2 Transportation*

20 Traffic congestion caused by commuting workers and truck deliveries on roads in the vicinity of  
21 WF3 would be reduced after power plant shutdown. Most of the reduction in traffic volume  
22 would be associated with the loss of jobs. The number of truck deliveries to WF3 also would be  
23 reduced until decommissioning. Traffic-related transportation impacts would be SMALL at WF3  
24 as a result of power plant shutdown.

25 **4.10.3 New Nuclear Alternative**

26 *4.10.3.1 Socioeconomics*

27 Socioeconomic impacts are defined in terms of changes in the social and economic conditions  
28 of a region. For example, the creation of jobs and the purchase of goods and services during  
29 the construction and operation of a replacement power plant could affect regional employment,  
30 income, and tax revenue.

31 Two types of jobs would be created by this alternative: (1) construction jobs, which are  
32 transient, short in duration, and less likely to have a long-term socioeconomic impact; and  
33 (2) power plant operations jobs, which have the greater potential for permanent, long-term  
34 socioeconomic impacts. Workforce requirements for the construction and operation of a new  
35 nuclear power plant were evaluated to measure their possible effects on current socioeconomic  
36 conditions.

37 The construction workforce could peak at 3,500 workers (Times-Free Press 2015;  
38 Entergy 2016a). The relative economic effect of this many workers on the local economy and  
39 tax base would vary with the greatest impacts occurring in the communities where the majority  
40 of construction workers would reside and spend their income. As a result, local communities  
41 could experience a short-term economic “boom” from increased tax revenue and income  
42 generated by construction expenditures and the increased demand for temporary (rental)  
43 housing and public as well as commercial services.

1 After construction, local communities could experience a return to pre-construction economic  
2 conditions. Based on this information and given the number of workers, socioeconomic impacts  
3 during construction in local communities could range from MODERATE to LARGE.

4 Approximately 640 workers would be required during nuclear power plant operations  
5 (Times-Free Press 2015; Entergy 2016a). Some workers could transfer from WF3 to the new  
6 nuclear power plant. Local communities would experience the economic benefits from  
7 increased income and tax revenue generated by the purchase of goods and services required to  
8 operate the nuclear power plant and the need for housing and public services. Based on this  
9 information and given the number of operations workers, socioeconomic impacts during nuclear  
10 power plant operations on local communities could range from SMALL to MODERATE.

11 This alternative also would result in a loss of jobs at WF3 and a corresponding reduction in  
12 income and tax revenue. These impacts are described in the no-action alternative  
13 (Section 4.10.2).

#### 14 *4.10.3.2 Transportation*

15 Transportation impacts during the construction of a new nuclear power plant would consist of  
16 commuting workers and truck deliveries of equipment and material to the construction site.  
17 During periods of peak construction activity, up to 3,500 workers could be commuting daily to  
18 the construction site (Times-Free Press 2015; Entergy 2016a). Workers would arrive via site  
19 access roads and the volume of traffic would increase substantially during shift changes. In  
20 addition, trucks would be transporting equipment and materials to the construction site,  
21 increasing the amount of traffic on local roads. The increase in traffic volumes could result in  
22 levels of service impacts and delays at intersections during certain hours of the day.  
23 Construction material also could be delivered by rail or barge. Based on this information,  
24 traffic-related transportation impacts during construction could range from MODERATE to  
25 LARGE.

26 Traffic-related transportation impacts would be greatly reduced after construction of the new  
27 nuclear power plant has been completed. Approximately 640 operations workers would be  
28 commuting daily to the new nuclear power plant site (Times-Free Press 2015; Entergy 2016a).  
29 Transportation impacts would include daily commuting by the operations workforce and  
30 deliveries of material, and the removal of commercial waste material by truck. Traffic on  
31 roadways would peak during shift changes and refueling outages, resulting in temporary levels  
32 of service impacts and delays at intersections. Overall, traffic-related transportation impacts  
33 during operations would be SMALL to MODERATE.

#### 34 **4.10.4 SCPC Alternative**

##### 35 *4.10.4.1 Socioeconomics*

36 Socioeconomic impacts from the construction and operation of a new SCPC plant would be the  
37 similar to the impacts described for the new nuclear alternative. The construction workforce  
38 could peak at 2,600 workers (Entergy 2016a, NRC 1996). Given the number of workers,  
39 socioeconomic impacts during construction in local communities could range from  
40 MODERATE to LARGE.

41 An estimated 350 workers would be required during power plant operations (Entergy 2016a,  
42 NRC 1996). Based on this information and given the number of operations workers,  
43 socioeconomic impacts during SCPC power plant operations on local communities could range  
44 from SMALL to MODERATE.

## Environmental Consequences and Mitigating Actions

### 1 4.10.4.2 *Transportation*

2 Transportation impacts from the construction and operation of a new SCPC plant would be the  
3 similar to the impacts described for the new nuclear alternative. Traffic-related transportation  
4 impacts during construction could range from MODERATE to LARGE.

5 Frequent coal and limestone deliveries and ash removal by rail would add to the overall  
6 transportation impact during power plant operations. Onsite coal storage would make it  
7 possible to receive several trains per day at a site with rail access. If the SCPC power plant is  
8 located on navigable waters, coal and other materials could be delivered by barge. Coal and  
9 limestone delivery and ash removal via rail would cause levels of service impacts due to delays  
10 at railroad crossings. Overall, traffic-related transportation impacts during operations could  
11 range from SMALL to MODERATE.

### 12 **4.10.5 NGCC Alternative**

#### 13 4.10.5.1 *Socioeconomics*

14 Socioeconomic impacts from the construction and operation of a new NGCC plant would be the  
15 similar to the impacts described for the new nuclear alternative. The construction workforce  
16 could peak at 1,650 workers (NRC 1996, Entergy 2016a). Given the number of workers,  
17 socioeconomic impacts during construction in local communities could range from  
18 MODERATE to LARGE.

19 An estimated 200 workers would be required during power plant operations (NRC 1996,  
20 Entergy 2016a). Based on this information and given the number of operations workers,  
21 socioeconomic impacts during NGCC power plant operations on local communities could range  
22 from SMALL to MODERATE.

#### 23 4.10.5.2 *Transportation*

24 Transportation impacts from the construction and operation of a new NGCC plant would be the  
25 similar to the impacts described for the new nuclear alternative. Gas pipeline construction and  
26 modification of existing natural gas pipeline systems could have a temporary impact.  
27 Traffic-related transportation impacts during construction could range from MODERATE to  
28 LARGE.

29 Because natural gas fuel is transported by pipeline, the transportation infrastructure would  
30 experience little to no increased traffic during power plant operations. Overall, given the  
31 relatively small number of operations workers, transportation impacts would be SMALL during  
32 power plant operations.

### 33 **4.10.6 Combination Alternative NGCC, Biomass and DSM**

#### 34 4.10.6.1 *Socioeconomics*

35 Socioeconomic impacts from the construction and operation of a new NGCC and biomass  
36 power plants would be similar to the impacts described for the new nuclear alternative. The  
37 NGCC component would require about 720 construction workers during peak construction and  
38 90 operations workers (NRC 2013a). Construction of the four biomass-fired plants would  
39 require 200 construction workers if all four units are constructed at the same time, and  
40 88 operations workers for this component of the combination alternative (Entergy 2016a).

41 The DSM component could generate additional employment, depending on the nature of the  
42 conservation programs and the need for direct measure installations in homes and office

1 buildings. Jobs would likely be few and scattered throughout the region, and would not have a  
2 noticeable effect on the local economy.

3 Because of the relatively small number of construction workers needed for the NGCC and  
4 biomass-fired plants, the socioeconomic impact of construction on local communities and the  
5 tax base would be SMALL. Given the small number of operations workers required,  
6 socioeconomic impacts associated with operation of this combination alternative would also be  
7 SMALL.

8 **4.10.6.2 Transportation**

9 Transportation impacts from the construction and operation of a new NGCC and biomass power  
10 plants would be the similar to the impacts described for the new nuclear alternative. The  
11 transportation impacts would not be concentrated as they are in the other alternatives; they  
12 would be spread out over a wider area. Transporting heavy and oversized components on local  
13 roads could have a noticeable impact over a large area. Traffic-related transportation impacts  
14 during construction could range from SMALL to MODERATE in the vicinity of the NGCC power  
15 plant and biomass power plant units, depending on current road capacities and average daily  
16 traffic volumes. During operations, transportation impacts from the NGCC and biomass portions  
17 of the combination alternative would be less noticeable than during construction and would be  
18 SMALL.

19 No incremental operations impacts would be expected for the DSM component of this  
20 alternative. Traffic volumes on local roads would remain unchanged.

21 **4.11 Human Health**

22 This section describes the potential impacts of the proposed action (license renewal) and  
23 alternatives to the proposed action on human health resources.

24 **4.11.1 Proposed Action**

25 The human health issues applicable to WF3 are discussed below and are listed in Table 4–14  
26 for Category 1, Category 2, and uncategorized issues. Table B-1 of Appendix B to Subpart A of  
27 10 CFR Part 51 contains more information on these issues.

28 **Table 4–14. Human Health Issues**

Issue	GEIS Section	Category
Radiation exposures to the public	4.9.1.1.1	1
Radiation exposures to plant workers	4.9.1.1.1	1
Human health impact from chemicals	4.9.1.1.2	1
Microbiological hazards to the public (plants with cooling ponds or canals or cooling towers that discharge to a river)	4.9.1.1.3	2
Microbiological hazards to plant workers	4.9.1.1.3	1
Chronic effects of electromagnetic fields (EMFs) <sup>(a)</sup>	4.9.1.1.4	N/A <sup>(b)</sup>
Physical occupational hazards	4.9.1.1.5	1
Electric shock hazards <sup>(a)</sup>	4.9.1.1.5	2

## Environmental Consequences and Mitigating Actions

Issue	GEIS Section	Category
(a) This issue applies only to the in-scope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.		
(b) N/A (not applicable) The categorization and impact finding definition does not apply to this issue.		

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51 (NRC 2013a)

### 1 4.11.1.1 Normal Operating Conditions

2 The NRC staff did not identify any new and significant information during its review of Entergy's  
3 ER (Entergy 2016a), the site audit, or the scoping process for the Category 1 issues listed in  
4 Table 4–14. Therefore, there are no impacts related to these issues beyond those discussed in  
5 the GEIS. For these Category 1 issues, the GEIS concluded that the impacts are SMALL.

### 6 Chronic Effects of Electromagnetic Fields

7 In the GEIS (NRC 2013a), the chronic effects of 60-Hz EMFs from power lines were not  
8 designated as Category 1 or 2 and will not be until a scientific consensus is reached on the  
9 health implications of these fields.

10 The potential for chronic effects from these fields continues to be studied and is not known at  
11 this time. The National Institute of Environmental Health Sciences (NIEHS) directs related  
12 research through the DOE.

13 The report by NIEHS (NIEHS 1999) contains the following conclusion:

14 The NIEHS concludes that ELF-EMF (extremely low frequency-electromagnetic  
15 field) exposure cannot be recognized as entirely safe because of weak scientific  
16 evidence that exposure may pose a leukemia hazard. In our opinion, this finding  
17 is insufficient to warrant aggressive regulatory concern. However, because  
18 virtually everyone in the United States uses electricity and therefore is routinely  
19 exposed to ELF-EMF, passive regulatory action is warranted such as continued  
20 emphasis on educating both the public and the regulated community on means  
21 aimed at reducing exposures. The NIEHS does not believe that other cancers or  
22 non-cancer health outcomes provide sufficient evidence of a risk to currently  
23 warrant concern.

24 This statement is not sufficient to cause the NRC staff to change its position with respect to the  
25 chronic effects of EMFs. The NRC staff considers the GEIS finding of "UNCERTAIN" still  
26 appropriate and will continue to follow developments on this issue.

### 27 Electric Shock Hazards

28 Based on the GEIS, the NRC found that electric shock resulting from direct access to energized  
29 conductors or from induced charges in metallic structures has not been found to be a problem at  
30 most operating plants and generally is not expected to be a problem during the license renewal  
31 term. However, a site-specific review is required to determine the significance of the electric  
32 shock potential along the portions of the transmission lines that are within the scope of this  
33 SEIS.

34 As discussed in Section 3.11.4, there are no offsite transmission lines that are in scope for this  
35 SEIS. Therefore, there are no potential impacts to members of the public.

36 As discussed in Section 3.11.5, WF3 maintains an occupational safety program in accordance  
37 with the Occupational Safety & Health Administration regulations for its workers, which includes

1 protection from acute electric shock. Therefore, the NRC staff concludes that the potential  
2 impacts from acute electric shock during the license renewal term would be SMALL.

#### 3 4.11.1.2 Microbiological Hazards

4 In the GEIS (NRC 2013a), the NRC staff determined that the effects of thermophilic  
5 microorganisms on the public for plants using cooling ponds, lakes, or canals or cooling towers  
6 or that discharge to a river is a Category 2 issue (see Table 4–14) that requires site-specific  
7 evaluation during each license renewal review.

8 In order to determine whether the continued operations of WF3 could promote increased growth  
9 of thermophilic microorganisms and thus have an adverse effect on the public, the NRC staff  
10 considered several factors: the thermophilic microorganisms of concern, WF3's thermal effluent  
11 characteristics, recreational use of the Mississippi River, and reports and input from the  
12 Louisiana Department of Health (LDH) and Louisiana Office of Public Health (LOPH).

13 Section 3.11.3 describes the thermophilic microorganisms that the GEIS identified to be of  
14 potential concern at nuclear power plants and summarizes data from the Centers for Disease  
15 Control and Prevention (CDC), LOPH, and LDH on the prevalence of waterborne diseases  
16 associated with these microorganisms. The CDC, LOPH, and LDH data indicate that no  
17 outbreaks or cases of waterborne *Salmonella*, *Pseudomonas aeruginosa*, or *Naegleria fowleri*  
18 infection from the Mississippi River or recreational waters have occurred in Louisiana in the past  
19 10 years (CDC 2015, 2016a; LDH undated; LOPH 2013). Based on the information presented  
20 in Section 3.11.3, the thermophilic organisms most likely to be of potential concern at or near  
21 WF3 are *Shigella* and *Legionella*.

22 Shigellosis infections have been reported in the United States because of exposure within lakes,  
23 reservoirs, and other recreational waters (CDC 2002, 2004, 2006, 2008, 2011). WF3  
24 continuously discharges thermal effluent to the Mississippi River. The WF3 thermal discharge,  
25 however, is not likely to increase the rate of Shigellosis infections given that recreational  
26 activities, such as swimming or boating, is prohibited near the WF3 discharge structure, which is  
27 located within the exclusionary area boundary (Entergy 2016a). In addition, although there may  
28 be a few periods of time when the thermal discharge is within the range of the optimal growth  
29 temperature for *Shigella* (95 °F (35 °C)), the thermal effluent is quickly dispersed given the fast  
30 flow of the Mississippi River current near the discharge structure (LP&L 1978; Entergy 2016a).  
31 In addition, LDH did not identify any concerns regarding any thermophilic organisms as result of  
32 WF3's thermal effluent discharged into the Mississippi River (Entergy 2016b; NRC 2016g).  
33 Given the small area of thermally heated waters, the unlikelihood of the water to create  
34 conditions favorable to thermophilic microorganisms, and the lack of recreational swimming  
35 allowed near the WF3 discharge structure, infections are unlikely.

36 *Legionellosis* outbreaks are often associated with complex water system houses inside  
37 buildings or structures, such as cooling towers (CDC 2016b). WF3 has cooling towers as part  
38 of the service water system. Public exposure to aerosolized *Legionella* would not be likely  
39 because such exposure would be confined to a small area of the site that restricts public  
40 access. Plant workers would be the most likely to be exposed when cleaning or providing other  
41 maintenance services that involve the cooling water system, including cooling towers and  
42 condensers. Entergy (2016a) stated that several procedural measures provide a standard  
43 methodology for identifying industrial hazards before performance of such jobs, including worker  
44 protection measures. For example, because respiratory or nasal infectivity routes are of primary  
45 concern with legionellosis, workers performing underwater activities should wear protective gear  
46 to prevent oral or nasal exposure to amoebae or other pathogenic bacteria (NRC 2013a).

1 Conclusion

2 The CDC, LOPH, and LDH data indicate no outbreaks or cases of waterborne Salmonella,  
 3 Pseudomonas aeruginosa, or Naegleria fowleri infection from the Mississippi River or other  
 4 recreational waters in Louisiana (CDC 2015a, 2016a; LDH undated; LOPH 2013). Although the  
 5 thermophilic microorganism Shigella has been linked to waterborne outbreaks in Louisiana,  
 6 Shigella infections are unlikely, given the small area of thermally heated waters, the unlikelihood  
 7 of the water to create conditions favorable to thermophilic microorganisms, and the restricted  
 8 public access near the WF3 discharge structure. In addition, LDH did not identify any concerns  
 9 regarding thermophilic organisms as result of WF3’s thermal effluent (Entergy 2016b;  
 10 NRC 2016). Although Legionella has the potential to occur within cooling towers and  
 11 condensers at WF3, infection is not likely given that these areas are restricted to the public and  
 12 that Entergy has procedures to help ensure that plant workers take protective measures to  
 13 minimize exposure to biological hazards. Based on the above information, the NRC staff  
 14 concludes that the impacts of thermophilic microorganisms to the public are SMALL for WF3  
 15 license renewal.

16 *4.11.1.3 Environmental Impacts of Postulated Accidents*

17 This section describes the environmental impacts from postulated accidents that WF3 might  
 18 experience during the period of extended operation. The term “accident” refers to any  
 19 unintentional event outside the normal plant operational envelope that results in a release or the  
 20 potential for release of radioactive materials into the environment. The two classes of  
 21 postulated accidents listed in Table 4–15 are contained in Table B-1 of Appendix B to Subpart A  
 22 of 10 CFR Part 51 and are evaluated in detail in the GEIS. These two classes of accidents are  
 23 design-basis accidents (DBAs) and severe accidents.

24 **Table 4–15. Issues Related to Postulated Accidents**

Issue	GEIS Section	Category
DBAs	4.9.1.2	1
Severe accidents	4.9.1.2	2

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

25 Design-Basis Accidents

26 In order to receive NRC approval to operate a nuclear power facility, an applicant for an initial  
 27 operating license must submit a safety analysis report (SAR) as part of its application. The SAR  
 28 presents the design criteria and design information for the proposed reactor and comprehensive  
 29 data on the proposed site. The SAR also discusses various hypothetical accident situations and  
 30 the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews  
 31 the application to determine whether the plant design meets the Commission’s regulations and  
 32 requirements and includes, in part, the nuclear plant design and its anticipated response to an  
 33 accident.

34 DBAs are those accidents that both the applicant and the NRC staff evaluate to ensure that the  
 35 plant can withstand normal and abnormal transients and a broad spectrum of postulated  
 36 accidents, without undue hazard to the health and safety of the public. Many of these  
 37 postulated accidents are not expected to occur during the life of the plant, but they are  
 38 evaluated to establish the design basis for the preventive and mitigative safety systems of the  
 39 nuclear power plant. Parts 50 and 100 of 10 CFR describe the acceptance criteria for DBAs.

1 The environmental impacts of DBAs are evaluated during the initial licensing process, and the  
2 ability of the plant to withstand these accidents is demonstrated to be acceptable before  
3 issuance of the operating license. The results of these evaluations are found in licensee  
4 documentation such as the applicant's final SAR, the safety evaluation report, the final  
5 environmental statement (FES), and Section 4.11. A licensee is required to maintain the  
6 acceptable design and performance criteria throughout the life of the plant, including any  
7 extended-life operation. The consequences for these events are evaluated for the hypothetical  
8 maximum exposed individual; as such, changes in the plant environment will not affect these  
9 evaluations. Because of the requirements that continuous acceptability of the consequences  
10 and aging management programs be in effect for the period of extended operation, the  
11 environmental impacts as calculated for DBAs should not differ significantly from initial licensing  
12 assessments over the life of the plant, including the period of extended operation. Accordingly,  
13 the design of the plant relative to DBAs during the period of extended operation is considered to  
14 remain acceptable, and the environmental impacts of those accidents were not examined  
15 further in the GEIS.

16 The Commission has determined that the environmental impacts of DBAs are of SMALL  
17 significance for all plants because the plants were designed to successfully withstand these  
18 accidents. Therefore, for the purposes of license renewal, DBAs are designated as a  
19 Category 1 issue. The early resolution of the DBAs makes them a part of the current licensing  
20 basis of the plant; the current licensing basis of the plant is to be maintained by the licensee  
21 under its current license and, therefore, under the provisions of 10 CFR 54.30, is not subject to  
22 review under license renewal.

23 No new and significant information related to DBAs was identified during the review of the WF3  
24 ER (Entergy 2016a), site audit, the scoping process, or evaluation of other available information.  
25 Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.

#### 26 Severe Accidents

27 Severe nuclear accidents are those that are more severe than DBAs because they could result  
28 in substantial damage to the reactor core, whether or not there are serious offsite  
29 consequences. In the GEIS, the NRC staff assessed the effects of severe accidents during the  
30 period of extended operation, using the results of existing analyses and site-specific information  
31 to conservatively predict the environmental impacts of severe accidents for each plant during  
32 the period of extended operation.

33 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,  
34 fires, and sabotage traditionally have not been discussed in quantitative terms in FESs and  
35 were not specifically considered for the WF3 site in the GEIS (NRC 1996, 2013a). However, the  
36 GEIS evaluated existing impact assessments performed by the NRC staff and by the industry at  
37 44 nuclear plants in the United States and concluded that the risk from beyond-design-basis  
38 earthquakes at existing nuclear power plants is SMALL. The GEIS for license renewal  
39 performed a discretionary analysis of terrorist acts in connection with license renewal, and  
40 concluded that the core damage and radiological release from such acts would be no worse  
41 than the damage and release expected from internally initiated events. In the GEIS, the NRC  
42 concludes that the risk from sabotage and beyond-design-basis earthquakes at existing nuclear  
43 power plants is small and, additionally, that the risks from other external events are adequately  
44 addressed by a generic consideration of internally initiated severe accidents (NRC 1996,  
45 2013a).

46 Based on information in the GEIS, the staff found the following to be true:

47           The probability weighted consequences of atmospheric releases, fallout onto  
48           open bodies of water, releases to groundwater, and societal and economic

## Environmental Consequences and Mitigating Actions

1 impacts from severe accidents are small for all plants. However, alternatives to  
2 mitigate severe accidents must be considered for all plants that have not  
3 considered such alternatives.

4 The NRC staff identified no new and significant information related to postulated accidents  
5 during the review of Entergy's ER for WF3 (Entergy 2016a), the site audit, the scoping process,  
6 or evaluation of other available information. Therefore, there are no impacts related to these  
7 issues beyond those discussed in the GEIS. However, in accordance with  
8 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation alternatives  
9 (SAMAs) for WF3.

### 10 Severe Accident Mitigation Alternatives

11 The NRC regulation 10 CFR 51.53(c)(3)(ii)(L) requires license renewal applicants to consider  
12 alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the  
13 applicant's plant in an environmental impact statement or related supplement. The purpose of  
14 this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with  
15 the potential for improving severe accident safety performance are identified and evaluated.  
16 SAMAs have not been previously considered for WF3; therefore, the remainder of this section  
17 addresses those alternatives.

#### 18 *Overview of SAMA Process*

19 This section presents a summary of the SAMA evaluation for WF3 conducted by Entergy  
20 Louisiana, LLC and Entergy Operations, Inc. (Entergy) and the NRC staff's review of that  
21 evaluation. The NRC staff performed its review with contract assistance from Pacific Northwest  
22 National Laboratory. The NRC staff's review is available in full in Appendix F; Entergy's SAMA  
23 evaluation is available in WF3's ER (Entergy 2016a, 2017a, 2017b).

24 The SAMA evaluation for WF3 was conducted using a four-step approach. In the first step,  
25 Entergy quantified the level of risk associated with potential reactor accidents using the  
26 plant-specific probabilistic safety assessment (PSA) and other risk models.

27 In the second step, Entergy examined the major risk contributors and identified possible  
28 methods (SAMAs) of reducing that risk. Common methods of reducing risk are changes to  
29 components, systems, procedures, and training. Entergy initially identified 201 potential SAMAs  
30 for WF3. Entergy performed an initial screening to determine if any SAMAs could be eliminated  
31 because they are not applicable to WF3 because of design differences, or had already been  
32 implemented at WF3, or were combined into a more comprehensive or plant-specific SAMA. As  
33 a result of this initial screening, 75 unique SAMAs remained for further evaluation.

34 In the third step, Entergy estimated the benefits and the costs associated with each of the  
35 SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates  
36 were developed in terms of dollars in accordance with NRC guidance for performing regulatory  
37 analyses (NRC 1997). The cost of implementing the proposed SAMAs was also estimated.

38 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were  
39 compared to determine whether the SAMA was cost beneficial, meaning the benefits of the  
40 SAMA were greater than the cost (a positive cost benefit). Entergy concluded in its ER that  
41 several of the SAMAs evaluated are potentially cost beneficial (Entergy 2016a, 2017a).

42 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging  
43 during the period of extended operation; therefore, they need not be implemented as part of  
44 license renewal pursuant to 10 CFR Part 54. Entergy's SAMA analyses and the NRC's review  
45 are discussed in more detail below.

1 *Estimate of Risk*

2 Entergy submitted an assessment of SAMAs for WF3 as part of the ER (Entergy 2016a, 2017a,  
 3 2017b). This assessment was based on the most recent revision of the WF3 PSA, a plant  
 4 specific offsite consequence analysis performed using the MELCOR Accident Consequence  
 5 Code System 2 (MACCS) computer program, and insights from the WF3 individual plant  
 6 examination (IPE) (Entergy 1992), individual plant examination of external events (IPEEE)  
 7 (Entergy 1995), the WF3 internal flooding PSA, and the updated WF3 fire PSA.

8 Entergy combined two distinct analyses to form the basis for the risk estimates used in the  
 9 SAMA analysis: (i) the WF3 Level 1 and 2 PSA model and (ii) a supplemental analysis of offsite  
 10 consequences and economic impacts (essentially a Level 3 PSA model) developed specifically  
 11 for the SAMA analysis. The scope of the models does not include external events or internal  
 12 flooding events.

13 The WF3 core damage frequency (CDF) for internal events is  $1.1 \times 10^{-5}$  per year. The  
 14 breakdown of CDF by initiating event for WF3 is provided in Table 4–16 for internal events.  
 15 Entergy used the PSA model for WF3 in determining the potential risk reduction benefits of each  
 16 SAMA. Entergy accounted for the potential risk reduction benefits associated with external  
 17 events (e.g., fire, seismic, high wind, and other events) and internal flooding events by  
 18 multiplying the estimated benefits obtained from the WF3 PSA by a factor of 3.57.

19 **Table 4–16. WF3 Core Damage Frequency for Internal Events**

Initiating Event	CDF (per year)	% CDF Contribution
Loss of offsite power initiator	$4.4 \times 10^{-6}$	42
Loss of 4.16 kV Bus 3B3-S	$2.5 \times 10^{-6}$	24
Small loss-of-coolant accident (LOCA)	$9.5 \times 10^{-7}$	9
Loss of 4.16 kV Bus 3A3-S	$8.8 \times 10^{-7}$	8
Inadvertent open relief valve	$4.8 \times 10^{-7}$	5
Turbine trip (general transient)	$2.0 \times 10^{-7}$	2
Reactor trip (general transient)	$1.2 \times 10^{-7}$	1
Other initiating events <sup>1</sup>	$9.3 \times 10^{-7}$	9
<b>Total CDF (Internal Events)</b>	<b><math>1.1 \times 10^{-5}</math></b>	<b>100</b>

<sup>1</sup> Multiple initiating events with each contributing less than 1 percent

20 Entergy estimated the population dose risk within 50 mi (80 km) of the WF3 site to be  
 21 approximately 0.171 person-Sievert (Sv) (17.1 person-rem) per year (Entergy 2017a). The  
 22 breakdown of the total population dose risk and offsite economic cost risk by containment  
 23 release mode is summarized in Table 4–17. Large early containment failures and interfacing  
 24 system loss-of-coolant accidents (LOCAs) are the dominant contributors to population dose risk.

1 **Table 4–17. Breakdown of Population Dose and Offsite Economic Cost by Containment**  
 2 **Release Mode<sup>1</sup>**

Containment Release Mode	Population Dose (Person-Rem <sup>2</sup> Per Year)	Percent Contribution	Offsite Economic Cost (\$/year)	Percent Contribution
High/Early Release <sup>4</sup>	6.0	35	5.4×10 <sup>4</sup>	33
High/Intermediate Release <sup>4</sup>	10.5	61	1.1×10 <sup>5</sup>	66
Intact Containment	0.47	3	4.6×10 <sup>2</sup>	<1
Other	0.19	1	1.2×10 <sup>3</sup>	<1
<b>Total<sup>3</sup></b>	<b>17.1</b>	<b>100</b>	<b>1.6×10<sup>5</sup></b>	<b>100</b>

<sup>1</sup> Values are calculated by the NRC staff based on revised ER Table D.1-12 (Entergy 2017a).

<sup>2</sup> One person-rem = 0.01 person-Sv.

<sup>3</sup> Column totals may be different due to round off.

<sup>4</sup> Magnitude of release/timing of release (see Appendix F for definitions).

3 The NRC staff has reviewed Entergy's data and evaluation methods and concludes that the  
 4 quality of the risk analyses is adequate to support an assessment of the risk reduction potential  
 5 for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs,  
 6 offsite doses, and offsite economic costs reported by Entergy.

7 *Potential Plant Improvements*

8 Once the dominant contributors to plant risk were identified, Entergy searched for ways to  
 9 reduce that risk. In identifying potential SAMAs, Entergy considered SAMAs identified in  
 10 industry documents, including the SAMA analyses performed for other operating plants, insights  
 11 from the plant-specific PSA models, plant improvements identified in the WF3 IPE, and plant  
 12 improvements identified in the WF3 IPEEE. Entergy identified 201 potential risk-reducing  
 13 improvements (SAMAs) to plant components, systems, procedures, and training.

14 In evaluating potential SAMAs, Entergy performed a qualitative screening and eliminated  
 15 127 SAMAs from further consideration because they are not applicable to WF3 because of  
 16 design differences, or they had already been implemented at WF3, or they were similar in  
 17 nature or could be combined with another SAMA. In response to an NRC RAI question, one  
 18 additional SAMA was added for further evaluation. A detailed cost-benefit analysis was  
 19 performed for each of the 75 remaining SAMAs.

20 The staff concludes that Entergy used a systematic and comprehensive process for identifying  
 21 potential plant improvements for WF3 and that the set of SAMAs evaluated in the ER, together  
 22 with those evaluated in response to NRC staff inquiries, is reasonably comprehensive and,  
 23 therefore, acceptable.

24 *Evaluation of Risk Reduction and Costs of Improvements*

25 Entergy evaluated the risk reduction potential of the 75 candidate SAMAs and others identified  
 26 in response to NRC staff inquiries. The SAMA evaluations were performed using generally  
 27 conservative assumptions. Entergy used PSA model requantification to determine the potential  
 28 benefits for each SAMA, except for those SAMAs that specifically address internal floods and  
 29 internal fires. The CDF, population dose, and offsite economic cost reductions for internal  
 30 events were estimated using the WF3 PRA models (Entergy 2016a, 2017a). For the internal  
 31 flooding related SAMAs, Entergy used the WF3 flooding analysis to estimate the reduction in

1 CDF. The ratio of this CDF reduction to the total CDF for internal events was multiplied by the  
 2 total present dollar value equivalent associated with completely eliminating severe accidents  
 3 from internal events at WF3 to obtain the benefit for the reduction in internal flood CDF. Entergy  
 4 assumed the three internal fire related SAMAs were cost-beneficial without further analysis.

5 The NRC staff reviewed Entergy's assumptions used to evaluate the benefit or risk reduction  
 6 estimate for each of the plant improvements and concludes that the rationale and assumptions  
 7 for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk  
 8 reduction is higher than what actually would be realized). Accordingly, the NRC staff based its  
 9 estimates of averted risk for the various SAMAs on Entergy's risk-reduction estimates.

10 Entergy estimated the costs of implementing each of the candidate SAMAs through the  
 11 development of WF3-specific cost estimates or with cost estimates developed by other NRC  
 12 licensees for similar improvements at other nuclear power plants. The cost estimates  
 13 conservatively did not account for inflation, include the cost of replacement power during  
 14 extended outages required to implement the modifications, or account for increased  
 15 maintenance or operation costs following SAMA implementation.

16 The NRC staff reviewed the bases for the applicant's cost estimates. For certain improvements,  
 17 the staff also compared the cost estimates to estimates developed elsewhere for similar  
 18 improvements, including estimates developed as part of other licensees' analyses of SAMAs for  
 19 operating reactors. The NRC staff concludes that the cost estimates provided by Entergy are  
 20 sufficient and appropriate for use in the SAMA evaluation.

21 *Cost-Benefit Comparison*

22 • The cost benefit analysis performed by Entergy was based primarily on NUREG/BR-  
 23 0184 (NRC 1997) and was executed consistent with this guidance. Revision 4 of  
 24 NUREG/BR-0058 states that two sets of estimates should be developed—one at  
 25 3 percent and one at 7 percent (NRC 2004). Entergy provided both sets of estimates  
 26 (Entergy 2016a) and based its decisions on potentially cost-beneficial SAMAs on  
 27 these values.

28 • In Entergy's analysis, if the implementation costs for a candidate SAMA exceeded  
 29 the calculated benefit, the SAMA was determined to be not cost beneficial. If the  
 30 SAMA benefit exceeded the estimated cost, the SAMA candidate was considered to  
 31 be potentially cost beneficial. Considering the results from the baseline and  
 32 sensitivity analyses, the full set of potentially cost-beneficial SAMAs identified in the  
 33 ER and in response to NRC staff inquiries are listed below:

- 34 – SAMA No. 1—Provide additional direct current (DC) battery capacity,
- 35 – SAMA No. 2—Replace lead-acid batteries with fuel cells,
- 36 – SAMA No. 3—Provide DC bus cross-ties,
- 37 – SAMA No. 5—Improve 4.16-kV bus cross-tie ability,
- 38 – SAMA No. 7—Install a gas turbine generator,
- 39 – SAMA No. 8—Bury offsite power lines,
- 40 – SAMA No. 9—Add a new backup source of diesel cooling,
- 41 – SAMA No. 26—Install improved reactor coolant pump seals,
- 42 – SAMA No. 34—Use fire water system as a backup for steam generator inventory,

## Environmental Consequences and Mitigating Actions

- 1           – SAMA No. 36—Implement procedures for temporary heating, ventilating, and air  
2           conditioning,
- 3           – SAMA No. 40—Use the fire water system as a backup source for the  
4           containment spray system,
- 5           – SAMA No. 61— Direct steam generator flooding after a steam generator tube  
6           rupture, prior to core damage,
- 7           – SAMA No. 71— Manufacture a gagging device for a steam generator safety  
8           valve and developing a procedure or work order for closing a stuck-open valve,  
9           and
- 10          – SAMA No. 77—Provide a diverse backup auto-start signal for the standby  
11          component cooling water trains on loss of the running train.

12 Entergy indicated that the 14 potentially cost-beneficial SAMAs have been submitted for  
13 detailed engineering project cost-benefit analysis to further evaluate their implementation  
14 (Entergy 2017b). The NRC staff reviewed Entergy’s cost-benefit evaluations of each SAMA and  
15 concluded that the costs of the SAMAs evaluated would be higher than the associated benefits,  
16 except for the potentially cost-beneficial SAMAs discussed above.

### 17 *Conclusions*

18 The NRC staff reviewed Entergy’s analysis and concludes that the methods used and the  
19 implementation of those methods was sound. The treatment of SAMA benefits and costs  
20 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable  
21 and sufficient for the license renewal submittal.

22 The staff agrees with Entergy’s conclusion that the 14 candidate SAMAs discussed in this  
23 section are potentially cost beneficial and are based on conservative treatment of costs,  
24 benefits, and uncertainties. The small number of potentially cost-beneficial SAMAs is consistent  
25 with the low residual level of risk indicated in the WF3 PSA and the fact that Entergy has  
26 already implemented the plant improvements identified from the IPE and IPEEE. Because the  
27 potentially cost-beneficial SAMAs do not relate to aging management during the period of  
28 extended operation, they do not need to be implemented as part of license renewal in  
29 accordance with 10 CFR Part 54. Nevertheless, Entergy stated that each of these potentially  
30 cost-beneficial SAMAs has been submitted for detailed engineering project cost-benefit analysis  
31 to further evaluate their implementation.

### 32 **4.11.2 No-Action Alternative**

33 Human health risks would be smaller following plant shutdown. The reactor unit, which is  
34 currently operating within regulatory limits, would emit less radioactive gaseous, liquid, and solid  
35 material to the environment. In addition, following shutdown, the variety of potential accidents at  
36 the plant (radiological or industrial) would be reduced to a limited set associated with shutdown  
37 events and fuel handling and storage. In Section 4.11.1.1 and 4.11.1.2, the NRC staff  
38 concluded that the impacts of continued plant operation on human health would be SMALL,  
39 except for “Chronic effects of electromagnetic fields (EMFs),” for which the impacts are  
40 UNCERTAIN. In Section 4.11.1.3, the NRC staff concluded that the impacts of accidents during  
41 operation are SMALL. Therefore, as radioactive emissions to the environment decrease, and  
42 as the likelihood and types of accidents decrease following shutdown, the NRC staff concludes  
43 that the risk to human health following plant shutdown would be SMALL.

1 **4.11.3 New Nuclear Alternative**

2 Impacts on human health from construction of one new nuclear unit would be similar to impacts  
 3 associated with the construction of any major industrial facility. Compliance with worker  
 4 protection rules would control those impacts on workers at acceptable levels. Impacts from  
 5 construction on the general public would be minimal, because limiting active construction area  
 6 access to authorized individuals is expected. Impacts on human health from the construction of  
 7 one new nuclear unit would be SMALL.

8 The human health effects from the operation of one new nuclear unit would be similar to those  
 9 of operating the existing WF3 unit. As presented in Section 4.11.1, impacts on human health  
 10 from the operation of WF3 would be SMALL, except for “Chronic effects of electromagnetic  
 11 fields (EMFs),” for which the impacts are UNCERTAIN. Therefore, the impacts on human  
 12 health from the operation of one new nuclear unit would be SMALL.

13 **4.11.4 SCPC Alternative**

14 Impacts on human health from the construction of the SCPC alternative are expected to be  
 15 similar to those experienced during construction of any major industrial facility. Construction  
 16 would increase traffic on local roads, which could affect the health of the general public. Human  
 17 health impacts would be the same for all facilities whether located on greenfield sites, brownfield  
 18 sites, or at an existing plant. Personal protective equipment, training, and engineered barriers  
 19 would protect the workforce (NRC 2013a). Therefore, the NRC staff concludes that the impacts  
 20 on human health from the construction of the SCPC alternative would be SMALL.

21 Coal-fired power generation introduces worker risks from coal and limestone mining; worker and  
 22 public risk from coal, lime, and limestone transportation; worker and public risk from disposal of  
 23 coal-combustion waste; and public risk from inhalation of stack emissions. In addition, human  
 24 health risks are associated with the management and disposal of coal combustion waste. Coal  
 25 combustion generates waste in the form of ash, and equipment for controlling air pollution  
 26 generates additional ash and scrubber sludge. Human health risks may extend beyond the  
 27 facility workforce to the public depending on their proximity to the coal combustion waste  
 28 disposal facility. The character and the constituents of coal combustion waste depend on both  
 29 the chemical composition of the source coal and the technology used to combust it. Generally,  
 30 the primary sources of adverse consequences from coal combustion waste are from exposure  
 31 to sulfur oxide and nitrogen oxide in air emissions and radioactive elements such as uranium  
 32 and thorium, as well as the heavy metals and hydrocarbon compounds contained in fly ash and  
 33 bottom ash, and scrubber sludge (NRC 2013a).

34 Regulatory agencies, including EPA and state agencies, base air emission standards and  
 35 requirements on human health impacts. These agencies also impose site-specific emission  
 36 limits as needed to protect human health. Given the regulatory oversight exercised by the EPA  
 37 and state agencies, the NRC staff concludes that the human health impacts from radiological  
 38 doses and inhaled toxins and particulates generated from the operation of an SCPC alternative  
 39 would be SMALL (NRC 2013a).

40 **4.11.5 NGCC Alternative**

41 Impacts on human health from construction of the NGCC alternative would be similar to effects  
 42 associated with the construction of any major industrial facility. Compliance with worker  
 43 protection rules would control those impacts on workers at acceptable levels. Impacts from  
 44 construction on the general public would be minimal, because crews would limit active

## Environmental Consequences and Mitigating Actions

1 construction area access to authorized individuals. Therefore, the NRC staff concludes that the  
2 impacts on human health from the construction of the NGCC alternative would be SMALL.

3 Impacts from the operation of an NGCC facility include public risk from inhalation of gaseous  
4 emissions. The risk may be attributable to nitrogen oxide emissions that contribute to ozone  
5 formation, which in turn contribute to health risk. Regulatory agencies, including the EPA and  
6 state agencies, base air emission standards and requirements on human health impacts.  
7 These agencies also impose site-specific emission limits as needed to protect human health.  
8 Given the regulatory oversight exercised by EPA and state agencies, the NRC staff concludes  
9 that the human health impacts from the NGCC alternative would be SMALL.

### 10 **4.11.6 Combination Alternative (NGCC, Biomass, and DSM)**

11 Impacts on human health from construction of a combination of NGCC, biomass, and DSM  
12 alternative would be similar to effects associated with the construction of any major industrial  
13 facility. Compliance with worker protection rules and personal protective equipment, training,  
14 and engineered barriers would protect the workforce (NRC 2013a). Impacts from construction  
15 on the general public would be minimal, because crews would limit active construction area  
16 access to authorized individuals. Based on the above, the NRC staff concludes that the impacts  
17 on human health from the construction of the NGCC, biomass, and DSM alternative would be  
18 SMALL.

19 Operational hazards at an NGCC facility are discussed in Section 4.11.5.

20 Operational hazards for biomass energy consists of the direct burning of forest residue/wood  
21 waste, which would likely include forest residue, primary mill residues, secondary mill residues,  
22 or urban wood residues. Given this method of fuel for power generation, the health impacts  
23 would be similar to those found in a fossil-fuel power generation facility. As discussed in the  
24 NGCC alternative, regulations restricting emissions enforced by either EPA or delegated state  
25 agencies have reduced the potential health effects from plant emissions, but they have not  
26 entirely eliminated them. These agencies also impose site-specific emission limits as needed to  
27 protect human health. As discussed in the NGCC alternative, proper emissions controls would  
28 protect workers and the public from the harmful effects of burning the biomass fuel.

29 Operational hazards impacts for the DSM portion of this alternative would be minimal and  
30 localized to activities such as weatherization efficiency of an end user's home or facility. The  
31 GEIS notes that the environmental impacts are likely to be centered on indoor air quality  
32 (NRC 2013a). This is because of increased weatherization of the home in the form of extra  
33 insulation and reduced air turnover rates from the reduction in air leaks. However, the actual  
34 impact is highly site-specific and not yet well established.

35 Therefore, given the expected compliance with worker and environmental protection rules and  
36 the use of personal protective equipment, training, and engineered barriers, the NRC staff  
37 concludes that the potential human health impacts for the NGCC, biomass, and DSM alternative  
38 would be SMALL.

### 39 **4.12 Environmental Justice Impacts**

40 This section describes the potential human health and environmental effects of the proposed  
41 action (license renewal) and alternatives to the proposed action on minority and low-income  
42 populations.

1 **4.12.1 Proposed Action**

2 The environmental justice NEPA issue from Table B–1 in Appendix B to Subpart A of  
 3 10 CFR Part 51, applicable to the license renewal of WF3 is listed in Table 4–18. Section 3.12  
 4 identifies minority and low-income populations living in the vicinity of WF3.

5 **Table 4–18. Environmental Justice NEPA Issue**

Issue	GEIS Section	Category
Minority and low-income populations	4.10.1	2

Source: Table B–1 in Appendix B, Subpart A of 10 CFR Part 51; NRC2013a.

6 The NRC addresses environmental justice matters for license renewal by (1) identifying the  
 7 location of minority and low-income populations that may be affected by the continued operation  
 8 of the nuclear power plant during the license renewal term, (2) determining whether there would  
 9 be any potential human health or environmental effects to these populations and special  
 10 pathway receptors, and (3) determining whether any of the effects may be disproportionately  
 11 high and adverse. Adverse health effects are measured in terms of the risk and rate of fatal or  
 12 nonfatal adverse impacts on human health. Disproportionately high and adverse human health  
 13 effects occur when the risk or rate of exposure to an environmental hazard for a minority or  
 14 low-income population is significant and exceeds the risk or exposure rate for the general  
 15 population or for another appropriate comparison group. Disproportionately high environmental  
 16 effects refer to impacts or risks of impacts on the natural or physical environment in a minority or  
 17 low-income community that are significant and appreciably exceed the environmental impact on  
 18 the larger community. Such effects may include biological, cultural, economic, or social  
 19 impacts.

20 Figures 3-14 and 3-15 show the location of predominantly minority and low-income population  
 21 block groups residing within a 50-mi (80-km) radius of WF3. This area of impact is consistent  
 22 with the impact analysis for public and occupational health and safety, which also focuses on  
 23 populations within a 50-mi (80-km) radius of the plant. Chapter 4 presents the assessment of  
 24 environmental and human health impacts for each resource area. With the exception of aquatic  
 25 resources, the analyses of impacts for all other environmental resource areas indicated that the  
 26 impact from license renewal would be SMALL.

27 Potential impacts on minority and low-income populations (including migrant workers or Native  
 28 Americans) mostly would consist of socioeconomic and radiological effects; however, radiation  
 29 doses from continued operations during the license renewal term are expected to continue at  
 30 current levels, and they would remain within regulatory limits. Section 4.11.1.2 discusses the  
 31 environmental impacts from postulated accidents that might occur during the license renewal  
 32 term, which include both DBAs and severe accidents. In both cases, the Commission has  
 33 generically determined that impacts associated with DBAs are small because nuclear plants are  
 34 designed and operated to successfully withstand such accidents, and the probability weighted  
 35 consequences of severe accidents are small.

36 Therefore, based on this information and the analysis of human health and environmental  
 37 impacts presented in Chapter 4 of this SEIS, there would be no disproportionately high and  
 38 adverse human health and environmental effects on minority and low-income populations from  
 39 the continued operation of WF3 during the license renewal term.

## Environmental Consequences and Mitigating Actions

### 1 *Subsistence Consumption of Fish and Wildlife*

2 As part of addressing environmental justice concerns associated with license renewal, the NRC  
3 staff also assessed the potential radiological risk to special population groups (such as migrant  
4 workers or Native Americans) from exposure to radioactive material received through their  
5 unique consumption practices and interaction with the environment, including subsistence  
6 consumption of fish and wildlife, native vegetation, surface waters, sediments, and local  
7 produce; absorption of contaminants in sediments through the skin; and inhalation of airborne  
8 radioactive material released from the plant during routine operation. The special pathway  
9 receptors analysis is an important part of the environmental justice analysis because  
10 consumption patterns may reflect the traditional or cultural practices of minority and low-income  
11 populations in the area, such as migrant workers or Native Americans. The results of this  
12 analysis is presented here.

13 Section 4–4 of Executive Order 12898 (1994) (59 FR 7629) directs Federal agencies, whenever  
14 practical and appropriate, to collect and analyze information about the consumption patterns of  
15 populations that rely principally on fish and/or wildlife for subsistence and to communicate the  
16 risks of these consumption patterns to the public. In this SEIS, the NRC considered whether  
17 there were any means for minority or low-income populations to be disproportionately affected  
18 by examining impacts on American Indian, Hispanics, migrant workers, and other traditional  
19 lifestyle special pathway receptors. The assessment of special pathways considered the levels  
20 of radiological and nonradiological contaminants in broad leaf vegetation, sediments, water,  
21 milk, and fish on or near WF3.

22 Radionuclides released to the atmosphere may deposit on soil and vegetation; therefore, they  
23 may eventually be incorporated into the human food chain. To assess the impact of WF3  
24 operations to humans from the ingestion pathway, Entergy collects and analyzes samples of air,  
25 water, sediment, milk, fish, and broad leaf vegetation for radioactivity. The following describes  
26 Entergy's Radiological Environmental Monitoring Program (REMP).

27 Entergy has an ongoing comprehensive REMP to assess the impact of WF3 operations on the  
28 environment. To assess the impact of nuclear power plant operations, samples are collected  
29 annually from the environment and analyzed for radioactivity. A plant effect would be indicated  
30 if the radioactive material detected in a sample was larger or higher than background levels.  
31 Two types of samples are collected. The first type, a control sample, is collected from areas  
32 that are beyond the influence of the nuclear power plant or any other nuclear facility. These  
33 samples are used as reference data to determine normal background levels of radiation in the  
34 environment. These samples are then compared with the second type of samples, indicator  
35 samples, collected near the nuclear power plant. Indicator samples are collected from areas  
36 where any contribution from the nuclear power plant will be at its highest concentration. These  
37 samples are then used to evaluate the contribution of nuclear power plant operations to  
38 radiation or radioactivity levels in the environment. An effect would be indicated if the  
39 radioactivity levels detected in an indicator sample was larger or higher than the control sample  
40 or background levels.

41 Samples were collected from the aquatic and terrestrial environment in the vicinity of WF3  
42 in 2015. The aquatic environment includes surface water, fish, and shoreline sediment. Aquatic  
43 monitoring results for 2015 of water, sediment, and fish showed only naturally occurring  
44 radioactivity and radioactivity associated with fallout from past atmospheric nuclear weapons  
45 testing and were consistent with levels measured before the operation of WF3. No radioactivity  
46 was detected greater than the minimum detectable activity in any aquatic sample during 2015,  
47 and no adverse long-term trends were identified in aquatic monitoring data (Entergy 2016a).

1 The terrestrial environment includes airborne particulates, milk, and broad leaf vegetation.  
2 Terrestrial monitoring results for 2015 of milk and broad leaf garden vegetable samples, showed  
3 only naturally occurring radioactivity. The radioactivity levels detected were consistent with  
4 levels measured before the operation of WF3. No radioactivity was detected greater than the  
5 minimum detectable activity in any terrestrial samples during 2015. The terrestrial monitoring  
6 data also showed no adverse trends in the terrestrial environment (Entergy 2016a).

7 Analyses performed on all samples collected from the environment at WF3 in 2015 showed no  
8 significant measurable radiological constituent above background levels. Overall, radioactivity  
9 levels detected in 2015 were consistent with previous levels and with radioactivity levels  
10 measured before the operation of WF3. REMP sampling in 2015 did not identify any  
11 radioactivity above the minimum detectable activity (Entergy 2016a).

12 Based on the radiological environmental monitoring data from WF3, the NRC finds that no  
13 disproportionately high and adverse human health impacts would be expected in special  
14 pathway receptor populations in the region as a result of subsistence consumption of water,  
15 local food, fish, or wildlife. Continued operation of WF3 would not have disproportionately high  
16 and adverse human health and environmental effects on these populations.

#### 17 **4.12.2 No-Action Alternative**

18 Impacts on minority and low-income populations would depend on the number of jobs and the  
19 amount of tax revenues lost by communities in the immediate vicinity of the power plant after  
20 WF3 ceases operations. Not renewing the operating licenses and terminating reactor  
21 operations could have a noticeable impact on socioeconomic conditions in the communities  
22 located near WF3. The loss of jobs and income could have an immediate socioeconomic  
23 impact. Some, but not all, of the 641 employees would begin to leave after reactor operations  
24 are terminated; and overall tax revenue generated by plant operations would be reduced. The  
25 reduction in tax revenue would decrease the availability of public services in St. Charles County,  
26 which could disproportionately affect minority and low-income populations that may have  
27 become dependent on these services. See also Appendix J of NUREG-0586, Supplement 1  
28 (NRC 2002), for additional discussion of these impacts.

#### 29 **4.12.3 New Nuclear Alternative**

30 Potential impacts to minority and low-income populations from the construction of a new nuclear  
31 power plant would mostly consist of environmental and socioeconomic effects (e.g., noise, dust,  
32 traffic, employment, and housing impacts). Noise and dust impacts from construction would be  
33 short term and primarily limited to onsite activities. Minority and low-income populations  
34 residing along site access roads would be affected by increased commuter vehicle traffic during  
35 shift changes and truck traffic. However, these effects would be temporary during certain hours  
36 of the day and would not likely be high and adverse. Increased demand for rental housing  
37 during construction could affect low-income populations. However, given the proximity of WF3  
38 to the New Orleans metropolitan areas, construction workers could commute to the site, thereby  
39 reducing the potential demand for rental housing.

40 Potential impacts to minority and low-income populations from new nuclear power plant  
41 operations would mostly consist of radiological effects; however, radiation doses are expected  
42 to be well within regulatory limits. All people living near the new nuclear power plant would be  
43 exposed to the same potential effects from power plant operations, and permitted air emissions  
44 are expected to remain within regulatory standards.

## Environmental Consequences and Mitigating Actions

1 Based on this information and the analysis of human health and environmental impacts  
2 presented in this SEIS, it is not likely that the construction and operation of a new nuclear power  
3 plant would have disproportionately high and adverse human health and environmental effects  
4 on minority and low-income populations. However, this determination would depend on the  
5 location, plant design, and operational characteristics of the new power plant. Therefore, the  
6 NRC staff cannot determine whether this alternative would result in disproportionately high and  
7 adverse human health and environmental effects on minority and low-income populations.

### 8 **4.12.4 SCPC Alternative**

9 Potential impacts to minority and low-income populations from the construction of a new SCPC  
10 plant would be similar to the impacts described for the new nuclear alternative. Emissions from  
11 the SCPC plant during power plant operations could disproportionately affect nearby minority  
12 and low-income populations. However, permitted air emissions are expected to remain within  
13 regulatory standards.

14 Based on this information and the analysis of human health and environmental impacts  
15 presented in this SEIS, it is not likely that the construction and operation of a new SCPC plant  
16 would have disproportionately high and adverse human health and environmental effects on  
17 minority and low-income populations. However, this determination would depend on the  
18 location, plant design, and operational characteristics of the new power plant at the WF3 site or  
19 at another existing power plant site. Therefore, the NRC cannot determine whether this  
20 alternative would result in disproportionately high and adverse human health and environmental  
21 effects on minority and low-income populations.

### 22 **4.12.5 NGCC Alternative**

23 Potential impacts to minority and low-income populations from the construction of a new NGCC  
24 plant would be similar to the impacts described for the new nuclear alternative. Emissions from  
25 the NGCC plant during power plant operations could disproportionately affect minority and  
26 low-income populations living in the vicinity of the new power plant. However, permitted air  
27 emissions are expected to remain within regulatory standards.

28 Based on this information and the analysis of human health and environmental impacts  
29 presented in this SEIS, it is not likely that the construction and operation of a new NGCC plant  
30 would have disproportionately high and adverse human health and environmental effects on  
31 minority and low-income populations. However, this determination would depend on the  
32 location, plant design, and operational characteristics of the new power plant. Therefore, it  
33 cannot be conclusively determined whether this alternative would result in disproportionately  
34 high and adverse human health and environmental effects on minority and low-income  
35 populations.

### 36 **4.12.6 Combination Alternative (NGCC, Biomass, and DSM)**

37 Potential impacts to minority and low-income populations from the construction of new NGCC  
38 and biomass power plants would be similar to the impacts described for the new nuclear  
39 alternative. No incremental human health or environmental impacts related to construction  
40 would be expected from the DSM component of this alternative.

41 Minority and low-income populations living in close proximity to operating power generating  
42 facilities could be disproportionately affected by emissions associated with NGCC and biomass  
43 power plant operations. However, because emissions are expected to remain within regulatory  
44 standards, impacts from emissions are not expected to be high and adverse.

1 Low-income populations could benefit from weatherization and insulation programs in a DSM  
 2 energy conservation program. This could have a greater effect on low-income populations than  
 3 the general population because low-income households generally experience greater home  
 4 energy burdens than the average household. Low-income populations could also be  
 5 disproportionately affected by increased utility bills due to increasing power costs. However,  
 6 programs, such as the Louisiana Low Income Home Energy Assistance Program, are available  
 7 to assist low-income families in paying for electricity.

8 Overall, the construction and operation of the NGCC and biomass-fired plants and DSM  
 9 activities would not likely have disproportionately high and adverse human health and  
 10 environmental effects on minority and low-income populations. However, this determination  
 11 would depend on the location, plant design, and operational characteristics of the new power  
 12 plants. Therefore, it cannot be conclusively determined whether this alternative would result in  
 13 disproportionately high and adverse human health and environmental effects on minority and  
 14 low-income populations.

15 **4.13 Waste Management and Pollution Prevention**

16 This section describes the potential impacts of the proposed action (license renewal) and  
 17 alternatives to the proposed action on waste management and pollution prevention.

18 **4.13.1 Proposed Action**

19 The waste management issues applicable to WF3 are discussed below and listed in  
 20 Table 4–19. Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more  
 21 information on these issues.

22 **Table 4–19. Waste Management Issues**

Issue	GEIS Section	Category
Low-level waste storage and disposal	4.11.1.1	1
Onsite storage of spent nuclear fuel	4.11.1.2 <sup>(a)</sup>	1
Offsite radiological impacts of spent nuclear fuel and high-level waste disposal	4.11.1.3 <sup>(b)</sup>	1
Mixed-waste storage and disposal	4.11.1.4	1
Nonradioactive waste storage	4.11.1.4	1

<sup>(a)</sup> The environmental impact of this issue for the timeframe beyond the licensed life for reactor operations is discussed in NUREG-2157 (NRC 2014a).

<sup>(b)</sup> The technical feasibility of disposal in a geologic repository is discussed in NUREG-2157 (NRC 2014a).

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

23 The NRC staff’s evaluation of the environmental impacts associated with spent nuclear fuel is  
 24 addressed in two issues in Table 4–19, “Onsite storage of spent nuclear fuel” and “Offsite  
 25 radiological impacts of spent nuclear fuel and high-level waste disposal.” The onsite storage of  
 26 spent nuclear fuel issue now incorporates the generic environmental impact determinations  
 27 codified in Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51 and in the revised

1 10 CFR 51.23 pursuant to the Continued Storage Rule (79 FR 56238).<sup>6</sup> The offsite radiological  
2 impacts of spent nuclear fuel and high-level waste disposal issue are codified in Table B-1 in  
3 Appendix B, Subpart A, to 10 CFR Part 51 and the technical feasibility of disposal in a geologic  
4 repository is discussed in NUREG-2157.

5 The NRC staff did not identify any new and significant information related to waste management  
6 issues listed in Table 4-19 during its review of the applicant's ER (Entergy 2016a), the site visit,  
7 or the scoping process. Therefore, there are no impacts related to these issues beyond those  
8 discussed in the GEIS (NRC 2013a) and the *Generic Environmental Impact Statement for*  
9 *Continued Storage of Spent Nuclear Fuel, Volumes 1 and 2* (NUREG-2157) (NRC 2014a).  
10 During the license renewal term, for these Category 1 issues discussed in the GEIS, the NRC  
11 staff concludes that the impacts are SMALL.

#### 12 **4.13.2 No-Action Alternative**

13 If the no-action alternative were implemented, WF3 would cease operation at the end of the  
14 term of the initial operating licenses, or sooner, and enter decommissioning. The plant, which is  
15 currently operating within regulatory limits, would generate less spent nuclear fuel and emit less  
16 gaseous and liquid radioactive effluents into the environment. In addition, following shutdown,  
17 the variety of potential accidents at the plant (radiological and industrial) would be reduced to a  
18 limited set associated with shutdown events and fuel handling and storage. In Section 4.15.2  
19 of this SEIS, the NRC staff concludes that the impacts from decommissioning would be SMALL.  
20 Therefore, as radioactive emissions to the environment decrease, and the likelihood and variety  
21 of accidents decrease following shutdown and decommissioning, the NRC staff concludes that  
22 impacts from implementation of the no-action alternative would be SMALL.

#### 23 **4.13.3 New Nuclear Alternative**

24 Construction-related debris would be generated during construction activities, and would be  
25 recycled or disposed of in approved landfills.

26 During normal plant operations, routine plant maintenance and cleaning activities would  
27 generate radioactive low-level waste, spent nuclear fuel, and high-level waste, as well as  
28 nonradioactive waste. Sections 3.1.4 and 3.1.5 discuss radioactive and nonradioactive waste  
29 management at WF3. Quantities of radioactive and nonradioactive waste generated by WF3  
30 would be comparable to that generated by the new nuclear plant.

31 According to the GEIS (NRC 2013a), the generation and management of solid radioactive and  
32 nonradioactive waste during the license renewal term are not expected to result in significant  
33 environmental impacts.

34 Based on this information, the waste impacts would be SMALL for the new nuclear alternative.

#### 35 **4.13.4 SCPC Alternative**

36 Construction-related debris would be generated during plant construction activities and recycled  
37 or disposed of in approved landfills.

38 Coal combustion generates waste in the form of fly ash and bottom ash. In addition, equipment  
39 for controlling air pollution generates additional ash, spent selective catalytic reduction (SCR)

---

<sup>6</sup> 79 FR 56238. U.S. Nuclear Regulatory Commission. "Continued Storage of Spent Nuclear Fuel" *Federal Register* 79 (182):56238-56263. September 19, 2014.

1 catalyst, and scrubber sludge. The management and disposal of the large amounts of coal  
2 combustion waste is a significant part of the operation of a coal-fired power generating facility.  
3 Although a coal-fired power generating facility is likely to use offsite disposal of coal combustion  
4 waste, some short-term storage of coal combustion waste (either in open piles or in surface  
5 impoundments) is likely to take place on site, thus establishing the potential for leaching of toxic  
6 chemicals into the local environment.  
7 Based on the large volume, as well as the toxicity of waste generated by coal combustion, the  
8 NRC staff concludes that the impacts from waste generated at a coal-fired plant would be  
9 MODERATE.

#### 10 **4.13.5 NGCC Alternative**

11 Construction related debris would be generated during plant construction activities and recycled  
12 or disposed of in approved landfills.

13 Waste generation from NGCC technology would be minimal. The only significant waste  
14 generated at an NGCC power plant would be spent SCR catalyst, which is used to control  
15 nitrogen oxide emissions.

16 The spent catalyst would be regenerated or disposed of off site. Other than the spent SCR  
17 catalyst, waste generation at an operating natural gas-fired plant would be limited largely to  
18 typical operations and maintenance of nonhazardous waste. Overall, the NRC staff concludes  
19 that waste impacts from the NGCC alternative would be SMALL.

#### 20 **4.13.6 Combination Alternative (NGCC, Biomass, and DSM)**

21 The waste impacts at an NGCC facility are discussed in Section 4.13.5.

22 During construction of the biomass-fired plants, land clearing and other construction activities  
23 would generate waste that could be recycled, disposed of on site, or shipped to an offsite waste  
24 disposal facility. A wood biomass-fired plant may use as fuel the residues from forest clear cut  
25 and thinning operations, noncommercial species, or harvests of forests for energy purposes. In  
26 addition to the gaseous emissions, wood ash is the primary waste product of wood combustion.

27 For DSM, there may be an increase in wastes generated during installation or implementation of  
28 energy conservation measures, such as appropriate disposal of old appliances, installation of  
29 control devices, and building modifications. New and existing recycling programs would help  
30 minimize the amount of generated waste.

31 Overall, the NRC staff concludes that waste impacts for the NGCC, biomass, and DSM  
32 alternative would be SMALL.

#### 33 **4.14 Evaluation of New and Potentially Significant Information**

34 New and significant information must be new based on a review of the GEIS (NRC 2013a) as  
35 codified in Table B–1 of Appendix B to Subpart A of 10 CFR Part 51 and must bear on the  
36 proposed action or its impacts, presenting a seriously different picture of the impacts from those  
37 envisioned in the GEIS (i.e., impacts of greater severity than impacts considered in the GEIS,  
38 considering their intensity and context).

39 In accordance with 10 CFR 51.53(c), the ER that the applicant submits must provide an analysis  
40 of the Category 2 issues in Table B–1 of 10 CFR Part 51, Subpart A, Appendix B. Additionally,  
41 it must discuss actions to mitigate any adverse impacts associated with the proposed action and

## Environmental Consequences and Mitigating Actions

1 environmental impacts of alternatives to the proposed action. In accordance with  
2 10 CFR 51.53(c)(3), the ER does not need to contain an analysis of any Category 1 issue  
3 unless there is new and significant information on a specific issue.

4 The NRC process for identifying new and significant information is described in NUREG–1555,  
5 Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants,*  
6 *Supplement 1: Operating License Renewal* (NRC 2013d). The search for new information  
7 includes:

- 8 • review of an applicant’s ER and the process for discovering and evaluating the  
9 significance of new information;
- 10 • review of public comments;
- 11 • review of environmental quality standards and regulations;
- 12 • coordination with Federal, State, and local environmental protection and resource  
13 agencies; and
- 14 • review of technical literature.

15 New information that the staff discovers is evaluated for significance using the criteria set forth  
16 in the GEIS. For Category 1 issues in which new and significant information is identified,  
17 reconsideration of the conclusions for those issues is limited in scope to assessment of the  
18 relevant new and significant information; the scope of the assessment does not include other  
19 facets of an issue that the new information does not affect.

20 The NRC staff reviewed the discussion of environmental impacts associated with operation  
21 during the renewal term in the GEIS and has conducted its own independent review, including a  
22 public involvement process (e.g., public meetings) to identify new and significant issues for the  
23 WF3 license renewal application environmental review. The NRC staff has not identified new  
24 and significant information on environmental issues related to operation of WF3 during the  
25 renewal term. The NRC staff also determined that information provided during the public  
26 comment period did not identify any new issue that requires site-specific assessment.

### 27 **4.15 Impacts Common to All Alternatives**

#### 28 **4.15.1 Fuel Cycle**

29 This section describes the environmental impacts associated with the fuel cycles of the  
30 proposed action and replacement power alternatives. Most replacement power alternatives  
31 employ a set of steps in the utilization of their fuel sources, which can include extraction,  
32 transformation, transportation, and combustion. Emissions generally occur at each stage of the  
33 fuel cycle (NRC 2013a).

##### 34 *4.15.1.1 Uranium Fuel Cycle*

35 The uranium fuel cycle issues applicable to WF3 are discussed below and listed in Table 4–20  
36 for Category 1 issues. Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more  
37 information on these issues.

38 **Table 4–20. Issues Related to the Uranium Fuel Cycle**

Issue	GEIS Section	Category
Offsite radiological impacts—individual impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	1

Issue	GEIS Section	Category
Offsite radiological impacts—collective impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	1
Nonradiological impacts of the uranium fuel cycle	4.12.1.1	1
Transportation	4.12.1.1	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

1 The uranium fuel cycle includes uranium mining and milling, the production of uranium  
 2 hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation  
 3 of radioactive materials, and management of low-level wastes and high-level wastes related to  
 4 uranium fuel cycle activities. The generic potential impacts of the radiological and  
 5 nonradiological environmental impacts of the uranium fuel cycle and transportation of nuclear  
 6 fuel and wastes are described in detail in NUREG–1437 (NRC 2013a).

7 The NRC staff did not identify any new and significant information related to the uranium fuel  
 8 cycle issues “Offsite radiological impacts—individual impacts from other than the disposal of  
 9 spent fuel and high-level waste,” “Offsite radiological impacts—collective impacts from other  
 10 than the disposal of spent fuel and high-level waste,” and “Nonradiological impacts of the  
 11 uranium fuel cycle,” listed above in Table 4–20, during its review of the applicant’s ER (Energry  
 12 2016a), the site visit, and the scoping process. Therefore, there are no impacts related to these  
 13 issues beyond those discussed in the GEIS. For these Category 1 issues, the GEIS concludes  
 14 that the impacts are SMALL, except for the issue, “Offsite radiological impacts—collective  
 15 impacts,” to which the NRC has not assigned an impact level. This issue assesses the  
 16 100-year radiation dose to the U.S. population (i.e., collective effects or collective dose) from  
 17 radioactive effluent released as part of the uranium fuel cycle for a nuclear power plant during  
 18 the license renewal term compared to the radiation dose from natural background exposure. It  
 19 is a comparative assessment for which there is no regulatory standard to base an impact level.

20 *4.15.1.2 Replacement Power Plant Fuel Cycles*

21 Fossil Fuel Energy Alternatives

22 Fuel cycle impacts for a fossil fuel fired plant result from the initial extraction of fuel, cleaning  
 23 and processing of fuel, transport of fuel to the facility, and management and ultimate disposal of  
 24 solid wastes from fuel combustion. These impacts are discussed in more detail in  
 25 Section 4.12.1.2 of the GEIS (NRC 2013a) and generally can include:

- 26 • significant changes to land use and visual resources;
- 27 • impacts to air quality, including release of criteria pollutants, fugitive dust, VOCs, and
- 28 coalbed methane in the atmosphere;
- 29 • noise impacts;
- 30 • geology and soil impacts due to land disturbances and mining;
- 31 • water resource impacts, including degradation of surface water and groundwater
- 32 quality;
- 33 • ecological impacts, including loss of habitat and wildlife disturbances;
- 34 • historic and cultural resources impacts within the mine footprint;

## Environmental Consequences and Mitigating Actions

- 1 • socioeconomic impacts from employment of both the mining workforce and service
- 2 and support industries;
- 3 • environmental justice impacts;
- 4 • health impacts to workers from exposure to airborne dust and methane gases; and
- 5 • generation of coal and industrial wastes.

### 6 New Nuclear Energy Alternatives

7 Uranium fuel cycle impacts for a nuclear plant result from the initial extraction of fuel, transport  
8 of fuel to the facility, and management and ultimate disposal of spent fuel. The environmental  
9 impacts of the uranium fuel cycle are discussed above in Section 4.15.1.

### 10 Renewable Energy Alternatives

11 The “fuel cycle” for renewable energy facilities is difficult to define for different technologies  
12 because these natural resources exist regardless of any effort to harvest them for electricity  
13 production. Impacts from the presence or absence of these renewable energy technologies are  
14 often difficult to determine (NRC 2013a).

## 15 **4.15.2 Terminating Power Plant Operations and Decommissioning**

16 This section describes the environmental impacts associated with the termination of operations  
17 and the decommissioning of a nuclear power plant and replacement power alternatives. All  
18 operating power plants will terminate operations and be decommissioned at some point after the  
19 end of their operating life or after a decision is made to cease operations. For the proposed  
20 action, license renewal would delay this eventuality for an additional 20 years beyond the  
21 current license period, which ends in 2024.

### 22 *4.15.2.1 Existing Nuclear Power Plant*

23 Environmental impacts from the activities associated with the decommissioning of any reactor  
24 before or at the end of an initial or renewed license are evaluated in Supplement 1 of  
25 NUREG–0586, *Final Generic Environmental Impact Statement on Decommissioning of Nuclear*  
26 *Facilities* (NRC 2002). Additionally, the incremental environmental impacts associated with  
27 decommissioning activities resulting from continued plant operation during the renewal term are  
28 discussed in the GEIS.

29 Table 4–21 lists the Category 1 issues in Table B-1 of Title 10 of the CFR Part 51, Subpart A,  
30 Appendix B that are applicable to WF3 decommissioning following the license renewal term.

31 **Table 4–21. Issues Related to Decommissioning**

Issue	GEIS Section	Category
Termination of plant operations and decommissioning	4.12.2.1	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

32 Decommissioning would occur whether WF3 were shut down at the end of its current operating  
33 license or at the end of the period of the license renewal term. Entergy stated in its ER  
34 (Entergy 2016a) that it is not aware of any new and significant information on the environmental  
35 impacts of WF3 during the license renewal term. The NRC staff has not found any new and  
36 significant information during its independent review of Entergy’s ER, the site visit, or the  
37 scoping process. Therefore, the NRC staff concludes that there are no impacts related to these

1 issues, beyond those discussed in the GEIS. For all of these issues, the NRC staff concluded in  
2 the GEIS that the impacts are SMALL.

#### 3 *4.15.2.2 Replacement Power Plants*

##### 4 Fossil Fuel Energy Alternatives

5 The environmental impacts from the termination of power plant operations and  
6 decommissioning of a fossil fuel-fired plant are dependent on the facility's decommissioning  
7 plan. General elements and requirements for a fossil fuel plant decommissioning plan are  
8 discussed in Section 4.12.2.2 of the GEIS and can include the removal of structures to at least  
9 3 ft (1 m) below grade; removal of all coal, combustion waste, and accumulated sludge; removal  
10 of intake and discharge structures; and the cleanup and remediation of incidental spills and  
11 leaks at the facility. The decommissioning plan outlines the actions necessary to restore the  
12 site to a condition equivalent in character and value to the site on which the facility was first  
13 constructed (NRC 2013a).

14 The environmental consequences of decommissioning are discussed in Section 4.12.2.2 of the  
15 GEIS and can generally include the following:

- 16 • short-term impacts on air quality and noise from the deconstruction of facility  
17 structures,
- 18 • short-term impacts on land use and visual resources,
- 19 • long-term reestablishment of vegetation and wildlife communities,
- 20 • socioeconomic impacts due to decommissioning the workforce and the long-term  
21 loss of jobs, and
- 22 • elimination of health and safety impacts on operating personnel and general public.

##### 23 New Nuclear Alternatives

24 Termination of operations and decommissioning impacts for a nuclear plant include all activities  
25 related to the safe removal of the facility from service and the reduction of residual radioactivity  
26 to a level that permits release of the property under restricted conditions or unrestricted use and  
27 termination of a license (NRC 2013a). The environmental impacts of the uranium fuel cycle are  
28 discussed in Section 4.15.1.1.

##### 29 Renewable Alternatives

30 Termination of power plant operation and decommissioning for renewable energy facilities  
31 would be similar to the impacts discussed for fossil fuel-fired plants above. Decommissioning  
32 would involve the removal of facility components and operational wastes and residues to restore  
33 the site to a condition equivalent in character and value to the site on which the facility was first  
34 constructed (NRC 2013a).

#### 35 **4.15.3 Greenhouse Gas Emissions and Climate Change**

36 The following sections discuss GHG emissions and climate change impacts. Section 4.15.3.1  
37 evaluates GHG emissions associated with operation of WF3 and replacement power  
38 alternatives. Section 4.15.3.2 discusses the observed changes in climate, the potential future  
39 climate change during the license renewal term based on climate model simulations under  
40 future global GHG emission scenarios, and the impacts of climate change on affected  
41 resources. The cumulative impacts of global GHG emissions on climate are discussed in  
42 Section 4.16.11.

1 4.15.3.1 Greenhouse Gas Emissions from the Proposed Project and Alternatives

2 Gases found in the Earth’s atmosphere that trap heat and play a role in the Earth’s climate are  
 3 collectively termed GHGs. GHGs include carbon dioxide (CO<sub>2</sub>); methane (CH<sub>4</sub>); nitrous  
 4 oxide (N<sub>2</sub>O); water vapor (H<sub>2</sub>O); and fluorinated gases, such as hydrofluorocarbons (HFCs),  
 5 perfluorocarbons (PFCs), and sulfur hexafluoride (SF<sub>6</sub>). The Earth’s climate responds to  
 6 changes in concentrations of GHGs in the atmosphere because GHGs affect the amount of  
 7 energy absorbed and heat trapped by the atmosphere. Increasing GHG concentrations in the  
 8 atmosphere generally increase the Earth’s surface temperature. Atmospheric concentrations of  
 9 carbon dioxide, methane, and nitrous oxide have significantly increased since 1750  
 10 (IPCC 2007a, 2013). Carbon dioxide, methane, nitrous oxide, water vapor, and fluorinated  
 11 gases (termed long-lived GHGs) are well mixed throughout the Earth’s atmosphere, and their  
 12 impact on climate is long-lasting as a result of their long atmospheric lifetime (EPA 2009a).  
 13 Carbon dioxide is of primary concern for global climate change, because of its long atmospheric  
 14 lifetime, and it is the primary gas emitted as a result of human activities. Climate change  
 15 research indicates that the cause of the Earth’s warming over the last 50 years is due to the  
 16 buildup of GHGs in the atmosphere, resulting from human activities (USGCRP 2014;  
 17 IPCC 2013). The EPA has determined that GHGs “may reasonably be anticipated both to  
 18 endanger public health and to endanger public welfare” (74 FR 66496).

19 Proposed Action

20 Operation of WF3 emits GHGs directly and indirectly. WF3’s direct GHG emissions result from  
 21 stationary and portable combustion sources (see Table 3-7), electrical equipment, and  
 22 stationary refrigeration appliances (Entergy 2016a). Indirect GHG emissions originate from  
 23 mobile combustion sources (e.g., employee vehicles, visitor and delivery vehicles). Table 4–22  
 24 presents quantified annual direct and indirect GHG emission sources at WF3. Table 4–22 does  
 25 not account for potential GHG emissions from stationary refrigeration appliances, transformers,  
 26 or visitor and delivery vehicles. Entergy does not maintain a comprehensive inventory of GHG  
 27 emissions as a result of operations at WF3, and data pertaining to visitor and delivery vehicles  
 28 were not readily available (Entergy 2016a). During the 2010–2014 timeframe, Entergy did not  
 29 have to add perfluorocarbon to WF3 transformers and, therefore, fugitive emissions were  
 30 negligible (Entergy 2016a). Chlorofluorocarbon and hydrochlorofluorocarbon emissions from  
 31 refrigerant sources can result from leakage, servicing, repair, or disposal of refrigerant sources.  
 32 Chlorofluorocarbons and hydrochlorofluorocarbons are ozone-depleting substances regulated  
 33 by the CAA under Title VI. Entergy maintains a program to manage stationary refrigeration  
 34 appliances at WF3 to recycle, recapture, and reduce emissions of ozone-depleting substances  
 35 (Entergy 2016a). Estimating GHG emissions from refrigerant sources is complicated because  
 36 of their ability to deplete ozone, which is also a GHG, making their global warming potentials  
 37 difficult to quantify. Consequently, they are commonly excluded from GHG inventories  
 38 (EPA 2014).

39 **Table 4–22. Estimated<sup>(a)</sup> GHG Emissions from Operations at WF3 (MT/yr of CO<sub>2e</sub>)**

Year	WF3 Combustion Sources <sup>(b)</sup>	Workforce Commuting <sup>(b)</sup>	Total
2010	650	3,000	3,650
2011	1,500	3,000	4,500
2012	2,100	3,000	5,100
2013	2,800	3,000	5,800
2014	1,700	3,000	4,700

Year	WF3 Combustion Sources <sup>(b)</sup>	Workforce Commuting <sup>(b)</sup>	Total
------	---------------------------------------	------------------------------------	-------

<sup>(a)</sup> Emissions are rounded up

<sup>(b)</sup> Includes stationary and portable diesel and gasoline engines described in Table 3-6.

Sources: Entergy 2016a, 2016b

1 No-Action Alternative

2 As discussed in previous no-action alternative sections, the no-action alternative represents a  
 3 decision by the NRC not to renew the operating license of a nuclear power plant beyond the  
 4 current operating license term. At some point, all nuclear plants will terminate operations and  
 5 undergo decommissioning. The impacts from decommissioning are considered in  
 6 NUREG-0586, *Final Generic Environmental Impact Statement on Decommissioning of Nuclear*  
 7 *Facilities* (NRC 2002). Therefore, the scope of impacts considered under the no-action  
 8 alternative includes the immediate impacts resulting from activities at WF3 that would occur  
 9 between plant shutdown and the beginning of decommissioning (i.e., activities and actions  
 10 necessary to cease operation of WF3). WF3 operations would terminate at or before the end of  
 11 the current license term. When the plant stops operating, a reduction in GHG emissions from  
 12 activities related to plant operation, such as the use of diesel generators and employee vehicles,  
 13 would occur. GHG emissions for the no-action alternative are anticipated to be less than those  
 14 presented in Table 4-22.

15 Since the no-action alternative will result in a loss of power generating capacity due to  
 16 shutdown, GHG emissions associated with replacement baseload power generation are  
 17 discussed below for each replacement power alternative analyzed.

18 New Nuclear Alternative

19 As discussed in Section 2.2.2.1, the new nuclear alternative would consist of a gross capacity of  
 20 1,333 MWe and a capacity factor of 90 percent. The GEIS presents lifecycle GHG emissions  
 21 associated with nuclear power generation. As presented in Tables 4.12-4 through 4.12-6 of the  
 22 GEIS (NRC 2013a), lifecycle GHG emissions from nuclear power generation can range from 1  
 23 to 288 grams carbon dioxide equivalent per kilowatt-hour (g CO<sub>2eq</sub>/kWh). Operation of nuclear  
 24 power plants does not burn fossil fuels to generate electricity and does not directly emit GHGs.  
 25 Sources of GHG emissions from the new nuclear alternative would include stationary  
 26 combustion sources such as diesel generators, boilers, and pumps similar to existing sources at  
 27 WF3 (see Section 3.2.1). The NRC staff estimates that GHG emissions from a new nuclear  
 28 alternative would be similar to those from WF3.

29 SCPC Alternative

30 As discussed in Section 2.2.2.2, the SCPC alternative would consist of two 706-MWe units for a  
 31 total of 1,412 MWe with a capacity factor of 85 percent each. The GEIS (NRC 2013a) presents  
 32 lifecycle GHG emissions associated with coal-power generation. As presented in Table 4.12-4  
 33 of the GEIS, lifecycle GHG emissions from coal-power generation can range from 264 to  
 34 1,689 g CO<sub>2eq</sub>/kWh. The two SCPC 706-MWe units with postcombustion carbon capture  
 35 capabilities have the capacity to remove 90 percent of the carbon dioxide produced from  
 36 operation of the facility (NETL 2010). The NRC staff estimates that direct emissions from  
 37 operation of two 706-MWe units would total 1.8 million tons (1.6 million MT) of CO<sub>2eq</sub> per year.

## Environmental Consequences and Mitigating Actions

### 1 NGCC Alternative

2 The NGCC alternative would consist of two 690 MWe units with a capacity factor of 87 percent  
3 for a total gross capacity of 1,380 MWe. The GEIS (NRC 2013a) presents lifecycle GHG  
4 emissions associated with natural gas power generation. As presented in Table 4.12-5 of the  
5 GEIS, lifecycle GHG emissions from natural gas can range from 120 to 930 g CO<sub>2eq</sub>/kWh. The  
6 NRC staff estimates that direct emissions from operation of two 690 MWe NGCC units would  
7 total 5.2 million tons (4.7 million MT) of CO<sub>2eq</sub>.

### 8 Combination Alternative

9 For the combination alternative, the NRC staff evaluated an NGCC unit with gross capacity of  
10 690 MWe, four biomass-fired units with a gross capacity of 48 MWe each, and DSM programs  
11 to achieve 1,200 MWe in energy savings. GHGs primarily would be emitted from the NGCC  
12 and biomass-fired portions of this combination alternative. The NRC staff estimates that  
13 operation of the NGCC and biomass-fired units would emit a total of 5.1 million tons  
14 (4.6 million MT) of CO<sub>2eq</sub> per year.

### 15 Summary of GHG emissions from the Proposed Action and Alternatives

16 Table 4–23 presents the direct GHG emissions from operation of the proposed action and  
17 alternatives. GHG emissions from the proposed action (license renewal), no-action alternative,  
18 and new nuclear alternative would be the lowest. GHG emissions from the NGCC, SCPC, and  
19 combination alternatives are several orders of magnitude greater than those from continued  
20 operation of WF3. Therefore, if WF3 generating capacity were to be replaced by these three  
21 alternatives, there would be an increase in GHG emissions. Consequently, continued operation  
22 of WF3 (the proposed action) results in GHG emissions avoidance.

23 **Table 4–23. Direct<sup>(a)</sup> GHG Emissions from Operation of the**  
24 **Proposed Action and Alternatives**

Technology/Alternative	CO <sub>2eq</sub> (MT/yr)
Proposed action (WF3 license renewal) <sup>(a)</sup>	2.8×10 <sup>3</sup>
No-action alternative <sup>(b)</sup>	<2.8×10 <sup>3</sup>
New nuclear <sup>(c)</sup>	2.8×10 <sup>3</sup>
SCPC <sup>(d)</sup>	1.6×10 <sup>6</sup>
NGCC <sup>(e)</sup>	4.7×10 <sup>6</sup>
Combination alternative <sup>(f)</sup>	4.6×10 <sup>6</sup>

<sup>(a)</sup> GHG emissions include only direct emissions from combustion sources for the year 2013 presented in Table 4–22. Source: Entergy 2016a, 2016b.

<sup>(b)</sup> Emissions resulting from activities at WF3 that would occur between plant shutdown and the beginning of decommissioning and assumed not to be greater than GHG emissions from operation of WF3.

<sup>(c)</sup> Emissions assumed to be similar to WF3 operation.

<sup>(d)</sup> Emissions from direct combustion of coal and assumes 90 percent removal of the carbon dioxide produced by facility power generation. GHG emissions estimated using emission factors developed by DOE's NETL (NETL 2010).

<sup>(e)</sup> Emissions from direct combustion of natural gas. GHG emissions estimated using emission factors developed by DOE's NETL (NETL 2012).

<sup>(f)</sup> Emissions from the NGCC and biomass components of the alternative. GHG emissions estimated using emission factors developed by DOE's National Renewable Energy Laboratory (NREL 1997).

#### 1 4.15.3.2 *Climate Change Impacts to Resource Areas*

2 Climate change is the decades or longer change in climate measurements (e.g., temperature  
3 and precipitation) that has been observed on a global, national, and regional level (IPCC 2007a;  
4 EPA 2016; USGCRP 2014). Climate change can vary regionally, spatially, and seasonally,  
5 depending on local, regional, and global factors. Just as regional climate differs throughout the  
6 world, the impacts of climate change can vary between locations.

7 On a global level, from 1901 to 2015, average surface temperatures rose at a rate of 0.15 °F  
8 (0.08 °C) per decade, and total annual precipitation increased at an average rate of 0.8 in.  
9 (2 cm) per decade (EPA 2016a). The year 2015 was the warmest on record and 2006–2015  
10 was the warmest decade on record (EPA 2016a). The observed global change in average  
11 surface temperature and precipitation has been accompanied by an increase in sea surface  
12 temperatures, a decrease in global glacier ice, an increase in sea level, and changes in extreme  
13 weather events. Such extreme events include an increase in the frequency of heat waves,  
14 heavy precipitation, and recorded maximum daily high temperatures (IPCC 2007a;  
15 USGCRP 2009, 2014; EPA 2016).

16 In the United States, the U.S. Global Change Research Program (USGCRP) reports that, from  
17 1895 to 2012, average surface temperature increased by 1.3 °F to 1.9 °F (0.72 to 1.06 °C) and,  
18 since 1900, average annual precipitation has increased by 5 percent. On a seasonal basis,  
19 warming has been the greatest in winter and spring. Since the 1980s, an increase in the length  
20 of the frost-free season, the period between the last occurrence of 32 °F (0 °C) in the spring and  
21 first occurrence of 32 °F (0 °C) in the fall, has been observed for the contiguous United States;  
22 between 1991 and 2011, the average frost-free season was 10 days longer than between  
23 1901 and 1960 (USGCRP 2014). Observed climate-related changes in the United States  
24 include increases in the frequency and intensity of heavy precipitation, earlier onset of spring  
25 snowmelt and runoff, rise of sea level in coastal areas, increase in occurrence of heat waves,  
26 and a decrease in occurrence of cold waves (USGCRP 2014). Since the 1980s, the intensity,  
27 frequency, and duration of North Atlantic hurricanes has increased; however, there is no trend in  
28 landfall frequency along the U.S. Eastern and Gulf coasts (USGCRP 2014).

29 Temperature data indicate that the Southeast region, where WF3 is located, did not experience  
30 significant warming overall for the time period from 1900 to 2012 (USGCRP 2014). The lack of  
31 warming in the Southeast has been termed the “warming hole” (NOAA 2013a). However,  
32 since 1970, average annual temperatures in the Southeast have risen by 2 °F (1.1 °C) and have  
33 been accompanied by an increase in the number of days with daytime maximum temperatures  
34 above 90 °F (32.2 °C) and nights above 75 °F (23.9 °C) (USGCRP 2009; NOAA 2013b;  
35 IPCC 2007a; USGCRP 2014). Annual average temperature data from the WF3 onsite  
36 meteorological tower for the 1996–2015 period show a large year-to-year variation and no clear  
37 upward or downward trend (Entergy 2016b). Average annual precipitation data for the  
38 Southeast does not exhibit an increasing or decreasing trend for the long-term period (1895–  
39 2011) or a trend in the length of the freeze-free season (NOAA 2013a). However, average  
40 precipitation in the Southeast region has increased in the fall and decreased in the summer  
41 (NOAA 2013a and USGCRP 2009). In addition, very heavy precipitation events (defined as the  
42 heaviest 1 percent of all daily events) have increased by 27 percent across the Southeast as a  
43 whole over the 1958 to 2007 period (USGCRP 2014). Relative sea level along the southeastern  
44 Louisiana coast has increased by more than 8 in. (20 cm) between 1960 and 2015 (EPA  
45 2016a). Sea level rise in coastal Louisiana is partially driven by land subsidence, both as a  
46 result of natural and anthropogenic processes (Jones et al. 2016). As discussed in  
47 Section 3.4.3 of this SEIS, much of southern Louisiana is located on the Mississippi River delta,  
48 which has been built up over many years by sediment deposited by the river. Over time, the

## Environmental Consequences and Mitigating Actions

1 deposited sediments compact, which results in land subsidence of the delta. The extraction of  
2 water, oil, and gas has resulted in further subsidence.

3 Future global GHG emission concentrations (emission scenarios) and climate models are  
4 commonly used to project possible climate change. Climate models indicate that over the next  
5 few decades, temperature increases will continue because of current GHG emission  
6 concentrations in the atmosphere (USGCRP 2014). Over the longer term, the magnitude of  
7 temperature increases and climate change effects will depend on both past and future global  
8 GHG emissions (IPCC 2007c; USGCRP 2009, 2014). Climate model simulations often use  
9 GHG emission scenarios to represent possible future social, economic, technological, and  
10 demographic development that, in turn, drive future emissions. The Intergovernmental Panel on  
11 Climate Change (IPCC) has generated various climate scenarios commonly used by  
12 climate-modeling groups (IPCC 2000). For instance, the A2 scenario is representative of a  
13 high-emission scenario in which GHG emissions continue to rise during the 21st century from  
14 40 gigatons (GT) of CO<sub>2e</sub> per year in 2000 to 140 GT of CO<sub>2e</sub> per year by 2100. The B1  
15 scenario, on the other hand, is representative of a low-emission scenario in which emissions  
16 rise from 40 GT of CO<sub>2e</sub> per year in 2000 to 50 GT of CO<sub>2e</sub> per year mid-century before falling to  
17 30 GT of CO<sub>2e</sub> per year by 2100. Therefore, climate model simulations identify how climate may  
18 change in response to the Earth's atmospheric GHG composition.

19 For the license renewal period of WF3 (2024–2044), climate model simulations (between  
20 2021–2050 relative to the reference period (1971–1999)) indicate an increase in annual mean  
21 temperature in the Southeast region from 1.5–3.5 °F (0.83–1.9 °C), with larger temperature  
22 increases for the northwest part of the region, for both a low- and high-emission-modeled  
23 scenario (NOAA 2013a). Increases in temperature during this time period occurs for all  
24 seasons with the largest increase occurring in the summertime (June, July, and August).  
25 Climate model simulations (for the time period 2021–2050) suggest spatial differences in annual  
26 mean precipitation changes with some areas experiencing an increase and others a decrease in  
27 precipitation. On a seasonal basis, climate models are not in agreement on the sign (increases  
28 or decreases) of precipitation changes. For Louisiana, a 0 to 3 percent decrease in annual  
29 mean precipitation is predicted under both a low- and high-emission-modeled scenario;  
30 however, these changes in precipitation were not significant and the models indicate changes  
31 that are less than normal year-to-year variations (NOAA 2013a). Climate models are not in  
32 agreement when projecting changes in Atlantic hurricane activity; however, models agree that  
33 under a warmer climate, hurricane-associated rainfall rates will increase (USGCRP 2014).

34 Changes in climate have broad implications for public health, water resources, land use and  
35 development, and ecosystems. For instance, changes in precipitation patterns and increase in  
36 air temperature can affect water availability and quality, distribution of plant and animal species,  
37 land use patterns, and land cover, which can, in turn, affect terrestrial and aquatic habitats. The  
38 sections below discuss how future climate change may impact air quality, land use, water  
39 resources, aquatic resources, terrestrial resources, human health, and minority and low-income  
40 populations in the region of interest for WF3. Although the future effects of climate change are  
41 uncertain, the following discussions describe the potential implications of climate change on  
42 affected environmental resource areas.

### 43 Air Quality

44 Air pollutant concentrations result from complex interactions between physical and dynamic  
45 properties of the atmosphere, land, and ocean. The formation, transport, dispersion, and  
46 deposition of air pollutants depend, in part, on weather conditions (IPCC 2007b). Air pollutant  
47 concentrations are sensitive to winds, temperature, humidity, and precipitation (EPA 2009a).

1 Hence, climate change can impact air quality as a result of the changes in meteorological  
2 conditions.

3 Ozone has been found to be particularly sensitive to climate change (IPCC 2007b; EPA 2009b).  
4 Ozone is formed, in part, as a result of the chemical reaction of nitrogen oxides and VOCs in the  
5 presence of heat and sunlight. Nitrogen oxides and VOC sources include both natural  
6 emissions (e.g., biogenic emissions from vegetation or soils) and human activity-related  
7 emissions (e.g., motor vehicles and power plants). Sunshine, high temperatures, and air  
8 stagnation are favorable meteorological conditions to higher levels of ozone (IPCC 2007b;  
9 EPA 2009a). The emission of ozone precursors also depends on temperature, wind, and solar  
10 radiation (IPCC 2007b); both nitrogen oxide and biogenic VOC emissions are expected to be  
11 higher in a warmer climate (EPA 2009b). Although surface temperatures are expected to  
12 increase in the Southeast region, this may not necessarily result in an increase in ozone  
13 concentrations. The observed correlation between increased ozone concentrations and  
14 temperature has been found to occur in polluted and urban regions (those areas where ozone  
15 concentration are greater than 60 parts per billion). Additionally, increases in ozone  
16 concentrations correlated with temperature increases occur in combination with cloud-free  
17 regions and air stagnation episodes (Jacob and Winner 2009; IPCC 2013). Wu et al. (2008)  
18 modeled changes ozone levels in response to climate change and found negligible climate  
19 change-driven in ozone concentrations for the Southeast region. Tao et al. (2007) found  
20 differences in future changes in ozone for the Southeast region with decreases in ozone  
21 concentrations under a low-emission modelled scenario and increase under a high emission  
22 modelled scenario. Wu et al. (2008) found that for the Southeast region, ozone concentration  
23 was insensitive to climate change or had a negligible effect.

#### 24 Land Use

25 Anthropogenic land use is both a contributor to climate change, as well as a receptor of climate  
26 change impacts (Dale 1997). For instance, land cover change accounts for about one-third of  
27 all carbon released into the atmosphere since 1850 (USGCR 2014). The Southeast region has  
28 experienced an expanding population and regional land use changes faster than any other  
29 region in the United States, which has resulted in reduced land available for agriculture and  
30 forests (USGCRP 2014). Since the 1930s, 1,880 mi<sup>2</sup> (3,030 km<sup>2</sup>) of land have been lost as a  
31 result of natural and human-made factors (USGCRP 2014; Coastal Protection and Restoration  
32 Authority 2012). Projections in land use changes between 2010 and 2050 indicate that the  
33 Southeast region will experience a continued increase in exurban and suburban development  
34 and a decrease in forests and cropland land cover (USGCRP 2014). The USGCRP (2014)  
35 indicates that land use changes, such as the continued expansion of urban areas, paired with  
36 climate change effects, such as heavier precipitation events, can exacerbate climate change  
37 effects, including reduced water filtration into the soil and increased surface runoff due to  
38 increases in impervious surface area.

39 Although anthropogenic land uses will contribute to climate change in these and other ways,  
40 land uses also will be affected by climate change in several ways. Changes or fluctuations in  
41 river water and sea levels could result in land use changes along affected water bodies as well  
42 as the possible loss of manmade infrastructure. Increases in sea level rise, as is projected for  
43 coastal areas of the Southeast, can result in land loss of wetlands or barrier islands and erosion  
44 (USGCRP 2014, Figure 25.9; EPA 2016). In its climate change action plan for the Gulf of  
45 Mexico, NMFS (2016) reports that Louisiana may lose as much as an additional 1,750 mi<sup>2</sup>  
46 (2,816 km<sup>2</sup>) over the next 50 years. Such loss would require current infrastructure, including  
47 docks, fish houses, and marinas, as well as commercial buildings and residences to be  
48 modified, abandoned, or relocated to accommodate the rising water levels (NMFS 2016).  
49 Barrier islands, which reduce incoming storm surge and protect against flooding; could be

## Environmental Consequences and Mitigating Actions

1 affected; the loss of barrier islands can result in navigation routes and energy infrastructure  
2 becoming more susceptible to floods. Highway 1 in southern Louisiana is the only road to  
3 Port Fourchon, whose infrastructure supports 18 percent of United States oil and 90 percent of  
4 offshore oil and gas production (USGCRP 2014). Infrastructure impairment as a result of sea  
5 level rise and land loss could adversely affect the energy and transportation infrastructure and  
6 necessitate infrastructure redesign and replacement or its relocation.

### 7 Water Resources

8 Predicted changes in the timing, intensity, and distribution of precipitation likely would result in  
9 changes in surface water runoff affecting water availability across the Southeast. As discussed  
10 above, there is uncertainty associated with future precipitation changes for the Southeast.  
11 However, the USGCRP has reasonable expectation that there will be reduced water availability  
12 due to the increased evaporative losses from rising temperatures alone (USGCRP 2014). The  
13 loss of moisture from soils because of higher temperatures along with evapotranspiration from  
14 vegetation is likely to increase the frequency, duration, and intensity of droughts across the  
15 region into the future (USGCRP 2009, 2014). Across southeastern Louisiana, water demands  
16 due to population growth combined with climate change are projected to increase by 10 to  
17 25 percent by the year 2060. While historically, runoff and streamflow has increased in the  
18 Mississippi Basin (USGCRP 2014), increased evapotranspiration can reduce the volume of  
19 water available for surface runoff and streamflow. Changes in runoff in a watershed along with  
20 reduced stream flows and higher air temperatures all contribute to an increase in the ambient  
21 temperature of receiving waters. Land use changes, particularly those involving the conversion  
22 of natural areas to impervious surface, exacerbate these effects.

23 Climate change impacts on groundwater availability depend on basin geology, frequency and  
24 intensity of high-rainfall periods, recharge, soil moisture, and groundwater and surface water  
25 interactions (USGCRP 2014). Precipitation and evapotranspiration are key drivers in aquifer  
26 recharge. Portions of the Southeast are highly vulnerable to sea level rise, including the  
27 Louisiana coastal regions. Depending on the extent of ice sheet melting, sea level along the  
28 southeastern region of Louisiana could rise by up to 2.3 ft (0.7 m) by 2050 (USGCRP 2014,  
29 Figure 25.3). Higher sea levels will accelerate saltwater intrusion into groundwater sources  
30 near the coast, potentially resulting in the need to develop new water sources further inland  
31 (USGCRP 2014).

### 32 Terrestrial Resources

33 As the climate changes, terrestrial resources will either be able to tolerate the new physical  
34 conditions, such as less water availability, or shift their population range to new areas with a  
35 more suitable climate, or decline and perhaps be extirpated from the area. Scientists currently  
36 estimate that species are shifting their ranges at a rate of between 6.1 to 11 m (20 to 36 ft)  
37 in elevation per decade and 6.1 to 16.9 km (3.8 to 10.5 mi) in latitude per decade  
38 (Chen et al. 2011; Thuiller 2007). Although some species may readily adapt to a changing  
39 climate, others may be more prone to experience adverse effects. For example, species whose  
40 ranges are already limited by habitat loss or fragmentation or that require very specific  
41 environmental conditions may not be able to successfully shift their ranges over time. Migratory  
42 birds that travel long distances also may be disproportionately affected because they may not  
43 be able to pick up on environmental clues that a warmer, earlier spring is occurring in the  
44 United States while they are overwintering in tropical areas. Fraser et al. (2013) found that  
45 songbirds overwintering in the Amazon did not leave their winter sites earlier, even when spring  
46 sites in the Eastern United States experienced a warmer spring. As a result, the song birds  
47 missed periods of peak food availability.

1 Special status species and habitats, such as those that are Federally protected by the ESA,  
2 likely would be more sensitive to climate changes because these species' populations are  
3 already experiencing threats that are endangering their continued existence throughout all or a  
4 significant portion of their ranges. Because of this, these species populations already are  
5 experiencing reduced genetic variability that could prohibit them from adapting to and surviving  
6 amidst habitat and climate changes. Climate changes also could favor non-native invasive  
7 species and promote population increases of insect pests and plant pathogens, which may be  
8 more tolerant to a wider range of climate conditions. Physiological stressors associated with  
9 climate change also may exacerbate the effects of other existing stressors in the natural  
10 environment, such as those caused by habitat fragmentation, nitrogen deposition and runoff  
11 from agriculture, and air emissions.

12 In the Southeast, sea level rise and storm surges likely will result in the loss of coastal, riparian,  
13 and wetland terrestrial habitats. Doyle et al. (2010) report that some tidal freshwater forests are  
14 already retreating, while mangrove forests, which are adapted to coastal conditions, are  
15 expanding landward. As sea level rise progresses, more coastal wetlands in the Southeast will  
16 be inundated (USGCRP 2014). In coastal Louisiana, such inundation has been ongoing for  
17 several decades; 1,880 mi<sup>2</sup> (3,030 km<sup>2</sup>) of land has been lost since the 1930s (USGCRP 2014;  
18 Coastal Protection and Restoration Authority 2012). Increasing temperatures will affect forest  
19 disturbances by insects and pathogens with variable effects. While increasing temperatures  
20 could allow some non-native insects and pathogens to spread and grow more rapidly,  
21 temperatures also have been linked to reductions in infestations. For instance, recent declines  
22 in southern pine beetle epidemics in Louisiana and East Texas have been attributed to rising  
23 temperatures (Friedenberg et al. 2007).

#### 24 Aquatic Resources

25 The potential effects of climate change could result in degradation to aquatic resources in the  
26 Lower Mississippi River. Raised air temperatures likely would increase water temperatures,  
27 increasing the potential for thermal stress to aquatic biota sensitive to warmer water.  
28 Freshwater mussels, for example, are particularly prone to climate change because of their  
29 patchy distribution, limited mobility, and dependence on host fish. Scientists found that as a  
30 result of elevated water temperatures, heart and growth rates of young freshwater species  
31 declined and lethal temperature affecting 50 percent of the mussel population ranged from 77.5  
32 to 86° F (25.3 to 30.3 °C) (Ganser et al. 2013).

33 More rainfall and heavy downpours can increase the rate of runoff and pollutants reaching the  
34 Mississippi River because the heavier precipitation, and the pollutants washed away in the runoff,  
35 has less time to be absorbed in the soil before reaching the river and other surface waterbodies.  
36 Over the past 50 years, as a result of climate change and land use changes, the Mississippi  
37 River Basin is yielding an additional 32 million acre-feet and increased nitrogen loads into the  
38 Gulf of Mexico. Increased runoff also would likely increase the sediment load within the  
39 Mississippi River, and concurrently limit photosynthesis and growth of primary producers that  
40 provide an important base of the riverine food chain.

41 The cumulative effects of increased temperatures, altered river flows, and increased sediment  
42 loading could exacerbate existing environmental stressors, such as excess nutrients and  
43 lowered dissolved oxygen associated with eutrophication (NCADAC 2013). As discussed above  
44 under "terrestrial resources," special status species, such as those that are Federally protected  
45 under the ESA, would be more sensitive to such changes. Invasions of non-native species may  
46 thrive under such changes because many invasive species can tolerate a wide range of  
47 environmental conditions (NRC 2013a). As described in Section 3.7.4, invasive species near

## Environmental Consequences and Mitigating Actions

1 WF3 often outcompete native species for food and space, which could further disrupt the  
2 current structure and function of aquatic communities near WF3.

### 3 Historic and Cultural Resources

4 Changes or fluctuations in sea levels because of climate change could result in the disturbance  
5 or loss of historic and cultural resources from flooding, erosion, inundation, or drying out.  
6 Because of water-level changes, archaeological sites could be lost before they could be  
7 documented or otherwise studied. Depending on the extent and rate of ice sheet melting, sea  
8 levels along the southeastern region of Louisiana could rise up to 2.3 ft (0.7 m) by 2050  
9 (USGCRP 2014, Figure 25.3).

### 10 Socioeconomics

11 Changes in climate conditions could impact certain industries such as tourism and recreation,  
12 which create jobs and bring significant revenue to regional economies. Across the nation,  
13 fishing, hunting, and other outdoor recreational activities contribute to rural economies and have  
14 become part of the cultural tradition. A changing climate could reduce opportunities for these  
15 activities to occur in some areas while expanding opportunities elsewhere. The USGCRP  
16 reports that climate changes in the Southeast region by the year 2050 could create unfavorable  
17 summertime outdoor conditions for recreation and tourism (USGCRP 2014).

18 In 2010, sea ports provided more than 13 million jobs in the United States and handled  
19 90 percent of imported consumer goods (USGCRP 2014). Changes or fluctuations in sea levels  
20 could affect port operations. The port of New Orleans is one of the most vulnerable to sea level  
21 rise. In addition, oil and gas infrastructure along the U.S. Gulf Coast is likely to become  
22 vulnerable to sea level rise and barrier islands deterioration. Highway 1 in southern Louisiana is  
23 the only road to Port Fourchon, whose infrastructure supports 18 percent of U.S. oil and  
24 90 percent of offshore oil and gas production (USGCRP 2014). Flooding on Highway 1 has  
25 become common and the U.S. Department of Homeland Security estimated that a 90-day  
26 shutdown of this highway would cost the United States \$7.8 billion (DHS 2011).

27 Coastal counties and parishes in Alabama, Mississippi, Louisiana and Texas, for instance, have  
28 experienced significant economic losses that average \$14 billion annually from hurricane winds,  
29 land subsidence, and sea level rise; predicted future annual losses could be as high as \$18 to  
30 \$23 billion (USGRCP 2014). Annual damage to capital assets in the Gulf region alone could be  
31 \$2.7 to \$4.6 billion by 2030, and \$8.3 to \$13.2 billion by 2050; about 20 percent of these at-risk  
32 assets are in the oil and gas industry (USGCRP 2014).

### 33 Human Health

34 Increasing temperatures because of changes in climate conditions could impact human health.  
35 The USGCRP (2009) indicates that “infants and children, pregnant women, the elderly, people  
36 with chronic medical conditions, outdoor workers, and people living in poverty are especially at  
37 risk from a variety of climate-related health effects.” Examples of these effects include  
38 increased heat stress, air pollution, extreme weather events, and diseases carried by food,  
39 water, and insects. In addition, the elderly have a reduced ability to regulate their own body  
40 temperature or sense when they are too hot. According to the USGCRP (2009), they “are at  
41 greater risk of heart failure, which is further exacerbated when cardiac demand increases in  
42 order to cool the body during a heat wave.” The USGCRP study also found that people taking  
43 medications, such as diuretics for high blood pressure, have a higher risk of dehydration  
44 (USGCRP 2009). Increased water temperatures also may increase the potential for adverse  
45 effects of thermophilic organisms that can be a threat to human health. However, changes in  
46 climate conditions that may occur during the license renewal term will not result in any change  
47 to the impacts discussed in Section 4.11 from WF3’s radioactive and nonradioactive effluents.

## 1 Environmental Justice

2 Rapid changes in climate conditions could disproportionately affect minority and low-income  
 3 populations. Tribal communities in coastal Louisiana have been experiencing climate change  
 4 induced changes including rising sea levels, saltwater intrusion, erosion, loss of land and  
 5 traditional medicinal plants, forcing communities to relocate or find ways to adapt  
 6 (USGCRP 2014,; Coastal Louisiana Tribal Communities 2012). For instance, in response to  
 7 saltwater intrusion, alternative farming methods have been implemented, including raised-bed  
 8 gardens by the Grand Bayou Village (Coastal Louisiana Tribal Communities 2012). Sea level  
 9 rise will exacerbate ongoing land loss, saltwater intrusion, and other climate change induced  
 10 impacts already affecting Louisiana tribes.

11 The USGCRP (2009) indicates that “people living in poverty are especially at risk from a variety  
 12 of climate-related health effects.” As previously discussed in the section on Human Health,  
 13 these effects include increased heat stress, air pollution, extreme weather events, and diseases  
 14 carried by food, water, and insects. The greatest health burdens are likely to fall on the poor,  
 15 especially those lacking adequate shelter and access to other resources such as air  
 16 conditioning. Elderly poor people on fixed incomes are more likely to have debilitating chronic  
 17 diseases or limited mobility. The USGCRP (2014) study reconfirmed previous report findings  
 18 regarding risks of climate change on low-income populations. The report also warns that  
 19 climate change could affect the availability and access to local plant and animal species,  
 20 thereby impacting the people who have historically depended on them for food or medicine  
 21 (USGCRP 2014). In coastal regions, social and cultural disparities vary regionally and social  
 22 factors (i.e., low-income, minority status, educational achievement) can limit the ability of some  
 23 people to adapt to changing environmental conditions caused by climate change. This can  
 24 result in the displacement of vulnerable minority and low-income populations and lead to social  
 25 disruption.

### 26 *4.15.3.3 Climate Change Mitigation and Adaptation*

27 EPA (2016) defines climate change mitigation as, “[a] human intervention to reduce the human  
 28 impact on the climate system; it includes strategies to reduce greenhouse gas sources and  
 29 emissions and enhancing greenhouse gas sinks.” As discussed in Section 4.15.3.1, GHG  
 30 emissions are emitted from ancillary operations at WF3. As discussed in Section 4.16.11, the  
 31 NRC staff concludes that that the incremental impact from the contribution of GHG emissions  
 32 from continued operation of WF3 on climate change would be SMALL. Based on its limited  
 33 statutory authority under the Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 et seq.),  
 34 the NRC cannot impose mitigation measures or standards on its nuclear power plant licensees  
 35 that are not related to public health and safety from radiological hazards or common defense  
 36 and security. However, mitigation for GHGs emitted from combustion sources at operations can  
 37 be accomplished, as necessary, through the applicable air permitting processes and the  
 38 enforcement of regulatory standards (see Section 3.3.2).

39 Climate change adaptation is defined as the “[a]djustment or preparation of natural or human  
 40 systems to a new or changing environment which moderates harm or exploits beneficial  
 41 opportunities” (EPA 2016a). The Council on Environmental Quality (CEQ) defines climate  
 42 change adaptation and resilience as “adjustments to natural or human systems in response to  
 43 actual or expected climate change changes” (CEQ 2016<sup>7</sup>). The implications of climate change  
 44 on WF3 operations and adjustments or preparations by WF3 to a new or changing environment  
 45 are outside the scope of the NRC’s license renewal environmental review, which documents the

<sup>7</sup> Pursuant to Executive Order 13783, “Promoting Energy Independence and Economic Growth,” CEQ withdrew its “Final Guidance for Federal Departments and Agencies on Consideration of Greenhouse Gas Emissions and the Effects of Climate Change in National Environmental Policy Act Reviews,” for further consideration (82 FR 16576).

## Environmental Consequences and Mitigating Actions

1 potential environmental impacts from continued reactor operations; however, adaptation of WF3  
2 to climate change is addressed through the NRC's ongoing regulatory process. Site-specific  
3 environmental conditions are considered when siting nuclear power plants, including the  
4 consideration of meteorological and hydrologic conditions, as required by 10 CFR Part 100.  
5 WF3 was designed and constructed in accordance with the general design criteria in  
6 Appendix A to 10 CFR Part 50.

7 NRC regulations require that plant structures, systems, and components important to safety be  
8 designed to withstand the effects of natural phenomena, such as flooding, without loss of  
9 capability to perform safety functions. Furthermore, nuclear power plants are required to  
10 operate within technical safety specifications in accordance with the NRC-issued operating  
11 license, which includes specifications for coping with natural phenomena hazards. Any change  
12 to technical specifications would require the NRC to conduct a safety review before allowing  
13 licensees to make operational changes because of changing environmental conditions.

14 Additionally, the NRC evaluates nuclear power plant operating conditions and physical  
15 infrastructure through its reactor oversight program to ensure ongoing safe operations. If new  
16 information about changing environmental conditions becomes available, the NRC will evaluate  
17 the new information to determine whether any safety-related changes are needed at existing  
18 nuclear power plants. Should climate change happen more quickly or change more  
19 substantially than what is currently forecasted, the NRC will evaluate the new information to  
20 determine whether any safety-related changes are needed at existing nuclear power plants.  
21 However, this is a separate and distinct process from the NRC's license renewal environmental  
22 review that is conducted in accordance with NEPA.

### 23 **4.16 Cumulative Impacts of the Proposed Action**

24 The NRC staff considered potential cumulative impacts in the environmental analysis of  
25 continued operation of WF3 during the 20-year license renewal period. Cumulative impacts  
26 may result when the environmental effects associated with the proposed action are overlaid or  
27 added to temporary or permanent effects associated with other past, present, and reasonably  
28 foreseeable actions. Cumulative impacts can result from individually minor, but collectively  
29 significant, actions taking place over a period of time. An impact that may be SMALL by itself  
30 possibly could result in a MODERATE or LARGE cumulative impact when it is considered in  
31 combination with the impacts of other actions on the affected resource. Likewise, if a resource  
32 is regionally declining or imperiled, even a SMALL individual impact could be important if it  
33 contributes to, or accelerates, the overall resource decline.

34 For the purposes of this cumulative analysis, past actions are those before the receipt of the  
35 LRA; present actions are those related to the resources at the time of current operation of the  
36 power plant; and future actions are those that are reasonably foreseeable through the end of  
37 plant operation, including the period of extended operation. Therefore, the analysis considers  
38 potential impacts through the end of the current license terms, as well as the 20-year renewal  
39 license term. The geographic area over which past, present, and reasonably foreseeable  
40 actions would occur depends on the type of action considered and is described below for each  
41 resource area.

42 To evaluate cumulative impacts, the incremental impacts of the proposed action, as described  
43 in Sections 4.2 to 4.15, are combined with other past, present, and reasonably foreseeable  
44 future actions regardless of which agency (Federal or non-Federal) or person undertakes such  
45 actions. The NRC staff used the information provided in Entergy's ER; responses to RAIs;  
46 information from other Federal, State, and local agencies; scoping comments; and information  
47 gathered during the visits to the WF3 site to identify other past, present, and reasonably

1 foreseeable actions. To be considered in the cumulative analysis, the NRC staff determined  
 2 whether the project would occur within the noted geographic areas of interest and within the  
 3 period of extended operation, whether it was reasonably foreseeable, and whether there would  
 4 be a potential overlapping effect with the proposed project. For past actions, consideration  
 5 within the cumulative impacts assessment is resource and project-specific. In general, the  
 6 effects of past actions are included in the description of the affected environment in Chapter 3,  
 7 which serves as the baseline for the cumulative impacts analysis. However, past actions that  
 8 continue to have an overlapping effect on a resource that potentially could be affected by the  
 9 proposed action are considered in the cumulative analysis.

10 Appendix E describes other actions and projects identified during this review and considered in  
 11 the NRC staff's analysis of the potential cumulative effects. Not all actions or projects listed in  
 12 Appendix E are considered in each resource area because of the uniqueness of the resource  
 13 and its geographic area of consideration.

#### 14 **4.16.1 Air Quality and Noise**

##### 15 *4.16.1.1 Air Quality*

16 The region of influence (ROI) considered in the cumulative air quality analysis is the St. Charles  
 17 Parish because in Louisiana, air quality designations are made at the parish level. With regard  
 18 to NAAQS, St. Charles Parish is designated unclassifiable/attainment for all criteria pollutants,  
 19 which means that the parish meets or is cleaner than NAAQS. As noted in Section 3.3.2, air  
 20 emission sources at WF3 include diesel generators, pumps, and portable diesel and gasoline  
 21 engines that are used intermittently. No refurbishment-related activities are proposed during the  
 22 license renewal period. As a result, the NRC staff expects similar emissions during the license  
 23 renewal period, as presented in Section 3.3.2, from operation of WF3.

24 Table E-1 provides a list of present and reasonably foreseeable projects that could contribute to  
 25 cumulative impacts to air quality. The EPA's Enforcement and Compliance History Online  
 26 database identifies 22 facilities that are major sources and 45 facilities that are minor sources of  
 27 air emissions in St. Charles Parish (EPA 2016b). Major sources emit, or have the potential to  
 28 emit, 10 tons per year of any one HAP, 25 tons per year of any combination of HAPs, or  
 29 100 tons per year of any other regulated air contaminant. A minor source has a potential to emit  
 30 air emissions that are less than the threshold levels for a major source. These major sources  
 31 (including Waterford 1 and 2, Occidental Chemical Corporation, and Taft Cogeneration Facility)  
 32 and minor air emission sources currently are operating and, given the designated  
 33 unclassifiable/attainment status for all NAAQS in St. Charles Parish, these emissions have not  
 34 resulted in NAAQS violations. Consequently, cumulative changes to air quality in St. Charles  
 35 Parish would be the result of future projects and actions that change present-day emissions  
 36 within the parish.

37 Development and construction activities identified in Table E-1 (e.g., A.M. Agrigen Industries,  
 38 BeAed Corporation, Kongsberg Maritime) can increase air emissions during their respective  
 39 construction period, but air emissions would be temporary and localized. However, future  
 40 operation of new commercial and industrial facilities (e.g., St. Charles Power Station), increases  
 41 in vehicular traffic, and population growth can result in overall long-term air emissions that  
 42 contribute to cumulative air quality impacts. As discussed in Section 3.10, the population of  
 43 St. Charles Parish is expected to increase at a moderate to low rate. Any new stationary  
 44 sources of emissions that would be established in the region would be required to apply for an  
 45 air permit from LDEQ and be operated in accordance with regulatory requirements.

## Environmental Consequences and Mitigating Actions

1 Climate change can impact air quality as a result of changes in meteorological conditions. Air  
2 pollutant concentrations are sensitive to wind, temperature, humidity, and precipitation  
3 (EPA 2009a). As discussed in Section 4.15.3.2, although surface temperatures are expected to  
4 increase in the Southeast region, increases in ozone concentrations correlated with temperature  
5 increases occurred in combination with cloud-free regions, polluted and urban regions, and air  
6 stagnation episodes (Jacob and Winner 2009; IPCC 2013). Therefore, changes in air emission  
7 concentrations will depend on a combination of changes in meteorological conditions and  
8 precursor concentrations. Furthermore, climate models disagree on ozone concentration  
9 changes in response to climate change models (Jacob and Winner 2009).

10 Given the number of reasonably foreseeable projects that may increase air emissions in the  
11 region, combined with present day emissions from various facilities, the NRC staff concludes  
12 that the cumulative impacts on air quality would be SMALL to MODERATE.

### 13 4.16.1.2 Noise

14 Section 3.3.3 presents a summary of noise sources at WF3 and in the vicinity of the site. The  
15 ROI considered for this cumulative noise impact analysis is a 1-mi (1.6-km) radius from the WF3  
16 site because noise levels attenuate rapidly with distance. For instance, when distance is  
17 doubled from a point source, noise levels decrease by 6 dBA (FHWA 2011).

18 Noise levels in the vicinity of a nuclear power plant could increase from planned activities  
19 associated with urban, industrial, and commercial development. The magnitude of cumulative  
20 impacts depends on the nuclear plant's proximity to other noise sources. Foreseeable future  
21 projects in and around the WF3 site, as identified in Table E-1, can increase noise levels only in  
22 the vicinity of their noise sources. As noted in Table E-1, most of the new projects are not  
23 located within 1 mi (1.6 km) of WF3. Existing projects within the ROI are not anticipated to  
24 increase noise levels and are within a heavy manufacturing zoning district, as described in  
25 Section 3.3.3. Construction activities related to WF3 independent spent fuel storage installation  
26 (ISFSI) expansion and intake canal modifications, and increases in vehicular traffic, could  
27 introduce additional noise sources and levels. However, given the vicinity's existing heavy  
28 manufacturing setting, noise levels from new projects are not expected to be greater than  
29 current levels surrounding the WF3 site. Consequently, the NRC staff concludes that the  
30 cumulative impact to the noise environment from past, present, and reasonably foreseeable  
31 actions would be SMALL.

### 32 4.16.2 Geology and Soils

33 The cumulative impacts on the geologic environment primarily relate to land disturbance and the  
34 potential for soil erosion and loss, as well as the projected consumption of geologic resources.  
35 Ongoing operation and maintenance activities at WF3 are expected to be confined to previously  
36 disturbed areas. Any use of geologic materials, such as aggregates to support operation and  
37 maintenance activities, would be procured from local and regional sources. Thus, activities  
38 associated with continued operations are not expected to affect the geologic environment.

39 The NRC staff assumes that other construction activities would use material from local and  
40 regional sources because these materials are abundant in the region. These identified projects  
41 are of such a scale as to not likely impact regional sources and supplies of the identified  
42 resources. Furthermore, construction activities would need to be conducted in accordance with  
43 State and local requirements. Development activities would be subject to BMPs for soil erosion  
44 and sediment control, which would serve to minimize soil erosion and loss.

45 Land subsidence is a significant issue in the New Orleans area and southern Louisiana.  
46 However, little if any subsidence has been identified at the WF3 site. The continuation of

1 ongoing site activities is not anticipated to contribute to land subsidence. As a result, there is no  
2 significant cumulative effect on land subsidence from the proposed action. Considering ongoing  
3 activities and reasonably foreseeable actions, the NRC staff concludes the cumulative impacts  
4 on geology and soils during the license renewal term would be SMALL.

### 5 **4.16.3 Water Resources**

#### 6 *4.16.3.1 Surface Water Resources*

7 This section addresses the direct and indirect effects of the proposed action (license renewal)  
8 on surface water resources when they are added to the aggregate effects of other past, present,  
9 and reasonably foreseeable future actions. As described in Section 4.5.1.1, the incremental  
10 impacts on surface water resources from continued operations of WF3 during the license  
11 renewal term would be SMALL. The NRC staff has also evaluated other projects and actions  
12 (Table E–1 in Appendix E) as part of its analysis of potential cumulative impacts on surface  
13 water use and quality, along with associated resource trends and climate change  
14 considerations.

15 The description of the affected environment in Section 3.5.1 serves as the baseline for the  
16 cumulative impacts assessment for surface water resources. The geographic area of analysis  
17 considered for the surface water resources component of the cumulative impacts analysis  
18 comprises the Lower Mississippi–New Orleans portion of the Lower Mississippi River Basin  
19 (as described in Section 3.5.1.1), with a detailed focus on a 5-mi (8-km) radius surrounding the  
20 WF3 intake and discharge structures and the three parishes traversed by the river within that  
21 area. As such, this review centered on those projects and activities that would withdraw water  
22 from, or discharge effluents to, the cited segment of the Lower Mississippi River or to  
23 contributing water bodies.

#### 24 Water Use Considerations

25 In support of this cumulative impacts analysis, the NRC staff obtained and evaluated the best  
26 available data on water consumption and projected trends in water use, as compiled by  
27 responsible water resources management agencies. The U.S. Geological Survey (USGS), in  
28 cooperation with the Louisiana Department of Transportation and Development, maintains water  
29 withdrawal and use information for the state of Louisiana. Every 5 years, the USGS publishes a  
30 water use report that presents data by category of use (public supply, industrial, power  
31 generation, livestock, irrigation, and aquaculture) for each parish and surface water basin  
32 (Sargent 2012). Since 2012, the USGS began estimating water withdrawals in Louisiana  
33 annually (USGS 2016a). Data that the USGS collects includes water withdrawals but not  
34 quantify consumptive water use (i.e., water that is withdrawn but not returned to its source).

35 The WF3 site is located along a heavily industrialized segment of the Lower Mississippi River, a  
36 waterway intensively managed and engineered for multiple uses. For the purpose of this  
37 analysis, the Killona segment of the Lower Mississippi River is the stretch of the river that  
38 traverses the parishes of St. John the Baptist, St. Charles (where WF3 is located), and  
39 Jefferson. In these parishes, surface water is withdrawn primarily for public supply; industrial  
40 use (e.g., chemicals, petroleum refining, primary metals); power generation; general irrigation;  
41 and for livestock (Sargent 2012).

42 Table 4–24 presents cumulative surface water withdrawals from the Lower Mississippi River  
43 relative to the three parishes. In 2014, a total of approximately 3,577 mgd (5,534 cfs; 156 m<sup>3</sup>/s)  
44 of surface water was withdrawn within the three parishes included in the Killona segment  
45 (USGS 2016b). As shown in Table 4–24, surface water withdrawals for thermoelectric power  
46 generation account for about 80 percent of the total volume withdrawn. In addition to WF3, this

## Environmental Consequences and Mitigating Actions

1 volume reflects total annual withdrawals for such power generation and industrial facilities as  
 2 the Little Gypsy Power Plant, Waterford 1 and 2, Taft Cogeneration Facility, and Dow St.  
 3 Charles, as described in Table E–1 in Appendix E. However, Table 4–24 does not reflect  
 4 surface water withdrawals for the St. Charles Power Station, which is under construction  
 5 adjacent to the Little Gypsy Power Plant. The NRC staff estimates that operation of this new  
 6 facility using closed-cycle cooling will require an additional 10 mgd (15 cfs; 0.4 m<sup>3</sup>/s) of surface  
 7 water. As further discussed in Section 3.5.1.2, WF3 withdraws an average of 1,029 mgd  
 8 (1,593 cfs; 45.0 m<sup>3</sup>/s) of water from the Mississippi River. Thus, WF3 accounts for about  
 9 30 percent of the total withdrawals from the Killona segment.

10 **Table 4–24. Cumulative Surface Water Withdrawals from the Lower Mississippi River,**  
 11 **Killona Segment**

Water Use Sector	Volume <sup>(a)</sup> (mgd)
Public Supply	74.7
Industrial	673.7
Thermoelectric Power Generation	2,828.6
General Irrigation	0.2
Livestock	0.1
Aquaculture	0
Total	3,577.3

Note: To convert million gallons per day (mgd) to cubic feet per second (cfs), multiply by 1.547.

<sup>(a)</sup> All values are rounded and include withdrawals from St. Charles, Jefferson, and St. John the Baptist Parishes.  
 mgd = million gallons per day

Source: USGS 2016b

12 Furthermore, St. Charles Parish has the greatest surface water and total water withdrawals  
 13 within the state of Louisiana, driven by withdrawals for power generation and industrial water  
 14 use (USGS 2016b). Nonetheless, most of the water withdrawn for industrial and power  
 15 generation is used for once-through cooling and, therefore, is returned to its water source after  
 16 use and is not consumed (Sargent 2012). Such is the case with WF3, which uses a  
 17 once-through cooling system, with a consumptive use rate of only about 0.01 percent of the total  
 18 volume of water withdrawn.

19 As discussed in Section 3.5.1.1, the mean annual discharge (flow) of the Lower Mississippi  
 20 River through the Killona segment near WF3 exceeds 500,000 cfs (14,120 m<sup>3</sup>/s), averaging  
 21 536,600 cfs (15,160 m<sup>3</sup>/s) at Baton Rouge (see Section 3.5.1.1). This is equivalent to  
 22 approximately 346,860 mgd. Since cumulative water consumption from the geographic area of  
 23 analysis is not readily available, the total water withdrawal rate from the surface water source is  
 24 used as a conservative measure of potential water use conflict. Accordingly, total surface water  
 25 withdrawals from the Lower Mississippi River by users within the Killona area of analysis are  
 26 currently equivalent to approximately 1.0 percent of the mean annual flow of the river. Even if a  
 27 substantial portion of the water withdrawn was consumptive in nature and otherwise not  
 28 returned to the river, this volume would not be expected to impact the downstream availability of  
 29 surface water for other users.

30 In predicting future surface water demands and cumulative impacts on surface water use, the  
 31 NRC staff considered past, present, and reasonably foreseeable future actions as well as  
 32 available data on water use trends. Between 2005 and 2010, total surface water withdrawals

1 for public supply increased by 0.8 percent. Meanwhile, surface water withdrawals for industrial  
2 use and power generation decreased by 36 and 15 percent, respectively. St. Charles Parish,  
3 where WF3 is located, experienced the greatest decrease in withdrawals for industrial use  
4 (i.e., 470 mgd). Information that Entergy provided in its ER (Entergy 2016a), and as discussed  
5 in Section 3.10.3 of this SEIS, indicates a potential annual population growth rate of about  
6 1.0 percent. Using this rate, the NRC staff projected potential surface water demand within the  
7 area of analysis. Accordingly, total annual surface water withdrawals from the Killona segment  
8 of the Lower Mississippi River could increase from 3,577 mgd (5,534 cfs; 156 m<sup>3</sup>/s) to as much  
9 as 4,822 mgd (7,460 cfs; 211 m<sup>3</sup>/s) by the end of the period of extended operation in 2044,  
10 should WF3's operating license be renewed. This total increase is equivalent to approximately  
11 1.4 percent of the mean annual flow of the Lower Mississippi through the Killona segment.  
12 Given this very small incremental increase, the NRC staff finds that it is extremely unlikely that  
13 continued WF3 operations withdrawing surface water from the Killona segment of the Lower  
14 Mississippi River, combined with those of other users, would have any measurable impact on  
15 the downstream availability of surface water.

### 16 Water Quality Considerations

17 Water quality along the Mississippi River varies as a result of environmental changes along the  
18 river and its basin, hydrologic modifications (e.g., locks, dams, levees), and point and nonpoint  
19 pollutant sources. Water quality in the Lower Mississippi River is primarily a function of  
20 upstream inputs (Alexander 2012; National Research Council 2008). Because of the regulatory  
21 and infrastructure improvement mechanisms afforded under the Federal Water Pollution Control  
22 Act (i.e., Clean Water Act of 1972, as amended (CWA)) (33 U.S.C. 1251 et seq.) that focused  
23 on industrial wastewater and public sewage discharges, the water quality of the Mississippi  
24 River has improved dramatically over the last several decades (Entergy 2016a; National  
25 Research Council 2008). Nonpoint source pollution remains a problem, however. The potential  
26 for continued increases in agricultural production in the U.S. Midwest, such as for biofuel crops,  
27 along with an increased use of fertilizers is likely to increase sediment- and nutrient-laden runoff  
28 to the Mississippi River (National Research Council 2008).

29 Nevertheless, as discussed in Section 3.5.1.3 of this SEIS, the Killona segment of the Lower  
30 Mississippi River that receives WF3 effluent currently meets designated water uses for primary  
31 contact recreation, secondary contact recreation, fish and wildlife propagation, and drinking  
32 water supply and is not identified as impaired.

33 Development projects can result in water quality degradation if they increase sediment loading  
34 and the discharge of other pollutants to nearby surface water bodies. The magnitude of  
35 cumulative impacts would depend on the nature and location of the actions relative to surface  
36 water bodies; the number of actions (e.g., facilities or projects); and whether facilities comply  
37 with regulating agency requirements (e.g., land use restrictions, habitat avoidance and  
38 restoration requirements, stormwater management, and wastewater discharge limits). Table E-  
39 1 in Appendix E of this SEIS identifies a number of ongoing and reasonably foreseeable future  
40 actions that could impact ambient water quality within the Killona segment of the Lower  
41 Mississippi-New Orleans watershed.

42 Wastewater discharges from existing and new and modified industrial manufacturing, power  
43 generation, wastewater treatment, and large commercial facilities would be subject to regulation  
44 under the Federal CWA. Across a particular watershed, Section 303(d) of the Federal CWA  
45 requires states to identify all "impaired" waters for which effluent limitations and pollution control  
46 activities are not sufficient to attain water quality standards and to establish total maximum daily  
47 loads (TMDLs) to ensure future compliance with water quality standards. On an individual  
48 facility basis, State-administered NPDES (LPDES in Louisiana) permits issued under CWA

## Environmental Consequences and Mitigating Actions

1 Section 402 set limits on wastewater, stormwater, and other point source discharges to surface  
2 waters, including runoff from construction sites. Furthermore, CWA Section 404 governs the  
3 discharge of dredge and fill materials to navigable waters, including wetlands, primarily through  
4 permits issued by the USACE. Construction affecting navigable waterways, such as for flood  
5 control, is also regulated by the USACE pursuant to Section 10 of the Rivers and Harbors Act of  
6 1899 (33 U.S.C. 403 et seq.).

7 Consequently, a substantial regulatory framework exists to address current and potential future  
8 sources of water quality degradation within the mainstem of the Lower Mississippi River with  
9 respect to potential cumulative impacts on surface water quality. This makes it unlikely that  
10 serious degradation of ambient water quality in the Lower Mississippi River would occur during  
11 the license renewal term.

### 12 Climate Change and Related Considerations

13 The NRC staff also considered the best available information regarding the potential impacts of  
14 climate change at a regional and local scale, including the USGCRP's most recent compilations  
15 of the state of knowledge relative to global climate change effects (USGCRP 2014).

16 Climate change can impact surface water resources as a result of changes in temperature and  
17 precipitation. As discussed in Section 4.15.3, there is uncertainty regarding future precipitation  
18 changes associated with climate change for the Southeast United States. However, given the  
19 size of the Mississippi River Basin, contributions to river flow and downstream discharge are  
20 affected by precipitation changes beyond the Southeast region. For instance, in 2012, low-flow  
21 conditions on the Mississippi River due to drought conditions in the Midwest and across  
22 Louisiana resulted in saltwater encroachment up the bird-foot delta, which required the USACE  
23 to install a sill within the river channel to protect the freshwater intake at Belle Chasse,  
24 Louisiana (LWRC 2013). For such occurrences, the USACE maintains a mitigation program for  
25 limiting upriver salt-water encroachment above Mississippi RM 64 (103 river kilometer (RKm)).  
26 Before 2012, the USACE last installed a sill in 1999 (USACE 2016).

27 Runoff and streamflow have increased in the Mississippi River Basin over time  
28 (USGCRP 2014). However, increased evapotranspiration, as a result of higher temperatures in  
29 the future, can reduce the volume of water available for surface runoff and streamflow.  
30 Changes in runoff in a watershed along with reduced stream flows and higher air temperatures  
31 all contribute to an increase in the ambient temperature of receiving waters. Meanwhile, an  
32 increase in heavy precipitation events has been observed for and is expected to persist for the  
33 Southeast (Section 4.15.3.2). Such a trend toward heavy precipitation increases the rate of  
34 runoff from the land surface and the transport of pollutants to surface waters such as the  
35 Mississippi River. This could have future water quality implications during the license renewal  
36 term.

37 Elevated surface water temperature, along with degraded surface water quality, also can  
38 decrease the cooling efficiency of thermoelectric power generating facilities and plant capacity.  
39 As intake water temperatures warm, cooling water makeup requirements increase  
40 (USCRP 2014). Degraded surface water quality also increases the costs of water treatment for  
41 both industrial cooling water and potable water because of the need for increased filtration and  
42 higher additions of chemical treatments, including for disinfection. Power plants, other industrial  
43 interests, and public water supply facilities would have to account for any changes in water  
44 temperature and quality in operational practices and procedures, and perhaps require  
45 investment in additional infrastructure and capacity.

46 At present, the data available to the NRC staff do not indicate any warming trend in the segment  
47 of the Lower Mississippi River that supplies cooling water to WF3 (Entergy 2016b).

1 Furthermore, as detailed in Section 3.5.1.3, the chemical and thermal quality of WF3's  
 2 discharges to the Lower Mississippi River are subject to the effluent limitations and monitoring  
 3 requirements prescribed by the LPDES permit issued to Entergy (LDEQ 2017). WF3's LPDES  
 4 permit imposes a maximum temperature limit of 118 °F (47.7 °C) on the plant's primary outfall.  
 5 Any changes in effluent quality or thermal characteristics would have to comply with WF3's  
 6 LPDES permit limits. Likewise, and as previously indicated above, existing and new facilities  
 7 withdrawing water from and discharging effluents to the Killona segment of the Lower  
 8 Mississippi River would be required to comply with applicable LPDES permit requirements  
 9 under the Federal CWA, local and regional health standards, and river TMDLs imposed  
 10 by the State.

11 Finally, relative sea level along the southeastern region of Louisiana, as a result of both  
 12 absolute sea level change and land subsidence, could rise by up to 2.3 ft (0.7 m) by the end of  
 13 the license renewal term (USGCRP 2014). This sea level rise would further exacerbate the  
 14 ongoing effects of coastal erosion and subsidence occurring across the Mississippi River Delta  
 15 region of Louisiana and in portions of St. Charles Parish (St. Charles Parish 2015). This  
 16 projected increase could, in part, cause an increase in the upstream migration of the saltwater  
 17 wedge and a general deterioration in ambient surface water quality in the Lower Mississippi  
 18 River. However, given the current flow regime of the Lower Mississippi River as further  
 19 discussed in Section 3.5.1.1, it is not expected that the saltwater wedge would threaten the  
 20 Killona segment of the river during the license renewal term. The NRC staff also considers the  
 21 likelihood for substantial changes in salinity levels in the Killona segment of the river during the  
 22 license renewal term to be low.

23 In summary, no substantial adverse changes in surface water availability or ambient water  
 24 quality are expected during the license renewal term. The existing regulatory framework is  
 25 expected to continue to effectively manage effluent discharges and stormwater runoff from  
 26 existing and proposed facilities. Surface water withdrawals from the Killona segment of the  
 27 Lower Mississippi River, which are primarily nonconsumptive in nature, would be unlikely to  
 28 result in water use conflicts during the WF3 license renewal term. Climate change could result  
 29 in minor changes in the hydrology and ambient water quality of the Lower Mississippi River.  
 30 Overall, the NRC staff concludes that the cumulative impacts from past, present, and  
 31 reasonably foreseeable future actions and trends on surface water resources during the license  
 32 renewal term would be SMALL.

#### 33 4.16.3.2 *Groundwater Resources*

34 As noted in Section 4.5.1.2, the NRC staff concludes that the impacts of the proposed action  
 35 (license renewal) on groundwater consumption and quality would be SMALL. No groundwater  
 36 is consumed at the WF3 site and no use of groundwater is expected during the license renewal  
 37 term; therefore, the proposed action would have no direct, incremental impact on groundwater  
 38 availability or on groundwater conditions in the region. Further, present and future WF3  
 39 operations are not expected to impact the quality of groundwater in any aquifers that are a  
 40 current or potential future source of water for offsite users. As a result, there is no significant  
 41 cumulative effect on groundwater resources from the proposed action. Considering ongoing  
 42 activities and reasonably foreseeable actions, the NRC staff concludes that the cumulative  
 43 impacts on groundwater use and quality during the WF3 license renewal term would be SMALL.

#### 44 4.16.4 **Terrestrial Resources**

45 Section 4.6 finds that the direct and indirect impacts on terrestrial resources from the proposed  
 46 license renewal when considered in the absence of aggregate effects would be SMALL. The

## Environmental Consequences and Mitigating Actions

1 cumulative impact is the total effect on terrestrial resources of all actions taken, no matter who  
2 has taken the actions.

3 Direct and indirect impacts from WF3 continued operation are largely limited to the Entergy  
4 property and immediate vicinity. However, other projects or actions located beyond the  
5 boundaries of this geographic area could contribute to cumulative effects on terrestrial  
6 resources on the Entergy property and immediate vicinity. For instance, air emissions from  
7 fossil fuel plants can have far-reaching effects and would have the potential to affect terrestrial  
8 resources on the Entergy property even if the fossil fuel plant is not located particularly close  
9 to WF3.

10 The NRC measures cumulative impacts against a “baseline,” which is the condition of the  
11 resource without the action (i.e., under the no-action alternative) consistent with the  
12 CEQ’s (1997) NEPA guidance. Under the no-action alternative, WF3 would shut down, and  
13 terrestrial resources would conceptually return to a condition without the plant (which is not  
14 necessarily the same as the condition before the plant was constructed). The baseline, or  
15 benchmark, for assessing cumulative impacts on terrestrial resources also takes into account  
16 the preoperational environment as recommended by EPA (1999) for its review of NEPA  
17 documents.

### 18 Past Development and Habitat Alteration

19 As discussed in Section 3.6, about one-third of the Entergy property is occupied by WF3 and  
20 the oil/gas-fired Waterford 1, 2, and 4, or it is being leased for agricultural use. During siting and  
21 construction of the four energy generating units, much of this land was permanently converted  
22 for industrial use, and Entergy (2016b) anticipates that agricultural use on 660 ac (270 ha) of the  
23 Entergy property will continue throughout the proposed license renewal period.

24 In the broader area—the Mississippi Alluvial Plains Level III Ecoregion—the majority of native  
25 bottomland deciduous forest has been cleared for agricultural use. Wiken et al. (2011) report  
26 that the Mississippi Alluvial Plain is one of the most altered ecoregions in the United States, and  
27 Weakley et al. (2016) estimate that over 90 percent of the landscape has been converted to  
28 cropland. The extensive loss of native habitats, including 400- to 600-year-old cypress stands,  
29 has likely led to a decrease in the biodiversity and richness of remaining plant and animal  
30 communities in this ecoregion. Habitat loss, in general, can negatively affect breeding success,  
31 dispersal success, predation rates, and other animal behaviors (Fahrig 2003). Habitat  
32 fragmentation (the breaking up of a larger area of habitat into smaller patches of smaller total  
33 area) also has negative effects on terrestrial biota. Fragmentation disrupts many basic  
34 ecological interactions of a community, including predator-prey, parasite-host, and  
35 plant-pollinator, and can result in cascading extinctions (Wilcove et al. 1986). For instance, in  
36 the eastern United States, the disappearance of large predators that regulate populations of  
37 smaller, omnivorous species such as raccoons, opossums, squirrels, and blue jays, has led to  
38 increased predation upon the eggs and nestlings of forest song birds (Wilcove et al. 1986).

### 39 Energy Production and Manufacturing Facilities

40 One nuclear power plant site with one operating reactor (River Bend Station, Unit 1) lies within  
41 75 mi (120 km) of the WF3 site. Because the effects of this facility primarily would be limited to  
42 the terrestrial resources on the River Bend Station, Unit 1 site and immediate vicinity, the  
43 operation of River Bend during the proposed WF3 license renewal term would not result in  
44 cumulative effects to the terrestrial resources affected by WF3 operation.

45 Several other non-nuclear energy generating facilities operate either on or within 1 mi (1.6 km)  
46 of the Entergy property (Waterford 1, 2, and 4; Little Gypsy Power Plant; and Taft Cogeneration  
47 Facility). Twenty-five manufacturing facilities of various types occur within 10 mi (16 km) of the

1 Entergy property (Table E–1 in Appendix E). Additionally, construction of a new natural gas  
2 combined-cycle plant, St. Charles Power Station, began in 2017. The plant will be located next  
3 to the Little Gypsy Power Plant approximately 1 mi (1.6 km) northeast of WF3. Air emissions  
4 from these facilities include GHGs, such as nitrogen oxides, carbon dioxide, and methane, all of  
5 which can have far-reaching consequences because they cumulatively contribute to climate  
6 change. The effects of climate change on terrestrial resources are discussed in  
7 Section 4.15.3.2.

#### 8 Development, Urbanization, and Habitat Fragmentation

9 As the region surrounding the WF3 site becomes more developed, habitat fragmentation will  
10 increase and the amount of forested and wetland habitat is likely to decline further.  
11 Transmission lines and associated corridors established to connect WF3 and other energy  
12 producing facilities to the regional electric grid represent past habitat fragmentation because  
13 some of the corridors split otherwise continuous tracts of habitat. Construction of transmission  
14 lines associated with new energy projects also may result in habitat fragmentation if the lines  
15 are not collocated within existing corridors or sited within previously developed areas. Edge  
16 species that prefer open or partially open habitats likely will benefit from the fragmentation,  
17 whereas species that require interior forest or wetland habitat likely will suffer. Continued  
18 urbanization in the future likely will include construction of additional housing units and  
19 associated commercial buildings; roads, bridges, and rail; and water or wastewater treatment  
20 and distribution facilities and associated pipelines. Increased development likely will decrease  
21 the overall availability and quality of terrestrial habitats. Species that require larger ranges,  
22 especially predators, likely will suffer population reductions. Similarly, species with threatened  
23 or endangered Federal or State status or otherwise declining populations would be more  
24 sensitive to changes in habitat quality and availability.

#### 25 Wildlife Refuges, State Parks, and Recreational Areas

26 A number of wildlife refuges, wildlife management areas, State parks, and recreational areas  
27 located near WF3 (Table E–1 in Appendix E) provide valuable habitat to native wildlife,  
28 migratory birds, and protected terrestrial species and habitats. As fragmentation and land use  
29 changes continue, these protected areas will become ecologically more important because they  
30 provide large, uninterrupted areas of minimally disturbed habitat. For instance, the Maurepas  
31 Swamp is a 122,098-ac (49,411-ha) wildlife management area that includes flooded cypress  
32 tupelo swamp, and the Salvador Wildlife Management Area includes 30,192 ac (12,218 ha) of  
33 freshwater marsh and cypress stands. Continued management of these and other natural  
34 areas will provide high-quality habitat to many species of native wildlife and migrating birds and  
35 will ensure that biota dependent upon these sensitive and rare habitats persist.

#### 36 Conclusion

37 The NRC staff concludes that the cumulative impacts of past, present, and reasonably  
38 foreseeable future actions on terrestrial resources on and in the vicinity of the Entergy property  
39 are MODERATE. This level of impact is primarily the result of past habitat alterations and  
40 losses within the Mississippi Alluvial Plains Level III Ecoregion, which has resulted in noticeable  
41 impacts to terrestrial communities. Environmental stressors, including air emissions associated  
42 with energy production and manufacturing facilities and further habitat loss associated with  
43 continued development, will continue during the proposed license renewal term. These  
44 stressors likely will result in noticeable effects on certain attributes of the terrestrial environment,  
45 such as species diversity and distribution. The NRC staff does not expect these effects to  
46 destabilize any important attributes of the terrestrial environment, however, because these  
47 impacts likely will be gradual and occur over a sufficient timeframe to allow affected terrestrial  
48 biota to adapt. The incremental, site-specific impact from the continued operation of WF3

## Environmental Consequences and Mitigating Actions

1 during the license renewal period would be an unnoticeable or minor contributor to cumulative  
2 impacts on terrestrial resources.

### 3 **4.16.5 Aquatic Resources**

4 Section 4.7 finds that the direct and indirect impacts on aquatic resources from the proposed  
5 license renewal would be SMALL for all aquatic ecology issues. The geographic area  
6 considered in the cumulative aquatic resources analysis includes the vicinity of the intake and  
7 discharge structures on the Mississippi River affected by WF3 water withdrawal and discharge.  
8 The baseline, or benchmark, for assessing cumulative impacts on aquatic resources takes into  
9 account the preoperational environment as recommended by EPA (1999) for its review of NEPA  
10 documents.

11 Section 3.7 presents an overview of the current condition of the Mississippi River and the history  
12 and factors that led to current conditions. In summary, the direct and indirect impacts from  
13 human modifications in the Mississippi River has drastically changed available habitats and the  
14 biological communities that can inhabit and spawn within the river. Since the 1700s, efforts to  
15 control flooding and increase navigation along the Mississippi River has deepened the main  
16 channel and decreased the availability of high-quality shallow water habitats associated with  
17 floodplains, backwaters, and oxbow lakes. In addition to physical changes to aquatic habitat,  
18 land use changes within the Mississippi River basin have introduced new industrial and  
19 chemical inputs into the river and resulted in degraded water quality conditions  
20 (Brown et al. 2005).

21 Many natural and human activities can influence the current and future aquatic life in the area  
22 surrounding WF3. Potential biological stressors include operational impacts from WF3  
23 (as described in Section 4.7); modifications to the Mississippi River; runoff from industrial,  
24 agricultural, and urban areas; other water users and dischargers; and climate change.

#### 25 *4.16.5.1 Modifications to the Mississippi River*

26 The relative abundance of hard substrate, deep channel, and river bank habitat has been  
27 largely influenced by human activities to decrease flooding events and increase navigability.  
28 The USACE and Mississippi River Commission continue to oversee a comprehensive river  
29 management program that includes:

- 30 • levees for containing flood flows;
- 31 • floodways for the passage of excess flows past critical reaches of the Mississippi  
32 River;
- 33 • channel improvement and stabilization to provide an efficient and reliable navigation  
34 channel, increase the flood-carrying capacity of the river, and protect the levee  
35 system; and
- 36 • tributary basin improvements for major drainage basins to include dams and  
37 reservoirs, pumping plants, auxiliary channels, and pumping stations (MRC 2016).

38 Implementing this management program will continue to affect the relative availability of aquatic  
39 habitats, resulting in, for example, a decrease in the amount of soft sediment river bank habitat  
40 and an increase in the amount of hard substrates (e.g., riprap or other materials used to line the  
41 river bank). Consequently, invertebrates that depend on a hard surface for attachment, and can  
42 colonize human-made materials, such as tires, concrete, or riprap used to line river banks, likely  
43 will continue to increase in relative abundance as compared to species that require soft  
44 sediments along the river bank.

1 The Mississippi River Commission also implements various programs to support the  
2 sustainability of aquatic life within the Mississippi River. For example, the Davis Pond and  
3 Caernarvon freshwater diversion structures divert more than 18,000 ft<sup>3</sup>/s (510 m<sup>3</sup>/s) of fresh  
4 water to coastal marshlands. The input of freshwater helps to preserve the marsh habitat and  
5 reduce coastal land loss (MRC 2016). In addition, the Mississippi River Commission conducted  
6 research and determined that using grooved articulated concrete mattresses to line river banks  
7 can help support benthic invertebrate and fish populations. For example, using grooved  
8 articulated concrete mattresses increases larval insect production, which is an important source  
9 of prey for many fish (MRC 2016).

#### 10 4.16.5.2 *Runoff from Industrial, Agricultural, and Urban Areas*

11 Nearly 40 percent of the land within the contiguous United States drains into the Mississippi  
12 River. Land use changes and industrial activities within this area have had a substantial impact  
13 on aquatic habitat and water quality within the Mississippi River. For example, the Mississippi  
14 River historically experienced decreased water quality as a result of industrial discharges,  
15 agricultural runoff, municipal sewage discharges, surface runoff from mining activity, and  
16 surface runoff from municipalities. However, over the past few decades, water quality within the  
17 Mississippi River has improved because of the implementation of the CWA and other  
18 environmental regulations (Caffey et al. 2002). For example, most of the older, first-generation  
19 chlorinated insecticides have been banned since the late 1970s. Similarly, the addition and  
20 upgrading of numerous municipal sewage treatment facilities, rural septic systems, and animal  
21 waste management systems have helped to significantly decrease the concentration of median  
22 fecal coliform bacteria in the Mississippi River (Caffey et al. 2002). Despite the trend of  
23 improving water quality within the Mississippi River, trace levels of some contaminants and  
24 increased nutrients from agricultural lands remain a source of concern for aquatic life  
25 (Caffey et al. 2002; Rabalais et al. 2009).

#### 26 4.16.5.3 *Water Users and Discharges*

27 Several other facilities withdraw and discharge water from and to the Lower Mississippi River  
28 (e.g., see Table E-1). These facilities also may entrain and impinge aquatic organisms and add  
29 to the cumulative thermal stress to aquatic populations that inhabit waters near WF3. ENSR  
30 (2007) examined the cumulative impingement and entrainment impacts from nearby plants on  
31 the Lower Mississippi River (e.g., WF3, Waterford 1 and 2, Little Gypsy, Ninemile, Willow Glen,  
32 Baxter Wilson, and Ritchie) and determined that the combined impacts would not be substantial,  
33 given that the intakes are located in areas of low biological richness (e.g., near deep,  
34 fast-flowing channel waters) and no important, sensitive, or rare habitats occur near the intakes.  
35 Entergy's (2016b) planned replacement of the intake structure weir wall at WF3 would minimize  
36 impingement impacts at WF3.

37 LP&L (1978) estimated the cumulative entrainment rates at Waterford 1 and 2, WF3, and Little  
38 Gypsy, and determined that during typical low-flow conditions (5,664 m<sup>3</sup> (200,000 cfs)), all four  
39 plants operating at full capacity would entrain 2.3 percent of the river flow. The NRC staff  
40 (1981) did not predict significant impacts based on the low percent of ichthyoplankton that likely  
41 would be entrained and because of the low density of ichthyoplankton near WF3.

42 LDEQ has previously examined the cumulative thermal impacts to operating plants near WF3.  
43 As described in Section 4.7.1.3, LDEQ (1998) estimated a zone of passage of 81 percent when  
44 Waterford 1 and 2, and WF3, and Little Gypsy are operating and the river is at extreme low flow.  
45 LDEQ (1998) concluded that the Mississippi River near WF3 would still meet Louisiana Water  
46 Quality Criteria standards even with the combined thermal output to the river. In addition,  
47 LDEQ (1998) examined the cumulative thermal impacts to aquatic biota from the four plants  
48 mentioned above and Union Carbide, which is 1.6 river miles (2.6 river kilometers) downstream

## Environmental Consequences and Mitigating Actions

1 of WF3. LDEQ (1998) concluded that the additional heat load from Union Carbide would be  
2 undetectable because the discharged water would enter via canals, where water would cool  
3 before reentering the river.

4 The St. Charles Power Station would also impinge, entrain, and release thermal discharges into  
5 the Mississippi River once it begins operation in 2019 (Entergy 2017a, 2017b). Given the  
6 relatively close proximity of the two plants, many of the same fish populations and other  
7 aquatic resources would be impacted by operation of WF3, the St. Charles Power Station, as  
8 well as other energy generating plants within the ROI. However, cumulative impacts would not  
9 be noticeable given that the intakes are located in areas of low biological richness (e.g., near  
10 deep, fast-flowing channel waters) and no important, sensitive, or rare habitats occur near the  
11 intakes.

12 Climate patterns (e.g., increased droughts and salt water intrusion) and increased water  
13 demands upstream of WF3 also may increase the number of water users and rate of withdrawal  
14 from the Mississippi River (Caffey et al. 2002). Aquatic life, especially threatened and  
15 endangered species, rely on sufficient flow within streams and rivers to survive. As described in  
16 Section 4.12.3.1, continued regulation of the flow by the USACE is expected to preserve the  
17 course and flow of the Mississippi River. Additionally, Entergy and other water dischargers  
18 would be required to comply with NPDES permits that must be renewed every 5 years, allowing  
19 LDEQ to ensure that the permit limits provide the appropriate level of environmental protection.

### 20 4.16.5.4 *Climate Change*

21 The potential effects of climate change, including increased temperatures and heavy  
22 downpours, could result in degradation to aquatic resources in the Lower Mississippi  
23 River. Increased temperature and thermal stress to aquatic biota could increase the frequency  
24 of shellfish-borne illness, alter the distribution of native fish, increase the local loss of rare  
25 species, and increase the displacement of native species by non-native species  
26 (USGCRP 2009, 2014).

27 More rainfall and heavy downpours can increase the rate of runoff and pollutants reaching the  
28 Mississippi River because the pollutants washed away in the high volume of runoff have less  
29 time to absorb into the soil before reaching the river. Over the past 50 years, as a result of  
30 climate change and land use changes, the Mississippi River Basin is yielding an additional  
31 32 million acre-feet (4 million hectare meters) of nitrogen load, which is being discharged into  
32 the Gulf of Mexico (USGCRP 2014). Future increases in runoff would further increase the  
33 sediment load within the Mississippi River and concurrently limit photosynthesis and growth of  
34 primary producers that provide an important food source for fish and other aquatic organisms.

35 The cumulative effects of increased temperatures, altered river flows, and increased sediment  
36 loading could exacerbate existing environmental stressors, such as high nutrient levels and low  
37 dissolved oxygen, both of which are associated with eutrophication. A decline in oxygen is  
38 especially likely within shallow aquatic habitats that provide high-quality habitat for spawning,  
39 foraging, and resting. Low oxygen also may lead to fish, shellfish, eggs, and larvae mortality.

### 40 4.16.5.5 *Protected Habitats*

41 Several wildlife management areas, parks, and recreation sites lie within the vicinity of WF3  
42 (see Table E-1). The continued preservation of these areas will protect aquatic habitats, and  
43 these areas will become ecologically more important in the future because they will provide  
44 large areas of protected aquatic habitats as other stressors increase in magnitude and intensity.

1 **4.16.5.6 Conclusion**

2 The direct and indirect impacts to aquatic resources from historical Mississippi River  
 3 modifications and pollutants and sediments introduced into the river have had a substantial  
 4 effect on aquatic life and their habitat. The incremental impacts from WF3 are SMALL for  
 5 aquatic resources because WF3 operation would have minimal impacts on aquatic resources.  
 6 The cumulative stress from the activities described above, spread across the geographic area of  
 7 interest depends on many factors that the NRC staff cannot quantify. This stress may  
 8 noticeably alter some aquatic resources. For example, climate change may increase the  
 9 temperature of the Mississippi River and the rate of runoff into the river. This may noticeably  
 10 alter the habitat for species most sensitive to nutrient loading, high levels of contaminants, and  
 11 higher temperatures. Therefore, the staff concludes that the cumulative impacts from the  
 12 proposed license renewal and other past, present, and reasonably foreseeable projects would  
 13 be MODERATE.

14 **4.16.6 Historic and Cultural Resources**

15 As described in Section 4.9, historic properties (36 CFR 800.5(b)) at WF3 are not likely to be  
 16 adversely affected by license renewal because no ground-disturbing activities or physical  
 17 changes would occur during the license renewal term beyond those associated with ongoing  
 18 maintenance. As discussed in Section 4.9, Entergy has site procedures and work instructions  
 19 to ensure cultural resources on WF3 lands are considered during planned maintenance  
 20 activities.

21 The geographic area considered in this analysis is the APE associated with the proposed  
 22 undertaking, as described in Section 3.9. The archaeological record for the region indicates  
 23 prehistoric and historic occupation of the WF3 and its immediate vicinity. Although the  
 24 construction of WF3 resulted in the destruction and loss of cultural resources within much of the  
 25 industrial site area, there remains the possibility for additional historic or cultural resources to be  
 26 present elsewhere within the WF3 site. Present and reasonably foreseeable projects that could  
 27 affect these resources, in addition to the effects of ongoing maintenance and operational  
 28 activities during the license renewal term, are summarized in Appendix E. Direct impacts would  
 29 occur if historic and cultural resources in the APE were physically removed or disturbed during  
 30 maintenance activities. It is unlikely that the projects discussed in Appendix E would impact  
 31 historic and cultural resources on the WF3 site because those resources are not in areas which  
 32 would be subject to foreseeable future development during the license renewal term.

33 The NRC staff concludes that the contributory effects of continued reactor operations and  
 34 maintenance at WF3, when combined with other past, present, and reasonably foreseeable  
 35 future activities, would have no new or increased impact on cultural resources within the APE  
 36 beyond what already has been experienced.

37 **4.16.7 Socioeconomics**

38 As discussed in Section 4.10, continued operation of WF3 during the license renewal term  
 39 would have no impact on socioeconomic conditions in the region beyond what is already being  
 40 experienced.

41 The primary geographic area of interest considered in this cumulative analysis is St. Charles  
 42 and St. John the Baptist Parishes, where approximately 29 and 7 percent, respectively, of WF3  
 43 employees reside (see Table 3–11). This is where the economy, tax base, and infrastructure  
 44 most likely would be affected because the majority of WF3 workers and their families reside,  
 45 spend their incomes, and use their benefits within these counties.

## Environmental Consequences and Mitigating Actions

1 Because Entergy has no plans to hire additional workers during the license renewal term,  
2 overall expenditures and employment levels at Entergy would remain relatively unchanged with  
3 no new or increased demand for housing and public services. Based on this and other  
4 information presented in Chapter 4, there would be no contributory effect on socioeconomic  
5 conditions in the region during the license renewal term from the continued operation of WF3  
6 beyond what is currently being experienced. Therefore, the only contributory effects would  
7 come from reasonably foreseeable future planned activities at WF3, unrelated to the proposed  
8 action (license renewal), and other reasonably foreseeable planned offsite activities, such as  
9 residential development in St. Charles and St. John the Baptist Parishes. The availability of  
10 new housing could attract individuals and families from outside the region, thereby increasing  
11 the local population and causing increased traffic on local roads and increased demand for  
12 public services.

13 Entergy has no reasonably foreseeable future planned activities at WF3 beyond continued  
14 reactor operations and maintenance. When combined with other past, present, and reasonably  
15 foreseeable future activities, the contributory effects of continuing reactor operations and  
16 maintenance at WF3 would have no new or increased socioeconomic impact in the region  
17 beyond what is currently being experienced.

### 18 **4.16.8 Human Health**

19 The NRC and EPA established radiological dose limits for protection of the public and workers  
20 from both acute and long-term exposure to radiation and radioactive materials. These dose  
21 limits are codified in 10 CFR Parts 20 and 40 CFR Part 190. As discussed in Section 4.11.1,  
22 the NRC staff concluded that impacts to human health from continued plant operations are  
23 SMALL. For the purposes of this analysis, the geographical area considered is the area  
24 included within an 80-km (50-mi) radius of the WF3 plant site. There are no other nuclear  
25 power plants within the 80-km (50-mi) radius of WF3, but that radius does overlap with the  
26 80-km (50-mi) radius of River Bend Station, Unit 1, as it is approximately 121 km (75 mi)  
27 northwest. As discussed in Section 3.1.4.4, in addition to storing its spent nuclear fuel in a  
28 storage pool, WF3 stores some of its spent nuclear fuel in an onsite ISFSI.

29 The EPA regulations in 40 CFR Part 190 limit the dose to members of the public from all  
30 sources in the nuclear fuel cycle, including nuclear power plants, fuel fabrication facilities, waste  
31 disposal facilities, and transportation of fuel and waste. As discussed in Section 3.1.4.5, WF3  
32 has a REMP that measures radiation and radioactive materials in the environment from WF3, its  
33 ISFSI, and all other sources. The NRC staff reviewed the radiological environmental monitoring  
34 results for the 5-year period from 2011 to 2015 as part of the cumulative impacts assessment.  
35 The NRC staff's review of Entergy's data showed no indication of an adverse trend in  
36 radioactivity levels in the environment from WF3 or its ISFSI. The data showed no measurable  
37 impact to the environment from operations at WF3.

38 The NRC staff concludes that the cumulative radiological impacts of the proposed license  
39 renewal, when combined with other past, present, and reasonably foreseeable future activities,  
40 would be SMALL. This is based on the NRC staff's review of REMP data, radioactive effluent  
41 release data, worker dose, and WF3's expected continued compliance with Federal radiation  
42 protection standards during continued operation, and regulation of any future development or  
43 actions in the vicinity of the WF3 site by the NRC and the State of Louisiana.

#### 1 **4.16.9 Environmental Justice**

2 As discussed in Section 4.12, there would be no disproportionately high and adverse impacts on  
3 minority and low-income populations from the continued operation of WF3 during the license  
4 renewal term.

5 Everyone living near WF3 currently experiences its operational effects, including minority and  
6 low-income populations. The NRC addresses environmental justice matters for license renewal  
7 by identifying the location of minority and low-income populations, determining whether there  
8 would be any potential human health or environmental effects to these populations, and  
9 determining whether any of the effects may be disproportionately high and adverse.

10 Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse  
11 impacts on human health. Disproportionately high and adverse human health effects occur  
12 when the risk or rate of exposure to an environmental hazard for a minority or low-income  
13 population is significant and exceeds the risk or exposure rate for the general population or for  
14 another appropriate comparison group. Disproportionately high environmental effects refer to  
15 impacts or risks of impacts on the natural or physical environment in a minority or low-income  
16 community that are significant and appreciably exceed the environmental impact on the larger  
17 community. Such effects may include biological, cultural, economic, or social impacts. Some of  
18 these potential effects have been identified in resource areas presented in preceding sections of  
19 Chapter 4. As previously discussed in this chapter, with the exception of aquatic resources and  
20 the potential risk to cultural resources, the impact from license renewal for all other resource  
21 areas (e.g., land, air, water, and human health) would be SMALL.

22 As discussed in Section 4.12, there would be no disproportionately high and adverse impacts on  
23 minority and low-income populations from the continued operation of WF3 during the license  
24 renewal term. Because Entergy has no plans to hire additional workers during the license  
25 renewal term, employment levels at WF3 would remain relatively constant, and there would be  
26 no additional demand for housing or increased traffic. Based on this information and the  
27 analysis of human health and environmental impacts presented in the preceding sections, it is  
28 not likely there would be any disproportionately high and adverse contributory effect on minority  
29 and low-income populations from the continued operation of WF3 during the license renewal  
30 term. Therefore, the only contributory effects would come from the other reasonably  
31 foreseeable future planned activities at WF3, unrelated to the proposed action (license renewal),  
32 and other reasonably foreseeable planned offsite activities.

33 Entergy has no reasonably foreseeable future planned activities at WF3 beyond continued  
34 reactor operations and maintenance. When combined with other past, present, and reasonably  
35 foreseeable future activities, the contributory effects of continuing reactor operations and  
36 maintenance at WF3 likely would not cause disproportionately high and adverse human health  
37 and environmental effects on minority and low-income populations residing in the vicinity of  
38 WF3 beyond what already has been experienced.

#### 39 **4.16.10 Waste Management and Pollution Prevention**

40 For the purpose of this cumulative impacts analysis, the area within a 50-mi (80-km) radius of  
41 WF3 was considered. The NRC staff concluded, in Section 4.13, that the potential human  
42 health impacts from WF3's waste during the license renewal term would be SMALL.

43 Entergy operates two fossil fuel plants on the same site as WF3. They are Waterford 1 and 2,  
44 which is an oil/gas-fueled plant with approximately 825 MW generating capacity and  
45 Waterford 4, an oil-fueled peaking plant with approximately 33 MW generating capacity.  
46 Waterford 1, 2 and 4 are located on site approximately 0.7 km (0.4 mi) from WF3

## Environmental Consequences and Mitigating Actions

1 (Entergy 2016a). These fossil fuel plants are not a part of the WF3 license and have their own  
2 procedures in place to comply with Federal and State permits and other regulatory requirements  
3 for the management of waste material.

4 As discussed in Sections 3.1.4 and 3.1.5, Entergy maintains waste management programs for  
5 radioactive and nonradioactive waste generated at WF3 and is required to comply with Federal  
6 and State permits and other regulatory requirements for the management of waste material.  
7 The nuclear power plants and other facilities within a 50-mi (80-km) radius of WF3 also are  
8 required to comply with appropriate NRC, EPA, and State requirements for the management of  
9 radioactive and nonradioactive waste. Current waste management activities at WF3 likely  
10 would remain unchanged during the license renewal term, and continued compliance with  
11 Federal and State requirements for radioactive and nonradioactive waste is expected.

12 Based on the above, the NRC staff concludes that the potential cumulative impacts from  
13 radioactive and nonradioactive waste during the license renewal term would be SMALL.  
14 Continued compliance with Federal and State of Louisiana requirements for radioactive and  
15 nonradioactive waste management by Entergy is expected.

### 16 **4.16.11 Global Greenhouse Gas Emissions**

17 The cumulative impact of a GHG emission source on climate is global. GHG emissions are  
18 transported by wind and become well mixed in the atmosphere as a result of their long  
19 atmospheric residence time. Therefore, the extent and nature of climate change is not specific  
20 to where GHGs are emitted. Because of the global significance of GHG emissions, a global  
21 climate change cumulative impacts analysis inherently considers the entire Earth's atmosphere  
22 and, therefore, global emissions (as opposed to county, state, or national emissions). As  
23 discussed in Section 4.15.3.2, climate change and climate-related environmental changes have  
24 been observed on a global level, and climate models indicate that future climate change will  
25 depend on present and future global GHG emissions. Climate models indicate that short-term  
26 climate change (through the year 2030) is dependent on past GHG emissions. Therefore,  
27 climate change is projected to occur with or without present and future GHG emissions from  
28 WF3. With continued increases in global GHG emission rates, climate models project that the  
29 Earth's average surface temperature will continue to increase and climate-related changes  
30 will persist.

31 In April 2016, EPA published the official U.S. inventory of GHG emissions, which identifies and  
32 quantifies the primary anthropogenic sources and sinks of GHGs. The EPA GHG inventory is  
33 an essential tool for addressing climate change and participating with the United Nations  
34 Framework Convention on Climate Change to compare the relative global contribution of  
35 different emission sources and GHGs to climate change. In 2014, the United States emitted  
36 6,870 million metric tons (MMT) of CO<sub>2eq</sub> and from 1990 to 2014, emissions increased by  
37 4.7 percent (EPA 2016c). In 2013 and 2014, the total amount of CO<sub>2eq</sub> emissions related to  
38 electricity generation was 2,057 teragrams (TG) (2,038 MMT) and 2,059 Tg (2,059 MMT),  
39 respectively. The Energy Information Administration (EIA) reported that, in 2013, the electric  
40 power sector alone in Louisiana was responsible for 40.8 MMT of carbon dioxide (41.2 CO<sub>2eq</sub>)  
41 (EIA 2015). Facilities that emit 25,000 MT CO<sub>2eq</sub> or more per year are required to annually  
42 report their GHG emissions to EPA. These facilities are known as direct emitters, and the data  
43 are publicly available in EPA's facility-level information on the GHG tool (FLIGHT). In 2014,  
44 FLIGHT identified 17 facilities in St. Charles Parish, where WF3 is located, which emitted a total  
45 of 15 MMT of CO<sub>2eq</sub> and 415 facilities in the State of Louisiana that emitted a total of 137 MMT  
46 of CO<sub>2eq</sub> (EPA 2016d).

1 Appendix E provides a list of current and reasonably foreseeable future projects and actions  
 2 that could contribute to GHG emissions. Permitting and licensing requirements and other  
 3 mitigative measures can minimize the impacts of GHG emissions. For instance, in 2012, EPA  
 4 issued a final GHG Tailoring Rule (77 FR 41051) to address GHG emissions from stationary  
 5 sources under the CAA permitting requirements; the GHG Tailoring Rule establishes when an  
 6 emission source will be subject to permitting requirements and control technology to reduce  
 7 GHG emissions. The Clean Power Plan Final Rule<sup>8</sup> (80 FR 64661), aimed at reducing carbon  
 8 pollution from power plants, requires carbon emissions from the power sector to be 32 percent  
 9 below 2005 levels (870 million tons less). The Clean Power Plan sets forth carbon dioxide  
 10 emission performance rate standards for fossil fuel-fired power plants that should be achieved  
 11 by 2030. Under the Clean Power Plan Rule, Louisiana would need to reduce the power-sector  
 12 carbon dioxide emissions rate by 30 percent below 2012 levels by 2030. The State of Louisiana  
 13 currently has not enacted state-level GHG reduction goals or strategies. Future actions and  
 14 steps taken to reduce GHG emissions can lessen the impacts on climate change.

15 EPA’s U.S. inventory of GHG emissions illustrates the diversity of GHG sources, such as  
 16 electricity generation (including fossil fuel combustion and incineration of waste), industrial  
 17 processes, and agriculture. As presented in Section 4.15.3.1, annual direct GHG emissions  
 18 from combustion sources resulting from ancillary operations at WF3 range from 3,650 to  
 19 5,800 MT of CO<sub>2eq</sub>. In comparing WF3’s GHG emission contribution to different emissions  
 20 sources, whether it be total U.S. GHG emissions, emissions from electricity production in  
 21 Louisiana, or emissions on a county level, GHG emissions from WF3 are minor relative to these  
 22 inventories and negligible when compared to global emissions; this is evident, as presented in  
 23 Table 4–25. Furthermore, as presented in Table 4–22 in Section 4.15.3.1, the SCPC, NGCC,  
 24 and combination alternatives’ annual GHG emissions are higher by several orders of magnitude  
 25 than those from continued operation of WF3. Therefore, if WF3’s generating capacity were to  
 26 be replaced by other non-nuclear power generating alternatives assessed in this SEIS, there  
 27 would be an increase in GHG emissions. Consequently, continued operation of WF3  
 28 (the proposed action) results in GHG emissions avoidance and would have a net, beneficial  
 29 contribution to GHG emissions and climate change impacts during the license renewal term  
 30 compared to other baseload replacement power generation sources assessed in this SEIS.

31 **Table 4–25. Comparison of GHG Emission Inventories**

Source	CO <sub>2eq</sub> MMT/year
Global fossil fuel combustion emissions (2014) <sup>(a)</sup>	36,000
U.S. emissions (2014) <sup>(b)</sup>	6,870
Louisiana (2014) <sup>(c)</sup>	138
St. Charles Parish, Louisiana (2014) <sup>(c)</sup>	15
WF3 <sup>(d)</sup>	0.0058

<sup>8</sup> On February 9, 2016, the U.S. Supreme Court issued a stay of implementation of the Clean Power Plan pending judicial review in the U.S. Court of Appeals for the District of Columbia. The Clean Power Plan requirements are therefore on hold until the U.S. Court of Appeals makes a final ruling on the plan. Pursuant to Executive Order 13783, “Promoting Energy Independence and Economic Growth,” the EPA Administrator has been directed to review the Clean Power Plan for consistency with E.O. 13783 and if appropriate, take necessary steps to suspend, revise, or rescind.

Source	CO <sub>2eq</sub> MMT/year
(a) Source: GCP 2015	
(b) Source: EPA 2016a	
(c) GHG emissions account only for direct emitters, those facilities that emit 25,000 MT or more a year (EPA 2016d).	
(d) Emissions rounded from and obtained from Entergy 2016a.	

1 **4.17 Resource Commitments Associated with the Proposed Action**

2 **4.17.1 Unavoidable Adverse Environmental Impacts**

3 Unavoidable adverse environmental impacts are impacts that would occur after implementation  
 4 of all workable mitigation measures. Carrying out any of the energy alternatives considered in  
 5 this SEIS, including the proposed action, would result in some unavoidable adverse  
 6 environmental impacts.

7 Minor unavoidable adverse impacts on air quality would occur due to emission and release of  
 8 various chemical and radiological constituents from power plant operations. Nonradiological  
 9 emissions resulting from power plant operations are expected to comply with EPA emissions  
 10 standards, although the alternative of operating a fossil fuel-based power plant in some areas  
 11 may worsen existing attainment issues. Chemical and radiological emissions would not exceed  
 12 the National Emission Standards for Hazardous Air Pollutants.

13 During nuclear power plant operations, workers and members of the public would face  
 14 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be  
 15 exposed to radiation and chemicals associated with routine plant operations and the handling of  
 16 nuclear fuel and waste material. Workers would have higher levels of exposure than members  
 17 of the public, but doses would be administratively controlled and would not exceed standards or  
 18 administrative control limits. In comparison, the alternatives involving the construction and  
 19 operation of a nonnuclear power generating facility also would result in unavoidable exposure to  
 20 hazardous and toxic chemicals to workers and the public.

21 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,  
 22 hazardous waste, and nonhazardous waste, also would be unavoidable. In comparison,  
 23 hazardous and nonhazardous wastes also would be generated at nonnuclear power generating  
 24 facilities. Wastes generated during plant operations would be collected, stored, and shipped for  
 25 suitable treatment, recycling, or disposal in accordance with applicable Federal and State  
 26 regulations. Because of the costs of handling these materials, power plant operators would be  
 27 expected to carry out all activities and to optimize all operations in a way that generates the  
 28 smallest amount of waste possible.

29 **4.17.2 Relationship between Short-Term Use of the Environment and Long-Term**  
 30 **Productivity**

31 The operation of power generating facilities would result in short-term uses of the environment,  
 32 as described in this chapter. "Short term" is defined as the period of time during which  
 33 continued power generating activities take place (Regulatory Guide 4.2, Supplement 1,  
 34 *Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications*,  
 35 September 2014 (ADAMS Accession No. ML13067A354)).

1 Power plant operations require short-term use of the environment and commitment of  
2 resources, and also commitment of certain resources (e.g., land and energy) indefinitely or  
3 permanently. Certain short-term resource commitments are substantially greater under most  
4 energy alternatives, including license renewal, than they are under the no-action alternative  
5 because of the continued generation of electrical power and the continued use of generating  
6 sites and associated infrastructure. During operations, all energy alternatives require similar  
7 relationships between local short-term uses of the environment and the maintenance and  
8 enhancement of long-term productivity.

9 Air emissions from power plant operations introduce small amounts of radiological and  
10 nonradiological constituents to the region around the plant site. Over time, these emissions  
11 would result in increased concentrations and exposure, but they are not expected to impact air  
12 quality or radiation exposure to the extent that public health and long-term productivity of the  
13 environment would be impaired.

14 Continued employment, expenditures, and tax revenues generated during power plant  
15 operations directly benefit local, regional, and State economies over the short term. The  
16 investment of project-generated tax revenues into infrastructure and other required services by  
17 local governments could enhance economic productivity over the long term.

18 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous  
19 waste, and nonhazardous waste require an increase in energy and they consume space at  
20 treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet  
21 waste disposal needs would reduce the long-term productivity of the land.

22 Power plant facilities are committed to electricity production over the short term. After  
23 decommissioning these facilities and restoring the area, the land could be available for other  
24 future productive uses.

#### 25 **4.17.3 Irreversible and Irrecoverable Commitment of Resources**

26 This section describes the irreversible and irretrievable commitment of resources that have  
27 been noted in this SEIS. Resources are irreversible when primary or secondary impacts limit  
28 future options for a resource. An irretrievable commitment refers to the use or consumption of  
29 resources that are neither renewable nor recoverable for future use. Irreversible and  
30 irretrievable commitment of resources for electrical power generation include the commitment of  
31 land, water, energy, raw materials, and other natural and manmade resources required for  
32 power plant operations. In general, the commitment of capital, energy, labor, and material  
33 resources also are irreversible.

34 The implementation of any of the energy alternatives considered in this SEIS would entail the  
35 irreversible and irretrievable commitment of energy; water; chemicals; and, in some cases, fossil  
36 fuels. These resources would be committed during the license renewal term and over the entire  
37 lifecycle of the power plant, and they would be unrecoverable.

38 Energy expended would be in the form of fuel for equipment, vehicles, and power plant  
39 operations and electricity for equipment and facility operations. Electricity and fuel would be  
40 purchased from offsite commercial sources. Water would be obtained from existing water  
41 supply systems. These resources are readily available, and the amounts required are not  
42 expected to deplete available supplies or exceed available system capacities.

1 **4.18 References**

- 2 10 CFR Part 20. *Code of Federal Regulations*, Title 10, Energy, Part 20, “Standards for  
3 protection against radiation.”
- 4 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, “Domestic licensing of  
5 production and utilization facilities.”
- 6 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, “Environmental  
7 protection regulations for domestic licensing and related regulatory functions.”
- 8 10 CFR Part 100. *Code of Federal Regulations*, Title 10, Energy, Part 100, “Reactor site  
9 criteria.”
- 10 36 CFR Part 60. *Code of Federal Regulations*. Title 36, Parks, Forests, and Public Property,  
11 Part 60, “National Register of Historic Places.”
- 12 36 CFR Part 800, Protection of Historic Properties, National Historic Preservation Act of 1966,  
13 as amended. 54 U.S.C. §300101 et seq.
- 14 40 CFR Part 51. *Code of Federal Regulations*, Title 40, Protection of the Environment, Part 51,  
15 “Requirements for preparation, adoptions, and submittal of implementation plans.”
- 16 40 CFR Part 60. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 60,  
17 “Standards of performance for new stationary sources.”
- 18 40 CFR Part 75. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 75,  
19 “Continuous emission monitoring.”
- 20 40 CFR Part 125. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 125,  
21 “Criteria and standards for the National Pollutant Discharge Elimination System.”
- 22 40 CFR Part 190. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 190,  
23 “Environmental radiation protection standards for nuclear power operations.”
- 24 50 CFR Part 402. *Code of Federal Regulations*, Title 50, Wildlife and Fisheries, Part 402,  
25 “Interagency cooperation—Endangered Species Act of 1973, as amended.”
- 26 49 FR 34658. U.S. Nuclear Regulatory Commission. “Waste confidence decision and  
27 requirements for licensee actions regarding the disposition of spent fuel upon expiration of  
28 reactor operating licenses; Final Rules.” *Federal Register* 49(171): 34658–34696.  
29 August 31, 1984.
- 30 55 FR 38472. U.S. Nuclear Regulatory Commission. “Consideration of environmental impacts  
31 of temporary storage of spent fuel after cessation of reactor operation; and waste confidence  
32 decision review; Final Rules.” *Federal Register* 55(181):38472–38514. September 18, 1990.
- 33 59 FR 7629. Executive Order No. 12898. “Federal actions to address environmental justice in  
34 minority populations and low-income populations.” *Federal Register* 59(32):7629–7634.  
35 February 16, 1994.
- 36 61 FR 28467. U.S. Nuclear Regulatory Commission. “Environmental review for renewal of  
37 nuclear power plant operating licenses.” Final Rule. *Federal Register* 61(109):28467–28497.  
38 June 5, 1996.
- 39 61 FR 66537. U.S. Nuclear Regulatory Commission. “Environmental review for renewal of  
40 nuclear power plant operating licenses.” *Federal Register* 61(244):66537–66544.  
41 December 18, 1996.

- 1 64 FR 68005. U.S. Nuclear Regulatory Commission. "Waste confidence decision review:  
2 status." *Federal Register* 64(233):68005–68007. December 6, 1999.
- 3 65 FR 79825. U.S. Environmental Protection Agency. "Regulatory finding on the emissions of  
4 hazardous air pollutants from electric utility steam generating units." *Federal Register*  
5 65(245):79825–79831. December 20, 2000.
- 6 74 FR 38117. U.S. Nuclear Regulatory Commission. "Revisions to environmental review for  
7 renewal of nuclear power plant operating licenses." Proposed Rule. *Federal Register*  
8 74(146):38117–38140. July 31, 2009.
- 9 74 FR 56260. Environmental Protection Agency. 2009. "Mandatory reporting of greenhouse  
10 gases." *Federal Register* 74(209):56260–56519.
- 11 74 FR 66496. U.S. Environmental Protection Agency. 2009. "Endangerment and cause or  
12 contribute findings for greenhouse gases under Section 202(a) of the Clean Air Act. *Federal*  
13 *Register* 74(239):66496–66546. December 15, 2009.
- 14 75 FR 81032. U.S. Nuclear Regulatory Commission. "Consideration of environmental impacts  
15 of temporary storage of spent fuel after cessation of reactor operation." *Federal Register*  
16 75(246):81032–81037. December 23, 2010.
- 17 75 FR 81037. U.S. Nuclear Regulatory Commission. "Waste confidence decision update."  
18 *Federal Register* 75(246):81037–81076. December 23, 2010.
- 19 76 FR 48208. U.S. Environmental Protection Agency. 2011. "Federal implementation plans:  
20 Interstates transport of fine particulate matter and correction of SIP approvals." *Federal*  
21 *Register* 76(152):48208-48483.
- 22 77 FR 9304. U.S. Environmental Protection Agency. "National emission standards for  
23 hazardous air pollutants from coal- and oil-fired electric utility steam generating units and  
24 standards of performance for fossil-fuel-fired electric utility, industrial commercial institutional,  
25 and small industrial commercial institutional generating units." *Federal Register* 77(32):  
26 9304–9513.
- 27 77 FR 41051. U.S. Environmental Protection Agency. "Prevention of significant deterioration  
28 and Title V greenhouse gas tailoring rule step 3 and GHG plant-wide applicability limits."  
29 *Federal Register* 77(134):41051–41075.
- 30 78 FR 37282. U.S. Nuclear Regulatory Commission. "Revisions to environmental review for  
31 renewal of nuclear power plant operating licenses." *Federal Register* 78(119):37282–37324.  
32 June 20, 2013.
- 33 79 FR 48300. U.S. Environmental Protection Agency. "National Pollutant Discharge  
34 Elimination System—Final regulations to establish requirements for cooling water intake  
35 structures at existing facilities and amend requirements at Phase I facilities." *Federal Register*  
36 79(158):48300–48439. August 15, 2014.
- 37 79 FR 56238. U.S. Nuclear Regulatory Commission. "Continued storage of spent nuclear fuel."  
38 *Federal Register* 79(182):56238–56263. September 19, 2014.
- 39 79 FR 56263. U.S. Nuclear Regulatory Commission. "Generic environmental impact statement  
40 for continued storage of spent nuclear fuel." *Federal Register* 79(182):56263–56264.  
41 September 19, 2014.
- 42 80 FR 64661. U.S. Environmental Protection Agency. "Carbon pollution emission guidelines for  
43 existing stationary sources: Electric utility generating units." *Federal Register* 80(205):  
44 64661–65120. October 23, 2015.

## Environmental Consequences and Mitigating Actions

- 1 82 FR 16093. Executive Order No. 12898. "Promoting energy independence and economic  
2 growth." *Federal Register* 82(61):16093–16097. March 31, 2017.
- 3 82 FR 16576. Council on Environmental Quality. "Withdrawal of final guidance for Federal  
4 departments and agencies on consideration of greenhouse gas emissions and the effects of  
5 climate change in National Environmental Policy Act reviews." *Federal Register* 82(64):  
6 16576–16577.
- 7 Adams SR, Hoover JJ, Killgore KJ. 1999. Swimming endurance of juvenile pallid sturgeon,  
8 *Scaphirhynchus albus*. *Copeia* 3:802-807.
- 9 Alexander JS, Wilson RC, Green WR. 2012. A Brief History and Summary of the Effects of  
10 River Engineering and Dams on the Mississippi River System and Delta. Reston, VA: USGS  
11 Circular 1375. Available at <<http://pubs.usgs.gov/circ/1375/>> (accessed 25 October 2016).
- 12 Baker JA, Killgore KJ, Kasul RL. 1991. Aquatic habitats and fish communities in the Lower  
13 Mississippi River. *Rev. Aquatic. Sci.* 3:313–356.
- 14 Blevins DW. 2011. Water-quality requirements, tolerances, and preferences of pallid sturgeon  
15 (*Scaphirhynchus albus*) in the Lower Missouri River. U.S. Department of the Interior,  
16 U.S. Department of Geological Survey, and U.S. Army Corps of Engineers. USGS Scientific  
17 Investigations Report 2011-5186. 28 p. Available at  
18 <<https://pubs.usgs.gov/sir/2011/5186/pdf/sir2011-5186.pdf>> (accessed 6 December 2016).
- 19 Brown AV, Brown KB, Jackson DC, Pierson WK. 2005. The lower Mississippi River and its  
20 tributaries. In Benke AC, Cushing CE, editors. *Rivers of North America*. New York, Academic  
21 Press.
- 22 Caffey R, Coreil P, Demcheck D. 2002. Mississippi River Water Quality: Implications for  
23 Coastal Restoration, Interpretive Topic Series on Coastal Wetland Restoration in Louisiana,  
24 Coastal Wetland Planning, Protection, and Restoration Act (editors.), National Sea Grant Library  
25 No. LSU-G-02-002.
- 26 Carlson DM, Pflieger WL, Trial L, Haverland PS. 1985. Distribution, biology and hybridization  
27 of *Scaphirhynchus albus* and *S. platyrhynchus* in the Missouri and Mississippi rivers.  
28 *Environmental Biology of Fishes* 14:51–59.
- 29 Chipps SR, Klumb RA, Wright EB. 2010. Development and application of juvenile pallid  
30 sturgeon bioenergetics model: Final Report, South Dakota State Wildlife Grant Program.  
31 Brookings, South Dakota. Study T–24–R; Study No. 2424. 40 p. Available at  
32 <<http://gfp.sd.gov/images/WebMaps/Viewer/WAP/Website/SWGSummaries/Pallid%20Bioenergetics%20Report%20T-24.pdf>> (accessed 7 December 2016).
- 34 Ciferno JP, Marano JJ. 2002. Benchmarking Biomass Gasification Technologies for Fuels,  
35 Chemicals, and Hydrogen Production. Available at  
36 <<https://www.netl.doe.gov/File%20Library/Research/Coal/energy%20systems/gasification/pubs/BMassGasFinal.pdf>> (accessed 4 November 2016).
- 38 Coastal Protection and Restoration Authority. 2012. Louisiana's Comprehensive Master Plan  
39 for a Sustainable Coast. Available at <<http://coastal.la.gov/a-common-vision/2012-coastal-master-plan/>> (accessed 13 October 2016).
- 41 [CDC] Centers for Disease Control and Prevention. 2002. "Surveillance for  
42 Waterborne-Disease Outbreaks—United States, 1999–2000." *Morbidity and Mortality Weekly*  
43 *Report* 51(8):1–28. November 22, 2002. Available at  
44 <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5108a1.htm>> (accessed 14 December 2016).

- 1 [CDC] Centers for Disease Control and Prevention. 2004. "Surveillance for  
 2 Waterborne-Disease Outbreaks and Other Health Events Associated with Recreational  
 3 Water—United States, 2001–2002." *Morbidity and Mortality Weekly Report* 53(8):1–22.  
 4 October 22, 2004. Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5308a1.htm>>  
 5 (accessed 14 December 2016).
- 6 [CDC] Centers for Disease Control and Prevention. 2006. "Surveillance for Waterborne  
 7 Disease and Outbreaks and Other Health Events Associated with Recreational Water—United  
 8 States, 2003–2004." *Morbidity and Mortality Weekly Report* 55(12):1–24. December 22, 2006.  
 9 Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5512a1.htm>> (accessed  
 10 14 December 2016).
- 11 [CDC] Centers for Disease Control and Prevention. 2008. "Surveillance for Waterborne  
 12 Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic  
 13 Facility-Associated—United States, 2005–2006." *Morbidity and Mortality Weekly Report*  
 14 57(9):1–29. September 9, 2008. Available at  
 15 <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5709a1.htm>> (accessed 14 December 2016).
- 16 [CDC] Centers for Disease Control and Prevention. 2011. "Surveillance for Waterborne  
 17 Disease Outbreaks and Other Health Events Associated with Recreational Water—United  
 18 States, 2007–2008." *Morbidity and Mortality Weekly Report* 60(12):1–32. September 23, 2011.  
 19 Available at <[http://www.cdc.gov/mmwr/preview/mmwrhtml/ss6012a1.htm?s\\_cid=ss6012a1\\_w](http://www.cdc.gov/mmwr/preview/mmwrhtml/ss6012a1.htm?s_cid=ss6012a1_w)>  
 20 (accessed 14 December 2016).
- 21 [CDC] Centers for Disease Control and Prevention. 2015. "Technical Information on  
 22 Salmonella." Updated March 9, 2015. Available at  
 23 <<http://www.cdc.gov/salmonella/general/technical.html>> (accessed 12 December 2016).
- 24 [CDC] Centers for Disease Control and Prevention. 2016a. "Reports of Salmonella Outbreak  
 25 Investigations." Updated November 28, 2016. Available at  
 26 <<https://www.cdc.gov/salmonella/outbreaks-2016.html>> (accessed 12 December 2016).
- 27 [CDC] Centers for Disease Control and Prevention. 2016b. "Legionella: Home Page—  
 28 Legionnaires Disease and Pontiac Fever." January 15, 2016. Available at  
 29 <<http://www.cdc.gov/legionella/index.html>> (accessed 2 March 2016).
- 30 Clean Air Act of 1970. 42 U.S.C. §7401 et seq.
- 31 [CEQ] Council on Environmental Quality. 1997. "Considering Cumulative Effects under the  
 32 National Environmental Policy Act." Executive Office of the President, Washington, DC. 122 p.  
 33 Available at  
 34 <[http://energy.gov/sites/prod/files/nepapub/nepa\\_documents/RedDont/G-CEQ-ConsidCumulEff](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/G-CEQ-ConsidCumulEffects.pdf)  
 35 <[ects.pdf](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/G-CEQ-ConsidCumulEffects.pdf)> (accessed 13 December 2016).
- 36 [CEQ] Council on Environmental Quality. 2016. Memorandum for Heads of Federal  
 37 Departments and Agencies. Available at  
 38 <[https://www.whitehouse.gov/sites/whitehouse.gov/files/documents/nepa\\_final\\_ghg\\_guidance.p](https://www.whitehouse.gov/sites/whitehouse.gov/files/documents/nepa_final_ghg_guidance.pdf)  
 39 <[df](https://www.whitehouse.gov/sites/whitehouse.gov/files/documents/nepa_final_ghg_guidance.pdf)> (accessed 6 September 2016).
- 40 [DoT] U.S. Department of Transportation. 2006. Construction Noise Handbook. Available at  
 41 <[http://www.fhwa.dot.gov/environment/noise/construction\\_noise/handbook/](http://www.fhwa.dot.gov/environment/noise/construction_noise/handbook/)> (accessed  
 42 December 15, 2016).
- 43 Doyle TW, Krauss KW, Conner WH, From AS. 2010. Predicting the retreat and migration of  
 44 tidal forests along the northern Gulf of Mexico under sea-level rise. *Forest Ecology and*  
 45 *Management* 259:770–777.

## Environmental Consequences and Mitigating Actions

- 1 [EIA] Energy Information Administration. 2015. Energy-Related Carbon Dioxide Emissions at  
2 the State Level, 2000-2013. Available at  
3 <<http://www.eia.gov/environment/emissions/state/analysis/>> (accessed 27 September 2016).
- 4 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.
- 5 [ENSR] ENSR International. 2005a. Proposal for Information Collection, Entergy Louisiana,  
6 Inc. Waterford 1 & 2 Plant. Document Number 10785-001. June 2005. ADAMS Accession  
7 No. ML17034A323.
- 8 [ENSR] ENSR International. 2005b. Proposal for Information Collection, Entergy Louisiana,  
9 Inc. Waterford 3 Plant. Document Number 000970-026-400. December 2005. ADAMS  
10 Accession No. ML17024A247.
- 11 [ENSR] ENSR Corporation. 2007. Impingement Mortality and Entrainment Characterization  
12 Study (IMECS) Entergy—Waterford 3. December 2007. ADAMS Accession  
13 No. ML12157A426.
- 14 [Entergy] Entergy Operations, Inc. 1992. Letter from R.F. Burski, Entergy to U.S. Nuclear  
15 Regulatory Commission Document Control Desk. Subject: Waterford 3 SES, Docket  
16 No 50-382, License No. NPF-38, Response to Generic Letter 88-20, “Individual Plant  
17 Examination for Severe Accident Vulnerabilities, 10 CFR 50.54(f).” August 1992. ADAMS  
18 Accession No. ML080090452.
- 19 [Entergy] Entergy Operations, Inc. 1995. Letter from R.F. Burski, Entergy to U.S. Nuclear  
20 Regulatory Commission Document Control Desk. Subject: Waterford 3 SES, Docket  
21 No. 50-382, License No. NPF-38, Response to Generic Letter 88-20, Supplement 4, “Individual  
22 Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities.” July 28,  
23 1995. ADAMS Accession No. ML080090465.
- 24 [Entergy] Entergy Louisiana, LLC. 2015a. Letter from R. Buckley, Entergy, to B. Rieck, Deputy  
25 Field Supervisor, U.S. Fish and Wildlife Service. Subject: Waterford 3 Steam Electric Station  
26 Unit 3 License Renewal Application. May 28, 2015. In Attachment B of Entergy 2016a.
- 27 [Entergy] Entergy Operations, Inc. 2015b. Letter from M.R. Chisum, Site Vice President,  
28 Waterford 3, to Louisiana Department of Environmental Quality, Office of Environmental  
29 Services. Subject: Application for Renewal of LPDES Permit and Request for Waiver for Early  
30 Submittal of 122.21(r) Impingement and Entrainment Characterization Data. March 30, 2015.  
31 ADAMS Accession No. ML17037D290.
- 32 [Entergy] Entergy Louisiana, LLC. 2016a. Applicant’s Environmental Report—Operating  
33 License Renewal Stage, Waterford Steam Electric Station, Unit 3, March. ADAMS Accession  
34 No. ML16088A324.
- 35 [Entergy] Entergy Louisiana, LLC. 2016b. Letter from M.R. Chisum, Waterford 3 Site Vice  
36 President, Entergy, to NRC Document Control Desk. Responses to Request for Additional  
37 Information for Environmental Review Regarding the License Renewal Application for Waterford  
38 Steam Electric Station, Unit 3 (Waterford 3). November 23, 2016. ADAMS Accession  
39 No. ML16328A414.
- 40 [Entergy] Entergy Operations, Inc. 2016c. Annual Radiological Environmental Operating  
41 Report—2015, Waterford Steam Electric Station, Unit 3, January 1, 2015–December 31, 2015.  
42 April 26, 2016. ADAMS Accession No. ML16132A515; Package No. ML16132A489.

- 1 [Entergy] Entergy Operations, Inc. 2017a. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
 2 Regulatory Commission Document Control Desk. Subject: "Responses to Request for  
 3 Additional Information for the Environmental Review of the Waterford Steam Electric Station,  
 4 Unit 3 (Waterford 3). February 7, 2017. ADAMS Accession No. ML17038A436.
- 5 [Entergy] Entergy Operations, Inc. 2017b. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
 6 Regulatory Commission Document Control Desk. Subject: Responses to Request for  
 7 Additional Information for the Environmental Review (SAMA Round 2) of the Waterford Steam  
 8 Electric Station, Unit 3 (Waterford 3). April 21, 2017. ADAMS Accession No. ML17117A281.
- 9 [EPA] U.S. Environmental Protection Agency. 1998. Guidelines for Ecological  
 10 Risk Assessment. Washington, DC: EPA Risk Assessment Forum. EPA/630/R-95/002F.  
 11 188 p. Available at <<http://www.epa.gov/raf/publications/pdfs/ECOTXTBX.PDF>> (accessed  
 12 27 March 2014).
- 13 [EPA] U.S. Environmental Protection Agency. 1999. Consideration of Cumulative Impacts in  
 14 EPA Review of NEPA Documents. EPA-315-R-99-002. Office of Federal Activities (2252A),  
 15 Washington, DC. Available at <[http://www2.epa.gov/sites/production/files/2014-  
 16 08/documents/cumulative.pdf](http://www2.epa.gov/sites/production/files/2014-08/documents/cumulative.pdf)> (accessed 13 December 2016).
- 17 [EPA] U.S. Environmental Protection Agency. 2002. Case Study Analysis for the Proposed  
 18 Section 316(b) Phase II Existing Facilities Rule. EPA-821-R-02-002. Office of Science and  
 19 Technology, Washington, D.C. February.
- 20 [EPA] U.S. Environmental Protection Agency. 2004. Technical Development Document for the  
 21 Final Section 316(b) Phase II Existing Facilities Rule. Washington, DC: EPA Office of Water.  
 22 EPA 821-R-04-007. February 12, 2004. 228 p. Available at <[https://www.epa.gov/cooling-  
 23 water-intakes/support-documents-phase-ii-cooling-water-intake-rule-2004-withdrawn](https://www.epa.gov/cooling-water-intakes/support-documents-phase-ii-cooling-water-intake-rule-2004-withdrawn)>  
 24 (accessed 1 December 2016).
- 25 [EPA] U.S. Environmental Protection Agency. 2009a. Endangerment and Cause or Contribute  
 26 Finding for Greenhouse Gases under Section 202(a) of the Clean Air Act. Available at  
 27 <[https://www.epa.gov/sites/production/files/2016-08/documents/endangerment\\_tsd.pdf](https://www.epa.gov/sites/production/files/2016-08/documents/endangerment_tsd.pdf)>  
 28 (accessed 8 November 2016).
- 29 [EPA] U.S. Environmental Protection Agency. 2009b. Assessment of the Impacts of Global  
 30 Change on Regional U.S. Air Quality: A Synthesis of Climate Change Impacts on Ground-Level  
 31 Ozone. EPA/600/R-07/094F. April. Available at  
 32 <[http://ofmpub.epa.gov/eims/eimscomm.getfile?p\\_download\\_id=491176](http://ofmpub.epa.gov/eims/eimscomm.getfile?p_download_id=491176)> (accessed  
 33 8 November 2016).
- 34 [EPA] Environmental Protection Agency. 2014. Greenhous Gas Inventory Guidance, Direct  
 35 Fugitive Emissions from Refrigeration, Air Conditioning, Fire Suppression, and Industrial Gases.  
 36 Available at <[https://www.epa.gov/sites/production/files/2015-  
 37 07/documents/fugitiveemissions.pdf](https://www.epa.gov/sites/production/files/2015-07/documents/fugitiveemissions.pdf)> (accessed 15 September 2016).
- 38 [EPA] U.S. Environmental Protection Agency. 2016a. Climate Change Indicators in the United  
 39 States, 2014. Fourth Edition. EPA-430-R-14-004. Available at <[https://www.epa.gov/climate-  
 40 indicators/downloads-indicators-report](https://www.epa.gov/climate-indicators/downloads-indicators-report)> (accessed 6 September 2016).
- 41 [EPA] Environmental Protection Agency. 2016b. Enforcement and Compliance History Online,  
 42 St. Charles Parish. Available at <<https://echo.epa.gov/>> (accessed 4 November 2016).
- 43 [EPA] Environmental Protection Agency. 2016c. Inventory of U.S. Greenhouse Gas Emissions  
 44 and Sinks: 1990-2014. Available at <[https://www.epa.gov/ghgemissions/us-greenhouse-gas-  
 45 inventory-report-1990-2014](https://www.epa.gov/ghgemissions/us-greenhouse-gas-inventory-report-1990-2014)> (accessed 28 September 2016).

## Environmental Consequences and Mitigating Actions

- 1 [EPA] Environmental Protection Agency. 2016d. Facility Level Information on Greenhouse Gas  
2 Tool, St. Charles Parish. Available at <<https://ghgdata.epa.gov/ghgp/main.do>> (accessed  
3 27 September 2016).
- 4 [Espey, Huston & Associates] Espey, Huston, & Associates, Inc. 1977. Annual Data Report,  
5 Waterford Power Station, Units 1 and 2, Screen Impingement Studies, February 1976 through  
6 January 1977. Prepared for Louisiana Power and Light Company. May 6, 1977. 46 p.  
7 ADAMS Accession No. ML17037C948.
- 8 Farage L. 2003. Effects of habitat fragmentation on biodiversity. *Annual Review of Ecology,*  
9 *Evolution, and Systematics* 34:487–515.
- 10 Federal Water Pollution Control Act (Clean Water Act) of 1972, as amended. 33 U.S.C. §1251  
11 et seq.
- 12 FishNet. 2014. FishNet2, Search FishNet. Available at <<http://www.fishnet2.net>> (accessed  
13 8 November 2016).
- 14 [FHWA] Federal Highway Administration. 2011. Highway Traffic Noise: Analysis and  
15 Abatement Guidance. Available at  
16 <[http://www.fhwa.dot.gov/environment/noise/regulations\\_and\\_guidance/analysis\\_and\\_abateme](http://www.fhwa.dot.gov/environment/noise/regulations_and_guidance/analysis_and_abateme)  
17 [nt\\_guidance/revguidance.pdf](http://www.fhwa.dot.gov/environment/noise/regulations_and_guidance/analysis_and_abateme)> (accessed 8 November 2016).
- 18 [FWS] U.S. Fish and Wildlife Service. 2013. Biological Opinion for Channel Improvement  
19 Program, Mississippi River and Tributaries Project, Lower Mississippi River.  
20 December 12, 2013. Available at  
21 <<https://www.fws.gov/mississippies/pdf/LMRBiologicalOpinion.pdf>> (accessed  
22 1 September 2016).
- 23 [FWS] U.S. Fish and Wildlife Service. 2014. Guidance for Preparing a Biological Assessment.  
24 6 p. Available at <<http://www.fws.gov/midwest/endangered/section7/pdf/BAGuidance.pdf>>  
25 (accessed 19 May 2016).
- 26 [FWS] U.S. Fish and Wildlife Service. 2015. Letter from D. Fuller, FWS, to R. Buckley, Entergy.  
27 Reply to Entergy's May 28, 2015, letter concerning Waterford 3 Steam Electric Station Unit 3  
28 License Renewal Application. June 26, 2015. In Attachment B of Entergy 2016a.
- 29 [FWS] U.S. Fish and Wildlife Service. 2016. E-mail from FWS to K. Hamilton, LDEQ.  
30 Subject: Renewal application for facility subject to 316(b) requirements for existing facilities;  
31 Entergy Louisiana, LLC – Waterford 3 Steam Electric Station; AL35260 LA0007374.  
32 March 31, 2016. Activity No. 10153457. Available at <<http://edms.deq.louisiana.gov/>>  
33 (accessed 6 December 2016).
- 34 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 1998.  
35 Endangered Species Consultation Handbook: Procedures for Conducting Consultation and  
36 Conference Activities Under Section 7 of the Endangered Species Act. March 1998. 315 p.  
37 Available at <[http://www.fws.gov/endangered/esa-library/pdf/esa\\_section7\\_handbook.pdf](http://www.fws.gov/endangered/esa-library/pdf/esa_section7_handbook.pdf)>  
38 (accessed 19 May 2016).
- 39 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 2009.  
40 Gulf Sturgeon (*Acipenser oxyrinchus desotoi*) 5-Year Review: Summary and Evaluation.  
41 September 2009. 49 p. Available at <[https://ecos.fws.gov/docs/five\\_year\\_review/doc2620.pdf](https://ecos.fws.gov/docs/five_year_review/doc2620.pdf)>  
42 (accessed 1 September 2016).
- 43 Friedenber NA, Powell JA, Ayres MP. 2007. Synchrony's double edge: transient dynamics  
44 and the Allee effect in stage structured populations. *Ecology Letters* 10:564–573.

- 1 [GCP] Global Carbon Project. Global Carbon Budget 2015. Available at  
 2 <[http://www.globalcarbonproject.org/carbonbudget/archive/2015/GCP\\_budget\\_2015\\_v1.02.pdf](http://www.globalcarbonproject.org/carbonbudget/archive/2015/GCP_budget_2015_v1.02.pdf)>  
 3 (accessed 18 January 2017).
- 4 [GSU] Georgia State University. 2016. HyperPhysics, Estimating Sound Levels with the  
 5 Inverse Square Law. Available at <[http://hyperphysics.phy-](http://hyperphysics.phy-astr.gsu.edu/hbase/acoustic/isprob2.html)  
 6 [astr.gsu.edu/hbase/acoustic/isprob2.html](http://hyperphysics.phy-astr.gsu.edu/hbase/acoustic/isprob2.html)> (accessed 3 November 2016).
- 7 Herkert JR. 1994. The effects of habitat fragmentation on Midwestern grassland bird  
 8 communities. *Ecological Applications* 4(3):461–471.
- 9 [IRENA] International Renewable Energy Agency. 2012. Renewable Energy Technologies:  
 10 Cost Analysis Series, Biomass Power Generation. Available at  
 11 <[https://www.irena.org/DocumentDownloads/Publications/RE\\_Technologies\\_Cost\\_Analysis-](https://www.irena.org/DocumentDownloads/Publications/RE_Technologies_Cost_Analysis-BIOMASS.pdf)  
 12 [BIOMASS.pdf](https://www.irena.org/DocumentDownloads/Publications/RE_Technologies_Cost_Analysis-BIOMASS.pdf)> (accessed 3 November 2016).
- 13 [IPCC] Intergovernmental Panel on Climate Change. 2000. IPCC Special Report: Emissions  
 14 Scenarios. Available at <<http://www.ipcc.ch/ipccreports/sres/emission/index.php?idp=0>>  
 15 (accessed 8 October 2016).
- 16 [IPCC] Intergovernmental Panel on Climate Change. 2007a. Climate Change 2007: The  
 17 Physical Science Basis. Contribution of Working Group I to the Fourth Assessment Report of  
 18 the Intergovernmental Panel on Climate Change. Solomon S, Qin D, Manning M, Chen Z,  
 19 Marquis M, Averyt KB, Tignor M, Miller HL editors. Cambridge University Press, Cambridge,  
 20 UK, and New York, NY.
- 21 [IPCC] Intergovernmental Panel on Climate Change. 2007b. Climate Change 2007: Impacts,  
 22 Adaptation and Vulnerability. Contribution of Working Group II to the Fourth Assessment  
 23 Report of the Intergovernmental Panel on Climate Change Parry ML, Canziani OF, Palutikof JP,  
 24 van der Linden PJ, Hanson CE, editors. Cambridge University Press, Cambridge, UK.
- 25 [IPCC] Intergovernmental Panel on Climate Change. 2013. Climate Change 2013: The  
 26 Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the  
 27 Intergovernmental Panel on Climate Change. Stocker TF, Qin D, Plattner G-K, Tignor M,  
 28 Allen SK, Boschung J, Nauels A, Xia Y, Bex V, Midgley PM, editors. Available at  
 29 <[http://www.ipcc.ch/pdf/assessment-report/ar5/wg1/WG1AR5\\_SPM\\_FINAL.pdf](http://www.ipcc.ch/pdf/assessment-report/ar5/wg1/WG1AR5_SPM_FINAL.pdf) >
- 30 [IEA/OECD/NEA] International Energy Agency/Organisation for Economic Co-operation and  
 31 Development/Nuclear Energy Agency. 2005. Projected Costs of Generating Electricity 2005.  
 32 OECD Publishing. 230 p. Available at <[https://www.oecd-neo.org/ndd/pubs/2005/5968-](https://www.oecd-neo.org/ndd/pubs/2005/5968-projected-costs.pdf)  
 33 [projected-costs.pdf](https://www.oecd-neo.org/ndd/pubs/2005/5968-projected-costs.pdf)> (accessed 17 December 2014).
- 34 Jacob DJ and Winner DA. 2009. Effect of climate change on air quality. *Atmospheric*  
 35 *Environment* 43:51–63).
- 36 Jones CE, An K, Blom RG, Kent JD, Ivins JER, Bekaert D. 2016. Anthropogenic and Geologic  
 37 Influences on Subsidence in the Vicinity of New Orleans, Louisiana. *Journal of Geophysical*  
 38 *Research: Solid Earth* 121:3867–3887).
- 39 Kapperman KM, Fraser WC, Toner M, Dean J, Webb MAH. 2009. Effect of temperature on  
 40 growth, condition, and survival of juvenile shovelnose sturgeon. *Transactions of the American*  
 41 *Fisheries Society* 138:927–937.
- 42 [LDEQ] Louisiana Department of Environmental Quality. 1998. Louisiana Pollutant Discharge  
 43 Elimination System (LPDES) Fact Sheet and Rational for the Waterford 3 Draft LPDES Permit  
 44 to Discharge to Waters of Louisiana, LPDES Permit Number LA0007374, July, 22 1998.  
 45 ADAMS Accession No. ML17037C997.

## Environmental Consequences and Mitigating Actions

- 1 [LDEQ] Louisiana Department of Environmental Quality. 2006. Letter from L. Young, LDEQ, to  
2 M. Louque, Entergy. Subject: Response to the Proposal for Information Collection (PIC) for  
3 Entergy Operations, Inc., Waterford 3 Electric Station. August 17, 2006. Available at  
4 <<http://edms.deq.louisiana.gov/app/doc/querydef.aspx>> (accessed 3 August 2016).
- 5 [LDEQ] Louisiana Department of Environmental Quality. 2010. Permit No. LA0007374, Water  
6 Discharge Permit, Entergy Operations, Inc. Waterford 3 Steam Electric Station. Baton Rouge,  
7 LA: Office of Environmental Services. Issued September 7, 2010. Effective date  
8 October 1, 2010. In: Appendix E, Applicant's Environmental Report, Operating License  
9 Renewal Stage, Waterford Steam Electric Station, Unit 3. Attachment A. ADAMS Accession  
10 No. ML16088A335.
- 11 [LDEQ] Louisiana Department of Environmental Quality. 2015. Letter from S. Guilliams,  
12 Administrator, Water Permit Division, to K.M. Dowell, Entergy Services, Inc. RE: Entergy  
13 Operations, Inc.– Waterford Steam Electric Station Unit 3 Water Quality Certification.  
14 January 30, 2015. In: Appendix E, Applicant's Environmental Report, Operating License  
15 Renewal Stage, Waterford Steam Electric Station, Unit 3. Attachment A. ADAMS Accession  
16 No. ML16088A335.
- 17 [LDEQ] Louisiana Department of Environmental Quality. 2016. E-mail from K. Hamilton, LDEQ,  
18 to A. Trahan and D. Walther, U.S. Fish and Wildlife Service. Subject: Renewal application for  
19 facility subject to 316(b) requirements for existing facilities; Entergy Louisiana LLC –  
20 Waterford 3 Steam Electric Station; AI 35260; LA0007374. March 1, 2016. Activity  
21 No. 10153457. Available at <<http://edms.deq.louisiana.gov/>> (accessed 6 December 2016).
- 22 [LDEQ] Louisiana Department of Environmental Quality. 2017. Permit No. LA0007374, AI  
23 No.: 35260, Water Discharge Permit, Entergy Operations, Waterford 3 Steam Electric Station.  
24 Baton Rouge, LA: Office of Environmental Services. Issued August 1 2017. Effective date  
25 October 1 2017. Available at  
26 <<http://edms.deq.louisiana.gov/app/doc/view.aspx?doc=10769669&ob=yes&child=yes>>  
27 (accessed 10 October 2017).
- 28 [LDH] Louisiana Department of Health. Undated. "Annual Infectious Disease Surveillance  
29 Reports." Available at <<http://new.dhh.louisiana.gov/index.cfm/page/536>> (accessed  
30 14 December 2016).
- 31 [LDH] Louisiana Department of Health. Undated. "Annual Infectious Disease Surveillance  
32 Reports." Available at <<http://new.dhh.louisiana.gov/index.cfm/page/536>> (accessed  
33 14 December 2016).
- 34 [LP&L] Louisiana Power & Light Company. 1978. Environmental Report–Operating License  
35 Stage, Waterford Steam Electric Station Unit No. 3, Vols. 1, 2, and 3. ADAMS Accession  
36 Nos. ML16207A102, ML16207A125, and ML16207A148.
- 37 [LP&L] Louisiana Power & Light Company. 1979. Demonstration under Section 316(b) of the  
38 Clean Water Act. Waterford Steam Electric Station Unit No. 3. April 1979. ADAMS Accession  
39 No. ML17037D017.
- 40 [LP&L] Louisiana Power & Light Company. 1978. Environmental Report–Operating License  
41 Stage, Waterford Steam Electric Station Unit No. 3, Vols. 1, 2, and 3. ADAMS Accession  
42 Nos. ML16207A102, ML16207A125, and ML16207A148.
- 43 [LOCD] Louisiana Office of Cultural Development. 2011. Our Places, Our Heritage:  
44 A Plan for Historic Preservation and Archaeological Conservation in Louisiana, 2011–2015.  
45 Available at <[http://www.crt.state.la.us/Assets/OCD/hp/SHPO/SHPO\\_Jan\\_2011.pdf](http://www.crt.state.la.us/Assets/OCD/hp/SHPO/SHPO_Jan_2011.pdf)> (accessed  
46 13 February 2017).

- 1 [LOCD] Louisiana Office of Cultural Development. 2015. Division of Historic Preservation –  
 2 National Register. Available at <[http://www.crt.state.la.us/cultural-development/historic-](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)  
 3 [preservation/national-register/index](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)> (accessed 13 February 2017).
- 4 [LOCD] Louisiana Office of Cultural Development. 2017. Division of Historic Preservation –  
 5 National Register. Available at <[http://www.crt.state.la.us/cultural-development/historic-](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)  
 6 [preservation/national-register/index](http://www.crt.state.la.us/cultural-development/historic-preservation/national-register/index)> (accessed 13 February 2017).
- 7 [LOPH] Louisiana Office of Public Health. 2013. Meningo-Encephalitis Due to Free Living  
 8 Amebas Annual Report. Available at <[http://new.dhh.louisiana.gov/assets/oph/Center-](http://new.dhh.louisiana.gov/assets/oph/Center-PHCH/Center-CH/infectious-epi/Annuals/AmebaFreeLivingEncephalitis_LaIDAnnual.pdf)  
 9 [PHCH/Center-CH/infectious-epi/Annuals/AmebaFreeLivingEncephalitis\\_LaIDAnnual.pdf](http://new.dhh.louisiana.gov/assets/oph/Center-PHCH/Center-CH/infectious-epi/Annuals/AmebaFreeLivingEncephalitis_LaIDAnnual.pdf)>  
 10 (accessed 14 December 2016).
- 11 [LWRC] Louisiana Water Resources Commission. 2013. Update to the March 2012 Interim  
 12 Report to the Louisiana Legislature. Baton Rouge, LA. June 2013. Available at  
 13 <[http://dnr.louisiana.gov/assets/OC/env\\_div/gw\\_res/NEWS\\_RELEASE/WRC2013UpdateFinalV](http://dnr.louisiana.gov/assets/OC/env_div/gw_res/NEWS_RELEASE/WRC2013UpdateFinalVersion.pdf)  
 14 [ersion.pdf](http://dnr.louisiana.gov/assets/OC/env_div/gw_res/NEWS_RELEASE/WRC2013UpdateFinalVersion.pdf) > (accessed 21 October 2016).
- 15 Mannouris C, Byers DL. 2013. The impact of habitat fragmentation on fitness-related traits in a  
 16 native prairie plant, *Chamaecrista fasciculata* (Fabaceae). *Biological Journal of the Linnean*  
 17 *Society* 108(1):55–67.
- 18 [MSA] Magnuson–Stevens Fishery Conservation and Management Reauthorization Act of 2006,  
 19 as amended. 16 U.S.C. §§1801–1884.
- 20 Mayhew DA, Jensen LD, Hanson DF, Muessig PH. 2000. A comparative review of  
 21 entrainment survival studies at power plants in estuarine environments. *Environmental Science*  
 22 *and Policy* 3:295–301.
- 23 McLaren JB, Tuttle LR. 2000. Fish survival on fine mesh traveling screens. *Environmental*  
 24 *Science and Policy* 3:S369–S376.
- 25 Menzie C, Henning MH, Cura J, Finkelstein K, Gentile J, Maughan J, Mitchell D, Petron S,  
 26 Potocki B, Svirsky S, Tyler P. 1996. Special report of the Massachusetts weight-of-evidence  
 27 workgroup: A weight-of-evidence approach for evaluating ecological risks. *Human and*  
 28 *Ecological Risk Assessment* 2(2):227–304.
- 29 [MRC] Mississippi River Commission. 2016. Mississippi River Commission. Available at  
 30 <<http://www.mvd.usace.army.mil/About/Mississippi-River-Commission-MRC/>> (accessed  
 31 12 December 2016).
- 32 National Environmental Policy Act of 1969, as amended (NEPA). 42 U.S.C. §4321 et seq.  
 33 National Historic Preservation Act of 1966, as amended (NHPA). 54 U.S.C. §300101 et seq.
- 34 [NREL] National Renewable Energy Laboratory. 2003. Biopower Technical Assessment: State of  
 35 the Industry and Technology. Available at <<http://www.nrel.gov/docs/fy03osti/33123.pdf>>  
 36 (accessed 3 November 2016).
- 37 [NREL] National Renewable Energy Laboratory. 2006. Comparing Statewide Economic  
 38 Impacts of New Generation from Wind, Coal, and Natural Gas in Arizona, Colorado, and  
 39 Michigan. Available at <<http://www.nrel.gov/docs/fy06osti/37720.pdf>> (accessed  
 40 3 November 2016).

## Environmental Consequences and Mitigating Actions

- 1 [NETL] National Energy Technology Laboratory. 2010. Life Cycle Analysis: Supercritical  
2 Pulverized Coal (SCPC) Power Plant. Available at  
3 <[https://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Life%20Cycle%20Ana](https://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Life%20Cycle%20Analysis/SCPC-LCA-Final-Report---Report---9-30-10---Final---Rev-1.pdf)  
4 [lysis/SCPC-LCA-Final-Report---Report---9-30-10---Final---Rev-1.pdf](https://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Life%20Cycle%20Analysis/SCPC-LCA-Final-Report---Report---9-30-10---Final---Rev-1.pdf)> (accessed  
5 3 November 2016).
- 6 [NETL] National Energy Technology Laboratory. 2012. Life Cycle Analysis: Natural Gas  
7 Combined Cycle (NGCC) Power Plant. Available at <[https://www.netl.doe.gov/energy-](https://www.netl.doe.gov/energy-analyses/temp/FY13_LifeCycleAnalysisNaturalGasCombinedCycle(NGCC)PowerPlantFinal_060113.pdf)  
8 [analyses/temp/FY13\\_LifeCycleAnalysisNaturalGasCombinedCycle\(NGCC\)PowerPlantFinal\\_06](https://www.netl.doe.gov/energy-analyses/temp/FY13_LifeCycleAnalysisNaturalGasCombinedCycle(NGCC)PowerPlantFinal_060113.pdf)  
9 [0113.pdf](https://www.netl.doe.gov/energy-analyses/temp/FY13_LifeCycleAnalysisNaturalGasCombinedCycle(NGCC)PowerPlantFinal_060113.pdf)> (accessed 3 November 2016).
- 10 National Research Council. 2008. Mississippi River Water Quality and the Clean Water Act:  
11 Progress, Challenges, and Opportunities. Washington, DC: The National Academies Press.  
12 Available at <[https://www.nap.edu/catalog/12051/mississippi-river-water-quality-and-the-clean-](https://www.nap.edu/catalog/12051/mississippi-river-water-quality-and-the-clean-water-act-progress)  
13 [water-act-progress](https://www.nap.edu/catalog/12051/mississippi-river-water-quality-and-the-clean-water-act-progress)> (accessed 19 October 2016)
- 14 [NMFS] National Marine Fisheries Service. Biological Opinion for Continued Operation of Indian  
15 Point Nuclear Generating Unit Nos. 2 and 3. January 30, 2013. ADAMS Accession  
16 No. ML14202A146.
- 17 [NMFS] National Marine Fisheries Service. Biological Opinion for Continued Operation of  
18 Salem and Hope Creek Nuclear Generating Stations. July 17, 2014. ADAMS Accession  
19 No. ML13032A569.
- 20 [NOAA] National Oceanic and Atmospheric Administration. 2013a. Regional Trends and  
21 Scenarios for the U.S. National Climate Assessment, Part 9 Climate of the Contiguous United  
22 States. NOAA Technical Report NESDID 142-9.
- 23 [NOAA] National Oceanic and Atmospheric Administration. 2013b. Regional Climate Trends  
24 and Scenarios for the U.S. National Climate Assessment, Part 2. Climate of the Southeast.  
25 NOAA Technical Report NESDID 142-2.
- 26 [NRC] U.S. Nuclear Regulatory Commission. 1981. Final Environmental Statement Related to  
27 the Operation of Waterford Steam Electric Station, Unit No. 3. Docket No. 50-382.  
28 NUREG– 0779. September 1981. ADAMS Accession No. ML16095A114.
- 29 [NRC] U.S. Nuclear Regulatory Commission. 1997. *Regulatory Analysis Technical Evaluation*  
30 *Handbook*. NUREG/BR–0184. Washington, DC. January 1997. ADAMS Accession  
31 No. ML050190193.
- 32 [NRC] U.S. Nuclear Regulatory Commission. 2010. *Supplemental Environmental Impact*  
33 *Statement Regarding Indian Point Generating, Units 2 and 3*. Washington, DC: NRC.  
34 NUREG–1437, Supplement 38. December 2010. ADAMS Accession No. ML103270072.
- 35 [NRC] U.S. Nuclear Regulatory Commission. 2013a. *Generic Environmental Impact Statement*  
36 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG–1437, Revision 1.  
37 Volumes 1, 2, and 3. June 30, 2013. 1,535 p. ADAMS Accession No. ML13107A023.
- 38 [NRC] U.S. Nuclear Regulatory Commission. 2013b. “Interim Staff Guidance on Environmental  
39 Issues Associated with New Reactors, Attachment 1—Staff Guidance for Greenhouse Gas and  
40 Climate Change.” September 2013. Adams Accession No. ML12326A811.
- 41 [NRC] U.S. Nuclear Regulatory Commission. 2013c. Event Report Guidelines: 10 CFR 50.72  
42 and 50.73. Revision 3. Washington, DC: NRC. NUREG–1022. January 31, 2013. 107 p.  
43 ADAMS Accession No. ML13032A220.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2013d. *Standard Review Plans for Environmental*  
2 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG–1555,  
3 Supplement 1, Revision 1. June 2013. ADAMS Accession No. ML13106A246.
- 4 [NRC] U.S. Nuclear Regulatory Commission. 2013e. *Final Supplemental Environmental Impact*  
5 *Statement Regarding South Texas Project*. NUREG–1437, Supplement 48. November 2013.  
6 ADAMS Accession No. ML13322A890.
- 7 [NRC] U.S. Nuclear Regulatory Commission. 2014. *Generic Environmental Impact Statement*  
8 *for Continued Storage of Spent Nuclear Fuel*. Washington, DC: NRC, Office of Nuclear  
9 Material Safety and Safeguards. NUREG–2157, Volumes 1 and 2. September 2014. ADAMS  
10 Accession Nos. ML14196A105 and ML14196A107.
- 11 [NRC] U.S. Nuclear Regulatory Commission. 2015a. *Final Supplemental Environmental Impact*  
12 *Statement Regarding Braidwood Station*. NUREG–1437, Supplement 55. November 2015.  
13 ADAMS Accession No. ML15062A428.
- 14 [NRC] U.S. Nuclear Regulatory Commission. 2015a. *Final Supplemental Environmental Impact*  
15 *Statement Seabrook Station*. NUREG–1437, Supplement 46. July 2015. ADAMS Accession  
16 Nos. ML15209A575 and ML15209A870.
- 17 [NRC] U.S. Nuclear Regulatory Commission. 2016a. Teleconference Summary between  
18 M. Moser, NRC, and B. Fielding, LDEQ, regarding Impingement Studies to Support the  
19 Environmental Review for the Waterford 3 License Renewal Application. ADAMS Accession  
20 No. ML17087A172.
- 21 [NRC] U.S. Nuclear Regulatory Commission. 2016b. Conversation Record for July 26, 2016,  
22 Conversation Between R. Hartman, Fishery Biologist, National Marine Fisheries Service, and  
23 B. Grange, Biologist, NRC. July 27, 2016. ADAMS Accession No. ML16209A351.
- 24 [NRC] U.S. Nuclear Regulatory Commission. 2016c. Email from B. Grange, NRC, to  
25 R. Hartman, National Marine Fisheries Service. Subject: No adverse effects to EFH for  
26 Waterford Unit 3 proposed license renewal. July 26, 2016. ADAMS Accession  
27 No. ML16209A330.
- 28 [NRC] U.S. Nuclear Regulatory Commission. 2016d. Letters from J. Danna to Federally  
29 recognized Tribes. Subject: Request for scoping comments and notifications of Section 106  
30 review. June 2013. ADAMS Accession No. ML16146A730.
- 31 [NRC] U.S. Nuclear Regulatory Commission. 2016e. Letter from J. Danna to P. Boggan,  
32 Louisiana Office of Cultural Development. Subject: Request for scoping comments and  
33 notifications of Section 106 review. June 2013. ADAMS Accession No. ML16147A280.
- 34 [NRC] U.S. Nuclear Regulatory Commission. 2016f. Letter from J. Danna to R. Nelson,  
35 Advisory Council on Historic Preservation. Subject: Request for scoping comments and  
36 notifications of Section 106 review. June 2013. ADAMS Accession No. ML16147A235.
- 37 [NRC] U.S. Nuclear Regulatory Commission. 2016g. Teleconference Summary between  
38 M. Moser, NRC, and R. Ratard, LPH, regarding Thermophilic Organisms Related to the  
39 Operation of Waterford 3 for the Environmental Review of the Waterford 3 License Renewal  
40 Application. ADAMS Accession No. ML17087A183.
- 41 [NRC] U.S. Nuclear Regulatory Commission. 2016h. *Final Supplemental Environmental Impact*  
42 *Statement Regarding LaSalle County Station*. NUREG–1437, Supplement 57. August 2016.  
43 ADAMS Accession No. ML16238A029.
- 44 Rabalais NN, Turner RE, Díaz RJ, Justić D. 2009. Global change and eutrophication of coastal  
45 waters. *ICES Journal of Marine Science* 66:1528–1537.

## Environmental Consequences and Mitigating Actions

- 1 Rivers and Harbors Appropriation Act of 1899. 33 U.S.C. §403 et seq.
- 2 Sargent BP. 2012. Water Use in Louisiana, 2010. Baton Rouge, LA: Louisiana Department of  
3 Transportation and Development and U.S. Geological Survey. Water Resources Special Report  
4 No. 17. Revised December 2012. Available at  
5 <<https://la.water.usgs.gov/publications/pdfs/WaterUse2010.pdf>> (accessed 5 December 2016).
- 6 St. Charles Parish. 2015. Hazard Mitigation Plan. Prepared by Providence for St. Charles  
7 Parish, LA. January 2015. Available at <[http://stcharlesparish-la.gov/departments/emergency-](http://stcharlesparish-la.gov/departments/emergency-preparedness)  
8 [preparedness](http://stcharlesparish-la.gov/departments/emergency-preparedness)> (accessed 5 December 2016).
- 9 Tao Z, Williams A, Huan HC, Caughey M, Lian XZ. 2007. Sensitivity of U.S. surface ozone to  
10 future emissions and climate changes. *Geophysical Research Letters* 34(8):L08811. Available  
11 at <<http://onlinelibrary.wiley.com/doi/10.1029/2007GL029455/epdf>>. (accessed  
12 8 November 2016).
- 13 [USACE] United States Army Corps of Engineers. 2016. “An Overview of the Mississippi  
14 River’s Saltwater Wedge.” New Orleans District. No page date. Available at <  
15 [http://www.mvn.usace.army.mil/Missions/Engineering/Stage-and-Hydrologic-](http://www.mvn.usace.army.mil/Missions/Engineering/Stage-and-Hydrologic-Data/SaltwaterWedge/SaltwaterWedgeOverview/)  
16 [Data/SaltwaterWedge/SaltwaterWedgeOverview/](http://www.mvn.usace.army.mil/Missions/Engineering/Stage-and-Hydrologic-Data/SaltwaterWedge/SaltwaterWedgeOverview/)> (accessed 5 December 2016).
- 17 [USGS] U.S. Geological Survey. 2016a. “Louisiana Water Use Program.” Available at  
18 <<https://la.water.usgs.gov/WaterUse/>> (accessed 5 December 2016).
- 19 [USGS] United States Geological Survey. 2016b. “Louisiana Water Use, 2012–2014 Data  
20 Tables.” [2014 Water Usage Type by Parish.] Page updated December 23, 2016. Available at  
21 <[https://la.water.usgs.gov/WaterUse/data table/parishTable.asp](https://la.water.usgs.gov/WaterUse/data_table/parishTable.asp)> (accessed  
22 23 December 2016).
- 23 [USGCRP] U.S. Global Change Research Program. 2009. Global Climate Change Impacts in  
24 the United States. Karl TR, Melillo JM, Peterson TC, editors. Cambridge University Press:  
25 New York, NY. Available at <[http://library.globalchange.gov/products/assessments/2009-](http://library.globalchange.gov/products/assessments/2009-national-climate-assessment/2009-global-climate-change-impacts-in-the-united-states)  
26 [national-climate-assessment/2009-global-climate-change-impacts-in-the-united-states](http://library.globalchange.gov/products/assessments/2009-national-climate-assessment/2009-global-climate-change-impacts-in-the-united-states)>  
27 (accessed 11 May 2012).
- 28 [USGCRP] U.S. Global Change Research Program. 2014. Climate Change Impacts in the  
29 United States. Melillo JM, Richmond TC, Yohe GW, editors. May. ADAMS Accession  
30 No. ML14129A233
- 31 Weakley A, Dinerstein E, Snodgrass R, Wolfe K. 2016. “Mississippi Lowland Forests.”  
32 Available at <<http://www.worldwildlife.org/ecoregions/na0409>> (accessed 18 May 2016).
- 33 Wiken E, Nava FJ, Griffith G. 2011. North American Terrestrial Ecoregions—Level III.  
34 Montreal, Canada: Commission for Environmental Cooperation. Available at  
35 <[http://www3.cec.org/islandora/en/item/10415-north-american-terrestrial-ecoregionslevel-iii-](http://www3.cec.org/islandora/en/item/10415-north-american-terrestrial-ecoregionslevel-iii-en.pdf)  
36 [en.pdf](http://www3.cec.org/islandora/en/item/10415-north-american-terrestrial-ecoregionslevel-iii-en.pdf)> (accessed 18 May 2016).
- 37 Wilcove DS, McLellan CH, Dobson AP. 1986. Habitat Fragmentation in the Temperate Zone.  
38 In Soule M, editor. Conservation Biology: The Science of Scarcity and Diversity. Sunderland,  
39 MA: Sinauer Associates, Inc.
- 40 Wu S, Mickley LJ, Leibensperger EM, Jacob DJ, Rind D, Streets DG. 2008. Effects of  
41 2000–2050 global change on ozone air quality in the United States. *Journal of Geophysical*  
42 *Research* 113, D06302, Doi:10.1029/2007JD008917.

## 5.0 CONCLUSION

This draft supplemental environmental impact statement (SEIS) contains the environmental review of the application for a renewed operating license for Waterford Steam Electric Station Unit 3 (WF3), submitted by Entergy Louisiana and Entergy Operations (collectively referred to as Entergy), as required by Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51. The regulations at 10 CFR Part 51 implement the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq.). This chapter presents conclusions and recommendations from the site-specific environmental review of WF3. Section 5.1 summarizes the environmental impacts of license renewal; Section 5.2 presents a comparison of the environmental impacts of license renewal and energy alternatives; and Section 5.3 presents the U.S. Nuclear Regulatory Commission (NRC) staff's conclusions and recommendation.

### 5.1 Environmental Impacts of License Renewal

The NRC staff's review of site-specific environmental issues in this SEIS leads to the conclusion that issuing a renewed license for WF3 would have SMALL impacts for the Category 2 issues applicable to license renewal at WF3. The NRC staff considered mitigation measures for each Category 2 issue, as applicable. The NRC staff concluded that no additional mitigation measure is warranted.

### 5.2 Comparison of Alternatives

In Chapter 4, the staff considered the following alternatives to the WF3 license renewal:

- no-action;
- new nuclear;
- supercritical pulverized coal;
- natural gas combined-cycle (NGCC); and
- combination alternative of NGCC, biomass, and demand side management.

Based on the summary of environmental impacts provided in Table 2–2, the NRC staff concluded that the environmental impacts of renewal of the operating license for WF3 would be smaller than those of feasible and commercially viable alternatives. The no-action alternative, the act of shutting down WF3 on or before its license expires, would have SMALL environmental impacts in most areas with the exception of socioeconomic impacts, which would have SMALL to MODERATE environmental impacts. Continued operations would have SMALL environmental impacts in all areas. The NRC staff concluded that continued operation of WF3 is the environmentally preferred alternative.

### 5.3 Recommendations

The NRC staff's preliminary recommendation is that the adverse environmental impacts of license renewal for WF3 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. This recommendation is based on the following:

- the analysis and findings in NUREG–1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, Volumes 1 and 2;

## Conclusion

- 1           • the environmental report submitted by Entergy;
- 2           • consultation with Federal, State, Tribal, and local agencies; and
- 3           • the NRC staff's environmental review.

## 6.0 LIST OF PREPARERS

Members of the U.S. Nuclear Regulatory Commission's (NRC's) Office of Nuclear Reactor Regulation (NRR) prepared this supplemental environmental impact statement with assistance from other NRC organizations and support from Pacific Northwest National Laboratory (PNNL) and Idoneous Consulting. PNNL provided support as identified in Table 6–1. Idoneous Consulting provided technical editing support. Table 6–1 identifies each contributor's name, affiliation, and function or expertise.

**Table 6–1. List of Preparers**

*(in alphabetical order)*

<b>Name &amp; Affiliation</b>	<b>Education/Experience</b>	<b>Function or Expertise</b>
<b>NRC Staff</b>		
Benjamin Beasley	M.S. Nuclear Engineering; B.S. Chemical Engineering; 27 years of combined industry and government experience including nuclear plant system analysis, risk analysis, and project management, with 13 years of management experience.	Management Oversight
Jerry Dozier	M.S. Reliability Engineering; M.B.A. Business Administration; B.S. Mechanical Engineering; 30 years of experience including operations, reliability engineering, technical reviews, and NRC branch management	Severe Accident Mitigation Alternative (SAMA)
Kevin Folk	M.S., Environmental Biology; B.A., Geoenvironmental Studies; 27 years of experience in NEPA compliance; geologic, hydrologic, and water quality impacts analysis; utility infrastructure analysis, and environmental regulatory compliance and water supply and wastewater discharge permitting	Cooling and Auxiliary Water Systems, Surface Water Resources
William Ford	M.S., Geology; 43 years of combined industry and government experience working on groundwater, surface water, and geology projects	Geology; Groundwater
Briana Grange	B.S., Conservation Biology; 12 years of experience in environmental impact analysis, section 7 consultations, and essential fish habitat consultations	Land Use and Visual Resources; Special Status Species and Habitats; Terrestrial Resources

List of Preparers

<b>Name &amp; Affiliation</b>	<b>Education/Experience</b>	<b>Function or Expertise</b>
Robert Hoffman	B.S., Environmental Resource Management; 30 years of experience in NEPA compliance, environmental impact assessment, alternatives identification and development, and energy facility siting.	Alternatives; Cumulative impacts
Elaine Keegan	B.S. Health Physics: 37 years of combined commercial and regulatory experience in reactor health physics, radiological effluent and environmental monitoring programs, radioactive waste, and spent fuel storage.	Project Manager
Nancy Martinez	M.S., Earth and Planetary Science; B.S., Earth and Environmental Science; 5 years of experience in environmental impact analysis	Greenhouse Gas Emissions and Climate Change; Air Quality, Meteorology, and Noise
Michelle Moser	M.S., Biological Sciences; B.S., Environmental Sciences; 13 years of experience in ecological studies, environmental impact assessment, and protected resource management.	Aquatic Resources; Microbiological Hazards
William Rautzen	M.S. Health Physics; B.S., Health Physics; B.S., Industrial Hygiene; 7 years of experience in environmental impact analysis	Human health, radiological, and waste management
Jeffrey Rikhoff	M.R.P., Regional Planning, M.S., Economic Development and Appropriate Technology; B.A English, 37 years of combined industry and government experience including 30 years of NEPA compliance, socioeconomics and environmental justice impact analyses, cultural resource impact assessments, consultations with American Indian tribes, and comprehensive land-use and development planning studies	Environmental Justice; Historic and Cultural Resources; Socioeconomics; Branch Chief – Management oversight
<b>SAMA Contractors – PNNL</b>		
Edward Schmidt	M.S. Nuclear Engineering; B.S. Mechanical Engineering; over 50 years of nuclear industry experience including 35 year experience in performing, managing and reviewing Probabilistic Risk Assessments and their applications.	SAMA

Name & Affiliation	Education/Experience	Function or Expertise
William Ivans	M.S. and B.S., Nuclear Engineering; M.S., Fire Protection Engineering; over 10 years of nuclear industry experience performing, managing and reviewing Probabilistic Risk Assessments and their applications.	SAMA
Steve Short	M.S. and B.S. Nuclear Engineering; MBA; over 30 years of nuclear industry experience including probabilistic risk assessment, life- cycle cost analysis, nuclear safety and accident consequence analysis, and decision analysis.	SAMA



1                   **7.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS**  
 2                   **TO WHOM COPIES OF THIS SEIS ARE SENT**

3                   **Table 7–1. List of Agencies, Organizations, and Persons to Whom Copies**  
 4                   **of This SEIS Are Sent**

<b>Name and Title</b>	<b>Affiliation and Address</b>
<b>John Dinelli, Site Vice President</b>	Entergy Operations, Inc. 17265 River Road Killona, LA 70057-0751
<b>Brad Schexnayder</b>	LA Department of Environmental Quality Office of Environmental Compliance Radiological Emergency Planning and Response P.O. Box 4312 Baton Rouge, LA 70821-4312
<b>Robert Houston, Chief</b>	Special Projects Section U.S. Environmental Protection Agency Region 6 1445 Ross Avenue, Suite 1200 Dallas, TX 75202-2733
<b>Melissa Darden, Chairman</b>	Chitimacha Tribe of Louisiana P.O. Box 661 Charenton, LA 70523
<b>Kimberly Walden</b>	Tribal Historic Preservation Officer Chitimacha Tribe of Louisiana P.O. Box 661 Charenton, LA 70523
<b>B. Cheryl Smith, Chief</b>	Jena Band of Choctaw Indians P.O. Box 14 Jena, LA 71342
<b>Alina Shively</b>	Tribal Historic Preservation Officer Jena Band of Choctaw Indians P.O. Box 14 Jena, LA 71342
<b>Joey P. Barbry, Chairman</b>	Tunica-Biloxi Tribe of Louisiana P.O. Box 1589 Marksville, LA 71351
<b>Earl Barbry, Jr.</b>	Tribal Historic Preservation Officer Tunica-Biloxi Tribe of Louisiana P.O. Box 1589 Marksville, LA 71351
<b>David Sickey, Chairman</b>	Coushatta Tribe of Louisiana P.O. Box 818 Elton, LA 70532
<b>Linda Langley</b>	Tribal Historic Preservation Officer Coushatta Tribe of Louisiana P.O. Box 818 Elton, LA 70532

List of Agencies, Organizations, and Persons

<b>Name and Title</b>	<b>Affiliation and Address</b>
<b>Jo Ann Battise, Chairperson</b>	Alabama Coushatta Tribe of Texas 571 State Park Road 56 Livingston, TX 77351
<b>Bryant Celestine</b>	Historic Preservation Officer Alabama Coushatta Tribe of Texas 571 State Park Road 56 Livingston, TX 77351
<b>Gary Batton, Chief</b>	The Choctaw Nation of Oklahoma P.P. Drawer 1210 Durant, OK 74702
<b>Ian Thompson</b>	Tribal Historic Preservation Officer The Choctaw Nation of Oklahoma P.P. Drawer 1210 Durant, OK 74702
<b>Phyliss J. Anderson, Chief</b>	Mississippi Band of Choctaw Indians P.P. Box 6010 Choctaw Branch Choctaw, MS 39350
<b>Kenneth Carleton</b>	Tribal Historic Preservation Officer Mississippi Band of Choctaw Indians P.P. Box 6010 Choctaw Branch Choctaw, MS 39350
<b>Gregory Chilcoat, Principal Chief</b>	The Seminole Nation of Oklahoma P.O. Box 1498 Wewoka, OK 74884
<b>Theodore Isham</b>	Historic Preservation Officer The Seminole Nation of Oklahoma P.O. Box 1498 Wewoka, OK 74884
<b>Marcellus W. Osceola, Chairman</b>	Seminole Tribe of Florida 6300 Stirling Road Hollywood, FL 33024
<b>Paul N. Backhouse,</b>	Tribal Historic Preservation Officer Seminole Tribe of Florida 6300 Stirling Road Hollywood, FL 33024
<b>Phil Boggan</b>	State Historic Preservation Officer Louisiana Office of Cultural Development P.O. Box 44247 Baton Rouge, LA 70804-4247
<b>Reid Nelson, Director</b>	Office of Federal Agency Programs Advisory Council on Historic Preservation 401 F Street NW, Suite 308 Washington, DC 20001-2637

List of Agencies, Organizations, and Persons

Name and Title	Affiliation and Address
<b>Joseph Ranson, Field Supervisor</b>	U.S. Fish and Wildlife Service Louisiana Ecological Services Field Office 646 Cajundome Boulevard, Suite 400 Lafayette, LA 70506-4290  <a href="mailto:joseph_ranson@fws.gov">joseph_ranson@fws.gov</a>
<b>Amy Trahan, Fish and Wildlife Biologist</b>	U.S. Fish and Wildlife Service Louisiana Ecological Services Field Office 646 Cajundome Boulevard, Suite 400 Lafayette, LA 70506-4290  <a href="mailto:amy_trahan@fws.gov">amy_trahan@fws.gov</a>
<b>Richard Hartman</b>	National Marine Fisheries Service Habitat Conservation Division c/o Louisiana State University Military Science Building, Room 266 South Stadium Drive Baton Rouge, LA 70803  <a href="mailto:richard.hartman@noaa.gov">richard.hartman@noaa.gov</a>
<b>Noah Silverman, NEPA Coordinator</b>	NOAA Fisheries Southeast Regional Office 263 13th Avenue South St. Petersburg, FL 33701-5505  <a href="mailto:noah.silverman@noaa.gov">noah.silverman@noaa.gov</a>
<b>JiYoung Wiley</b>	Louisiana Department of Environmental Quality Office of Environmental Compliance Radiological Emergency Planning and Response P.O. Box 4312 Baton Rouge, LA 70821-4312
<b>Raoult Ratard MD, MPH &amp; TM, FACPM</b>	Louisiana Department of Health Louisiana State Epidemiologist  <a href="mailto:raoult.ratard@la.gov">raoult.ratard@la.gov</a>
<b>Bruce Fielding</b>	Louisiana Department of Environmental Quality  <a href="mailto:Bruce.Fielding@la.gov">Bruce.Fielding@la.gov</a>
<b>St. Charles Parish Council</b>	St. Charles Parish P.O. Box 302 Hahnville, LA 70057
<b>Larry Cochran, President</b>	St. Charles Parish St. Charles Parish Courthouse, Third Floor 15045 River Road Hahnville, LA 70057
<b>Jeff Dauzat</b>	Louisiana Department of Environmental Quality Office of Environmental Compliance Assessment Division P.O. Box 4312 Baton Rouge, LA 70821-4312

List of Agencies, Organizations, and Persons

<b>Name and Title</b>	<b>Affiliation and Address</b>
<b>Wallace L. Taylor</b>	The Law Offices of Wallace L. Taylor 118 3rd Ave. S.E., Suite 326 Cedar Rapids, IA 52401

## 8.0 INDEX

- 2 **A**
- 3 **accidents** .....xxvi, 3-97, 4-76, 4-77,  
4 4-78, 4-79, 4-80, 4-84, 4-87, 4-92, B-1,  
5 F-43
- 6 **Advisory Council on Historic  
7 Preservation (AHP)**.....xxix, 1-7,  
8 4-65, 4-66, 4-141, 7-2, B-5, C-4
- 9 **aesthetic** .....3-98
- 10 **alternatives** ..... iii, xxvi, 1-5, 2-1, 2-3,  
11 2-4, 2-5, 2-6, 2-13, 2-16, 2-18, 2-19, 4-1,  
12 4-6, 4-14, 4-16, 4-18, 4-24, 4-25, 4-26,  
13 4-30, 4-31, 4-52, 4-73, 4-78, 4-86, 4-90,  
14 4-93, 4-94, 4-96, 4-97, 4-100, 4-126, 4-127,  
15 4-128, 5-1, 6-2, B-2, F-1, F-2, F-25, F-26,  
16 F-39, F-46
- 17 **archaeological resources** .....1-6, 3-82
- 18 **B**
- 19 **biological assessment** ..... C-1
- 20 **biota** .....3-46, 3-67, 3-68,  
21 4-37, 4-41, 4-42, 4-44, 4-45, 4-46, 4-47,  
22 4-48, 4-49, 4-56, 4-58, 4-105, 4-117, 4-118,  
23 4-120, 4-121
- 24 **boiling water reactor**.....2-2
- 25 **C**
- 26 **chronic effects** .....2-21, 4-74
- 27 **Clean Air Act (CAA)** .....xxix, 3-27,  
28 3-28, 3-104, 4-10, 4-11, 4-13, 4-98, 4-125,  
29 4-130, 4-132, 4-134, B-2, B-6
- 30 **closed-cycle cooling**.....2-7, 2-9,  
31 2-11, 2-12, 4-21, 4-22, 4-23, 4-25, 4-112
- 32 **Coastal Zone Management Act  
33 (CZMA)**..... xxx, 3-23, 3-104, B-3, B-6
- 34 **cold shock** .....4-50
- 35 **consumptive use**.....3-45, 4-21, 4-113
- 36 **cooling system**..... xxiv, xxx, 1-4,  
37 1-6, 2-7, 2-9, 2-10, 3-67, 3-75, 3-95, 4-18,  
38 4-22, 4-23, 4-26, 4-32, 4-33, 4-42, 4-43,  
39 4-44, 4-51, 4-52, 4-55, 4-63, 4-113, F-5,  
40 F-8, F-34
- 41 **core damage frequency (CDF)** ..... xxx,  
42 4-80, 4-81, F-1, F-2, F-3, F-5, F-6, F-10,  
43 F-11, F-12, F-13, F-14, F-15, F-22, F-24,  
44 F-26, F-28, F-30, F-36, F-42, F-43, F-44,  
45 F-45
- 46 **Council on Environmental Quality  
47 (CEQ)**..... xxx, 1-3, 3-98,  
48 3-105, 4-108, 4-116, 4-131, 4-132
- 49 **critical habitat**.....2-21, 3-75, 3-76,  
50 3-77, 3-79, 3-103, 4-53, 4-60, 4-61, 4-62,  
51 4-63, 4-64, B-5, C-1, C-2, C-3
- 52 **cultural resources** ..... xxv, 2-5, 2-21,  
53 3-79, 3-82, 4-3, 4-64, 4-65, 4-66, 4-67,  
54 4-68, 4-95, 4-106, 4-122, 4-124, B-1, B-5
- 55 **D**
- 56 **design-basis accident**..... xxx, 4-1, 4-76
- 57 **discharges** .....3-11, 3-12,  
58 3-15, 3-45, 3-48, 3-50, 3-51, 3-52, 3-53,  
59 3-75, 3-76, 3-95, 3-102, 4-20, 4-21, 4-22,  
60 4-23, 4-24, 4-25, 4-27, 4-41, 4-44, 4-46,  
61 4-51, 4-58, 4-75, 4-114, 4-115, 4-116,  
62 4-119, 4-120, B-1, B-4, E-5
- 63 **dose** .....xxxv, 3-11, 3-12,  
64 3-13, 3-15, 3-16, 3-94, 3-101, 4-80, 4-81,  
65 4-95, 4-123, B-2, B-4, F-1, F-3, F-4,  
66 F-16, F-18, F-19, F-26, F-42, F-43, F-45,  
67 F-46
- 68 **dredging** .....3-53, 3-76,  
69 4-18, 4-32, 4-50, 4-51
- 70 **E**
- 71 **education** .....3-90, 4-69
- 72 **electromagnetic fields** .....2-21, 4-73, 4-84
- 73 **endangered and threatened species** . B-5
- 74 **Endangered Species Act (ESA)**..... xxv,  
75 xxxi, 1-6, 1-7, 1-8, 2-5, 2-21, 2-24, 3-66,  
76 3-74, 3-75, 3-78, 3-103, 3-106, 4-53,  
77 4-54, 4-57, 4-59, 4-60, 4-61, 4-62, 4-63,  
78 4-64, 4-105, 4-106, 4-129, 4-133, 4-136,  
79 B-5, B-6, C-1, C-2, C-3, C-5, D-1

## Index

- 1 **Entergy Louisiana, LLC** .....iii, xxiii,  
2 1-1, 1-8, 2-7, 2-8, 2-11, 2-12, 2-24, 2-25,  
3 3-1, 3-33, 3-79, 3-82, 3-83, 3-92, 3-106,  
4 3-107, 3-108, 3-112, 4-8, 4-9, 4-12, 4-13,  
5 4-14, 4-15, 4-20, 4-21, 4-22, 4-24, 4-25,  
6 4-50, 4-51, 4-52, 4-67, 4-68, 4-79, 4-133,  
7 4-136, 4-137, 5-1, E-8, F-1
- 8 **Entergy Operations, Inc.**.....iii, xxiii,  
9 1-1, 1-8, 3-106, 3-107, 3-108, 3-111,  
10 3-112, 4-79, 4-133, 4-134, 4-137, 4-138,  
11 5-1, 7-1, B-7, C-2, D-1, E-8, F-1, F-47,  
12 F-48, F-50
- 13 **entrainment** ..... xxv, 3-75,  
14 3-78, 4-32, 4-33, 4-34, 4-36, 4-37, 4-38,  
15 4-39, 4-41, 4-42, 4-43, 4-44, 4-49, 4-50,  
16 4-51, 4-52, 4-54, 4-56, 4-59, 4-61, 4-120,  
17 4-139
- 18 **essential fish habitat (EFH)** ..... xxv, xxx,  
19 2-21, 3-79, 4-53, 4-61, 4-62, 4-63, 4-64,  
20 4-141, 6-2, B-5, C-2, C-3
- 21 **eutrophication**...4-32, 4-106, 4-121, 4-141  
22 **evaporative loss**.....4-21, 4-104
- 23 **F**
- 24 **Fish and Wildlife Coordination Act**  
25 **(FWCA)** ..... B-7
- 26 **G**
- 27 **Generic Environmental Impact**  
28 **Statement (GEIS)** ..... iii, xxiii, xxiv,  
29 xxv, xxvii, xxxi, 1-3, 1-4, 1-5, 1-6, 1-7,  
30 1-8, 1-9, 2-1, 2-2, 2-3, 2-4, 2-15, 2-21,  
31 2-26, 3-40, 3-85, 3-96, 3-115, 3-116, 4-1,  
32 4-2, 4-6, 4-7, 4-17, 4-18, 4-19, 4-20,  
33 4-26, 4-27, 4-28, 4-29, 4-30, 4-32, 4-44,  
34 4-51, 4-53, 4-58, 4-65, 4-66, 4-69, 4-73,  
35 4-74, 4-75, 4-76, 4-77, 4-78, 4-86, 4-91,  
36 4-92, 4-93, 4-94, 4-95, 4-96, 4-97, 4-99,  
37 4-100, 4-140, 5-2
- 38 **greenhouse gases** .....3-30, 4-8, 4-130  
39 **groundwater** ..... xxv, 3-4, 3-17,  
40 3-38, 3-39, 3-50, 3-54, 3-55, 4-18, 4-19,  
41 4-20, 4-21, 4-22, 4-23, 4-24, 4-25, 4-78,  
42 4-95, 4-104, 4-116, 6-1, B-1
- 43 **H**
- 44 **hazardous waste** .....3-18, 3-95,  
45 4-127, 4-128, B-4
- 46 **high-level waste** ..... xxiv, 1-4,  
47 4-91, 4-92, 4-94, 4-95
- 48 **I**
- 49 **impingement**.....3-70, 3-75,  
50 3-76, 3-78, 4-32, 4-33, 4-34, 4-35, 4-36,  
51 4-37, 4-39, 4-40, 4-41, 4-42, 4-43, 4-44,  
52 4-49, 4-50, 4-51, 4-52, 4-54, 4-55, 4-56,  
53 4-57, 4-59, 4-61, 4-120
- 54 **independent spent fuel storage**  
55 **installation (ISFSI)** .....xxxii, 3-1, 3-17,  
56 3-19, 3-21, 4-111, 4-123
- 57 **Indian tribes**..... 3-80, 3-98, 6-3  
58 **invasive species**..3-63, 3-74, 4-105, 4-106
- 59 **L**
- 60 **low-level waste** .....4-92, 4-95
- 61 **M**
- 62 **Magnuson–Stevens Fishery**  
63 **Conservation and Management Act**  
64 **(MSA)**.....xxxiv,  
65 1-8, 3-74, 3-79, 3-113, 4-61, 4-63, 4-64,  
66 4-138, B-5, B-7, C-3, C-5, D-1, F-13
- 67 **Marine Mammal Protection Act**  
68 **(MMPA)** ..... 3-79, 3-113, B-7
- 69 **mitigation**.....xxiv, xxxvi, 1-3, 1-4,  
70 1-5, 3-44, 4-8, 4-10, 4-50, 4-61, 4-67,  
71 4-107, 4-115, 4-127, 5-1
- 72 **mixed waste**.....3-11
- 73 **N**
- 74 **National Environmental Policy Act**  
75 **(NEPA)**..... xxiv, xxxv, 1-1,  
76 1-8, 1-9, 2-1, 2-4, 2-25, 3-79, 3-80, 3-98,  
77 3-105, 4-60, 4-66, 4-69, 4-86, 4-108,  
78 4-116, 4-118, 4-131, 4-132, 4-134,  
79 4-139, 5-1, 6-1, 6-2, 6-3, 7-3, B-2, B-7,  
80 C-1, C-2, C-3, C-4, C-5

- 1 **National Marine Fisheries Service**  
2 **(NMFS)**.....xxxv, 3-74, 3-75,  
3 3-76, 3-79, 3-109, 4-53, 4-54, 4-58, 4-60,  
4 4-61, 4-62, 4-63, 4-64, 4-104, 4-136,  
5 4-139, 4-141, 7-3, B-5, C-1, C-2, C-3,  
6 C-5  
7 **National Pollutant Discharge Elimination**  
8 **System (NPDES)** .....xxxv, 3-47,  
9 3-52, 3-53, 3-108, 4-24, 4-50, 4-58,  
10 4-114, 4-121, 4-129, 4-130, B-1, B-3,  
11 B-6, E-5  
12 **no-action alternative** ..... iii, xxvi, 2-1,  
13 2-3, 2-5, 2-19, 2-21, 4-1, 4-2, 4-3, 4-7,  
14 4-8, 4-28, 4-50, 4-61, 4-71, 4-92, 4-99,  
15 4-100, 4-116, 4-127, 5-1  
16 **nonattainment** .....3-28, 4-10
- 17 **P**
- 18 **postulated accidents** .....4-1, 4-76,  
19 4-77, 4-78, 4-87  
20 **pressurized water reactor**.....xxxvi, 2-1,  
21 3-1, F-1
- 22 **R**
- 23 **radon**.....3-11, 3-17  
24 **reactor** ..... xxiii, xxxvi, 2-1, 2-2,  
25 2-3, 2-8, 2-9, 2-21, 2-23, 3-1, 3-3, 3-10,  
26 3-12, 3-13, 3-14, 3-19, 3-21, 3-25, 3-29,  
27 3-51, 3-94, 3-102, 4-1, 4-3, 4-50, 4-59,  
28 4-65, 4-66, 4-67, 4-69, 4-70, 4-77, 4-78,  
29 4-79, 4-83, 4-84, 4-88, 4-91, 4-96, 4-108,  
30 4-117, 4-122, 4-123, 4-124, 4-129,  
31 4-130, 6-2, E-1, F-2, F-3, F-5, F-6, F-12,  
32 F-14, F-16, F-31, F-32, F-33, F-34, F-43,  
33 F-44  
34 **refurbishment**.....2-2, 4-6, 4-23,  
35 4-24, 4-25, 4-27, 4-28, 4-69, 4-109, F-43  
36 **replacement power** ..... xxvi, xxxvi,  
37 2-3, 2-5, 2-6, 2-11, 2-18, 4-1, 4-25, 4-70,  
38 4-82, 4-94, 4-96, 4-97, 4-99, 4-126, F-40,  
39 F-43
- 40 **S**
- 41 **salinity** .....4-116
- 42 **scoping** ..... iv, xxiii, xxiv, 1-1, 1-2,  
43 1-6, 4-2, 4-7, 4-17, 4-19, 4-26, 4-32,  
44 4-66, 4-69, 4-74, 4-77, 4-78, 4-91, 4-95,  
45 4-97, 4-109, 4-141, A-1, C-2, C-3, C-4  
46 **seismic**..... xxxvii, 3-33, 3-38,  
47 3-39, 4-80, F-10, F-11, F-13, F-14, F-25,  
48 F-26  
49 **severe accident mitigation alternative**  
50 **(SAMA)** .....xxv, xxvi, xxxvi,  
51 1-9, 4-78, 4-79, 4-80, 4-81, 4-82, 4-83,  
52 4-134, 6-1, 6-3, D-2, F-1, F-2, F-3, F-5,  
53 F-6, F-8, F-9, F-10, F-11, F-12, F-13,  
54 F-14, F-16, F-17, F-18, F-19, F-20, F-21,  
55 F-22, F-23, F-24, F-25, F-26, F-27, F-28,  
56 F-29, F-30, F-31, F-32, F-33, F-34, F-35,  
57 F-36, F-37, F-38, F-39, F-40, F-41, F-44,  
58 F-45, F-46, F-48  
59 **severe accidents** ..... xxvi, 4-1, 4-76,  
60 4-78, 4-81, 4-87, F-5, F-10, F-27, F-43,  
61 F-44  
62 **solid waste**..... xxvii, xxxvii,  
63 2-4, 2-12, 2-16, 2-17, 3-11, 3-12, 3-17,  
64 3-94, 3-101, 4-15, 4-95, B-1, B-4, B-6,  
65 E-5  
66 **spent fuel**.....xxiv, xxxii, 1-4,  
67 2-21, 3-15, 3-17, 3-19, 4-50, 4-94, 4-95,  
68 4-96, 4-129, 4-130, 6-2  
69 **State Historic Preservation Office**  
70 **(SHPO)**.....xxxvi, 1-7, 2-21,  
71 3-80, 3-82, 3-113, 4-65, 4-66, 4-138, 7-2  
72 **stormwater**..... xxxvii, 3-41,  
73 3-47, 3-48, 3-50, 3-51, 3-52, 4-21, 4-22,  
74 4-23, 4-24, 4-25, 4-27, 4-28, 4-50, 4-114,  
75 4-116, B-3  
76 **surface runoff**.....4-104, 4-115, 4-120  
77 **surface water** ..... 3-8, 3-40, 3-45,  
78 3-46, 3-50, 3-52, 3-53, 3-67, 3-96, 4-18,  
79 4-19, 4-20, 4-21, 4-22, 4-23, 4-24, 4-25,  
80 4-57, 4-87, 4-88, 4-95, 4-104, 4-106,  
81 4-111, 4-112, 4-113, 4-114, 4-115,  
82 4-116, 6-1, B-3
- 83 **T**
- 84 **taxes**.....3-92  
85 **transmission lines**.....2-10, 2-11,  
86 3-18, 3-20, 3-32, 3-75, 3-96, 3-97, 4-2,  
87 4-6, 4-7, 4-26, 4-32, 4-50, 4-65, 4-74,  
88 4-75, 4-117

1

**U**

2 **U.S. Army Corps of Engineers** ..... xxxvii,  
 3 3-40, 3-104, 3-113, 3-118, 4-21, 4-131,  
 4 B-3, E-10, E-11

5 **U.S. Department of Energy (DOE)**..... xxx,  
 6 2-5, 2-9, 2-13, 2-14, 2-15, 2-16, 2-17,  
 7 2-18, 2-22, 2-23, 2-25, 3-17, 4-10, 4-12,  
 8 4-74, 4-101

9 **U.S. Environmental Protection Agency**  
 10 **(EPA)** .....xxxi, 2-5, 2-16, 2-18,  
 11 2-24, 3-11, 3-12, 3-13, 3-15, 3-16, 3-27,  
 12 3-28, 3-30, 3-31, 3-32, 3-40, 3-46, 3-47,  
 13 3-52, 3-91, 3-92, 3-94, 3-102, 3-104,  
 14 3-108, 3-109, 3-111, 3-114, 4-13, 4-15,  
 15 4-20, 4-33, 4-35, 4-38, 4-41, 4-42, 4-58,  
 16 4-85, 4-98, 4-101, 4-102, 4-103, 4-104,  
 17 4-107, 4-108, 4-110, 4-117, 4-118,  
 18 4-123, 4-124, 4-125, 4-126, 4-127,  
 19 4-129, 4-130, 4-134, 4-135, 7-1, B-1,  
 20 B-3, B-4, B-6, E-3, E-4, E-5, E-9

21 **U.S. Fish and Wildlife Service (FWS)** xxxi,  
 22 1-7, 1-8, 3-58, 3-61, 3-74, 3-75, 3-76,  
 23 3-77, 3-78, 3-103, 3-104, 3-109, 4-53,  
 24 4-54, 4-55, 4-57, 4-58, 4-59, 4-60, 4-61,  
 25 4-62, 4-133, 4-135, 4-136, 4-137, 7-3,  
 26 B-5, C-1, C-2, C-3, C-5, E-6, E-9

27 **uranium**..... 3-3, 3-19, 4-1, 4-3,  
 28 4-4, 4-29, 4-84, 4-94, 4-95, 4-96, 4-97

29

**W**

30 **wastewater**.....3-18, 3-47, 3-50,  
 31 3-51, 3-52, 4-22, 4-23, 4-24, 4-114,  
 32 4-118, 6-1, E-5, E-7

1  
2  
3  
4

**APPENDIX A**  
**COMMENTS RECEIVED ON THE WATERFORD STEAM ELECTRIC**  
**STATION, UNIT 3 ENVIRONMENTAL REVIEW**



1 **A. Comments Received on the Waterford Steam Electric Station,**  
2 **Unit 3 Environmental Review**

3 **A.1 Comments Received During the Scoping Period**

4 The scoping process for the environmental review of the license renewal application for  
5 Waterford Steam Electric Station, Unit 3 (WF3) began on June 6, 2016, with the publication of  
6 U.S. Nuclear Regulatory Commission's (NRC's) Notice of Intent to conduct scoping in the  
7 *Federal Register* (81 FR 36354). The scoping process included a public meeting held at the St.  
8 Charles Parish Emergency Operations Center, Hahnville, Louisiana on June 8, 2016. Ten  
9 people attended the meeting. After the NRC staff's prepared statements pertaining to the  
10 license renewal process, the meeting was opened for public comments. No attendees provided  
11 oral statements at the meeting. The meeting was transcribed by a certified court reporter. A  
12 meeting summary, a copy of the presentation, and transcripts of the scoping meeting are  
13 available using the NRC's Agencywide Documents Access and Management System (ADAMS).  
14 The ADAMS Public Electronic Reading Room is accessible at [http://www.nrc.gov/reading-  
16 rm/adams.html](http://www.nrc.gov/reading-<br/>15 rm/adams.html). The scoping meeting summary can be found under ADAMS Accession  
17 No. ML16172A078. The presentation slides can be found under ADAMS Accession  
18 Nos. ML16190A084. Transcripts for the meeting can be found under ADAMS Accession  
Nos. ML16190A069.

19 The NRC staff had invited members of the public and interested state, local, and tribal  
20 governments to provide comments during the scoping period. No written comments were  
21 submitted during the scoping period. A Scoping Summary Report (ADAMS Accession  
22 No. ML18155A580) observes that no public comments were received during the scoping period.

23 One important part of the scoping period is to identify significant environmental issues to be  
24 evaluated further. While no issues were identified by members of the public or interested  
25 governmental entities during the scoping period, this supplemental environmental impact  
26 statement documents the comprehensive environmental review conducted by the NRC staff to  
27 evaluate the impacts of Waterford 3 operation for an additional 20 years.



1  
2  
3

**APPENDIX B**  
**APPLICABLE LAWS, REGULATIONS, AND OTHER REQUIREMENTS**



## 1 **B. Applicable Laws, Regulations, and Other Requirements**

2 There are a number of Federal laws and regulations that affect environmental protection, health,  
3 safety, compliance, and/or consultation at every nuclear power plant licensed by the  
4 U.S. Nuclear Regulatory Commission (NRC). Some of these laws and regulations require  
5 permits or consultation with other Federal agencies or State, Tribal, or local governments.  
6 Certain Federal environmental requirements have been delegated to State authorities for  
7 enforcement and implementation. Furthermore, States have also enacted laws to protect public  
8 health and safety and the environment. It is the NRC's policy to make sure nuclear power  
9 plants are operated in a manner that provides adequate protection of public health and safety  
10 and protection of the environment through compliance with applicable Federal and State laws,  
11 regulations, and other requirements.

12 The Atomic Energy Act of 1954, as amended (AEA) (42 U.S.C. 2011 et seq.) authorizes the  
13 NRC to enter into agreement with any State to assume regulatory authority for certain activities  
14 (see 42 U.S.C. 2021). Louisiana has been an NRC agreement state since 1967, and the  
15 Louisiana Department of Environmental Quality (LDEQ) has regulatory responsibility over  
16 certain byproduct, source, and quantities of special nuclear materials not sufficient to form a  
17 critical mass. In addition, LDEQ maintains a Radiological Emergency Planning and Response  
18 Program to provide response capabilities to radiological accidents or emergencies at the  
19 commercial nuclear power plants in and near Louisiana. (LDEQ undated).

20 In addition to carrying out some Federal programs, state legislatures develop their own laws.  
21 State statutes can supplement, as well as implement, Federal laws for protection of air, water  
22 quality, and groundwater. State legislation may address solid waste management programs,  
23 locally rare or endangered species, and historic and cultural resources.

24 The U.S. Environmental Protection Agency (EPA) has the primary responsibility to administer  
25 the Clean Water Act (33 U.S.C. 1251 et seq., herein referred to as CWA). The National  
26 Pollutant Discharge Elimination System (NPDES) program addresses water pollution by  
27 regulating the discharge of potential pollutants to waters of the United States. EPA allows for  
28 primary enforcement and administration through state agencies, as long as the state program is  
29 at least as stringent as the Federal program.

30 EPA has delegated the authority to issue NPDES permits to the State of Louisiana. The LDEQ  
31 issues Louisiana Pollutant Discharge Elimination System (LPDES) permits to regulate and  
32 control water pollutants. LDEQ provides oversight for public water supplies, issues permits to  
33 regulate the discharge of industrial and municipal wastewaters—including discharges to  
34 groundwater and monitors State water resources for water quality (Entergy 2016).

### 35 **B.1 Federal and State Requirements**

36 WF3 is subject to Federal and State requirements. Table B–1 lists the principal Federal and  
37 State regulations and laws that are used or mentioned in this supplemental environmental  
38 impact statement for WF3.

39 **Table B–1. Federal and State Requirements**

Law/regulation	Requirements
<b>Current operating license and license renewal</b>	
Atomic Energy Act, 42 U.S.C. 2011 et seq.	The Atomic Energy Act (AEA) of 1954, as amended, and the Energy Reorganization Act of 1974 (42 U.S.C. 5801 et seq.) give the NRC the

Appendix B

Law/regulation	Requirements
	licensing and regulatory authority for nuclear energy uses within the commercial sector. These regulations give the NRC responsibility for licensing and regulating commercial uses of atomic energy and allow the NRC to establish dose and concentration limits for protection of workers and the public for activities under NRC jurisdiction. The NRC implements its responsibilities under the AEA through regulations set forth in Title 10, “Energy,” of the Code of Federal Regulations (CFR).
National Environmental Policy Act of 1969, 42 U.S.C. 4321 et seq.	The National Environmental Policy Act (NEPA), as amended, requires Federal agencies to integrate environmental values into their decisionmaking process by considering the environmental impacts of proposed Federal actions and reasonable alternatives to those actions. NEPA establishes policy, sets goals (in Section 101), and provides means (in Section 102) for carrying out the policy. Section 102(2) contains action-forcing provisions to ensure that Federal agencies follow the letter and spirit of the Act. For major Federal actions significantly affecting the quality of the human environment, Section 102(2)(C) of NEPA requires Federal agencies to prepare a detailed statement that includes the environmental impacts of the proposed action and other specified information.
10 CFR Part 51	Regulations in 10 CFR Part 51, “Environmental protection regulations for domestic licensing and related regulatory functions,” contain environmental protection regulations applicable to the NRC’s domestic licensing and related regulatory functions.
10 CFR Part 54	Regulations in 10 CFR Part 54, “Requirements for renewal of operating licenses for nuclear power plants,” are NRC regulations that govern the issuance of renewed operating licenses and renewed combined licenses for nuclear power plants licensed pursuant to Sections 103 or 104b of the AEA, as amended, and Title II of the Energy Reorganization Act of 1974 (42 U.S.C. 5841 et seq.). The regulations focus on managing adverse effects of aging. The rule is intended to ensure that important systems, structures, and components will maintain their intended functions during the period of extended operation.
10 CFR Part 50	Regulations in 10 CFR Part 50, “Domestic licensing of production and utilization facilities,” are NRC regulations issued under the AEA, as amended (42 U.S.C. 2011 et seq.), and Title II of the Energy Reorganization Act of 1974 (42 U.S.C. 5841 et seq.), to provide for the licensing of production and utilization facilities. This part also gives notice to all persons who knowingly supply—to any licensee, applicant, contractor, or subcontractor—components, equipment, materials, or other goods or services that relate to a licensee’s or applicant’s activities subject to this part that they may be individually subject to NRC enforcement action for violation of 10 CFR 50.5.
<b>Air quality protection</b>	
Clean Air Act, 42 U.S.C. 7401 et seq.	The Clean Air Act (CAA) is intended to “protect and enhance the quality of the nation’s air resources so as to promote the public health and welfare and the productive capacity of its population.” The CAA establishes regulations to ensure maintenance of air quality standards and authorizes individual States to manage permits. Section 118 of the CAA (42 U.S.C. 7418) requires each Federal agency, with jurisdiction over properties or facilities engaged in any activity that might result in the discharge of air pollutants, to comply with all Federal, State, inter-State, and local requirements with regard to the control and abatement of air pollution.

Law/regulation	Requirements
	<p>Section 109 of the CAA (42 U.S.C. 7409) directs the U.S. Environmental Protection Agency (EPA) to set National Ambient Air Quality Standards (NAAQS) for criteria pollutants. The EPA has identified and set NAAQS for the following criteria pollutants: particulate matter, sulfur dioxide, carbon monoxide, ozone, nitrogen dioxide, and lead. Section 111 of the CAA requires establishment of national performance standards for new or modified stationary sources of atmospheric pollutants. Section 160 of the CAA requires that specific emission increases must be evaluated before permit approval to prevent significant deterioration of air quality. Section 112 requires specific standards for release of hazardous air pollutants (including radionuclides). These standards are implemented through plans developed by each State and approved by the EPA. The CAA requires sources to meet standards and obtain permits to satisfy those standards. Nuclear power plants may be required to comply with the CAA Title V, Sections 501–507, for sources subject to new source performance standards or sources subject to National Emission Standards for Hazardous Air Pollutants. Emissions of air pollutants are regulated by the EPA in 40 CFR Parts 50 to 99.</p>
<b>Water resources protection</b>	
<p>Clean Water Act, 33 U.S.C. 1251 et seq., and the NPDES (40 CFR 122)</p>	<p>The Clean Water Act (CWA) was enacted to “restore and maintain the chemical, physical, and biological integrity of the Nation’s water.” The Act requires all branches of the Federal Government, with jurisdiction over properties or facilities engaged in any activity that might result in a discharge or runoff of pollutants to surface waters, to comply with Federal, State, inter-State, and local requirements. As authorized by the CWA, the National Pollutant Discharge Elimination System (NPDES) permit program controls water pollution by regulating point sources that discharge pollutants into waters of the United States. The NPDES program requires all facilities that discharge pollutants from any point source into waters of the United States obtain an NPDES permit. A nuclear power plant may also participate in the NPDES General Permit for Industrial Stormwater due to stormwater runoff from industrial or commercial facilities to waters of the United States. EPA is authorized under the CWA to directly implement the NPDES program; however, EPA has authorized many States to implement all or parts of the national program. Section 401 of the CWA requires States to certify that the permitted discharge would comply with all limitations necessary to meet established State water quality standards, treatment standards, or schedule of compliance. The U.S. Army Corps of Engineers (USACE) is the lead agency for enforcement of CWA wetland requirements (33 CFR Part 320). Under Section 401 of the CWA, the EPA or a delegated State agency has the authority to review and approve, condition, or deny all permits or licenses that might result in a discharge to waters of the State, including wetlands.</p>
<p>Coastal Zone Management Act of 1972, as amended (16 U.S.C. 1451 et seq.)</p>	<p>Congress enacted the Coastal Zone Management Act (CZMA) in 1972 to address the increasing pressures of over-development upon the Nation’s coastal resources. The National Oceanic and Atmospheric Administration administers the Act. The CZMA encourages States to preserve, protect, develop, and, where possible, restore or enhance valuable natural coastal resources such as wetlands, floodplains, estuaries, beaches, dunes, barrier islands, and coral reefs, as well as the fish and wildlife using those habitats. Participation by States is voluntary. To encourage States to participate, the CZMA makes Federal financial assistance available to any coastal State or territory, including those on the Great Lakes, which are</p>

## Appendix B

Law/regulation	Requirements
	willing to develop and implement a comprehensive coastal management program.
Wild and Scenic Rivers Act, 16 U.S.C. 1271 et seq.	The Wild and Scenic River Act created the National Wild and Scenic Rivers System, which was established to protect the environmental values of free flowing streams from degradation by impacting activities, including water resources projects.
<b>Waste management and pollution prevention</b>	
Resource Conservation and Recovery Act, 42 U.S.C. 6901 et seq.	The Resource Conservation and Recovery Act (RCRA) requires the EPA to define and identify hazardous waste; establish standards for its transportation, treatment, storage, and disposal; and require permits for persons engaged in hazardous waste activities. Section 3006 (42 U.S.C. 6926) allows States to establish and administer these permit programs with EPA approval. EPA regulations implementing the RCRA are found in 40 CFR Parts 260 through 283. Regulations imposed on a generator or on a treatment, storage, and/or disposal facility vary according to the type and quantity of material or waste generated, treated, stored, and/or disposed. The method of treatment, storage, and/or disposal also impacts the extent and complexity of the requirements.
Pollution Prevention Act, 42 U.S.C. 13101 et seq.	The Pollution Prevention Act establishes a national policy for waste management and pollution control that focuses first on source reduction, then on environmental issues, safe recycling, treatment, and disposal.
10 CFR Part 20	Regulations in 10 CFR Part 20, "Standards for protection against radiation," establish standards for protection against ionizing radiation resulting from activities conducted under licenses issued by the NRC. These regulations are issued under the AEA of 1954, as amended, and the Energy Reorganization Act of 1974, as amended. The purpose of these regulations is to control the receipt, possession, use, transfer, and disposal of licensed material by any licensee in such a manner that the total dose to an individual (including doses resulting from licensed and unlicensed radioactive material and from radiation sources other than background radiation) does not exceed the standards for protection against radiation prescribed in the regulations in this part.
Louisiana Administrative Code (LAC) 33:1.3901 et seq.	This establishes the rules and regulations for reporting unauthorized discharges or spills.
LAC 33:V	This establishes the rules and regulations related to hazardous waste and hazardous materials
LAC 33:VII	This establishes the rules and regulations related to solid waste storage, recovery and reuse, and disposal.
LAC 33:XI	This establishes the regulations that apply to underground storage tank systems
LAC 33:XI.715	This establishes the release responses and corrective actions from reportable spills from an underground storage tank containing a petroleum product.
Tennessee Department of Environment and Conservation Rule 1200-2-10-32	This rule establishes the requirements for the licensing of shippers of radioactive material into or within Tennessee.

Law/regulation	Requirements
<b>Protected species</b>	
Endangered Species Act, 16 U.S.C. 1531 et seq.	The Endangered Species Act (ESA) was enacted to prevent the further decline of endangered and threatened species and to restore those species and their critical habitats. Section 7 of the Act requires Federal agencies to consult with the U.S. Fish and Wildlife Service or the National Marine Fisheries Service (NMFS) on Federal actions that may affect listed species or designated critical habitats.
Magnuson–Stevens Fishery Conservation and Management Act, 16 U.S.C. 1801-1884	The Magnuson–Stevens Fishery Conservation and Management Act, as amended, governs marine fisheries management in U.S. Federal waters. The Act created eight regional fishery management councils and includes measures to rebuild overfished fisheries, protect essential fish habitat, and reduce bycatch. Under Section 305 of the Act, Federal agencies are required to consult with NMFS for any Federal actions that may adversely affect essential fish habitat.
<b>Historic preservation and cultural resources</b>	
National Historic Preservation Act, 54 U.S.C. 300101 et seq.	The National Historic Preservation Act was enacted to create a national historic preservation program, including the National Register of Historic Places and the Advisory Council on Historic Preservation. Section 106 of the Act requires Federal agencies to take into account the effects of their undertakings on historic properties. The Advisory Council on Historic Preservation regulations implementing Section 106 of the Act are found in 36 CFR Part 800. The regulations call for public involvement in the Section 106 consultation process, including Indian Tribes and other interested members of the public, as applicable.

## 1 B.2 Operating Permits and Other Requirements

2 Table B–2 lists the permits and licenses issued by Federal, state, and local authorities for  
3 activities at WF3.

4 **Table B–2. Licenses and Permits**

Permit	Responsible Agency	Number	Dates	Authorized Activity
Operating License	NRC	NPF-38	Issued: 03/16/1985 Expires: 12/18/2024	Operation of WF3
Hazardous Materials Certification Registration	DOT	060115551059X	June 30, 2018	Radioactive and hazardous materials shipments
Radioactive Waste License for Delivery	Tennessee Department of Environment and Conservation Rule	T-LA001-L15	Updated annually	Shipment of radioactive material into Tennessee to a disposal/processing facility
Authorization to Export Waste	Central Interstate Low-Level Radioactive Waste Compact	None	Updated annually	Export of low-level radioactive waste outside of the region

Appendix B

Permit	Responsible Agency	Number	Dates	Authorized Activity
Federal Water Pollution Control Act, Section 402 (LPDES permit)	LDEQ	LA007374	October 1, 2022	Discharge of wastewaters to waters of the State
Air Permit	LDEQ	2520-00091-00	(a)	Operation of air emission sources(b)
Hazardous Waste Generator Identification	LDEQ	LAD000757450	None	Hazardous waste generation
Industrial Solid Waste Site Identification	LDEQ	G-089-3276	None	Industrial solid waste generation
Radioactive Waste Transport Permit	Mississippi Emergency Management Agency	4537	Updated annually	Transportation of radioactive waste into, within, or through the State of Mississippi

<sup>(a)</sup> Current air permit does not contain an expiration date. However, in 2015, LDEQ promulgated amendments to LAC 33:III503 to establish a regulatory framework for setting maximum terms and renewal procedures for minor source air permits of not more than 10 years. WF3 applied for the Title Vs air permit in June 2017 and expect permit approval in September 2018.

<sup>(b)</sup> Air emission sources such as diesel generators, diesel pumps, portable auxiliary boiler, and portable gas/diesel generators.

Source: Entergy 2016

1 **B.3 References**

- 2 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for  
3 protection against radiation.”
- 4 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic licensing of  
5 production and utilization facilities.”
- 6 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
7 protection regulations for domestic licensing and related regulatory functions.”
- 8 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for  
9 renewal of operating licenses for nuclear power plants.”
- 10 40 CFR Part 122. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 122,  
11 “EPA administered permit programs: the National Pollutant Discharge Elimination System.”
- 12 Atomic Energy Act of 1954, as amended. 42 U.S.C. §2011 et seq.
- 13 Clean Air Act of 1963, as amended. 42 U.S.C. §7401 et seq.
- 14 Clean Water Act of 1977, as amended. 33 U.S.C. §1251 et seq.
- 15 Coastal Zone Management Act of 1972, as amended. 16 U.S.C. §1451 et seq.
- 16 Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.
- 17 Energy Reorganization Act of 1974. 42 U.S.C. §5801 et seq.

- 1 [Entergy] Entergy Operations, Inc. 2016. Waterford Steam Electric Station, Unit 3, License
- 2 Renewal Application, Appendix E, Applicant's Environmental Report. March 2016. 920 p.
- 3 ADAMS Accession No. ML16088A333.
- 4 Fish and Wildlife Coordination Act of 1934, as amended. 16 U.S.C. §661 et seq.
- 5 Marine Mammal Protection Act of 1972, as amended. 16 U.S.C. §1361 et seq.
- 6 Magnuson–Stevens Fishery Conservation and Management Act, as amended.
- 7 16 U.S.C. §1801 et seq.
- 8 National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.
- 9 National Historic Preservation Act of 1966, as amended. 16 U.S.C. §470 et seq.
- 10 Pollution Prevention Act of 1990. 42 U.S.C. §13101 et seq.
- 11 Resource Conservation and Recovery Act of 1976, as amended. 42 U.S.C. §6901 et seq.
- 12 Wild and Scenic Rivers Act, as amended. 16 U.S.C. §1271 et seq.



1  
2  
3

**APPENDIX C  
CONSULTATION CORRESPONDENCE**



## 1 **C. Consultation Correspondence**

### 2 **C.1 Federal Agency Obligations under ESA Section 7**

3 As a Federal agency, the U.S. Nuclear Regulatory Commission (NRC) must comply with the  
4 Endangered Species Act of 1973, as amended (16 *United States Code* (U.S.C.) § 1531 et seq.;  
5 herein referred to as ESA), as part of any action authorized, funded, or carried out by the  
6 agency, such as the proposed agency action that this supplemental environmental impact  
7 statement (SEIS) evaluates: whether to issue a renewed license for the continued operation of  
8 Waterford Steam Electric Station, Unit 3 (WF3), for an additional 20 years beyond the current  
9 license term. Under section 7 of the ESA, the NRC must consult with the U.S. Fish and Wildlife  
10 Service (FWS) and the National Marine Fisheries Service (NMFS) (referred to jointly as “the  
11 Services” and individually as “Service”), as appropriate, to ensure that the proposed agency  
12 action is not likely to jeopardize the continued existence of any endangered or threatened  
13 species or result in the destruction or adverse modification of designated critical habitat.

14 The ESA and the regulations that implement ESA section 7 (Title 50 of the *Code of Federal*  
15 *Regulations* (50 CFR) Part 402, “Interagency cooperation—Endangered Species Act of 1973,  
16 as amended”) describe the consultation process that Federal agencies must follow in support of  
17 agency actions. As part of this process, the Federal agency shall either request that the  
18 Services provide a list of any listed or proposed species or designated or proposed critical  
19 habitats that may be present in the action area or request that the Services concur with a list of  
20 species and critical habitats that the Federal agency has created (50 CFR 402.12(c)). If it is  
21 determined that any such species or critical habitats may be present, the Federal agency is to  
22 prepare a biological assessment to evaluate the potential effects of the action and determine  
23 whether the species or critical habitat are likely to be adversely affected by the action  
24 (50 CFR 402.12(a); 16 U.S.C. § 1536(c)). Biological assessments are required for any agency  
25 action that is a “major construction activity” (50 CFR 402.12(b)), which is defined as a  
26 construction project or other undertaking having construction-type impacts that is a major  
27 Federal action significantly affecting the quality of the human environment under the National  
28 Environmental Policy Act of 1969, as amended (42 U.S.C. § 4321 et seq.; herein referred to as  
29 NEPA) (51 FR 19926). Federal agencies may fulfill their obligations to consult with the Services  
30 under ESA section 7 and to prepare a biological assessment in conjunction with the interagency  
31 cooperation procedures required by other statutes, including NEPA (50 CFR 402.06(a)). In  
32 such cases, the Federal agency should include the results of the ESA section 7 consultation in  
33 the NEPA document (50 CFR 402.06(b)).

### 34 **C.2 Biological Assessment**

35 License renewal does not require the preparation of a biological assessment because it is not a  
36 major construction activity. However, the NRC staff prepared a biological evaluation to analyze  
37 the potential impacts of the proposed license renewal on federally listed species and critical  
38 habitats, to support the NRC’s ESA effect determinations for listed species and critical habitats  
39 that may occur in the action area. The staff structured its evaluation in accordance with the  
40 Services’ suggested biological assessment contents described at 50 CFR 402.12(f). The  
41 evaluation is described in further detail below in Section C.3.

### 1 C.3 Chronology of ESA Section 7 Consultation

#### 2 ESA Section 7 with the FWS

3 During its review of Entergy Operations, Inc.'s (Entergy) license renewal application (LRA), the  
 4 NRC staff considered whether any Federally listed, proposed, or candidate species or proposed  
 5 or designated critical habitats may be present in the action area (as defined at 50 CFR 402.02)  
 6 for the proposed WF3 license renewal. With respect to species under the FWS's jurisdiction,  
 7 the NRC staff submitted project information to the FWS's Environmental Conservation Online  
 8 System (ECOS) Information for Planning and Conservation (IPaC) system to obtain an official  
 9 list of species in accordance with 50 CFR 402.12(c). On May 20, 2016, the FWS provided NRC  
 10 with a list of threatened and endangered species that may occur in the proposed action area,  
 11 and on April 13, 2017, the NRC staff obtained an updated list of species from the ECOS IPaC  
 12 system. The FWS's lists identify three species as having the potential to occur in the action  
 13 area: the gulf subspecies of Atlantic sturgeon (*Acipenser oxyrinchus desotoi*), pallid sturgeon  
 14 (*Scaphirhynchus albus*), and West Indian manatee (*Trichechus manatus*).

15 The NRC staff prepared a biological evaluation to address potential impacts to these three  
 16 species. The biological evaluation concludes that license renewal would have no effect on the  
 17 gulf subspecies of Atlantic sturgeon and West Indian manatee and that license renewal may  
 18 affect, but is not likely to adversely affect the pallid sturgeon. The NRC staff requested the  
 19 FWS's concurrence with its "not likely to adversely affect" determination for pallid sturgeon in a  
 20 letter dated July 5, 2017. By letter dated November 20, 2017, the FWS concurred with the  
 21 staff's determination. The FWS's concurrence letter concluded consultation, and the letter  
 22 documents that the NRC staff has fulfilled its ESA Section 7(a)(2) obligations with respect to the  
 23 proposed WF3 license renewal.

24 Table C–1 lists the letters, e-mails, and other correspondence related to the NRC's ESA  
 25 obligations with respect to its review of the WF3 LRA. This table will be updated in the final  
 26 SEIS, as applicable, to include correspondence transpiring between the issuance of the draft  
 27 and final SEIS.

28 **Table C–1. ESA Section 7 Consultation Correspondence with FWS**

<b>Date</b>	<b>Sender and Recipient</b>	<b>Description</b>	<b>ADAMS Accession No.<sup>(a)</sup></b>
May 20, 2016	Louisiana Ecological Services Field Office (FWS) to B. Grange (NRC)	List of threatened and endangered species for the proposed WF3 license renewal	ML16141A727
May 24, 2016	B. Grange (NRC) to D. Fuller (FWS)	Request for comments on list of species for ESA section 7 consultation and NEPA scoping	ML16145A311
May 24, 2016	B. Grange (NRC) to K. Shotts (NMFS)	Request for comments on list of species for ESA section 7 consultation, EFH, and NEPA scoping	ML16145A318
April 13, 2017	Louisiana Ecological Services Field Office (FWS) to B. Grange (NRC)	Updated list of threatened and endangered species for the proposed WF3 license renewal	ML17103A180

Date	Sender and Recipient	Description	ADAMS Accession No. <sup>(a)</sup>
July 5, 2017	B. Beasley (NRC) to M. Sikes (FWS)	Request for concurrence with determination that license renewal is not likely to adversely affect the pallid sturgeon	ML17163A168
November 20, 2017	J. Ranson (FWS) to B. Beasley (NRC)	Concurrence with the NRC's "not likely to adversely affect" determination for pallid sturgeon	ML17331A541

<sup>(a)</sup> These documents can be accessed through the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://adams.nrc.gov/wba/>.

## 1 ESA Section 7 with the NMFS

2 As discussed in Section 3.8 and 4.8, no Federally listed species or critical habitats under  
3 NMFS's jurisdiction occur within the action area. Therefore, the NRC did not engage the NMFS  
4 pursuant to ESA section 7 for the proposed WF3 license renewal.

## 5 **C.4 Essential Fish Habitat Consultation**

6 The NRC must comply with the Magnuson–Stevens Fishery Conservation and Management  
7 Act, as amended (16 U.S.C. § 1801 et seq., herein referred to as MSA), for any actions  
8 authorized, funded, or undertaken, or proposed to be authorized, funded, or undertaken that  
9 may adversely affect any essential fish habitat (EFH) identified under the MSA.

10 In Sections 3.8 and 4.8 of this SEIS, the NRC staff concludes that the NMFS has not designated  
11 any EFH under the MSA in the Mississippi River and that the proposed WF3 license renewal  
12 would have no effect on EFH. Thus, the MSA does not require the NRC to consult with the  
13 NMFS for the proposed WF3 license renewal. Table C-2 lists the letters, e-mail, and other  
14 correspondence related to this determination.

15 **Table C–2. EFH Correspondence with NMFS**

Date	Sender and Recipient	Description	ADAMS Accession No. <sup>(a)</sup>
May 24, 2016	B. Grange (NRC) to K. Shotts (NMFS)	Request for comments on list of species for ESA section 7 consultation, EFH, and NEPA scoping	ML16145A318
July 25, 2016	n/a	Conversation record between B. Grange (NRC) and R. Hartman (NMFS) regarding EFH for WF3 license renewal review	ML16209A351
July 26, 2016	B. Grange (NRC) to R. Hartman (NMFS)	No adverse effects to EFH for WF3 proposed license renewal	ML16209A330

<sup>(a)</sup> These documents can be accessed through the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://adams.nrc.gov/wba/>.

## 1 C.5 Section 106 Consultation

2 The National Historic Preservation Act of 1966, as amended (NHPA), requires Federal agencies  
 3 to consider the effects of their undertakings on historic properties and consult with applicable  
 4 State and Federal agencies, Tribal groups, and individuals and organizations with a  
 5 demonstrated interest in the undertaking before taking action. Historic properties are defined as  
 6 resources that are eligible for listing on the National Register of Historic Places. The historic  
 7 preservation review process (Section 106 of the NHPA) is outlined in regulations issued by the  
 8 Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800. In accordance with  
 9 36 CFR 800.8(c), the NRC has elected to use the NEPA process to comply with its obligations  
 10 under Section 106 of the NHPA.

11 Table C–3 lists the chronology of consultation and consultation documents related to the NRC’s  
 12 Section 106 review of the W3 license renewal. The NRC staff is required to consult with the  
 13 noted agencies and organizations in accordance with the statutes listed above.

14 **Table C–3. NHPA Correspondence**

<b>Date</b>	<b>Sender and Recipient</b>	<b>Description</b>	<b>ADAMS Accession No. <sup>(a)</sup></b>
June 2, 2016	J. Danna (NRC) to J.O. Darden, Chitimacha Tribe of Louisiana	Request for scoping comments/notification of section 106 review	ML16146A730
June 2, 2016	J. Danna (NRC) to L. Poncho, Coushatta Tribe of Louisiana	Request for scoping comments/notification of section 106 review	ML16146A730
June 2, 2016	J. Danna (NRC) to B.C. Smith, Jena Band of Choctaw Indians	Request for scoping comments/notification of section 106 review	ML16146A730
June 2, 2016	J. Danna (NRC) to J.P. Barbry, Tunica-Biloxi Tribe of Louisiana	Request for scoping comments/notification of section 106 review	ML16146A730
June 3, 2016	J. Danna (NRC) to P. Boggan, Louisiana Office of Cultural Development	Request for scoping comments/notification of section 106 review	ML16147A280
June 6, 2016	J. Danna (NRC) to R. Nelson, Advisory Council on Historic Preservation	Request for scoping comments/notification of section 106 review	ML16147A235

<sup>(a)</sup> These documents can be accessed through the NRC’s Agencywide Documents Access and Management System (ADAMS) at <http://adams.nrc.gov/wba/>.

## 1 C.6 References

- 2 36 CFR Part 800. *Code of Federal Regulations*, Title 36, Parks, Forests, and Public Property,  
3 Part 800, "Protection of historic properties."
- 4 50 CFR Part 402. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 402,  
5 "Interagency cooperation—Endangered Species Act of 1973, as amended."
- 6 51 FR 19926. U.S. Fish and Wildlife Service and National Marine Fisheries Service.  
7 Interagency cooperation—Endangered Species Act of 1973, as amended; final rule. *Federal*  
8 *Register* 51:19926-19963. June 3, 1986.
- 9 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.
- 10 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 1998.  
11 *Endangered Species Consultation Handbook: Procedures for Conducting Consultation and*  
12 *Conference Activities Under Section 7 of the Endangered Species Act*. March 1998. 315 p.  
13 Available at <[http://www.fws.gov/endangered/esa-library/pdf/esa\\_section7\\_handbook.pdf](http://www.fws.gov/endangered/esa-library/pdf/esa_section7_handbook.pdf)>  
14 (accessed 8 July 2013).
- 15 [MSA] Magnuson–Stevens Fishery Conservation and Management Act, as amended.  
16 16 U.S.C. § 1801 et seq.
- 17 [NEPA] National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.
- 18 [NHPA] National Historic Preservation Act of 1966, as amended. 54 U.S.C. §300101 et seq.



1

**APPENDIX D**

2

**CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE**



## 1 D. Chronology of Environmental Review Correspondence

2 This appendix, along with Appendix C, contains a chronological listing of correspondence  
3 between the U.S. Nuclear Regulatory Commission (NRC) staff and external parties as part of its  
4 environmental review for WF3. Appendix C contains the chronological listing of consultation  
5 correspondence associated with the Endangered Species Act of 1973, as amended  
6 (16 U.S.C. 1531 et seq.), the Magnuson–Stevens Fishery Conservation and Management Act,  
7 as amended (16 U.S.C. 1801–1884), and the National Historic Preservation Act of 1966, as  
8 amended (54 U.S.C. 300101, et seq.). Appendix D contains all other correspondence.

9 All documents, with the exception of those containing proprietary information, are available  
10 electronically in the NRC’s Library, which is found on the Internet at the following Web address:  
11 <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC’s  
12 Agencywide Documents Access and Management System (ADAMS), which provides text and  
13 image files of the NRC’s public documents. The ADAMS number for each document is included  
14 in the following list. If you need assistance in accessing or searching in ADAMS, contact the  
15 Public Document Room Staff at 1-800-397-4209.

### 16 D.1 Environmental Review Correspondence

17 Table D–1 lists the environmental review correspondence in chronological order beginning with  
18 the request by Entergy to renew the operating license for WF3. As noted above,  
19 correspondence related to consultations under the Endangered Species Act of 1973, the  
20 Magnuson–Stevens Fishery Conservation and Management Act, and the National Historic  
21 Preservation Act of 1966, can be found in Appendix C.

22 **Table D–1. Environmental Review Correspondence**

<b>Date</b>	<b>Correspondence Description</b>	<b>ADAMS Accession No.</b>
March 23, 2016	Entergy Operations, Inc. (EOI) License Renewal Application (LRA) for Waterford 3 (WF3).	ML16088A324
April 7, 2016	U.S. Nuclear Regulatory Commission (NRC) <i>Federal Register</i> Notice (FRN) of Receipt and Availability of the LRA for WF3	ML16062A009
April 7, 2016	NRC Letter to EOI, Notice of Receipt and Availability	ML16055A235
May 18, 2016	NRC Letter to EOI, Reference Portal	ML16118A408
May 20, 2016	NRC Letter to EOI, Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding the Application for Renewal of the Operating License for WF3	ML16130A023
May 20, 2016	NRC FRN of Acceptability and Opportunity Request Hearing	ML16131A008
June 1, 2016	NRC Letter to EOI, Notice of Intent To Prepare an Environmental Impact Statement and Conduct Scoping Process for License Renewal for WF3	ML16146A696
June 1, 2016	NRC FRN of Notice of Intent To Prepare an Environmental Impact Statement and Conduct Scoping Process for License Renewal for WF3	ML16148A493
July 8, 2016	NRC Letter to EOI, Environmental Site Audit Plan	ML16172A008

## Appendix D

<b>Date</b>	<b>Correspondence Description</b>	<b>ADAMS Accession No.</b>
July 28, 2016	Record of Conversation between NRC and Louisiana Department of Environmental Quality, Impingement Studies	ML17087A172
October 21, 2016	NRC Letter to EOI, Severe Accident Mitigation Analysis (SAMA) Site Audit.	ML16294A511
October 28, 2016	NRC Letter to EOI, Environmental Review – Request for Additional Information (RAI)	ML16295A369
November 22, 2016	NRC Letter to EOI, SAMA review – RAI	ML16309A580
November 23, 2016	EOI Letter to NRC, Response to Environmental Site Audit RAIs	ML16328A414
February 7, 2017	EOI Letter to NRC, Response to SAMA Site Audit RAIs	ML17038A436
March 28, 2017	NRC Letter to EOI, Second Round RAIs related to SAMA Review	ML17086A585
April 12, 2017	EOI Letter to NRC, Response to Second Round RAIs related to SAMA	ML17114A432
August 24, 2017	NRC Letter to EOI, Status Update and Schedule Revision for License Renewal	ML17131A194
December 20, 2017	NRC Letter to EOI, Status Update and Schedule Revision for License Renewal	ML17347A127

1  
2  
3

**APPENDIX E**  
**PROJECTS AND ACTIONS CONSIDERED IN THE CUMULATIVE**  
**IMPACTS ANALYSIS**



1 **E. Projects and Actions Considered in the Cumulative Impacts**  
 2 **Analysis**

3 Table E–1 identifies actions and projects considered in the U.S. Nuclear Regulatory Commission  
 4 (NRC) staff’s analysis of cumulative impacts related to the environmental analysis of the  
 5 continued operation of Waterford Steam Electric Station, Unit 3 (WF3). Potential cumulative  
 6 impacts associated with these actions and projects are addressed in Section 4.16 of this  
 7 supplemental environmental impact statement. However, not all actions or projects listed in this  
 8 appendix are considered in each resource area because of the uniqueness of the resource and  
 9 its geographic area of consideration.

10 **Table E–1. Projects and Actions Considered in the Cumulative Impacts Analysis**

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
<b>Onsite Facilities/Projects</b>			
Waterford Steam Electric Station, Units 1 and 2	Oil/gas-fueled plant with approximately 825 MW generating capacity	Onsite, approximately 0.4 mi (0.7 km) northwest	Operational (EIA 2016a, Entergy 2016a)
Waterford Steam Electric Station, Unit 4	Oil-fueled peaking plant with 33 MW generating capacity	Onsite, approximately 0.4 mi (0.7 km) northwest	Operational (Entergy 2016a)
Waterford 3 Independent Spent Fuel Storage Installation Expansion	Potential expansion of existing storage	Onsite	No timetable established (Entergy 2016a)
Waterford 3 Intake Canal Improvement/Modification	Planned replacement of intake structure weir wall	Onsite	Implementation estimated to start in 2018 (Entergy 2016b)
<b>Nuclear Energy Facilities</b>			
River Bend Station, Unit 1	Nuclear power plant, one 974-MWe General Electric Type 6 reactor	West Feliciana Parish, LA, approximately 75 mi (121 km) northwest. 50-mi (80-km) radii overlaps with that of Waterford 3.	Operational (Entergy 2016a, 2016d; NRC 2016)
<b>Fossil Fuel Energy Facilities</b>			
Little Gypsy Power Plant	Natural gas-fueled plant with 1,160 MW generating capacity	Montz, LA, approximately 1 mi (1.6 km) northeast	Operational (EIA 2016b)

Appendix E

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
St. Charles Power Station	New 980-MW natural gas combined-cycle plant adjacent to the Little Gypsy Power Plant. Project includes constructing and operating a new compressor station and 900 feet of natural gas pipeline	Montz, LA approximately 1 mi (1.6 km) northeast	Construction commenced in 2017; expected to be operational by mid-2019 (Entergy 2017a, 2017b; FERC 2017)
Taft Cogeneration Facility	Chemical manufacturing facility (Occidental) with approximately 740 MW capacity natural gas-fueled cogeneration	Hahnville, LA, approximately 1 mi (1.6 km) east-southeast	Operational (EIA 2016c; Entergy 2016c)
Dow St. Charles	Chemical manufacturing facility (Dow) with approximately 270 MW capacity natural gas-fueled combined heat and power plant	Taft, LA, approximately 1.8 mi (2.9 km) east-southeast	Operational (EIA 2016d; Entergy 2016c)
Nine Mile Point	Natural gas-fueled plant with 2,083 MW generating capacity	Westwego, LA, approximately 20 mi (32 km) east-southeast	Operational (EIA 2016e)
<b>Renewable Energy Facilities</b>			
Entergy New Orleans	Solar PV facility with approximately 1 MW generating capacity	In New Orleans East, approximately 26 mi (42 km) east	Completed 2016; operational (Times-Picayune 2016)
<b>Manufacturing Facilities</b>			
A.M. Agrigen Industries	Proposed fertilizer plant	In Killona area of St. Charles Parish, approximately 1.3 mi (2 km) west-northwest	Planned; construction of 650 ac (260 ha) granulated urea plant expected to commence in 2019 (Entergy 2016a, 2016b; Brown 2016; Griggs et. al. 2015)
Castleton Commodities International LLC	Proposed 390 acre (160 ha) methanol manufacturing plant	In Braithwaite area of Plaquemines Parish, approximately 32 mi (51 km) east-southeast	Undetermined; 2-year construction period was initially expected to commence in 2016. (Entergy 2016a, 2016b; LED 2014; Griggs et. al. 2015)
Yuhuang Chemical Inc.	Methanol manufacturing plant	In St. James Parish, approximately 22 mi (35 km) west	Construction ongoing (Entergy 2016a, 2016b; Griggs et. al. 2015; Brown 2016; Yuhuang Chemical 2016)

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
Williams Partners LP Ethane Cracker	Expansion of natural gas processing complex	In Geismar area of Ascension Parish, approximately 38 mi (61 km) west-northwest	Completed 2016 (Entergy 2016a, 2016b; Griggs et. al. 2015; Williams 2016)
Air Liquide America	Gas product manufacturing	Plants in Norco (approximately 4 mi (6 km) northeast) and Taft 1 mi (1.6 km) east-southeast	Operational (Entergy 2016c; EPA 2016b)
ArcelorMittal Bayou Steel	Structural steel manufacturing	In LaPlace, approximately 3 mi (5 km) north	Operational (Bloomberg 2016) Entergy 2016c)
CF Industries	New ammonia plant	In Donaldsonville area of Acension Parish, approximately 32 mi (51 km) west-northwest	Construction ongoing (Brown 2016; Entergy 2016c)
CGB Marine Services	Shipping services, supply, and repair	In LaPlace, approximately 4 mi (6 km) north	Operational (Entergy 2016c)
BeAed Corporation	Industrial manufacturing facility construction	In Luling area of St. Charles Parish, approximately 8 mi (13 km) east southeast	Construction completed 2016 (SCP 2017 Entergy 2016b)
Bent's RV	New office construction	In Paradis area of St. Charles Parish, approximately 8 mi (13 km) south-southeast	Construction completed 2017(SCP 2018; Entergy 2016b)
Blue Bell Creameries	New service center	In Luling area of St. Charles Parish, approximately 8 mi (13 km) east southeast	Construction completed (SCP 2016a; Entergy 2016b)
Dow Chemical	Petrochemical manufacturing improvements	In Hahnville, approximately 1 mi (1.6 km) southeast	Planned (SCP 2016a; Entergy 2016b)
Enterprise Products Partners LLC	Fractionation plant	In Norco, approximately 4 mi (6 km) east	Operational (Entergy 2016c; EPA 2016b)
Galata Chemicals	Chemical manufacturing plant	In Taft, approximately 1.4 mi (2.3 km) southeast	Operational (Entergy 2016c)
Hexion Inc. (Momentive Specialty Chemicals)	Epoxy manufacturing	In Norco, approximately 2.6 mi (4 km) east	Planning to shut down by 2019 (Entergy 2016c; St. Charles Herald-Guide 2016)

Appendix E

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
Koch Nitrogen	Ammonia terminal	In Taft, approximately 1.4 mi (2.3 km) southeast	Operational (Entergy 2016c; EPA 2016b)
Kongsberg Maritime	Office and training center construction	In St. Rose area of St. Charles Parish, approximately 10 mi (16 km) east	Construction ongoing (SCP 2016a; Entergy 2016b)
Monsanto	Chemical manufacturing facility expansion	In Luling area of St. Charles Parish, approximately 9 mi (14.5 km) east southeast	Construction commenced in 2017; operations expected to commence in 2019 (SCP 2018; (Entergy 2016b; Times-Picayune 2017)
Mosaic Phosphates Company	Fertilizer manufacturing	In Taft, approximately 0.7 mi (1 km) east southeast	Operational (Entergy 2016c)
Motiva Enterprises	Manufacturing complex additions and improvements	In Norco area of St. Charles Parish, approximately 4 mi (6 km) east	Planned (SCP 2016a; Entergy 2016b, 2016c)
Occidental Chemical	Chemical manufacturing	In Taft, approximately 1 mi (1.6 km) east southeast	Operational (Entergy 2016c; EPA 2016b)
Praxair	Industrial gas manufacturing	In Taft, approximately 1.3 mi (2 km) east southeast	Operational (Entergy 2016c)
Shell Chemical	Improvements to operating chemical manufacturing facility	In Norco area of St. Charles Parish, approximately 4 mi (6 km) east	Planned (Entergy 2016b, 2016c; EPA 2016b; SCP 2016a)
Sunbelt	New facility construction of industrial valve supplier	In Luling area of St. Charles Parish, approximately 8 mi (13 km) east southeast	Construction completed 2016(Entergy 2016b; SCP 2017; Sunbelt 2016)
Union Carbide	Taft/Star Complex	In Taft, approximately 1.4 mi (2.3 km) east southeast	Operational (Entergy 2016c; EPA 2016b)
Valero	Facility Improvements to St. Charles Refinery	In Norco area of St. Charles Parish, approximately 5 mi (8 km) east	Construction underway; expanded operations expected to commence in 2021 (SCP 2018; St. Charles Herald-Guide 2017; Entergy 2016b; 2016c; EPA 2016b)

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
Waugauspack Oil Company	Bulk fuel facility	In LaPlace, approximately 4.8 mi (7.7 km) north	Operational (Entergy 2016c)
Western International	Bulk fuel facility	In Taft, approximately 1.3 mi (2 km) east	Operational (Entergy 2016c)
W.R. Grace	Chemical catalyst plant	In Norco area of St. Charles Parish, approximately 2.6 mi (4.2 km) east	Operational (Entergy 2016c; Grace 2016)
<b>Landfills</b>			
Kv Ent Landfill	Municipal solid waste landfill	Approximately 3 mi (5 km) west-northwest	Operational (Wastebits 2016a)
River Birch Landfill	Municipal solid waste landfill	Approximately 13 mi (21 km) southeast	Operational (Wastebits 2016b)
Jefferson Parish Sanitary Landfill	Municipal solid waste landfill	Approximately 15 mi (24 km) southeast	Operational (Wastebits 2016c)
<b>Water Supply and Treatment Facilities</b>			
St. Charles Water Works Department	Municipal water supply with Mississippi River source	In New Sarpy, approximately 4.6 mi (7.4 km) east	Operational (EPA 2016a; Entergy 2016c)
St. Charles Parish wastewater treatment	Wastewater treatment plant	Approximately 8 mi (13 km) southeast	Operational (EPA 2016b)
St. John the Baptist Parish wastewater treatment	Wastewater treatment plant	In LaPlace, approximately 5 mi (8 km) north northwest	Operational (Entergy 2016c; EPA 2016b)
Various minor NPDES wastewater discharges	Various businesses with smaller wastewater discharges.	Within 50 mi (31 km)	Operational (EPA 2016b)
<b>Military Facilities</b>			
Naval Air Station Joint Reserve Base New Orleans	4,400 ac (1,780 ha) base supporting Navy, Air Force, Coast Guard, Marine Corps, and the Louisiana Air National Guard	In Plaquemines Parish, approximately 28 mi (45 km) southeast	Operational (MARCOA 2016)
<b>Parks and Recreation Sites</b>			
Maurepas Swamp Wildlife Management Area (WMA)	122,000 ac (49,400 ha) WMA. Public camping, fishing, hunting boating, and birdwatching occur within the park.	Approximately 6 mi (10 km) north at closest point	Operational Managed by Louisiana Department of Wildlife and Fisheries (Entergy 2016a; LDWF 2016a)

Appendix E

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
Salvador/Timken Wildlife Management Area	33,000 ac (13,000 ha) WMA. Public hunting, trapping, fishing, boating, and nature study occur within the park. Access available only by boat.	Approximately 15 mi (24 km) southeast	Operational Managed by Louisiana Department of Wildlife and Fisheries (Entergy 2016a; LDWF 2016b)
Bayou Segnette State Park	680 ac (280 ha) park offering boating, fishing, camping, canoeing, hiking, picnicking, and swimming	Approximately 19 mi (30 km) southeast	Operational Managed by Louisiana Department of Culture, Recreation and Tourism (BTNEP 2016, LDCRT 2016)
Jean Lafitte National Historical Park – Barataria Preserve	23,000 ac (9,300 ha) preserve containing trails through bayous, swamps, marshes, and forests	Approximately 23 mi (37 km) southeast	Operational Managed by National Park Service (Entergy 2016a; NPS 2016)
Bayou Sauvage National Wildlife Refuge	24,000 ac (9,700 ha) refuge located adjacent to Lakes Pontchartrain and Borgne, containing a wide variety of wildlife habitats	Approximately 34 mi (55 km) east-southeast	Operational Managed by U.S. Fish and Wildlife Service (Entergy 2016a; FWS 2015).
Wetland Watcher’s Park	28 ac (11 ha) park located within the Bonnet Carre Spillway offering public canoe and kayak launches	Approximately 1 mi (1.6 km) east northeast	Operational Managed by St. Charles Parish (Entergy 2016a; SCP 2012, 2016b)
Killona Park	12 ac (5 ha) community park containing basketball courts and baseball fields	Approximately 1 mi (1.6 km) northwest	Operational Managed by St. Charles Parish (Entergy 2016a; SCP 2012, 2016b)
Montz Park	12 ac (5 ha) community park that includes a baseball field	Approximately 1 mi (1.6 km) east-northeast	Operational Managed by St. Charles Parish (Entergy 2016a; SCP 2012, 2016b)
Bethune Park	11-ac (4.5-km) community park containing multi-purpose fields, basketball court, and picnic pavilion	Approximately 3 mi (4.8 km) east-northeast	Operational Managed by St. Charles Parish (Entergy 2016a; SCP 2012, 2016b)
Recreational Areas	Various parks, boat launches, and campgrounds	Within 10 mi (16 km)	Operational
<b>Transportation Projects</b>			
Louis Armstrong New Orleans International Airport	Full service commercial airport with planned new north terminal	In Kenner, approximately 11 mi (18 km) east	Operational New terminal under construction through 2018 (Entergy 2016a; MSY 2016)
Other Aviation	Three private heliports, one private airfield, and one public general aviation airport	Located within 10 mi (16 km) of plant	Operational (Entergy 2016a)

<b>Project Name</b>	<b>Summary of Project</b>	<b>Location (Relative to WF3)</b>	<b>Status</b>
Houma-Thibodaux to LA-3127 connection	Construction of new 25 mi (40 km) highway between US Highway 90 and Louisiana Highway 3127	Approximately 14 mi (23 km) west-southwest at nearest point	Proposed (Entergy 2016b; LaDOTD 2016)
<b>Other Projects</b>			
Lake Pontchartrain levee project	Proposed storm-surge risk reduction project	Along west shore of Lake Pontchartrain, west of the Bonnet Carre Spillway, approximately 8 mi (13 km) north-northeast	Under consideration (Entergy 2016b; USACE 2016a)
Bonnet Carre Spillway	7,600 acre (3,100 ha) flood control structure used for diverting Mississippi flood waters to Lake Pontchartrain. Also open to public for compatible outdoor recreational activities including hunting, fishing, biking, picnicking, boating, horseback riding, and ATV and motorcycle riding.	On east bank of the Mississippi River approximately 1 mi (1.6 km) east northeast at River Mile 129	Operational (Entergy 2016b; USACE 2016b; 2016c)
Davis Pond Freshwater Diversion Project	10,000 ac (4,000 ha) project diverting water and sediment to reduce saltwater intrusion and land loss	Approximately 10 mi (16 km) southeast at River Mile 118	Ongoing since 2002 (Entergy 2016b; USACE 2016d; Moretzsohn et.al. 2016)
St. Charles Parish Urban Flood Control Project	Addition of flood control pumping stations and canal improvements	Approximately 3 to 6 mi (5 to 10 km) west in Ormond, New Sarpy, and Norco	Implementation pending (Entergy 2016b; USACE 2016e)
Future Development	Construction of housing units and associated commercial buildings; roads, bridges, and rail; water and/or wastewater treatment and distribution facilities; and associated pipelines as described in local land-use planning documents.	Throughout region	Construction would occur in the future, as described in State and local land-use planning documents.

## 1 E.2 References

- 2 Bloomberg 2016. "Company Overview of ArcelorMittal LaPlace, LLC." Available at  
3 <<http://www.bloomberg.com/research/stocks/private/snapshot.asp?privcapId=100213>>  
4 (accessed December 2016).

## Appendix E

- 1 Brown, Trevor. 2016. "Ammonia plants in the pipeline. Will they, won't they?" *Ammonia*  
2 *Industry.com*, February 4. <<https://ammoniaindustry.com/tag/am-agrigen/>> (accessed  
3 11 July 2016).
- 4 [BTNEP] Barataria-Terrebonne National Estuary Program. 2016. *Field Guide to the*  
5 *Barataria-Terrebonne National Estuary*. Available at  
6 <<http://www.btnep.org/btnep/resources/downloads/lessons.aspx>> (accessed  
7 13 December 2016).
- 8 [EIA] U.S. Energy Information Administration. 2016a. "Louisiana State Profile and Energy  
9 Estimates – Waterford 1 & 2." Available at <<https://www.eia.gov/state/?sid=LA>> (accessed  
10 12 May 2016).
- 11 [EIA] U.S. Energy Information Administration. 2016b. "Louisiana State Profile and Energy  
12 Estimates, Profile Overview Interactive Map – Little Gypsy." Available at  
13 <<http://www.eia.gov/state/?sid=LA>> (accessed 12 May 2016).
- 14 [EIA] U.S. Energy Information Administration. 2016c. "Louisiana State Profile and Energy  
15 Estimates, Profile Overview Interactive Map – Taft Cogeneration Facility." Available at  
16 <<http://www.eia.gov/state/?sid=LA>> (accessed 12 May 2016).
- 17 [EIA] U.S. Energy Information Administration. 2016d. "Louisiana State Profile and Energy  
18 Estimates, Profile Overview Interactive Map – Dow St. Charles." Available at  
19 <<http://www.eia.gov/state/?sid=LA>> (accessed 12 May 2016).
- 20 [EIA] U.S. Energy Information Administration. 2016e. "Louisiana State Profile and Energy  
21 Estimates, Profile Overview Interactive Map – Nine Mile Point." Available at  
22 <<http://www.eia.gov/state/?sid=LA>> (accessed 12 May 2016).
- 23 [Entergy] Entergy Louisiana, LLC. 2016a. Applicant's Environmental Report—Operating  
24 License Renewal Stage, Waterford Steam Electric Station, Unit 3, March 2016. ADAMS  
25 Accession No. ML16088A326.
- 26 [Entergy] Entergy Operations, Inc. 2016b. Letter from Chisum MR, Site Vice President,  
27 Waterford 3, to NRC Document Control Desk. Subject: "Responses to Request for Additional  
28 Information for Environmental Review Regarding the License Renewal Application for Waterford  
29 Steam Electric Station, Unit 3 (Waterford 3). Docket No. 50-382, License No. NPF-38."  
30 November 23, 2016. ADAMS Accession No. ML16328A414.
- 31 [Entergy] Entergy Operations, Inc. 2016c. Letter from Jarrell III JP, Manager, Regulatory  
32 Assurance, Waterford 3, to NRC Document Control Desk. Subject: "2016 Survey of Toxic  
33 Chemicals in the Vicinity of Waterford 3." Waterford Steam Electric Station, Unit 3  
34 (Waterford 3). Docket No. 50-382, License No. NPF-38." September 26, 2016. ADAMS  
35 Accession No. ML16273A279.
- 36 [Entergy] Entergy Nuclear. 2016d. "River Bend Nuclear Station." Available at  
37 <[http://www.energy-nuclear.com/plant\\_information/river\\_bend.aspx](http://www.energy-nuclear.com/plant_information/river_bend.aspx)> (accessed 7 July 2016).
- 38 [Entergy] Entergy Louisiana, LLC. 2017a. "St. Charles Power Station: Generating Louisiana's  
39 Growth." Available at <[http://www.energynewsroom.com/latest-news/st-charles-power-station-  
40 generating-louisianagrowth/](http://www.energynewsroom.com/latest-news/st-charles-power-station-generating-louisianagrowth/)> (accessed 19 April 2017).
- 41 [Entergy] Entergy Louisiana, LLC. 2017b. "St. Charles Power Station: FAQs." Available at  
42 <<http://www.energynewsroom.com/scpsFAQ/>> (accessed 19 April 2017).

- 1 [EPA] U.S. Environmental Protection Agency. 2016a. “Envirofacts Safe Drinking Water  
2 Information System (SDWIS) search results for Saint Charles Parish, Louisiana: List of Active  
3 Water Systems.” November 7, 2016. Available at  
4 <[https://iaspub.epa.gov/enviro/sdw\\_query\\_v3.get\\_list?wsys\\_name=&fac\\_search=beginning  
5 &fac\\_county=St.%20Charles&pop\\_serv=500&pop\\_serv=3300&pop\\_serv=10000&pop\\_serv=10  
6 0000&pop\\_serv=100001&sys\\_status=active&fac\\_state=LA&page=1](https://iaspub.epa.gov/enviro/sdw_query_v3.get_list?wsys_name=&fac_search=beginning&fac_county=St.%20Charles&pop_serv=500&pop_serv=3300&pop_serv=10000&pop_serv=10000&pop_serv=100001&sys_status=active&fac_state=LA&page=1)> (accessed  
7 21 November 2016).
- 8 [EPA] U.S. Environmental Protection Agency. 2016b. “Envirofacts Multisystem Search –  
9 St. Charles Parish, Louisiana.” Available at  
10 <[https://iaspub.epa.gov/enviro/efsystemquery.multisystem?fac\\_search=primary\\_name&fac\\_valu  
11 e=&fac\\_search\\_type=Beginning+With&postal\\_code=&location\\_address=&add\\_search\\_type=Be  
12 ginning+With&city\\_name=&county\\_name=St+Charles&state\\_code=LA&TribalLand=0&TribeTyp  
13 e=selectTribeALL&selectTribe=noselect&selectTribe=noselect&tribedistance1=onLand&sic typ  
14 e=Equal+to&sic code to=&naics type=Equal+to&naics to=&chem name=&chem search=Beg  
15 inning+With&cas num=&page no=1&output sql switch=FALSE&report=1&database type=Mul  
16 tisystem](https://iaspub.epa.gov/enviro/efsystemquery.multisystem?fac_search=primary_name&fac_value=&fac_search_type=Beginning+With&postal_code=&location_address=&add_search_type=Beginning+With&city_name=&county_name=St+Charles&state_code=LA&TribalLand=0&TribeType=selectTribeALL&selectTribe=noselect&selectTribe=noselect&tribedistance1=onLand&sic_type=Equal+to&sic_code_to=&naics_type=Equal+to&naics_to=&chem_name=&chem_search=Beginning+With&cas_num=&page_no=1&output_sql_switch=FALSE&report=1&database_type=Multisystem)> (accessed 7 December 2016).
- 17 [FERC] U.S. Federal Energy Regulatory Commission. 2017. *St. Charles Parish Expansion  
18 Project Environmental Assessment, Gulf South Pipeline Company, LP*. Docket No. CP16-478-  
19 000. Available at <<https://www.ferc.gov/industries/gas/enviro/eis/2017/CP16-478-EA.pdf>>  
20 (accessed 30 May 2017).
- 21 [FWS] U.S. Fish and Wildlife Service. 2015. Bayou Sauvage National Wildlife Refuge.  
22 Available at <[https://www.fws.gov/refuge/Bayou Sauvage/about.html](https://www.fws.gov/refuge/Bayou_Sauvage/about.html)> (accessed  
23 13 December 2016).
- 24 [Grace] W.R. Grace. 2016. Grace Norco Plant. Available at  
25 <[http://www.stcharles.k12.la.us/cms/lib010/LA01906411/Centricity/Domain/18/Norco%20Grace  
26 %20overview%2008-15-2016.pdf](http://www.stcharles.k12.la.us/cms/lib010/LA01906411/Centricity/Domain/18/Norco%20Grace%20overview%2008-15-2016.pdf)> (accessed 15 August 2016).
- 27 [Griggs et al.] T. Griggs, B. Lodge, and T. Boone. 2016. “2014 in review: Mega-projects mount  
28 on the horizon.” *The Advocate.com*. January 3. Available at  
29 <[http://www.theadvocate.com/baton\\_rouge/news/business/article\\_a5111dd6-431f-57af-9bb5-  
30 038cf6105c3a.html](http://www.theadvocate.com/baton_rouge/news/business/article_a5111dd6-431f-57af-9bb5-038cf6105c3a.html)> (accessed 2 June 2016).
- 31 [LaDOTD and FHWA] Louisiana Department of Transportation and Development and  
32 U.S. Department of Transportation, Federal Highway Administration 2015. *Houma – Thibodaux  
33 to LA 3127 Connection Draft Environmental Impact Statement*. Available at  
34 <[http://wwwapps.dotd.la.gov/administration/public\\_info/projects/docs\\_test/90/documents/Houma-  
35 Thibodaux\\_to\\_LA\\_3127\\_Connection\\_DEIS.pdf](http://wwwapps.dotd.la.gov/administration/public_info/projects/docs_test/90/documents/Houma-Thibodaux_to_LA_3127_Connection_DEIS.pdf)> (accessed 28 November 2016).
- 36 [LDCRT] Louisiana Department of Culture, Recreation and Tourism. 2016. Bayou Segnette  
37 State Park. Available at <[http://www.crt.state.la.us/louisiana-state-parks/parks/bayou-segnette-  
38 state-park/index](http://www.crt.state.la.us/louisiana-state-parks/parks/bayou-segnette-state-park/index)> (accessed 21 November 2016).
- 39 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016a. Maurepas Swamp WMA.  
40 Available at <<http://www.wlf.louisiana.gov/wma/2791>> (accessed 12 December 2016).
- 41 [LDWF] Louisiana Department of Wildlife and Fisheries. 2016b. Salvador/Timken WMA.  
42 Available at <<http://www.wlf.louisiana.gov/wma/2765>> (accessed 12 December 2016).
- 43 [LED] Louisiana Economic Development. 2014. “Castleton Commodities International  
44 Announces \$1.2 Billion Methanol Project In Louisiana.” October 14. Available at  
45 <[http://www.opportunitylouisiana.com/led-news/news-releases/news/2014/10/10/castleton-  
46 commodities-international-announces-\\$1.2-billion-methanol-project-in-louisiana](http://www.opportunitylouisiana.com/led-news/news-releases/news/2014/10/10/castleton-commodities-international-announces-$1.2-billion-methanol-project-in-louisiana)> (accessed  
47 11 July 2016).

## Appendix E

- 1 [MARCOA] MARCOA Publishing, Inc. 2016. *My Base Guide: Naval Air Station Joint Reserve*  
2 *Base New Orleans*. Available at < [http://www.mybaseguide.com/navy/43-](http://www.mybaseguide.com/navy/43-767/nas_jrb_new_orleans_nas_joint_reserve_base)  
3 [767/nas\\_jrb\\_new\\_orleans\\_nas\\_joint\\_reserve\\_base](http://www.mybaseguide.com/navy/43-767/nas_jrb_new_orleans_nas_joint_reserve_base) > (accessed 12 December 2016).
- 4 [Moretzsohn et al.] 2016. F. Moretzsohn, J.A. Sánchez Chávez, and J.W. Tunnell, Jr., Editors.  
5 *GulfBase: Resource Database for Gulf of Mexico Research*. Available at  
6 <<http://www.gulfbase.org/project/view.php?pid=dpfdp>> (accessed 12 December 2016).
- 7 [MSY] Louis Armstrong New Orleans International Airport. 2016. “North Terminal Project”  
8 Available at <[http://www.flymsy.com/capitalimprovements/Projects-in-Construction/North-](http://www.flymsy.com/capitalimprovements/Projects-in-Construction/North-Terminal-Project-1)  
9 [Terminal-Project-1](http://www.flymsy.com/capitalimprovements/Projects-in-Construction/North-Terminal-Project-1)> (accessed 21 December 2016).
- 10 [NRC] U.S. Nuclear Regulatory Commission. 2016. “River Bend Station, Unit 1.” April 4, 2016.  
11 Available at <<http://www.nrc.gov/info-finder/reactors/rbs1.html>> (accessed 7 July 2016).
- 12 St. Charles Herald-Guide. 2016. “Hexion will begin laying off employees on July 1.” Available  
13 at <<http://www.heraldguide.com/details.php?id=17081>> (accessed 12 December 2016).
- 14 St. Charles Herald-Guide. 2017. “Valero, Darling look into doubling biodiesel capacity in  
15 Norco.” Available at <[https://www.heraldguide.com/news/valero-darling-look-into-doubling-](https://www.heraldguide.com/news/valero-darling-look-into-doubling-biodiesel-capacity-in-norco/)  
16 [biodiesel-capacity-in-norco/](https://www.heraldguide.com/news/valero-darling-look-into-doubling-biodiesel-capacity-in-norco/)> (accessed 27 April 2018).
- 17 [SCP] St. Charles Parish, Louisiana. 2012. “St. Charles Parish Parks and Recreation Master  
18 Plan.” Available at <<http://www.stcharlesgov.net/home/showdocument?id=5580>> (accessed  
19 18 November 2016).
- 20 [SCP] St. Charles Parish, Louisiana. 2016a. “St. Charles Parish Department of Economic  
21 Development and Tourism – 2015 Annual Report.” Available at <[http://www.stcharlesparish-](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=6667)  
22 [la.gov/Home/ShowDocument?id=6667](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=6667)> (accessed 5 December 2016).
- 23 [SCP] St. Charles Parish, Louisiana. 2016b. “St. Charles Parish Parks and Recreational  
24 Facilities.” Available at < [http://stcharlesparish-la.gov/departments/parks-and-](http://stcharlesparish-la.gov/departments/parks-and-recreation/facilities-list-reservations-and-rentals/parks-and-recreational-facilities)  
25 [recreation/facilities-list-reservations-and-rentals/parks-and-recreational-facilities](http://stcharlesparish-la.gov/departments/parks-and-recreation/facilities-list-reservations-and-rentals/parks-and-recreational-facilities)> (accessed  
26 11 July 2016).
- 27 [SCP] St. Charles Parish, Louisiana. 2017. “St. Charles Parish Department of Economic  
28 Development and Tourism – 2016 Annual Report.” Available at <[http://www.stcharlesparish-](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=8150)  
29 [la.gov/Home/ShowDocument?id=8150](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=8150)> (accessed 27 April 2018).
- 30 [SCP] St. Charles Parish, Louisiana. 2018. “St. Charles Parish Department of Economic  
31 Development and Tourism – 2017 Annual Report.” Available at <[http://www.stcharlesparish-](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=8435)  
32 [la.gov/Home/ShowDocument?id=8435](http://www.stcharlesparish-la.gov/Home/ShowDocument?id=8435)> (accessed 27 April 2018).
- 33 [Sunbelt] Sunbelt Supply Co. 2016. Available at <<http://sunbeltsupply.com/location/luling-la/>>  
34 (accessed 12 December 2016).
- 35 [Times-Picayune] The Times-Picayune. 2016. “Take a look inside Entergy’s new solar plant in  
36 New Orleans East.” September 15. Available at  
37 <[http://www.nola.com/business/index.ssf/2016/09/entergy\\_new\\_orleans\\_solar\\_plan\\_1.html](http://www.nola.com/business/index.ssf/2016/09/entergy_new_orleans_solar_plan_1.html)>  
38 (accessed 12 December 2016).
- 39 [Times-Picayune] The Times-Picayune. 2017. “Monsanto's \$975 million expansion breaking  
40 ground in Luling.” February 3. Available at  
41 [http://www.nola.com/business/index.ssf/2017/02/monsantos\\_975m\\_expansion\\_break.html](http://www.nola.com/business/index.ssf/2017/02/monsantos_975m_expansion_break.html)>  
42 (accessed 25 April 2017).
- 43 [USACE] U.S. Army Corps of Engineers. 2016a. “West Shore Lake Pontchartrain” New  
44 Orleans District. Available at <[http://www.mvn.usace.army.mil/About/Projects/West-Shore-](http://www.mvn.usace.army.mil/About/Projects/West-Shore-Lake-Pontchartrain/)  
45 [Lake-Pontchartrain/](http://www.mvn.usace.army.mil/About/Projects/West-Shore-Lake-Pontchartrain/)> (accessed 12 December 2016).

- 1 [USACE] U.S. Army Corps of Engineers. 2016b. "Bonnet Carre Spillway." New Orleans  
2 District. Available at <[http://www.mvn.usace.army.mil/Missions/Recreation/Bonnet-Carre-  
3 Spillway/](http://www.mvn.usace.army.mil/Missions/Recreation/Bonnet-Carre-Spillway/)> (accessed 11 August 2016).
- 4 [USACE] U.S. Army Corps of Engineers. 2016c. "Bonnet Carre Spillway Operational Effects."  
5 New Orleans District. Available at <[http://www.mvn.usace.army.mil/Missions/Mississippi-River-  
6 Flood-Control/Bonnet-Carre-Spillway-Overview/Spillway-Operation-Information/](http://www.mvn.usace.army.mil/Missions/Mississippi-River-Flood-Control/Bonnet-Carre-Spillway-Overview/Spillway-Operation-Information/)> (accessed  
7 12 December 2016).
- 8 [USACE] U.S. Army Corps of Engineers. 2016d. "Davis Pond Freshwater Diversions" New  
9 Orleans District. Available at <[http://www.mvn.usace.army.mil/About/Projects/Davis-Pond-  
10 Freshwater-Diversion/](http://www.mvn.usace.army.mil/About/Projects/Davis-Pond-Freshwater-Diversion/)> (accessed 12 December 2016).
- 11 [USACE] U.S. Army Corps of Engineers. 2016e. "St. Charles Parish Urban Flood Control" New  
12 Orleans District. Available at  
13 <<http://www.mvn.usace.army.mil/About/Projects/SCPFloodCont.aspx>> (accessed  
14 12 December 2016).
- 15 Wastebits 2016a. KV Enterprises LLC C&D Landfill. Available at  
16 <<https://wastebits.com/location/kv-enterprises-llc-c-d-landfill>> (accessed 22 December 2016).
- 17 Wastebits 2016b. River Birch Landfill LLC. Available at <[https://wastebits.com/location/river-  
18 birch-landfill-llc](https://wastebits.com/location/river-birch-landfill-llc)> (accessed 22 December 2016).
- 19 Wastebits 2016c. Jefferson Parish Kelven Tract Landfill. Available at  
20 <<https://wastebits.com/location/jefferson-parish-kelven-tract-landfill>> (accessed  
21 22 December 2016).
- 22 Williams 2016. Available at <[http://investor.williams.com/press-release/williams/williams-  
23 partners-announces-process-explore-monetization-geismar-olefins-faci](http://investor.williams.com/press-release/williams/williams-partners-announces-process-explore-monetization-geismar-olefins-faci)> (accessed  
24 28 November 2016).
- 25 Yuhuang Chemical. 2016. "Governor Jindal and Shandong Yuhuang Chemical Chairman  
26 Jinshu Wang Highlight Groundbreaking for \$1.85 Billion Methanol Project in Louisiana."  
27 September 15. Available at <[http://yci-us.com/2015/09/9-18-15-governor-jindal-and-shandong-  
28 yuhuang-chemical-chairman-jinshu-wang-highlight-groundbreaking-for-1-85-billion-methanol-  
29 project-in-louisiana/](http://yci-us.com/2015/09/9-18-15-governor-jindal-and-shandong-yuhuang-chemical-chairman-jinshu-wang-highlight-groundbreaking-for-1-85-billion-methanol-project-in-louisiana/)> (accessed 19 September 2016).



1  
2  
3  
4  
5

**APPENDIX F**  
**U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF**  
**SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR**  
**WATERFORD STEAM ELECTRIC STATION, UNIT 3 IN SUPPORT OF**  
**LICENSE RENEWAL APPLICATION REVIEW**



## **F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident Mitigation Alternatives for Waterford Steam Electric Station, Unit 3 in Support of License Renewal Application Review**

### **F.1 Introduction**

Entergy Louisiana, LLC and Entergy Operations, Inc. (Entergy or the applicant) submitted an assessment of severe accident mitigation alternatives (SAMAs) for Waterford Steam Electric Station (WF3), in Section 4.15 and Attachment D of the Environmental Report (ER) (Entergy 2016). This assessment was based on the most recent revision to the WF3 probabilistic safety assessment (PSA), including an internal events model and a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS) computer code, as well as insights from the WF3 individual plant examination (IPE) (Entergy 1992), the WF3 individual plant examination of external events (IPEEE) (Entergy 1995), the WF3 internal flooding PSA and the updated WF3 fire PSA from the National Fire Protection Association (NFPA) 805 transition license amendment request (LAR) (Entergy 2015a). In identifying and evaluating potential SAMAs, Entergy considered SAMAs that addressed the major contributors to core damage frequency (CDF), population dose at WF3 and offsite economic cost as well as insights and SAMA candidates found to be potentially cost beneficial from the analysis of other pressurized water reactor (PWR) nuclear power generating stations. Entergy initially identified a list of 201 potential SAMAs. This list was reduced to 75 unique SAMA candidates by eliminating SAMAs that (a) were not applicable to WF3, (b) had already been implemented at WF3, or (c) were combined into a more comprehensive or plant-specific SAMA. Of the 75 unique SAMA candidates remaining, Entergy concluded in the ER that 12 candidate SAMAs are potentially cost beneficial.

As a result of the review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) staff issued requests for additional information (RAIs) to Entergy by letters dated November 22, 2016 (NRC 2016a) and March 28, 2017 (NRC 2017). Key questions involved:

- changes and updates to the Level 1 PSA model that most affect CDF
- peer review of the PSA and disposition of associated findings
- the process used to assign release categories to containment event tree (CET) end states for incorporating Level 1 results into the Level 2 analysis
- selection of representative sequences for each release category in the Level 2 analysis
- review of the internal flood and fire PSA for identification of candidate SAMAs
- selection of input parameters to the Level 3 analysis
- further information on the cost-benefit analysis of several specific candidate SAMAs and low-cost alternatives

Entergy submitted additional information by letters dated February 7, 2017 (Entergy 2017a), and April 21, 2017 (Entergy 2017b). In response to the staff RAIs, Entergy provided further information on:

- the history and key changes to PSA models
- the resolution of peer review comments

## Appendix F

- 1 • the development of the Level 2 containment release model
- 2 • the reasons for differences between CDF values given in the submittal
- 3 • the results of an updated cost-benefit analysis based on resolution of CDF
- 4 differences
- 5 • the impact of new information on external events
- 6 • the basis for inputs to the Level 3 analysis
- 7 • the cost of various SAMAs and potential low-cost alternatives

8 Entergy's responses addressed the staff's concerns and resulted in the identification of six  
9 additional potentially cost-beneficial SAMAs. In addition, Entergy determined that one SAMA  
10 determined to be cost beneficial in the ER was no longer cost beneficial. Further, three SAMAs  
11 related to internal fire risk determined to be cost beneficial in the ER were removed from the  
12 revised list of cost-beneficial SAMAs as they have already been implemented.

13 An assessment of the SAMAs for WF3 is presented below. Guidance for the SAMA analysis  
14 submittal is provided in Nuclear Energy Institute (NEI) 05-01A, "Severe Accident Mitigation  
15 Alternatives (SAMA) Guidance Document" which is endorsed in Regulatory Guide 4.2,  
16 Supplement 1 (NEI 2005).

### 17 **F.2 Estimate of Risk for WF3**

18 Section F.2.1 summarizes Entergy's estimates of offsite risk at WF3. The summary is followed  
19 by the staff's review of Entergy's risk estimates in Section F.2.2.

### 20 **F.3 Entergy's Risk Estimates**

21 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA  
22 analysis: (1) the WF3 Level 1 and 2 PSA model, which is an updated version of the IPE  
23 (Entergy 1992), and (2) a supplemental analysis of offsite consequences and economic impacts  
24 (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The scope of  
25 the WF3 PSA used for the SAMA analysis (2015 R5) does not include external events or  
26 internal flooding events.

27 The WF3 internal events CDF is approximately  $1.1 \times 10^{-5}$  per reactor-year as determined from  
28 quantification of the Level 1 PSA model. This value was used as the baseline CDF in the SAMA  
29 evaluations (Entergy 2016). The CDF is based on the risk assessment for internally initiated  
30 events, which did not include internal flooding. Entergy did not explicitly include the contribution  
31 from external events within the WF3 risk estimates; however, it did account for the potential risk  
32 reduction benefits associated with external events and internal flooding events by multiplying  
33 the estimated benefits for internal events by a factor of 3.02. This was subsequently increased  
34 to 3.57 as a result of NRC staff RAIs (Entergy 2017a). This is discussed further in  
35 Sections F.2.2 and F.6.2.

36 The breakdown of CDF by initiating events is provided in Table F-1. As shown in this table,  
37 loss of offsite power (LOOP) and loss of 4.16kV bus 3B3-S are the dominant contributors to the  
38 CDF. While not listed explicitly in Table F-1 because they can occur as a result of multiple  
39 initiators, Entergy stated that station blackouts (SBO) contribute about 34 percent ( $3.6 \times 10^{-6}$  per  
40 reactor-year) of the total CDF and anticipated transients without scram (ATWS) contribute about  
41 1.4 percent ( $1.5 \times 10^{-7}$  per reactor-year) to the total internal events CDF (Entergy 2016).

1 The full Level 2 WF3 PSA model that forms the basis for the SAMA evaluation was developed  
 2 based on the 2015 internal events Level 1 model. The WF3 Level 2 model includes two types  
 3 of considerations: (1) a deterministic analysis of the physical processes for a spectrum of  
 4 severe accident progressions, and (2) a probabilistic analysis component in which the likelihood  
 5 of the various outcomes are assessed. The Level 2 model uses containment event trees  
 6 (CETs) containing both phenomenological and systemic events. Each of the Level 1 core  
 7 damage sequences is then evaluated by a CET to assess the frequency of various containment  
 8 release modes based on the operational configurations of the WF3 containment safeguard  
 9 systems.

10 **Table F–1. Waterford Steam Electric Station Core Damage Frequency (CDF) for Internal**  
 11 **Events**

Initiating Event	CDF (per year)	% CDF Contribution
Loss of Offsite Power Initiator	$4.4 \times 10^{-6}$	42
Loss of 4.16 kV Bus 3B3-S	$2.5 \times 10^{-6}$	24
Small Loss-of-Coolant Accident (LOCA)	$9.5 \times 10^{-7}$	9
Loss of 4.16 kV Bus 3A3-S	$8.8 \times 10^{-7}$	8
Inadvertent Open Relief Valve	$4.8 \times 10^{-7}$	5
Turbine Trip (General Transient)	$2.0 \times 10^{-7}$	2
Reactor Trip (General Transient)	$1.2 \times 10^{-7}$	1
Other Initiating Events(1)	$9.3 \times 10^{-7}$	9
<b>Total CDF (Internal Events)</b>	<b><math>1.1 \times 10^{-5}</math></b>	<b>100</b>

(1) Multiple initiating events with each contributing less than 1 percent

12 The CET considers the influence of physical and chemical processes on the integrity of the  
 13 containment and on the release of fission products once core damage has occurred. The  
 14 quantified CET sequences are binned into a set of end states that are subsequently grouped  
 15 into 13 release categories (or release modes) that provide the input to the Level 3 consequence  
 16 analysis. The frequency of each release category was obtained by summing the frequency of  
 17 the individual accident progression CET endpoints binned into the release category. Source  
 18 terms were developed for the release categories using the results of Modular Accident Analysis  
 19 Program (MAAP) Version 4.0.6 computer code calculations. From these results, source terms  
 20 were chosen to be representative of the release categories. The results of this analysis for WF3  
 21 are provided in Table D.1–10 of ER Attachment D (Entergy 2016) and in an updated Table  
 22 D.1- 10 resulting from responses to NRC staff RAIs as discussed below (Entergy 2017a).

23 Entergy computed offsite consequences for potential releases of radiological material using the  
 24 MACCS, Version 3.10.0 code and analyzed exposure and economic impacts from its  
 25 determination of offsite and onsite risks. Inputs for these analyses include plant-specific and  
 26 site-specific input values for core radionuclide inventory, source term and release  
 27 characteristics, site meteorological data, projected population distribution and growth within a  
 28 50-mile (mi) (80-kilometer (km)) radius, emergency response evacuation modeling, and local  
 29 economic data. Radionuclide inventory in the reactor core is based on a plant-specific  
 30 evaluation and corresponds to 100.5 percent of the extended power uprate (EPU) power of  
 31 3,716 megawatts thermal (Mwt) (Entergy 2016, Attachment D). The estimation of onsite  
 32 impacts (in terms of cleanup and decontamination costs and occupational dose) is based on

1 guidance in NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook*  
 2 (NRC 1997a). Additional details on the input parameter assumptions are discussed below.

3 In a revised Table D.1-12 to the ER, the applicant estimated the dose risk to the population  
 4 within 80 km (50 mi) of the WF3 site to be 0.171 person-Sieverts (Sv) per year (17.1 person-rem  
 5 per year) (Entergy 2017a). The NRC staff calculated revised population dose risk (PDR) and  
 6 offsite economic cost risk (OECR) contributions by containment release mode based on the  
 7 revised Table D.1-12 provided in the RAI response and summarized them in Table F-2. High  
 8 releases (H/E and H/I) provide the greatest contribution, totaling approximately 96 percent of the  
 9 PDR and 99 percent of the OECR for all timings.

10 **Table F-2. Base Case Mean Population Dose Risk and Offsite Economic Cost Risk**  
 11 **for Internal Events**

Release Mode ID <sup>(2)</sup>	Population Dose Risk <sup>(1)</sup>		Offsite Economic Cost Risk		
	Frequency (per year)	person- rem/yr	% Contribution	\$/yr	% Contribution
Intact	3.7×10 <sup>-6</sup>	4.7×10 <sup>-1</sup>	2.8%	4.6×10 <sup>2</sup>	0.3%
H/E	1.9×10 <sup>-6</sup>	6.0	35.1%	5.4×10 <sup>4</sup>	33.3%
H/I	4.8×10 <sup>-6</sup>	10	61.0%	1.1×10 <sup>5</sup>	65.7%
M/E	2.7×10 <sup>-8</sup>	4.8×10 <sup>-2</sup>	0.3%	4.3×10 <sup>2</sup>	0.3%
M/I	1.3×10 <sup>-7</sup>	1.2×10 <sup>-1</sup>	0.7%	6.1×10 <sup>2</sup>	0.4%
M/L	1.8×10 <sup>-8</sup>	2.1×10 <sup>-2</sup>	0.1%	1.6×10 <sup>2</sup>	0.1%
L/I	2.4×10 <sup>-9</sup>	1.4×10 <sup>-3</sup>	<0.1%	4.2	<0.1%
L/L	5.6×10 <sup>-10</sup>	2.3×10 <sup>-4</sup>	<0.1%	4.4×10 <sup>-1</sup>	<0.1%
L/LL	3.9×10 <sup>-10</sup>	2.5×10 <sup>-4</sup>	<0.1%	1.1	<0.1%
<b>Total</b>	<b>1.1×10<sup>-5</sup></b>	<b>17.1</b>	<b>100%</b>	<b>1.6×10<sup>5</sup></b>	<b>100%</b>

(1) Unit Conversion Factor: 1 Sv = 100 rem

(2) Release Mode Nomenclature (Magnitude/Timing)

Magnitude:

High (H) – Greater than 10 percent release fraction for Cesium Iodide

Moderate (M) – 1 to 10 percent release fraction for Cesium Iodide

Low (L) – 0.1 to 1 percent release fraction for Cesium Iodide

Low (LL) – Less than 0.1 percent release fraction for Cesium Iodide

Intact – Negligible release fraction for Cesium Iodide

Timing:

Early (E) – Less than 4 hours from declaration of general emergency

Intermediate (I) – 4 to 24 hours from declaration of general emergency

Late (L) – Greater than 24 hours from declaration of general emergency

### 12 F.3.2 Review of Entergy's Risk Estimates

13 Entergy's determination of offsite risk at WF3 is based on three major elements of analysis:

- 14 (1) the Level 1 and 2 risk models that form the bases for the 1992 IPE submittal  
 15 (Entergy 1992), and the external event analyses of the 1995 IPEEE submittal  
 16 (Entergy 1994)
- 17 (2) the major modifications to the IPE model that have been incorporated into the WF3  
 18 2015 (R5) PSA; and with a standalone updated internal floods model and separate  
 19 internal fire model (Entergy 2015a)
- 20 (3) the combination of offsite consequence measures from MACCS analyses with  
 21 release frequencies and radionuclide source terms from the Level 2 PSA model

1 Each analysis element was reviewed to determine the acceptability of Entergy's risk estimates  
2 for the SAMA analysis, as summarized further in this section.

### 3 *F.3.2.1 Internal Events CDF Model*

4 The internal events CDF value from the 1992 IPE ( $1.7 \times 10^{-5}$  per reactor-year) is below the  
5 average of the values reported for other Combustion Engineering (CE) PWR units. Figure 11.6  
6 of NUREG-1560, Volume 2, *Individual Plant Examination Program: Perspectives on Reactor*  
7 *Safety and Plant Performance Parts 2-5, Final Report* (NRC 1997b) shows that the IPE-based  
8 total internal events CDF for CE plants ranges from  $1 \times 10^{-5}$  per year to  $2 \times 10^{-4}$  per year, with an  
9 average CDF for the group of  $7 \times 10^{-5}$  per year. Other plants have updated the values for CDF  
10 subsequent to the IPE submittals to reflect modeling and hardware changes. The internal  
11 events CDF result for WF3 used for the SAMA analysis ( $1.1 \times 10^{-5}$  per year) is in the range for  
12 other similar plants.

13 From its review of the IPE submittal, the staff concluded that the licensee's IPE process was  
14 capable of identifying the most likely severe accidents and severe accident vulnerabilities, and  
15 therefore, that the WF3 IPE met the intent of Generic Letter (GL) 88-20 (NRC 1988). Although  
16 no vulnerabilities were identified in the IPE, eight improvements were identified by Entergy. The  
17 ER addressed the status of each of these improvements, which are discussed further in  
18 Section F.3 (Entergy 2016).

19 There have been four major revisions to the IPE Level 1 model since the 1992 IPE submittal. A  
20 listing of the changes made to the WF3 PSA since the original IPE submittal was provided in the  
21 ER (Entergy 2016) is summarized in Table F-3 and includes information provided in response  
22 to an NRC staff RAI (Entergy 2017a). A comparison of internal events CDF between the 1992  
23 IPE and the current PSA model indicates an overall slight decrease in the total CDF (from  
24  $1.7 \times 10^{-5}$  per reactor-year to  $1.1 \times 10^{-5}$  per reactor-year).

25 The NRC staff noted in an RAI that ER Section D.1.4 indicates that there is approximately a  
26 factor of 3 increase in CDF and a factor of 3 decrease in large early release frequency (LERF)  
27 from the peer reviewed PSA 2009 (R4) to PSA 2015 (R5) used for the SAMA analysis and  
28 requested Entergy to discuss the major reasons for these changes. In response to the RAI,  
29 Entergy indicated that the most significant change causing the increase in CDF was the revision  
30 of the battery depletion modeling to include procedural direction to strip batteries to allow for  
31 extended battery life (Entergy 2017a). The decrease in LERF was due to removal of  
32 conservatism in the LERF model including: removal of dependency to refill nitrogen  
33 accumulators (extending the credited operation time from 10 hours to 24 hours), addition of  
34 containment cooling system fan coil isolation valves into the model, revision of modeling  
35 associated with refill of the condensate storage pool (CSP) to reflect current procedural  
36 guidance, and updated human failure events (Entergy 2017a).

37 In response to an NRC staff RAI regarding the freeze date for the PSA model and model  
38 changes made since the freeze date, Entergy indicated that the WF3 2015 (R5) model reflects  
39 the WF3 design, component failure, and unavailability data as of November 1, 2015. Entergy  
40 also identified three plant changes made since the freeze date that would potentially have an  
41 impact on the SAMA analysis: (1) modifications made to implement FLEX (i.e., diverse and  
42 flexible coping strategies, which do not affect the WF3 design basis but primarily affect the  
43 operational response to an extended loss of alternating current (AC) power), (2) the temporary  
44 emergency diesel generator (EDG), and (3) the proceduralization of local manual control of  
45 emergency feedwater (EFW) pump turbine and flow control valves in a more prominent way.  
46 Entergy indicated that these changes would serve to reduce the SBO contribution to core  
47 damage and release categories. There were no fuel cycle changes that might impact the SAMA

1 analysis (Entergy 2017a). Since these changes will reduce the CDF and release frequencies,  
 2 there is no additional potentially cost beneficial SAMAs

3 The NRC staff noted in an RAI that the revised Attachment W to the WF3 NFWA 805 LAR  
 4 (Entergy 2015a) gives internal events CDF and LERF ( $6.5 \times 10^{-6}$  per reactor-year and  $8.7 \times 10^{-8}$   
 5 per reactor-year, respectively) that are approximately 60 percent of the values given for the  
 6 2015 (R5) PSA used for the SAMA analysis. In response to the RAI, Entergy discussed the  
 7 reasons for these differences and the impact on the SAMA analysis. Entergy indicated that the  
 8 internal events CDF value given in the NFWA LAR is from a prior interim model revision that did  
 9 not include the revision of the battery depletion modeling, which provides procedural direction to  
 10 strip batteries to extend battery life. The prior interim LERF model also had a slightly lower  
 11 value due to the update in the steam generator tube rupture (SGTR) sequences, which are  
 12 binned as LERF and which saw an increase due to the change in values of thermal-induced  
 13 SGTR and pressure-induced SGTR failure probabilities. Entergy concluded that the 2015 (R5)  
 14 PSA model used for the SAMA analysis best represents WF3 for license renewal purposes  
 15 (Entergy 2017a).

16 **Table F–3. Summary of Major PSA Models and Corresponding CDF and LERF Results**

PSA Model	Summary of Significant Changes from Prior Model	CDF (per year)	LERF (per year)
1992 (IPE-R1)		$1.7 \times 10^{-5}$	$1.5 \times 10^{-6}$
2000 (R2)	<ul style="list-style-type: none"> <li>• Removed asymmetries existing in the model for standby components and incorporated missed support functions</li> <li>• Added other direct current (DC) control power dependencies</li> <li>• Incorporated changes from a plant modification, which moved some loads from the AB battery to the turbine building battery</li> <li>• Updated emergency diesel generator (EDG) fail-to-run and start rates</li> <li>• Updated LOOP recovery analysis</li> </ul>	$2.5 \times 10^{-5}$	$5.3 \times 10^{-7}$
2003 (R3)	<ul style="list-style-type: none"> <li>• Included interfacing system loss-of-coolant accident (ISLOCA) and ATWS sequences</li> <li>• Improved reactor coolant pump (RCP) seal LOCA modeling</li> <li>• Updated human reliability analysis</li> <li>• Updated generic and plant-specific failure rates</li> <li>• Improved LOOP recovery analysis</li> <li>• Improved common cause failure analysis</li> <li>• Updated human reliability analysis and LOOP analyses to reflect the EPU</li> <li>• Added hot leg Injection to mitigate medium and large LOCAs after the EPU</li> <li>• Added primary safety valve LOCA initiating event</li> <li>• Updated the Level 1 containment heat removal logic</li> </ul>	$6.8 \times 10^{-6}$	$2.4 \times 10^{-7}$

PSA Model	Summary of Significant Changes from Prior Model	CDF (per year)	LERF (per year)
2009 (R4)	<ul style="list-style-type: none"> <li>• Updated initiating event data for plant operating experience with Bayesian updates using NUREG/CR-5750</li> <li>• Added safety injection (SI) valve rupture initiating events</li> <li>• Added instrument air system initiating event</li> <li>• Updated ATWS system interactions and failure propagations</li> <li>• Added initiating event %FVIVCC to the auxiliary feedwater (AFW) system modeling</li> <li>• Updated the LOOP logic to address both the consequential LOOP and the LOOP frequency for conditions such as severe weather, grid degradation, and switchyard work</li> <li>• Updated generic failure rates and component boundaries using NUREG/CR-6928</li> <li>• Added logic to the dry and wet cooling tower fans to allow for out of service selections</li> <li>• Added emergency feedwater (EFW) recirculation line and component failures</li> <li>• Added common cause failures for the diesel generator fuel oil transfer pumps</li> <li>• Added initiating event %T6OC, for a line break outside of containment</li> <li>• Addressed most peer review and expert panel model comments</li> </ul>	4.0×10 <sup>-6</sup>	4.9×10 <sup>-7</sup>

Appendix F

PSA Model	Summary of Significant Changes from Prior Model	CDF (per year)	LERF (per year)
2015 (R5)	<ul style="list-style-type: none"> <li>Resolved peer review findings</li> <li>Updated success criteria associated with the number of dry cooling towers and wet cooling towers required to mitigate various accident sequences</li> <li>Developed WF3-specific LOCA break sizes and associated frequencies</li> <li>Updated generic and plant-specific failure rate data</li> <li>Updated common cause failure (CCF) event probabilities</li> <li>Updated initiator frequencies</li> <li>Updated human failure events</li> <li>Removed heating, ventilation, and cooling (HVAC) dependencies from the switchgear rooms and some pump rooms based on room heat-up calculations</li> <li>A main control room notebook and model was developed and included in the integrated model</li> <li>Removed dependency to refill nitrogen accumulators by extending credited operation time from 10 hours to 24 hours</li> <li>Revised modeling of refill of the condensate storage pool (CSP) to reflect current procedural guidance</li> <li>Added containment cooling system fan coil isolation valves</li> <li>Revised battery depletion modeling to credit new procedural direction to strip batteries to extend battery life</li> </ul>	<ul style="list-style-type: none"> <li><math>1.1 \times 10^{-5}</math></li> </ul>	<ul style="list-style-type: none"> <li><math>1.4 \times 10^{-7}</math></li> <li>See Note<sup>(1)</sup></li> </ul>

<sup>(1)</sup>Note: This LERF value is from the 2015 (R5) simplified LERF model and is different from the value given in Table D.1–12 for the High Early (H/E) release category, which was obtained from the full Level 2 model (Entergy 2016). Refer to additional discussion in Section F.2.2.3

1 The NRC staff considered the peer reviews and other assessments performed for the WF3 PSA  
2 and the potential impact of the review findings on the SAMA evaluation. The most relevant of  
3 these is the August 2009 peer review of the WF3 2009, Revision 4 model against the  
4 requirements of the American Society of Mechanical Engineers (ASME) Probabilistic Risk  
5 Assessment (PRA) standard and the requirements of Regulatory Guide 1.200, Revision 1  
6 (NRC 2007). This peer review was performed using the process defined in NEI 05-04  
7 (NEI 2008). The peer review concluded that approximately 9 percent of the applicable PRA  
8 standard supporting requirements (SRs) were met at Capability Category I while 10 percent of  
9 the SRs were rated as not met (Entergy 2016).

10 In response to an NRC staff RAI to discuss any findings from the peer review that remain open  
11 in the PSA models used for the SAMA analysis and their potential impact on the SAMA  
12 analysis, Entergy indicated that three findings from the 2009 peer review, unrelated to internal  
13 flooding, remain open in the PSA models used for the SAMA analysis and discussed these

1 findings and their potential impact on the SAMA analysis. Two of the open findings were  
2 identified to be documentation issues with no impact on the results of the analysis. The third  
3 open finding involved the use of conditional failure probability rather than independent failure  
4 probability for two check valves in series in the interfacing system loss-of-coolant accident  
5 (ISLOCA) analysis. Entergy indicated that the use of the conditional failure probability had an  
6 insignificant impact on the SAMA analysis due to the very small contribution of ISLOCAs to the  
7 PSA result (Entergy 2017a).

8 The response to this same RAI summarizes eight open findings related to the internal flooding  
9 analysis. As indicated above, the WF3 SAMA analysis includes internal flooding by including it  
10 in the external events multiplier. Hence, the discussion of the disposition of the peer review  
11 comments related to the internal flooding model is included below in Section F.2.2.2.

12 In response to an NRC staff RAI to discuss the scope of the 2009 WF3 internal events peer  
13 review and the potential impact on the SAMA analysis of any elements that were not assessed,  
14 Entergy indicated that the peer review was a full scope review except for configuration control  
15 requirements and eight high-level requirements (HLRs). The configuration control requirements  
16 were addressed in a prior peer review of another Entergy plant and, since WF3 utilized these  
17 corporate procedures, no further review was considered necessary. The eight HLRs not within  
18 the scope of the 2009 WF3 peer review (two initiating event (IE) HLRs and six human reliability  
19 analysis (HRA) HLRs) were covered by an earlier peer review and did not need revisiting.  
20 Findings from the earlier peer review of these HLRs were carried over into the list of findings  
21 from the 2009 peer review. Entergy states that these findings have been closed, and no  
22 findings related to these HLRs remain open in the PSA models used for the SAMA analysis.  
23 Thus, there is no impact on the results of the SAMA analysis from this carry-over review  
24 (Entergy 2017a).

25 In response to an NRC staff RAI, Entergy confirmed that no changes have been made to the  
26 WF3 model used in the SAMA analysis since the peer review that would constitute an upgrade  
27 as defined by the PRA standard, ASME/ANS RA-Sa-2009 (ASME 2009), as endorsed by  
28 RG 1.200, Revision 2 (Entergy 2017a).

29 In response to an RAI, Entergy briefly described the process and procedures for assuring  
30 technical quality of PSA updates since the peer review. The PSA maintenance and update  
31 procedure describes the process for maintaining the PSA models current with the as-built and  
32 as operated plants and gives specific instructions for identifying model change requests,  
33 documenting those requests, and incorporating those requests into the PSA model. The PSA  
34 analysts performing model updates are experienced, trained professionals, and each change is  
35 reviewed by a second, experienced, trained PSA analyst. In addition, as described above,  
36 expert panel reviews are used to enhance the technical quality of the PSA updates. Changes  
37 from the expert panel review for an update are immediately incorporated into that update of  
38 the model (Entergy 2017a).

39 Given that the WF3 internal events PSA model has been peer reviewed and the peer review  
40 findings were all addressed, that Entergy has in place procedures to assure the technical quality  
41 of the PSA, and that Entergy has satisfactorily addressed NRC staff questions regarding the  
42 PSA, the NRC staff concludes that the internal events Level 1 PSA model is of sufficient quality  
43 to support the SAMA evaluation.

#### 44 *F.3.2.2 External Events*

45 NEI 05-01A allows the use of an external events multiplier on the maximum benefit and on the  
46 upper bound estimated benefits for individual SAMA candidates during the Phase II screening if  
47 external events are not included in the PSA used for SAMA analysis (NEI 2005). As stated

1 above, the WF3 PSA used for the SAMA analysis does not include external events. The SAMA  
2 submittal cites the fire PSA used in the NFWA 805 transition LAR to address the CDF due to fire  
3 events, a standalone analysis of internal floods to address the CDF due to internal floods, a  
4 separate estimate of seismic events CDF from Energy's integrated leak rate test (ILRT) interval  
5 extension request and the WF3 IPEEE to assess the impact of other (high winds, floods, and  
6 other) external events.

7 The final WF3 IPEEE was submitted in 1995 (Entergy 1995), in response to Supplement 4 of  
8 GL 88–20 (NRC 1991a). No fundamental weaknesses or vulnerabilities to severe accident risk  
9 in regard to the external events were identified in the WF3 IPEEE. However, five insights, three  
10 related to seismic events, one related to fire events and one related to external floods, were  
11 identified. All have been implemented. In the NRC staff's safety evaluation (SE) of the WF3  
12 IPEEE (NRC 2000), the staff stated that (1) the licensee's IPEEE process is capable of  
13 identifying the most likely severe accidents and severe accident vulnerabilities from external  
14 events, and (2) the WF3 IPEEE has met the intent of Supplement 4 to GL 88-20.

### 15 *Seismic Events*

16 As discussed in the ER, the WF3 IPEEE seismic analysis was a reduced scope seismic margins  
17 assessment (SMA) following NRC guidance (NRC 1991a, 1991b). The SMA approach is  
18 deterministic in nature and does not result in probabilistic risk information.

19 The ER indicated that there were three unresolved issues at the completion of the IPEEE  
20 walkdowns. Entergy stated that the three issues, loose items in the control room, station air  
21 pipe not meeting clearance requirements, and storage of temporary equipment, are not  
22 significant to seismic risk and that followup actions were taken to conform to standard practice  
23 in seismic design.

24 Following the accident at the Fukushima Dai-ichi Nuclear Power Plant, Entergy conducted  
25 additional seismic walkdowns. The NRC staff concluded that the licensee, through the  
26 implementation of the walkdown guidance activities and, in accordance with plant processes  
27 and procedures, verified the plant configuration with the current seismic licensing basis;  
28 addressed degraded, nonconforming, or unanalyzed seismic conditions; and verified the  
29 adequacy of monitoring and maintenance programs for protective features. Furthermore, the  
30 NRC staff notes that no immediate safety concerns were identified (NRC 2014).

31 While the IPEEE did not provide a seismic CDF, the WF3 ILRT interval extension request  
32 (Entergy 2014a) provided a calculated seismic CDF value  $6.9 \times 10^{-7}$  per year. This value was  
33 used in the SAMA analysis for the seismic contribution to the external events multiplier  
34 discussed below.

35 In response to NRC staff RAIs on the WF3 NFWA 805 transition LAR, Entergy provided an  
36 assessment of the seismic CDF to be  $9.0 \times 10^{-7}$  per year, which is higher than that given in the  
37 ILRT interval extension LAR (Entergy 2014b). Furthermore, following the accident at the  
38 Fukushima Dai-ichi Nuclear Power Plant, new seismic hazard estimates have been developed  
39 for most nuclear power plant sites in the United States. Based on this information, EPRI  
40 produced updates to the Generic Issue (GI)-199 seismic CDFs (EPRI 2014). Because of the  
41 availability of this more recent information, Entergy was asked in an RAI to update the  
42 NFWA 805 transition LAR seismic CDF to be based on the new post-Fukushima hazard  
43 estimates, and to discuss the impact of the use of this revised seismic CDF on the WF3 SAMA  
44 analysis. In response to the RAI, Entergy re-evaluated the WF3 seismic CDF using the new  
45 post-Fukushima hazard estimates in the same manner as was done in the NFWA 805 RAI  
46 response, which resulted in a revised seismic CDF of  $6.5 \times 10^{-6}$  per year. Entergy used this  
47 revised seismic CDF to revise the external events multiplier, which is discussed further below.

1 ER Table D.2–2, which provides the results of the SAMA benefit calculations, was also updated  
2 to use the revised multiplier (Entergy 2017a).

3 The NRC staff notes that Entergy's response to the Fukushima Near-Term Task Force  
4 Recommendation 2.1 for a Seismic Hazard and Screening Report (Entergy 2014c) was found  
5 acceptable, confirming the licensee's conclusion that the WF3 ground motion response  
6 spectrum (GMRS) for the Waterford site is bounded by the safe shutdown earthquake (SSE) in  
7 the 1 to 10 Hz range subject to further evaluation of high-frequency accelerations where the  
8 GMRS exceeds the SSE in a portion of the frequency range above 10 Hz. As such, a seismic  
9 risk evaluation is not merited (NRC 2015a). Furthermore, the high frequency exceedance issue  
10 was subsequently resolved (NRC 2016b).

11 Considering that the revised seismic CDF is based on the new post-Fukushima seismic hazard  
12 estimates, that the WF3 GMRS is bounded by the SSE, and that the high-frequency  
13 exceedance issue has been resolved, the NRC staff concludes that the seismic CDF, as  
14 discussed above, is acceptable for use in the development of the external events multiplier.

### 15 *Fire Events*

16 As discussed in the ER, the WF3 IPEEE included an internal fire analysis employing EPRI's  
17 Fire-Induced Vulnerability Evaluation (FIVE) methodology (EPRI 1992). However, the IPEEE  
18 fire analysis has been superseded by the WF3 fire PSA created for transition to NFPA 805,  
19 which utilizes guidance in NUREG/CR-6850 (NRC 2005). Since the WF3 fire PSA model is not  
20 fully integrated with the most recent Level 2 and 3 analyses, it wasn't used directly for the SAMA  
21 analysis to estimate the risk reduction of individual SAMAs. Rather, the WF3 fire PSA was used  
22 in the SAMA analysis for determining the fire contribution to the external events multiplier. The  
23 updated NFPA 805 fire PSA gives a total fire CDF of  $1.8 \times 10^{-5}$  per year (Entergy 2015a).

24 The technical adequacy of the WF3 fire PSA model was evaluated by a full-scope peer review  
25 in November 2010 and followup focused-scope peer reviews in September 2012 and  
26 May 2013. Subsequently, the results of these reviews and the fire PSA itself were reviewed by  
27 the NRC staff during its review of the WF3 NFPA 805 transition LAR. The NRC staff concluded  
28 that the licensee has demonstrated that the fire PSA meets the guidance in Regulatory  
29 Guide 1.200, Revision 2, and that, subject to completion of the implementation items described  
30 in the LAR, the fire PSA will be acceptable to support the WF3 NFPA 805 transition  
31 (NRC 2016c).

32 Entergy was asked in an RAI to provide an assessment of the impact of the recent changes to  
33 the internal events model (discussed in Section F.2.2.1 above) on the results of the fire PSA  
34 used in the SAMA analysis and of the resulting impact on the SAMA analysis. Entergy indicated  
35 that the changes that led to the increase in internal events CDF and LERF (the battery depletion  
36 modeling to include procedural direction to shed batteries to allow for extended battery life for  
37 CDF and the induced SGTR change for LERF) would not have such a significant impact on the  
38 fire PSA model results because those fire model results are driven by fire-specific factors.  
39 Entergy concluded that the use of the fire PSA CDF results from the WF3 NFPA LAR analysis is  
40 appropriate for determining the external events multiplier in the SAMA analysis (Entergy 2017a).  
41 Based on its review of the important contributors to the WF3 fire PSA results, the NRC staff  
42 agrees with this conclusion.

43 While no vulnerabilities with respect to fire were identified, the IPEEE submittal identifies two  
44 plant improvements related to reducing the impact of fires. These improvements, a revised  
45 transient combustible storage procedure and adding fire wrap (Entergy 1995) to the B Chilled  
46 Water cables in the vicinity of the A Chiller, have been implemented (Entergy 2016).

## Appendix F

1 Considering that the WF3 fire PSA model has been peer reviewed and reviewed by the NRC  
2 staff as part of the approved NFPA 805 transition LAR application, the staff concludes that the  
3 fire PSA model, as discussed above, is appropriate for determining the external events  
4 multiplier in the SAMA and provides an acceptable basis for identifying and evaluating the  
5 benefits of SAMAs.

### 6 *Internal Floods*

7 The ER indicates that an internal flooding analysis was performed as part of the IPE and that an  
8 updated analysis was performed with a number of significant changes, including how small  
9 diameter lines are handled, the assumed duration of releases, the handling of drains and turbine  
10 building floods, the characterization of rupture frequencies and sizes, and elimination of any  
11 screening of potential core damage scenarios by rupture frequency. It is stated that these  
12 changes allowed the internal flooding analysis to satisfy the requirements in the ASME Standard  
13 and Regulatory Guide 1.200. The CDF due to internal flooding from this analysis,  $2.5 \times 10^{-6}$  per  
14 reactor-year, was used in the SAMA analysis for the internal flooding contribution to the external  
15 events multiplier. Entergy indicated that the multiplier approach was used because the current  
16 internal flooding model has not been integrated with the current internal events model or the  
17 Level 2 and 3 models.

18 Entergy was asked in an RAI to provide further information on the internal flooding analysis,  
19 including consistency with the system modeling in the 2015 (R5) PSA and the process used to  
20 ensure the technical adequacy of the internal flooding analysis. Entergy indicated that the  
21 contribution the flood scenarios make to the CDF was calculated by manipulating event trees  
22 and data prepared in quantifying other accident scenarios in the 2003 (R3) PSA model. The  
23 sequence probabilities were then combined with initiating event (flooding) frequencies to  
24 determine the contribution of internal flooding to the CDF. The differences between the  
25 2003 (R3) PSA model and the 2015 (R5) PSA model are described in Sections D.1.4.3 and  
26 D.1.4.4 of the Environmental Report, and are summarized in Table F-3 above. As described  
27 above, the increase in CDF between the two models was predominantly due to a revision of the  
28 battery depletion modeling to include procedural direction to strip batteries to allow for extended  
29 battery life. This modeling increased the CDF from sequences initiated by a LOOP. Entergy  
30 concluded in the RAI response that since the internal flooding CDF comes from sequences  
31 initiated by internal floods, it would not be significantly impacted by this model change and thus  
32 there is no expected impact on the SAMA analysis (Entergy 2017a).

33 In response to the RAI to discuss the technical adequacy of the internal flood PSA, Entergy  
34 indicated that the PSA analyst performing the internal flooding analysis was an experienced,  
35 trained professional and the analysis was reviewed by a second, experienced, trained PSA  
36 analyst. The internal flooding analysis was performed consistent with guidance documents  
37 existing at the time (i.e., ASME PRA standard ASME RA-Sb-2005, NRC Regulatory  
38 Guide 1.200 for Trial Use, April 2004, Draft Regulatory Guide DG-1161, September 2006, and  
39 draft EPRI guidance document, "Guidelines for Performance of Internal Flooding Probabilistic  
40 Risk Assessment (IFPRA)," September 2006). Therefore, the NRC staff found that the internal  
41 flooding analysis provides an acceptable basis for identifying and evaluating internal flooding  
42 SAMAs. However, because the internal flooding model has not been updated since the peer  
43 review, and it has not been integrated with the current internal events model or the Level 2  
44 and 3 models, the internal flooding CDF was included with the external event CDF values to  
45 calculate the external events multiplier for the SAMA analysis (discussed further below).

46 In response to an NRC staff RAI to discuss the impact on the SAMA analysis of any open  
47 findings from the peer review of the internal flooding model, Entergy responded that there are

1 eight open findings. Some of the findings are documentation issues and resolution of others  
2 would tend to decrease or have no impact on the internal flooding CDF (Entergy 2017a).

3 Considering that the internal flooding analysis implemented in the 2003 (R3) PSA model has  
4 been peer reviewed and that resolution of open findings would tend to decrease or have no  
5 impact on the internal flooding CDF, and that changes made to the internal events PSA model  
6 that increased the CDF from the 2003 (R3) PSA model to the 2015 (R5) PSA model used in the  
7 SAMA analysis is not expected to impact the SAMA analysis, the NRC staff concludes that the  
8 internal flooding analysis, as discussed above, provides an acceptable basis for identifying and  
9 evaluating internal flooding SAMAs and that the internal flooding CDF, as discussed above, is  
10 acceptable for use in the development of the external events multiplier.

#### 11 *High Winds, Floods, and Other External Events*

12 The ER indicated that the WF3 IPEEE concluded for high winds, floods, and other external  
13 events that WF3 meets the applicable NRC Standard Review Plan requirements, and therefore  
14 has an acceptably low risk with respect to these hazards. As these events are not dominant  
15 contributors to external event risk and quantitative analysis of these events is not practical, they  
16 are considered by the applicant to be negligible and are not included in the external events  
17 multiplier.

18 As part of implementing lessons-learned from the accident at the Fukushima Dai-ichi nuclear  
19 power plant, the NRC issued a Title 10 *Code of Federal Regulations* (10 CFR) 50.54(f) letter  
20 request for information (NRC 2012a). Enclosure 2 to the letter requested licensees to re-  
21 evaluate flood-causing mechanisms using present-day methodologies and guidance.  
22 Concurrently with the re-evaluation of flooding hazards, licensees were required to develop and  
23 implement mitigating strategies in accordance with NRC Order EA-12-049, "Requirements for  
24 Mitigation Strategies for Beyond-Design-Basis External Events" (NRC 2012b).

25 As discussed in the NRC staff's "Interim Staff Response to Reevaluated Flood Hazards" at  
26 Waterford, dated April 12, 2016 (NRC 2016d), there are a number of re-evaluated flood hazards  
27 that exceed the current design basis. In an RAI, Entergy was asked to provide a discussion of  
28 the status of the WF3 Mitigation Strategy Assessment (MSA) and integrated assessment or  
29 focused evaluation and a discussion of the impact of flood hazards on the WF3 risk. Entergy  
30 replied that the WF3 MSA has been completed and concluded that the WF3 FLEX design basis  
31 flood is not affected by the results of the Mitigating Strategy Flood Hazard Information. The  
32 flood mechanisms, which bound the re-evaluated flood hazards that exceed the current design  
33 basis, do not impact the site FLEX strategies. Therefore, the current FLEX strategies can be  
34 fully deployed with no additional operator actions. Entergy indicated that the focused evaluation  
35 has not yet commenced at WF3 but concluded that no appreciable impact on risk is expected  
36 due to interim actions taken as part of the Flood Hazard Re-evaluation (Entergy 2017a).

37 Considering that the contribution to CDF from high winds and other external events is negligible,  
38 the NRC staff concludes that not including a CDF contribution for these hazards in the  
39 development of the external events multiplier is acceptable. Further, the need for any mitigating  
40 action for external floods is being dealt with as part of the NRC Order EA-12-049 program as a  
41 current operating issue, and no additional external flooding SAMAs need to be considered.

#### 42 *External Events Multiplier*

43 As stated in the ER (Entergy 2016), a multiplier of 3.02 was used to adjust the internal event risk  
44 benefit associated with a SAMA to account for external events and internal flooding events.  
45 This multiplier was based on a fire CDF from the NFPA 805 transition LAR of  $1.80 \times 10^{-5}$  per  
46 year, seismic CDF from the ILRT interval extension application of  $6.87 \times 10^{-7}$  per year, an  
47 internal flood CDF from the standalone internal flood analysis of  $2.48 \times 10^{-6}$  per year and the

1 assumption that other external events are negligible. Using the Level 1 internal event CDF of  
 2  $1.05 \times 10^{-6}$  per year the ratio of external to internal event CDFs is 2.02, which leads to a  
 3 multiplier of 3.02.

4 The Entergy responses to the NRC staff RAIs concerning the adequacy of these contributors  
 5 are discussed above. These responses concluded that the seismic CDF should be updated to  
 6  $6.48 \times 10^{-6}$  per year, and as a result, the external events multiplier was increased from 3.02 to  
 7 3.57 (Entergy 2017a).

8 Given that the WF3 IPEEE external event assessments have been reviewed by the staff, that  
 9 the internal fire assessment has been found acceptable for the NFPA 805 transition LAR, that  
 10 the flooding and seismic evaluations were addressed in accordance with NEI 05-01A guidance,  
 11 and that Entergy has satisfactorily addressed staff questions regarding the assessment, the  
 12 staff concludes that the external events assessments, with the above addressed revisions, is of  
 13 sufficient quality to support the SAMA evaluation.

#### 14 *F.3.2.3 Level 2 Fission Product Release Analysis*

15 The staff reviewed the general process Entergy used to translate the results of the Level 1 PSA  
 16 into containment releases, as well as the results of the Level 2 analysis, as described in the ER  
 17 and in responses to staff RAIs (Entergy 2017a, 2017b). Entergy indicated that the full Level 2  
 18 model used for the SAMA analysis was created for the 2015 (R5) PSA based on the  
 19 2015 internal events model superseding the prior simplified, LERF-only model. As indicated in  
 20 Table F-3, the simplified LERF-only model resulted in a LERF of  $1.4 \times 10^{-7}$  per reactor-year  
 21 versus the full Level 2 model result of  $1.9 \times 10^{-6}$  per reactor-year. The conversion of the peer  
 22 reviewed, simplified LERF model into a Level 2 analysis for WF3 included the following  
 23 (Entergy 2017a):

- 24 • restructuring the event trees for addition and consolidation of nodes
- 25 • execution and incorporation of plant-specific MAAP calculations to determine the  
 26 event tree outcomes
- 27 • development of 12 release categories, including the LERF release category
- 28 • incorporation of the WF3 Emergency Action Levels, evacuation estimates, and  
 29 MAAP accident sequence timing
- 30 • utilization of fission product release results derived from MAAP analyses in the  
 31 binning of the release categories
- 32 • development and incorporation of detailed ultimate containment capacity into the  
 33 Level 2 analysis

34 The Level 2 analysis is linked to the Level 1 model by extending the model to include the  
 35 containment event tree (CET) which characterizes the post-core melt accident response. The  
 36 CET considers the influence of physical and chemical processes on the integrity of the  
 37 containment and on the release of fission products. The ER lists and describes 13 functional  
 38 nodes incorporated into the WF3 Level 2 CETs. These nodes (or branches or questions)  
 39 address events occurring before vessel breach (including post-core damage depressurization  
 40 and the potential for in-vessel recovery), if containment is isolated or is bypassed, the status of  
 41 containment heat removal systems (CHRs) and the impact of these systems on containment  
 42 and vessel integrity.

43 Entergy indicated that the WF3 Level 2 model utilized four CETs in which each represents a  
 44 different configuration of CHR performance, specifically:

- 1 • Both Containment Sprays and Containment Cooling Fans are available (CHR-B)
- 2 • Only Containment Cooling Fans are available (CHR-D)
- 3 • Only Containment Sprays are available (CHR-F)
- 4 • No Containment Safeguards are available (CHR-H)

5 In response to an RAI, Entergy clarified that while the ER discussion of the CETs includes these  
6 events, they are not actual nodes in the CETs. Rather, they define the entry points for each of  
7 the trees (Entergy 2017a).

8 The ER indicates that for the WF3 Level 2 analysis, no grouping into plant damage states was  
9 performed to group accident sequences with similar safety features and containment failure  
10 responses. A more rigorous approach was taken in which each Level 2 accident sequence was  
11 assessed individually based on the accident-specific containment response. In response to an  
12 NRC staff RAI, Entergy indicated that each Level 1 sequence was evaluated using each of the  
13 four CETs. The Level 1 sequences were defined based on the initiating event and the Level 1  
14 CDF event tree functional failures that lead to core damage. The Level 2 sequence is then  
15 defined by the Level 1 sequence and the CHR status (Entergy 2017a).

16 The CET end points represent the outcomes of possible containment accident progression  
17 sequences with each end point representing a complete sequence from initiator to release to  
18 the environment. Associated with each CET end point or end state is an atmospheric  
19 radionuclide source term including the timing, magnitude, and other conditions associated with  
20 the release. Because of the large number of CET end points, they are grouped into release  
21 categories. Entergy defined 13 release categories: 12 release categories are based on  
22 magnitude of release (four levels) and timing of containment failure relative to the time of the  
23 declaration of a general emergency (GE) (three time groups) and 1 release category is for no  
24 containment failure (NCF) or INTACT.

25 Entergy stated that the CET end points were assigned to a release category based on the  
26 results of MAAP analysis except for Containment Bypass Sequences, Containment Isolation  
27 Sequences, Reactor Vessel Rupture Events and ISLOCA Events, which were all assigned to  
28 the High Early (H-E) release category. The frequency of each release category is then the sum  
29 of the frequencies of all the CET endpoints assigned to it, except that the frequency of the NCF  
30 release category was determined from the difference between the Level 1 CDF and the sum of  
31 frequencies for the other release categories.

32 Entergy was asked in an RAI to provide the results for the "intact" release category from the  
33 sum of the NCF CET end states and to discuss the impact of cut set truncation on the CDF and  
34 release category frequencies and the validity of the approach taken to determining the release  
35 category frequencies. Entergy discussed the results of convergence studies for CDF and  
36 release category frequency analyses. The CDF and release category frequencies were both  
37 quantified at a truncation of  $1 \times 10^{-11}$  and convergence studies were performed on both the  
38 Level 1 and Level 2 model results. The Level 1 results demonstrate CDF convergence (defined  
39 as a change of less than 5 percent per decade) at  $1 \times 10^{-11}$ . The Level 2 results also  
40 demonstrate a change of less than 5 percent at a  $1 \times 10^{-11}$  truncation for the highest frequency  
41 release categories (H-E and High-Intermediate (H-I)). Entergy concluded that no significant  
42 change in SAMAs would be expected by providing the results for the "intact" release category  
43 from the sum of the NCF CET end states versus taking the difference between the base CDF  
44 and the total of the other release categories (Entergy 2017a).

45 In response to an NRC staff RAI to explain the assignment of Containment Bypass Sequences,  
46 Containment Isolation Sequences, Reactor Vessel Rupture Events and ISLOCA Events to the

## Appendix F

1 H-E release category, Entergy indicated that this assignment was made because there would  
2 be no expectation of fission product removal in the containment and that no MAAP analyses  
3 were made for these sequences. Further justification by Entergy for not analyzing these  
4 scenarios and the basis for selection of the representative scenario for the H-E release category  
5 is provided below.

6 The NRC staff noted in an RAI that the population dose for two release categories (L-I and M-I)  
7 are greater than that for the H-E release category even though the Cesium and Iodine release  
8 fractions given in ER Table D.1-10 are less than those for the H-E release category and  
9 requested an explanation for this analysis result. Entergy responded that the scenarios  
10 selected for the M-I and L-I release categories were the dominant scenarios and represent early  
11 phase in-vessel core melt conditions under high RCS pressure (> 200 psi) and partially  
12 recovered/maintained reactor pressure vessel (RPV) water levels. Under these conditions,  
13 increased production of steam and hydrogen enhances fission product releases from the fuel  
14 rods and other core materials. These in-vessel conditions facilitate the release of the alkaline  
15 and rare earth (non-volatile) isotopes from fuel fracturing or powdering. A review of the fission  
16 product fractions for both the M-I and L-I accident sequences show these sequences to be  
17 outliers with regard to the ratio of barium to iodide in comparison to the other accident  
18 scenarios. Based on this, alternate accident sequences were selected to represent the M-I and  
19 L-I release categories and were used in the updated Level 3 model. The acceptability of the  
20 alternate scenario for M-I release category is discussed below. Since release category L-I  
21 contributes less than 0.1 percent to the total risk, the NRC staff concludes that the change in  
22 release fraction for this category is negligible and is therefore acceptable for use in the SAMA  
23 analysis.

24 Entergy stated that the representative accident sequences selected for each release category  
25 represented both the dominant accident class based on the Level 2 results and the maximum  
26 release of fission products from the MAAP analyses. In an RAI, Entergy was asked to provide a  
27 discussion of this process including a description of the Level 2 sequences used to characterize  
28 the source terms for each of the significant release categories, and the basis for this selection  
29 and its appropriateness for use in determining the benefit for the Phase II SAMAs evaluated.  
30 Entergy responded that following the process of identifying and screening of potential accident  
31 sequences from both the cutset review and the MAAP analysis, an additional review of the  
32 candidate sequences was used to select an accident sequence for each release category that is  
33 both conservative and representative of WF3 (Entergy 2017a).

34 Subsequently, Entergy was asked to provide a description of the specific Level 1 and Level 2  
35 accident sequences used to characterize the significant release categories (H-E, H-I and M-I)  
36 and why the particular Level 1 and Level 2 accident sequences were chosen to be  
37 representative for those release categories used in determining the benefit of the Phase II  
38 SAMAs (NRC 2017). In response to the request, Entergy provided a listing and description of  
39 the important contributors to the three release categories, the percent contribution of each to the  
40 release category frequency, the available Cesium Iodide (CsI) fission product release fraction  
41 results for the contributors, and the basis for the selection of the representative sequence for  
42 each of the three release categories (Entergy 2017b).

43 For the H-E release category, the representative sequence chosen was TQX\_H (a transient  
44 followed by successful reactor trip and RCS pressure control). In this sequence, the RCP seals  
45 develop a leak due to loss of seal cooling resulting in a small LOCA. High pressure safety  
46 injection (HPSI) is initially successful, but fails during recirculation after the reactor water  
47 storage pool (RWSP) inventory is exhausted. Containment fans and sprays fail early;  
48 containment fails due to over-pressurization during core uncover, prior to core damage. This  
49 sequence contributes approximately 81 percent of the release category frequency and has a

1 0.35 Csl release fraction. The next highest contributor is I-SGTR (pressure and thermally  
2 induced steam generator tube ruptures) which contributes approximately 11 percent to the  
3 release category frequency. The other contributors to this release category make an even  
4 smaller contribution. Entergy indicated that MAAP analysis was not performed for these  
5 sequences, due to the high uncertainties associated with evaluation of these types of  
6 sequences in the MAAP code, so the actual Csl release fractions were not calculated. Entergy  
7 judged that the existing conservatisms in the individual SAMA case analyses more than  
8 compensate for the potential for higher Csl release fractions from these sequences. Since the  
9 second most important sequence has a frequency that is approximately one seventh of that for  
10 the dominant sequence, and it is expected that the Csl release fraction would be similar to the  
11 35 percent used in the SAMA cost-benefit analysis, the NRC staff considers Entergy's selection  
12 of the TQX\_H as representative of the H-E release category to be acceptable.

13 For the H-I release category, the representative sequence chosen was SBO\_E (a Loss of offsite  
14 power followed by failure of both emergency diesel generators and failure of the turbine-driven  
15 EFW pump to start/run). In this sequence, containment fans and sprays are not available due to  
16 loss of power. Containment failure occurs prior to vessel breach. This sequence contributes  
17 approximately 66 percent of the release category frequency and has a 0.32 Csl release fraction.  
18 The next highest contributor is TB\_H (a transient with successful RCS pressure control and  
19 boundary integrity with loss of decay heat removal and failure to recover RCS inventory; early  
20 failure of containment fans and sprays; vessel breach with late (> 4 hours) containment failure.  
21 This sequence contributes approximately 28 percent of the release category frequency and has  
22 a 0.25 Csl release fraction. The next highest contributor makes an even smaller contribution  
23 and has a lower Csl release fraction. Entergy indicated that the SBO\_E scenario was elected to  
24 represent the H-I release category based on its dominant frequency in the release category as  
25 well as the largest release fractions of Csl. This is acceptable to the NRC staff because the  
26 selected scenario is representative or conservative for over 94 percent of the H-I release  
27 category scenarios.

28 For the M-I release category, the representative sequence chosen was TB\_B (a transient with  
29 successful RCS pressure control and boundary integrity with loss of decay heat removal and  
30 failure to recover RCS inventory). In this sequence, the vessel remains intact with containment  
31 failure occurring at 14 hours due to hydrogen burn. Both containment fans and sprays are  
32 available. This sequence contributes approximately 10 percent of the release category  
33 frequency and has a 0.063 Csl release fraction. The largest contributor to the release category  
34 frequency is SU\_H (a small LOCA with containment failure due to over-pressurization; failure of  
35 containment fans and sprays). This sequence contributes approximately 77 percent of the  
36 release category frequency and has a 0.077 Csl release fraction. The other contributor to this  
37 release category is TB\_F (a transient with successful RCS pressure control and boundary  
38 integrity with loss of decay heat removal and failure to recover RCS inventory). In this scenario,  
39 the vessel remains intact with containment failure due to over-pressurization occurring at 19  
40 hours. Containment spray is available, but containment fans are failed. This sequence  
41 contributes approximately 12 percent of the release category frequency and has a 0.079 Csl  
42 release fraction. Entergy's discussion of the selection of the representative sequence indicated  
43 that while SU\_H is the dominant contributor to the M-I release category and was considered as  
44 representative of this category in the original analysis, it was, as discussed above, identified as  
45 an outlier on the basis of its barium-to-iodide ratio in comparison to that of the other accident  
46 scenarios. Entergy indicated that it was acceptable to exclude SU\_H because the M-I release  
47 category is less than 2 percent of the total level 2 release frequency and the Csl release fraction  
48 is similar to the selected scenario (TB\_B) used in the updated analysis. Also, as shown in the  
49 revised ER Table D.2-2 (and Table F-5 below), Phase II SAMAs 13 and 18, which were  
50 evaluated to reduce the frequency of core melt from a small LOCA, are far (more than a factor

1 of 2) from being potentially cost-beneficial. Based on the above discussion and given that  
2 release category M-I contributes less than 2 percent of the total risk, the use of the TB\_B  
3 scenario as representative for this release category in the revised analysis is acceptable to the  
4 NRC staff.

5 Entergy indicated that Level 2 accident sequences were evaluated deterministically using the  
6 MAAP code and a 36-hour accident time period. This time period was selected to ensure that  
7 sufficient time was allotted to allow for late failures and to capture the peak steady-state fission  
8 product release concentrations. In an RAI, Entergy was asked to provide justification that the  
9 36-hour accident time period yields the peak fission product release over the 48-hour time  
10 period beginning at the time of declaration of a GE and if the peak fission product release does  
11 not occur using the 36-hour accident time period, to discuss the impact on the SAMA analysis if  
12 the analysis is extended to 48 hours after the declaration of a GE (NRC 2016a). In response,  
13 Entergy re-evaluated each release category representative accident sequence using the MAAP  
14 code over a time period extending to 48 hours following the declaration of the WF3 GE. This  
15 re-evaluation was performed to conservatively establish peak fission product fractions. The  
16 Level 3 model was updated using the extended 48-hour MAAP fission product fractions  
17 (Entergy 2017a).

18 In an NRC staff RAI, Entergy was asked to describe the steps taken to ensure the technical  
19 adequacy of the full Level 2 model (NRC 2016a). Entergy responded that the WF3 model is a  
20 Level 2 analysis capable of meeting the Category II requirements of Regulatory Guide 1.200  
21 and the ASME PRA Standard. The updated Level 2 analysis uses available technical work from  
22 the previous WF3 PSA analyses where appropriate, but it applies the most recent accident  
23 progression research, current industry practices, and realistic plant-specific analyses. The  
24 Level 2 analysis was performed by a contractor, received in-depth technical reviews within the  
25 contractor's organization and by a representative of Entergy with Level 2 experience, and all  
26 comments were resolved. In addition, an expert panel cutset review of the significant and  
27 non-significant cutsets for the Level 2 model was performed and all issues addressed  
28 (Entergy 2017a).

29 From its review of the Level 2 methodology that meets the NEI 05-01A guidance, Entergy's  
30 responses to staff RAIs, and the subjection of the Level 2 model to an internal self-assessment  
31 and reviews and an expert panel review of the Level 2 cutsets, the NRC staff concludes that the  
32 Level 2 PSA, as used in the revised SAMA analysis responding to the NRC staff RAIs provides  
33 an acceptable basis for evaluating the benefits associated with various SAMAs.

#### 34 *F.3.2.4 Level 3 Consequence Analysis*

35 Entergy used the MACCS, Version 3.10.0 code and a core inventory from a plant-specific  
36 calculation, as clarified by response to an NRC RAI, to determine the offsite consequences from  
37 potential releases of radioactive material (Entergy 2016, 2017a). Entergy calculated the core  
38 inventory for 3,735 MWt, which is consistent with 100.5 percent of the approved EPU  
39 (Entergy 2016).

40 The staff reviewed the process Entergy used to extend the containment performance (Level 2)  
41 portion of the PSA to an assessment of offsite consequences (Level 3 PSA model). Source  
42 terms used to characterize fission product releases for the applicable containment release  
43 categories and the major input assumptions used in the offsite consequence analyses were  
44 considered. In response to an NRC staff RAI on the core inventory used in the radiological  
45 dose calculation, Entergy confirmed that the radionuclides listed in Table D.1-11 of  
46 Attachment D to the ER (Entergy 2016) were applied in the Level 3 analysis and considered  
47 differences between fuel cycles expected during the period of extended operation as well as

1 changes to future fuel management practices or fuel design (Entergy 2017a). Additional  
2 plant-specific input to the assessment includes the core release fractions and source terms for  
3 each release category (Entergy 2016, Table D.1–10), site-specific meteorological data,  
4 projected population distribution and expected growth out to the year 2045 within an 80-km  
5 (50-mi) radius, emergency evacuation modeling, and economic data. This information is  
6 provided in Section D.1.5 of Attachment E to the ER (Entergy 2016). Since the staff determined  
7 that Entergy's source term information is consistent with NRC guidance (NEI 2005) and includes  
8 satisfactory responses to NRC questions, the staff concludes that Entergy's source term  
9 estimates are acceptable for use in the SAMA analysis.

10 The NRC staff noted in an RAI that the start of release times given in ER Table D.1–10 are not  
11 consistent with the release category definitions in Table D.1–8 for a number of release  
12 categories (NRC 2016a). In response to the RAI, Entergy provided a discussion of the various  
13 timing parameters used in the Level 3 model. In particular, the applicant explained that the  
14 parameter RDOALARM, which represents the time for the plant to evolve to general emergency  
15 (GE) conditions and includes a 15-minute assessment period, was incorrectly calculated in  
16 relation to the time from plant GE conditions (i.e., 15 minutes) rather than from the plant scram  
17 time. The applicant further explained that to establish GE conditions, an assessment of  
18 conditions that lead to the loss of two barriers to radiological release, with the potential loss of  
19 the third, was required for declaration of a WF3 GE condition. The maximum time to achieve a  
20 plant GE condition was used to represent the scenario-specific GE condition for each release  
21 scenario. Values of the RDOALARM parameter have been modified as shown in the revised  
22 ER Table D.1–10 and reflect the time between the recognition of GE conditions (plus the 15-  
23 minute assessment time) and the time of plant scram. The revised ER Table D.1–10 provides  
24 the timings associated with the release plumes used in the Level 3 analysis. The WF3 Level 3  
25 model was updated using the correct RDOALARM times (Entergy 2017a).

26 Entergy considered site-specific meteorological data for the calendar years 2004 through 2013  
27 and selected meteorological data from 2010 for the analysis as input to the MACCS code  
28 because they generated the highest population dose and the highest offsite economic cost  
29 (Entergy 2016). Meteorological data were acquired from the meteorological monitoring system  
30 at WF3 and regional National Weather Service stations. Meteorological data included wind  
31 speed, wind direction, atmospheric stability class, precipitation, and atmospheric mixing heights.

32 In response to an NRC staff RAI, Entergy explained that missing meteorological data were  
33 estimated using valid data substitution methods, including the use of data from a previous year  
34 that is representative (Entergy 2017a). With regard to seasonal mixing height averages for the  
35 years 2010 through 2013, the minimum and maximum average seasonal values for the years  
36 2000 through 2009 were used (Entergy 2016). In response to NRC staff concerns about the  
37 amount of missing data, Entergy clarified that for 2010, less than 2 percent of the annual data  
38 were missing, whereas for other years, less than 0.1 percent of annual data needed to be  
39 estimated (Entergy 2017a). The sources of data and models for atmospheric dispersion the  
40 applicant used are consistent with standard industry practice and acceptable for calculating  
41 consequences from potential airborne releases of radioactive material. Because the applicant  
42 considered multiple years of meteorological data and the annual data set that resulted in the  
43 largest total population dose and offsite economic cost was selected for the SAMA analysis, the  
44 NRC staff finds that the data selection was performed in accordance with NRC guidance  
45 (NEI 2005); therefore, the meteorological data are appropriate for use in the SAMA analysis.

46 Entergy projected population distribution and expected growth within a radius of 80 km (50 mi)  
47 out to the year 2045 to account for an anticipated 28-year period of remaining plant life,  
48 including 8 years remaining on the original operating license plus a 20-year license renewal  
49 period (Entergy 2016). The Entergy assessment incorporated U.S. Census 2010 data and

1 applied Parish-level projection estimates for each year thereafter (Entergy 2016, 2017a). In  
2 response to an NRC staff RAI, Entergy confirmed that transient and special facility populations  
3 were included (Entergy 2017a). Additionally, for parishes with declining population projections,  
4 Entergy clarified that the highest estimated population for parishes with a projected negative  
5 population growth was held constant for the remaining period of extended operation  
6 (Entergy 2017a). The staff considers the methods and assumptions for estimating population  
7 reasonable and acceptable for purposes of the SAMA evaluation because its review of  
8 Entergy's assessment determined that Entergy considered appropriate data sources, used a  
9 reasonable approach for applying data, followed NRC guidance (NEI 2005), and added  
10 conservatism by not crediting negative population growth.

11 Entergy assumed that 90 percent of the population would evacuate (Entergy 2016). This  
12 assumption is conservative relative to the NUREG-1150 study (NRC 1990), which assumed  
13 evacuation of 99.5 percent of the population within the emergency planning zone. The  
14 evacuated population was assumed to move at an average speed of approximately  
15 1.192 meters per second (m/s) (2.666 miles per hour (mph)). This evacuation speed is based  
16 on an evacuation time of 225 minutes, the longest evacuation time as determined by a  
17 plant-specific evaluation (Entergy 2016). Entergy performed a sensitivity analysis on the  
18 evacuation speed, reducing it by half to 0.596 m/s (1.333 mph), and consequence deviations  
19 were found to be less than 1 percent (Entergy 2016). A sensitivity analysis was also performed  
20 on the 2-hour delay-to-shelter time assumed in the analysis by increasing it to 3 hours, and  
21 again, consequence deviations were found to be less than 1 percent (Entergy 2016). Given that  
22 Entergy performed a site-specific analysis to determine evacuation assumptions and  
23 parameters, and showed radiological consequence results were insensitive to changes to  
24 certain evacuation parameters, the NRC staff concludes that the evacuation assumptions and  
25 analysis are reasonable and acceptable for the purposes of the SAMA evaluation.

26 Much of the site-specific economic data were provided from the 2012 U.S. Census of  
27 Agriculture, SECPOP2013, and the U.S. Bureau of Labor Statistics. Parish representation  
28 within a spatial element was based on the parish with the greatest area contribution. Data for  
29 certain counties and parishes were not incorporated into the analysis because of small area  
30 contributions within a spatial element. Agricultural data, including crop type, growing season,  
31 and average fraction of farmland devoted to each crop type, were obtained from 2012  
32 U.S. Census of Agriculture data for the 80-km (50-mi) area and applied to the MACCS crop  
33 categories. In response to a staff RAI, Entergy clarified that other economic data, including the  
34 cost of evacuation, cost of temporary relocation, cost of land decontamination and labor costs,  
35 are based on 1987 values obtained from NUREG-1150 (NRC 1990) and then adjusted to  
36 present pricing values using an escalation factor of 2.08 based on average U.S. consumer price  
37 indices. Entergy provided sensitivity analysis for two of the offsite contamination inputs  
38 (TIMDEC and CDNFRM) used in the MACCS code, which is further discussed in Section F.6.2.  
39 No new SAMAs were identified based on this sensitivity. Thus, the staff considers the NUREG  
40 values the applicant used to be reasonable for the SAMA analysis.

41 In summary, the NRC staff reviewed Entergy's assessments of the source term, radionuclide  
42 releases, meteorological data, projected population distribution, emergency response, and  
43 regional economic data and evaluated Entergy's responses to NRC staff RAIs, as previously  
44 described in this subsection. Based on the NRC staff's review, the NRC staff concludes that  
45 Entergy's consequence analysis is acceptable and that Entergy's methodology to estimate  
46 offsite consequences for WF3 and consideration of parameter sensitivities provide an  
47 acceptable basis to assess the risk reduction potential for candidate SAMAs. Accordingly, the  
48 NRC staff based its assessment of offsite risk on the CDFs, population doses, and offsite  
49 economic costs reported by Entergy.

## 1 **F.4 Potential Plant Improvements**

2 The process for identifying potential plant improvements (SAMAs), an evaluation of that  
3 process, and the improvements evaluated by Entergy are discussed in this section.

### 4 **F.4.1 Process for Identifying Potential Plant Improvements**

5 Entergy's process for identifying potential plant improvements consisted of the following  
6 elements:

- 7 • review of industry documents and consideration of other plant-specific  
8 enhancements not identified in published industry documents
- 9 • review of potential plant improvements identified in the WF3 IPE and IPEEE
- 10 • review of the risk-significant events in the current WF3 PSA Levels 1 and 2 models  
11 for plant-specific modifications for inclusion in the comprehensive list of SAMA  
12 candidates

13 Based on this process, Entergy identified an initial set of 201 candidate SAMAs, referred to as  
14 Phase I SAMAs. In Phase I of the evaluation, Entergy performed a qualitative screening of the  
15 initial list of SAMAs and eliminated SAMAs from further consideration using the following  
16 criteria:

- 17 • The SAMA modified features are not applicable to WF3.
- 18 • The SAMA has already been implemented at WF3.
- 19 • The SAMA is similar in nature and could be combined with another SAMA candidate.

20 Based on this screening, 48 of the Phase I SAMA candidates were screened out because they  
21 were not applicable to WF3. Sixty-eight were screened out because they already had been  
22 implemented at WF3, and 11 were screened out because they were similar in nature and could  
23 be combined with another SAMA candidate. Thus, 127 SAMAs were eliminated, leaving 74 for  
24 further evaluation. In response to an NRC staff RAI, one additional SAMA candidate was added  
25 for further evaluation (Entergy 2017a). These remaining 75 SAMAs, referred to as Phase II  
26 SAMAs, are listed in Table D.2–2 of Attachment E to the applicant's ER (Entergy 2016) and in  
27 the updated table provided in the response to the NRC staff RAIs (Entergy 2017a). In Phase II,  
28 a detailed evaluation was performed for each of the 75 remaining SAMA candidates, as  
29 discussed in Sections F.4 and F.6 below.

### 30 **F.4.2 Review of Entergy's Process**

31 Entergy's efforts to identify potential SAMAs included explicit consideration of potential SAMAs  
32 primarily for internal events because the current WF3 PSA does not include external events.  
33 The initial SAMA list was developed primarily from the review of generic industry SAMAs  
34 (NEI 2005), as well as SAMAs from four previous PWR license renewal applications. To this  
35 list, a number of SAMAs were added based on improvements identified in the IPE and IPEEE.  
36 Finally, a review of the WF3 PSA Level 1 and Level 2 LERF results was made to identify any  
37 additional SAMAs or confirm that all important events have been addressed. In response to an  
38 NRC staff RAI, Entergy provided the following breakdown of the source of Phase I SAMAs  
39 (Entergy 2017a):

- 40 • NEI 05-01A (NEI 2005) Generic List – 153 SAMAs
- 41 • Other PWR SAMAs – 32 SAMAs

## Appendix F

- 1 • Plant-Specific Fire Risk Analysis – 3 SAMAs
- 2 • Plant-Specific IPE – 8 SAMAs
- 3 • Plant-Specific IPEEE – 5 SAMAs

4 Furthermore, one additional SAMA was added in response to an NRC staff RAI  
5 (Entergy 2017a). This SAMA is discussed below.

6 Entergy provided a tabular listing of the Level 1 PSA basic event CDF importance down to a risk  
7 reduction worth (RRW) of 1.005. SAMAs affecting these basic events would have the greatest  
8 potential for reducing risk. An RRW of 1.005 corresponds to a reduction in CDF of  
9 approximately 0.5 percent, given 100 percent reliability of the SAMA. Based on the maximum  
10 averted cost risk, including external events and uncertainty (see Section F.6.1 below), this  
11 equates to a benefit of approximately \$65,000. This is near the minimum cost of a simple  
12 procedure change with associated training as given by Entergy (see Section F.5 below). All  
13 basic events in the Level 1 listing were reviewed to identify potential SAMAs and the listing  
14 annotated to indicate the Phase II SAMAs mitigating the failure associated with the basic event.  
15 All basic events, except flag events, which do not represent failures, were addressed by one or  
16 more Phase II SAMAs from the list based on the generic industry SAMAs or WF3 specific  
17 SAMAs (Entergy 2016).

18 Entergy also provided and reviewed the basic events with LERF RRWs down to 1.005. All  
19 basic events in the Level 2 LERF (or release category H/E) listing were reviewed to identify  
20 potential SAMAs and all were addressed by one or more Phase II SAMAs, except those that are  
21 flag or split fractions for which no SAMA would be appropriate. Similarly, Entergy reviewed the  
22 RRW risk significant events contributing to the total of all Level 2 release categories for potential  
23 SAMAs except for the intact release category, which does not result in any significant releases  
24 (Entergy 2016).

25 The NRC staff's review of the result of Entergy's correlation of the important basic events with  
26 Phase II SAMAs, as described in ER Tables D.1–2, D.1–4, and D.1–5, resulted in a number of  
27 RAIs, as follows:

- 28 • The NRC staff noted that the RRW for event %TAC3 – Loss of 4.16Kv Bus 3A3–S  
29 (1.0914) is considerably less than that for %TAC4 – Loss of 4.16Kv Bus 3B3–S  
30 (1.318). In response to a request to explain the reasons for this difference and  
31 consider a potential SAMA that addresses the cause of this difference, Entergy  
32 indicated that this difference is attributed to an asymmetry related to component  
33 cooling water (CCW). If a safety injection actuation signal occurs, the CCW system  
34 automatically splits into two independent trains. When initiator %TAC4 (Loss of  
35 4.16kV Bus 3B3–S) occurs and the operators fail to align CCW train AB and fail to  
36 trip the RCPs, it leads to a failure of the RCP seals. Phase II SAMA 5 (Improve  
37 4.16kV bus crosstie ability) was evaluated to address this asymmetry. In addition,  
38 Phase II SAMA 77 (Provide a diverse backup auto-start signal for the standby CCW  
39 trains on loss of the running train), which was proposed in an NRC staff RAI, also  
40 mitigates this failure (Entergy 2017a).
- 41 • The staff noted that event EHFALNAB\_P – Failure to energize bus 3AB3–S from bus  
42 opposite initial supply-recovery flag, is failure of a human action flag and is  
43 addressed by several hardware-related SAMAs. In response to a request to discuss  
44 the potential for SAMAs for improvements in procedures and training to reduce the  
45 impact of this human error and other important human error events (e.g., Events  
46 ZHFC2–011), Entergy indicated that the ER RRW tables were intended to show the  
47 Phase II SAMAs that were evaluated in the cost-benefit analyses to mitigate each of

- 1 the important events. Reviews of the procedures for the two events cited were  
 2 performed during the Phase 1 SAMA identification process and no improvements  
 3 were identified (Entergy 2017a).
- 4 • Entergy indicated that many enhancements to procedures and additional training to  
 5 reduce the impact of human errors were also considered for human actions in the  
 6 RRW tables, but were screened out during Phase I; therefore, they were not listed in  
 7 the RRW tables. Entergy indicated that Phase I SAMA candidates related to training  
 8 were also investigated to determine if additional training would mitigate high RRW  
 9 events. Examples include the following (Entergy 2017a):
    - 10 – Increase training on response to loss of two 120V AC buses, which causes  
 11 inadvertent actuation signals.
    - 12 – In training, emphasize steps in recovery of offsite power after an SBO.
    - 13 – Emphasize timely recirculation alignment in operator training.
    - 14 – Provide additional training on loss of CCW.
    - 15 – Improve operator training on ISLOCA coping.
    - 16 – Increase training and operating experience feedback to improve operator  
 17 response.
    - 18 – Develop simulator training for severe accident scenarios.
  - 19 • During the Phase I screening analysis, the WF3 procedure describing the licensed  
 20 operator requalification training program was reviewed to determine if significant  
 21 improvements could be made. The operators are repeatedly trained on  
 22 risk-significant actions. Classroom exercises and simulator training are provided on  
 23 these actions as well as on implementation of the severe accident guidelines.  
 24 Severe accident scenarios are also developed for emergency planning exercises.  
 25 The need for improvements in this area was not identified (Entergy 2017a).

26 The staff found Entergy's answer to these RAIs acceptable because they correlated the  
 27 important basic events with Phase II SAMAs consistent with NEI 05-01A guidance.

28 Entergy also considered the potential plant improvements described in the WF3 IPE and IPEEE  
 29 in the identification of plant-specific candidate SAMAs. Thirteen WF3 IPE and IPEEE  
 30 improvements were identified and are listed in ER Table D.2–1. The ER stated that eight of  
 31 these improvements have been implemented, three were similar to other SAMAs, and two were  
 32 retained as Phase II SAMAs.

33 The NRC staff review of the disposition of IPE and IPEEE insights as given in ER Table D.2–1  
 34 led to a number of RAIs as follows:

- 35 • Phase I SAMA 184—"Install a portable generator to charge the AB battery is  
 36 screened out as "already installed." The stated disposition indicates that the intent of  
 37 this SAMA is met by the ability to manually control the turbine-driven EFW (TDEFW)  
 38 pump after loss of DC. In response to a request to provide the importance of this  
 39 human action and discuss the potential for a SAMA involving the use of a portable  
 40 generator, Entergy clarified that the operator action to manually control the TDEFW  
 41 pump is not credited in the version of the PSA model used for the SAMA analysis.  
 42 The intent of SAMA 184 is to use a portable generator that can continue to supply  
 43 DC power to the EFW turbine-driven pump controls (and necessary monitoring  
 44 instrumentation) to decrease the likelihood of core melt before AC power is restored.

1 The intent of the SAMA is already addressed by implementation of the FLEX strategy  
2 to manually control the turbine-driven emergency feed water pump. Phase II  
3 SAMA 7 evaluated a similar modification to install a gas turbine generator that was  
4 retained as cost beneficial.

5 • Phase I SAMA 185–“Add guidance for aligning the low-pressure safety injection  
6 (LPSI) pump for containment spray is screened out as “already installed.” The  
7 procedure implemented is stated to address use of LPSI pumps for containment  
8 spray only for large LOCAs. In response to a request to discuss the benefit of this  
9 SAMA for other LOCAs or transients, Entergy indicated that the procedural guidance  
10 to align the LPSI pump for containment spray is a standard appendix to the  
11 emergency operating procedures (EOPs). Standard appendices are used for  
12 evolutions that are called-out by several different EOPs when conditions warrant.  
13 Thus, this guidance can be used any time both containment spray pumps are not  
14 available and high containment pressure exists.

15 These RAI responses are acceptable because they resolve the concerns relating to the  
16 disposition of the IPE and IPEEE recommendations as recommended in the NEI 05-01A  
17 guidance.

18 As discussed above, the internal flooding analysis is not integrated with the internal events  
19 analysis and the impact of internal flooding on the SAMA analysis was limited to its inclusion in  
20 the external events multiplier. Two SAMAs, SAMA 67–“Improve internal flooding response  
21 procedures and training to improve the response to internal flooding events” and  
22 SAMA 68–“Install flood doors to prevent water propagation in the electric boardroom,” were  
23 included in the Phase II evaluation. Entergy was asked in an RAI to provide a discussion of the  
24 identification of additional candidate SAMAs for mitigating internal flooding risk based on review  
25 of important contributors to the internal flooding CDF (NRC 2016a). In response to the RAI,  
26 Entergy stated that, in addition to Phase II SAMAs 67 and 68, a number of Phase I candidate  
27 SAMAs identified in NEI 05-01A and in the SAMA evaluations for other plants related to internal  
28 flooding were considered and found to be non-applicable or already installed. These SAMA  
29 candidates, and the two that were retained for evaluation, were compared with the internal  
30 flooding scenarios to determine if the candidates would significantly mitigate the internal  
31 flooding CDF. The SAMA candidates were considered globally, rather than specifically.  
32 SAMAs 67 and 68 were found to be potentially significant and were retained for Phase II  
33 evaluation, but the others were not (Entergy 2017a). In addition to considering these Phase I  
34 SAMAs, the internal flooding analysis was reviewed to identify significant unique vulnerabilities  
35 that WF3 has to internal flooding. A flood in the Reactor Auxiliary Building (RAB) that  
36 propagates between Electrical Switchgear Rooms A, B, and AB has the largest scenario  
37 contribution to the WF3 internal flooding and was identified as a vulnerability. SAMA 68 to  
38 “Install flood doors to prevent water propagation in the electric board room” was evaluated to  
39 address this vulnerability (Entergy 2017a).

40 The ER indicates that the WF3 fire PSA was used to identify potential SAMAs. Three  
41 fire-related SAMAs (74, 75, and 76) are included in the SAMA analysis because Entergy  
42 committed to installing them in the WF3 NFPA 805 LAR. In response to an RAI, Entergy stated  
43 that these SAMAs have already been implemented (Entergy 2017a). No other discussion was  
44 provided in the ER of how only these three modifications were selected as potential SAMAs.  
45 The NRC staff noted in an RAI that the WF3 fire PSA model, after crediting these commitments,  
46 gives a CDF for internal fires that is 1.7 times the internal events CDF (NRC 2016a). Entergy  
47 was asked in the RAI to provide a discussion of the identification of other candidate SAMAs for  
48 mitigating internal fire risk based on review of important contributors to the internal fire CDF. In  
49 response to the RAI, Entergy indicated that a number of Phase I candidate SAMAs related to

1 internal fires, identified from NEI 05-01A and from the SAMA analyses for other plants, were  
2 considered and found to be non-applicable or already installed. Examples are provided in the  
3 RAI response. These SAMA candidates were considered globally, rather than specifically. In  
4 addition to considering these Phase I SAMAs, the significant fire scenarios were reviewed for  
5 significant unique vulnerabilities, but no additional SAMAs were identified to mitigate the fire risk  
6 at WF3. Furthermore, no additional fire-related SAMAs were retained for cost-benefit evaluation  
7 (Entergy 2017a).

8 The NRC staff noted in an RAI that the Phase II candidate SAMAs did not include adding an  
9 emergency diesel generator (EDG) and asked Entergy to discuss why the cost benefit of adding  
10 an EDG was not performed or to provide such an evaluation (NRC 2016a). In response to the  
11 RAI, Entergy described the emergency power sources available at WF3. In addition to the two  
12 EDGs, WF3 also has “temporary” diesel generators that are staged on site prior to removing a  
13 permanent EDG from service for extended preplanned maintenance work or prior to exceeding  
14 the 72-hour allowed outage time for extended unplanned corrective maintenance work. When  
15 the TEDs are installed in place of an out of service EDG, the TEDs are aligned in the event of a  
16 LOOP and failure of the operable EDG and can be started and ready to load within 25 minutes.  
17 In addition, WF3 has two FLEX diesel generators capable of supplying 400 kW. One is pre-  
18 staged in an enclosure situated on the RAB +41-ft elevation roof and placed into service within  
19 12 hours of the onset of a beyond design basis external event, which is 30 minutes before the  
20 batteries deplete with the extended load shed strategy. The other FLEX diesel generator is  
21 stored in a storage building (south of the nuclear plant island structure) and can be swapped out  
22 with the staged FLEX diesel generator should this FLEX diesel generator become unavailable.  
23 This generator may be pre-staged within the RAB due to hurricane or flood warning. Entergy  
24 concluded that WF3 has many sources of power already installed; therefore, the cost benefit of  
25 adding another EDG was not evaluated (Entergy 2017a).

26 As discussed in Section F.2.2.2 above, the WF3 IPEEE used a limited scope seismic margins  
27 assessment. The seismic margins approach is a deterministic and conservative evaluation that  
28 does not calculate risk on a probabilistic basis. Thus, an external events multiplier was  
29 calculated and used to evaluate SAMAs as discussed in Section F.2.2.2. Also, as discussed  
30 above, additional reviews of the impact of seismic events to WF3 were undertaken following the  
31 accident at the Fukushima Dai-ichi Nuclear Power Plant. The NRC staff concluded that the  
32 applicant, through the implementation of the walkdown guidance activities and, in accordance  
33 with plant processes and procedures, verified the plant configuration with the current seismic  
34 licensing basis; addressed degraded, nonconforming, or unanalyzed seismic conditions; and  
35 verified the adequacy of monitoring and maintenance programs for protective features.  
36 The staff questioned the applicant about additional potentially lower cost alternatives to  
37 SAMA 27—“Install an additional CCW pump, which is evaluated as a means to increase cooling  
38 water availability.” Entergy was asked in an RAI to consider a potentially lower cost modification  
39 of replacing one of the pumps with a diverse design that would lower the common cause pump  
40 failure or to provide diverse backup auto-start signals for the standby CCW trains on loss of the  
41 running train (NRC 2016a). In response to the RAI, Entergy indicated that the common cause  
42 failure of the CCW pumps is not an important contributor to risk and that the benefit associated  
43 with eliminating them is insignificant (Entergy 2017a). In response to another RAI, Entergy  
44 evaluated the cost benefit of providing diverse backup auto-start signals for the standby CCW  
45 trains. This SAMA was added as SAMA 77 and was retained as potentially cost beneficial  
46 (Entergy 2017a).

47 In an RAI, the NRC staff asked if something, less than the full flood door in SAMA 68, such as a  
48 flood barrier, might achieve the same risk reduction benefit as found for SAMA 68 (NRC 2016a).  
49 Entergy responded that a flood barrier is not expected to achieve the same risk benefit as a

1 flood door (Entergy 2017a). Entergy was asked to clarify the basis for not further considering  
2 the cost benefit of flood barriers as a less expensive SAMA than using flood doors even if  
3 having a smaller benefit (NRC 2017). Entergy responded by providing a description of the  
4 internal flood scenarios involving the electrical equipment rooms and an assessment of risk  
5 reduction potential of a barrier rather than flood doors. The dominant contributor to internal  
6 flood risk assumes that no actions are taken and that the flood levels reach 3 feet. The scenario  
7 can only be mitigated by a SAMA that would prevent the doors from opening when the flood  
8 reaches the 3 foot level, or by extensive room drain modifications that would prevent water  
9 accumulation. It would not be mitigated by lower cost alternatives like a curb or flood barrier.  
10 Lower cost alternatives like curbs or flood barriers could, however, mitigate other flood  
11 scenarios. Entergy estimated the reduction of risk for these scenarios resulting from curbs or  
12 barriers to be \$173 including uncertainty. Entergy concludes that a SAMA involving lower cost  
13 curbs or barriers would not be cost-beneficial even when considering the added uncertainty  
14 associated with the assumptions made in estimating the benefit of internal-flood-related SAMAs.  
15 The NRC staff concludes that Entergy has adequately considered lower cost alternatives for  
16 mitigating internal flood damage. (NRC 2017b).

17 The staff notes that the set of SAMAs submitted is not all-inclusive because additional, possibly  
18 even less expensive, alternatives can always be proposed. However, the staff concludes that  
19 the benefits of any additional modifications are unlikely to exceed the benefits of the  
20 modifications evaluated and that the alternative improvements likely would not cost less than  
21 the least expensive alternatives evaluated, when the subsidiary costs associated with  
22 maintenance, procedures, and training are considered.

23 The staff concludes that Entergy used a systematic and comprehensive process for identifying  
24 potential plant improvements for WF3, and that the set of SAMAs evaluated in the ER, together  
25 with those evaluated in response to staff inquiries, is reasonably comprehensive and, therefore,  
26 acceptable. This search included reviewing insights from the WF3 plant-specific risk studies  
27 that included internal initiating events as well as fire, seismic, and other external initiated events  
28 and reviewing plant improvements considered in previous SAMA analyses.

## 29 **F.5 Risk Reduction Potential of Plant Improvements**

30 In the ER, and in response to RAIs, the applicant evaluated the risk-reduction potential of the  
31 75 SAMAs that were not screened out in the Phase I analysis and retained for the Phase II  
32 evaluation. The SAMA evaluations were performed using generally conservative assumptions.

33 Table F-5 lists the assumptions considered to estimate the risk reduction for each of the  
34 evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF, PDR, and  
35 OECR, and the estimated total benefit (present value) of the averted risk. The estimated  
36 benefits reported in Table F-5 reflect the combined benefit in both internal and external events.  
37 The determination of the benefits for the various SAMAs is further discussed in Section F.6.

38 With the exception of two SAMAs associated with internal floods and three SAMAs associated  
39 with internal fires, Entergy used model re-quantification to determine the potential benefits for  
40 each SAMA. The CDF, population dose, and offsite economic cost reductions were estimated  
41 using the WF3 2015 (R5) PSA model for the non-flood and non-fire SAMAs. The changes  
42 made to the model to quantify the impact of SAMAs are detailed in Section E.2.3 of  
43 Attachment E to the ER (Entergy 2016). Bounding evaluations (or analysis cases) were  
44 performed to address specific SAMA candidates or groups of similar SAMA candidates.

45 For the two internal flood-related SAMAs, SAMA 67 (Case 41) and SAMA 68 (Case 42), the  
46 benefit was determined by estimating the reduction in CDF using the internal flood analysis

1 implemented in the WF3 2003 (R3) PSA model. This was a bounding analysis in that Entergy  
2 assumed that each SAMA eliminated the risk of flooding in the flood zones impacted by these  
3 SAMAs. The ratio of the internal flooding CDF reduction to the total internal events CDF was  
4 multiplied by the total present dollar value equivalent associated with completely eliminating  
5 severe accidents from internal events at WF3, which is discussed in Section F.6.1, to obtain the  
6 benefit for the reduction in internal flood CDF.

7 Entergy assumed the three internal fire-related SAMAs were cost beneficial without further  
8 analysis since their implementation are commitments made in the WF3 NFWA 805 Transition  
9 LAR.

10 The NRC staff review of the assumptions and risk reduction potential for the SAMAs led to a  
11 number of RAIs, as discussed in the following paragraphs.

12 The benefit of SAMA 31, "Install a digital feedwater upgrade," is addressed by Case 2, "Improve  
13 Feedwater Reliability." Case 2 was evaluated by eliminating the loss of feedwater initiating  
14 event. Entergy was asked in an RAI to discuss the added benefit that might occur if the  
15 upgrade would increase the availability of feedwater subsequent to other initiating events  
16 (NRC 2016a). Entergy indicated that the added benefit that might occur if the upgrade  
17 increased the availability of feedwater subsequent to other initiating events is given by analysis  
18 Case 17, "Main Feedwater System Reliability." Case 17 analyzed the benefit of increasing the  
19 availability of the feedwater system for Phase II SAMA 33 to add a feedwater pump and  
20 included the benefit of increasing the availability of feedwater subsequent to other initiating  
21 events. Analysis Case 17 resulted in an internal and external events benefit with uncertainty of  
22 \$3.6M. SAMA 31, with a cost of \$6.1M remains not cost beneficial when compared with the  
23 Analysis Case 17 benefit (Entergy 2017a).

24 The benefit of Case 7, "Reduced Frequency of Loss of Auxiliary Component Cooling Water  
25 (ACCW)," assumes elimination of failure of ACCW. ER Section D.2.3 indicates that the model  
26 was changed by adding the ability to crosstie the ACCW. Entergy was asked in an RAI to  
27 provide further information on the modeling to clarify this apparent difference (NRC 2016a). In  
28 the response to the RAI, Entergy explained that the purpose of Case 7 is to represent the risk  
29 reduction from cross tying the ACCW trains, and that a bounding analysis was performed by  
30 eliminating failure of ACCW rather than specifically modeling the crosstie (Entergy 2017a).

31 The benefit of SAMA 19, "Add redundant DC control power for Service Water pumps," is  
32 evaluated in Case 12 by eliminating the DC control power gates to the ACCW pumps. The  
33 NRC staff asked Entergy in an RAI to discuss the benefit associated with eliminating DC control  
34 power failures for the CCW pumps, in addition to the ACCW pumps (NRC 2016a). Entergy  
35 responded to the RAI by indicating that a sensitivity analysis was performed for Case 12 in  
36 which the DC control power to the CCW pumps was removed in addition to the DC power gates  
37 that were removed previously in the Case 12 analysis. With this change incorporated, the  
38 internal and external events benefit with uncertainty is \$39K, a small increase from the  
39 estimated benefit of \$26K for the original modeling assumptions. Entergy concluded that  
40 SAMA 19 remains not cost beneficial with this change (Entergy 2017a).

41 The benefit of Case 24, "Debris Coolability and Core Concrete Interaction," was evaluated by  
42 eliminating failure of debris coolability and core concrete interaction and used to determine the  
43 benefit associated with relatively low cost SAMAs 38, 47, 72, and 73, all of which provide water  
44 to the cavity or otherwise improve core coolability or reduce core concrete interaction. Case 28,  
45 "Increase Cooling and Containment of Molten Core Debris," was evaluated by eliminating  
46 containment core melt propagation and was used to determine the benefit associated with  
47 relatively high cost SAMAs 44, 45, and 46. The benefit associated with Case 28 is  
48 approximately \$6.9M compared to that for Case 24 of \$61K. It would appear that the SAMAs

1 evaluated by Case 24 would achieve much of the benefit associated with SAMA 28. In an NRC  
2 staff RAI, Entergy was asked to discuss the reasons for this significant difference and the  
3 potential for SAMAs 38, 47, 72, and 73 or some combination of them to be cost beneficial  
4 (NRC 2016a).

5 In response to the RAI, Entergy explained that the evaluation of Case 28 incorporated deleting  
6 failure to maintain the cavity at lower pressure via the containment cooling fans, which removes  
7 all possibility of base mat failure. This is a very conservative assessment of the benefit that did  
8 not need to be further refined due to the high cost of Phase II SAMAs 44, 45, and 46.  
9 Furthermore, Phase II SAMAs 38, 47, 72, and 73 were evaluated using Case 24, which is less  
10 conservative than Case 28, but still bounds the achievable benefit of the SAMAs. Case 24  
11 removed failure to cool debris and core-concrete interaction, but did not remove failure to  
12 maintain the cavity at lower pressure. This modeling bounds the achievable benefit from the  
13 SAMAs that would introduce water to the cavity or otherwise cool the external lower vessel head  
14 (Entergy 2017a). The NRC staff agrees that deleting failure to maintain the cavity at lower  
15 pressure via the containment cooling fans is very conservative because this assumption would  
16 be crediting the SAMAs with preventing other containment overpressure failure modes not  
17 intended by these SAMAs.

18 The benefit of Case 43, "Gagging Device To Close a Stuck Open Safety Valve," is evaluated by  
19 eliminating failure events for stuck open relief valves and was used to estimate the benefit of  
20 SAMA 71, "Manufacture a gagging device for a steam generator safety valve and developing a  
21 procedure or work order for closing a stuck-open valve." The original assessment in the ER of  
22 the benefit for Case 43 is only \$76. The benefit of Case 33, "Reduce Consequences of Steam  
23 Generator Tube Ruptures," was used to estimate the benefit of SAMA 61, "Direct steam  
24 generator flooding after a steam generator tube rupture, prior to core damage." The original  
25 assessment in the ER of the benefit for Case 33 is approximately \$100K. Both of these SAMAs  
26 are intended to reduce the releases resulting from an SGTR. The very large difference between  
27 assessed benefit was not expected. Entergy was asked in an RAI to provide a further  
28 description of the failure events listed for Case 43 and their relevance to limiting release  
29 following an SGTR event and to explain the reasons for this difference or revise the  
30 assessments as appropriate (NRC 2016a). In response to the RAI, Entergy described the listed  
31 events but indicated that SAMA 71 has been changed to conservatively use the same benefit as  
32 SAMA 61 and is now retained as potentially cost beneficial. In response to other RAIs, Entergy  
33 reassessed the internal and external events benefit with uncertainty for Case 33 to be \$558K,  
34 which is greater than the implementation cost of both SAMAs 61 and 71 (Entergy 2017a).

35 The benefit of Case 41, "Improve Internal Flooding Response Procedures and Training," and  
36 Case 42, "Water Tight Doors for the Largest Contributor to Internal Flooding," were evaluated by  
37 assuming that the reduction in risk was proportional to the reduction in internal flooding CDF.  
38 SAMAs evaluated by these cases were SAMA 67, "Improve internal flooding response  
39 procedures and training to improve the response to internal flooding events," and SAMA 68,  
40 "Install flood doors to prevent water propagation in the electric board room." An examination of  
41 the reductions in risk given in ER Table D.2-2 for other cases indicates that the reduction in  
42 person-rem risk and OECR may be greater than the reduction in CDF and therefore the  
43 assumption for evaluating the internal flooding benefit may be non-conservative depending on  
44 the failures resulting from the specific flooding events mitigated. Entergy was asked in an RAI  
45 to describe the system failures involved in the internal flood events mitigated by these SAMAs  
46 and to select evaluation cases that would be more representative for these specific internal  
47 flooding SAMAs (NRC 2016a). In response to the RAI, Entergy acknowledged that the  
48 evaluation may be non-conservative, but that the SAMAs would remain not cost beneficial even

1 if the benefit were increased by a factor of three, which bounds the impact of this assumption  
2 (Entergy 2017a).

3 The NRC staff requested in an RAI for Entergy to clarify that the scope of SAMA 36, "Implement  
4 procedures for temporary HVAC," is applicable to rooms other than EDG Room 3A, because  
5 analysis of this SAMA only assumed elimination of failure of EDG Room 3A cooling (Case 23)  
6 (NRC 2016a). Entergy confirmed that the scope of SAMA 36 is to implement procedures for  
7 temporary HVAC for the main control room, EDG rooms, and battery rooms. Analysis Case 23,  
8 assuming EDG Room 3A cooling removed, provided the greatest benefit; therefore, it was used  
9 to represent the bounding benefit for Case 23. Since SAMA 36 was determined to be  
10 potentially cost beneficial, it is potentially cost beneficial to implement procedures for temporary  
11 HVAC for the battery, EDG, and main control rooms (Entergy 2017a).

12 The staff concludes that, with the above clarifications and changes, the consideration of risk  
13 reduction potential of plant improvements by Entergy is sufficient and appropriate for use in the  
14 SAMA evaluation because it is technically sufficient and meets the guidance provided in  
15 NEI 05-01A.

**Table F-4. SAMAs Cost/Benefit Analysis for Waterford Steam Electric Station Unit 3. Percentage Risk Reductions are Presented for Core Damage Frequency (CDF), Population Dose Risk (PDR), and Offsite Economic Cost Risk (OECR)**

Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
Case 1. SBO Reduction <i>Assumption: Eliminates failure due to SBO</i> (Analysis Case for SAMA Nos. 1, 2, & 7) 1—Provide additional direct current (DC) battery capacity 2—Replace lead-acid batteries with fuel cells 7—Install a gas turbine generator	34%	44%	47%	\$3,792,000
Case 2. Improve Feedwater Reliability <i>Assumption: Eliminates failure of feedwater</i> (Analysis Case for SAMA No. 31) 31—Install a digital feedwater upgrade	1%	<1%	<1%	\$21,600
Case 3. Add DC System Cross-Ties <i>Assumption: Reduces failure of DC buses</i> (Analysis Case for SAMA No. 3) 3—Provide DC bus cross-ties	21%	31%	30%	\$2,430,000
Case 4. Increase Availability of Onsite Alternating Current (AC) Power <i>Assumption: Reduces failure of AC buses</i> (Analysis Case for SAMA No. 5) 5—Improve 4.16-kV bus cross-tie ability	22%	32%	31%	\$2,515,000
Case 5. Reduce Loss of Off-Site Power <i>Assumption: Eliminates the severe weather contribution to loss of offsite power</i> (Analysis Case for SAMA Nos. 6 & 10) 6—Install an additional buried off-site power source 10—Bury off-site power lines	11%	12%	12%	\$1,022,000
Case 6. Provide Backup Emergency Diesel Generator (EDG) Cooling <i>Assumption: Eliminates failure of component cooling water to the EDGs</i> (Analysis Case for SAMA Nos. 8 & 9) 8—Use fire water system as a backup source for diesel cooling 9—Add a new backup source of diesel cooling <sup>(b)</sup>	4%	10%	11%	\$847,000
				\$1,745,000

1  
2

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
Case 7. Reduced Frequency of Loss of Auxiliary Component Cooling Water <i>Assumption: Eliminates failure of Auxiliary Component Cooling Water (ACCW)</i> (Analysis Case for SAMA Nos. 21 & 22)	6%	10%	<1%	\$92,800
21—Enhance procedural guidance for use of cross-tied component cooling or service water pumps				\$6,529,000 <sup>(c)</sup>
22—Add a service water pump				\$1,043,000
23 <sup>(d)</sup> —On loss of essential raw cooling water, proceduralize shedding component cooling water loads to extend the component cooling water heat-up time				\$200,000
Case 8. Increased Availability of Feedwater <i>Assumption: Eliminates Demineralized Water Storage Tank (DWST) failure to supply the Condensate Storage Pool (CSP)</i> (Analysis Case for SAMA No. 32)	1%	<1%	<1%	\$27,700
32—Create ability for emergency connection of existing or new water sources to feedwater and condensate systems				\$886,000
Case 9. High Pressure Injection System <i>Assumption: Eliminates failure of High Pressure Safety Injection (HPSI)</i> (Analysis Case for SAMA Nos. 13 & 17)	8%	3%	3%	\$268,000
13—Install an independent active or passive high pressure injection system				\$1,500,000
17—Replace two of the four electric safety injection pumps with diesel-powered pumps				\$1,500,000
Case 10. Extend Reactor Water Storage Pool (RWSP) Capacity <i>Assumption: Eliminates failure of operator actions to swap ECCS pump suction from the RWSP to the Safety Injection Sump and eliminates rupture of the RWST</i> (Analysis Case for SAMA Nos. 16, 29, 30, & 49)	2%	<1%	<1%	\$22,100
16—Throttle low pressure injection pumps earlier in medium or large-break LOCAs to maintain reactor water storage tank inventory				\$3,000,000
29—RWST fill from firewater during containment injection—Modify 6 inch RWST flush flange to have a 2½-inch female fire hose adapter with isolation valve				\$748,000
30—High-volume makeup to the refueling water storage tank				\$565,000

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
Case 11. Eliminate ECCS Dependency on Component Cooling Water System <i>Assumption: Eliminates failure of ECCS motor cooling due to failure of CCW</i> (Analysis Case for SAMA No. 20)	<1%	3%	3%	\$246,000 \$508,000
20—Replace ECCS pump motors with air-cooled motors				\$6,000,000
Case 12. Increase Availability of ACCW <i>Assumption: Eliminates failure of DC control power to the ACCW pumps</i> (Analysis Case for SAMA No. 19)	<1%	<1%	<1%	\$12,500 \$25,700
19—Add redundant DC control power for service water (SW) pumps				\$100,000
Case 13. Low Pressure Safety Injection System <i>Assumption: Eliminates failure of the low pressure safety injection system</i> (Analysis Case for SAMA Nos. 14 & 15)	<1%	<1%	<1%	<\$1,000 <\$1,000
14—Add a diverse low pressure injection system				\$1,000,000
15—Provide capability for alternate injection via diesel-driven fire pump				\$6,500,000
Case 14. Increase Component Cooling Water Availability <i>Assumption: Eliminates independent and common cause failures of CCW pumps</i> (Analysis Case for SAMA No. 27)	14%	29%	28%	\$2,210,000 \$4,553,000
27—Install an additional component cooling water pump				\$6,000,000
Case 15. Decreased Charging Pump Failure <i>Assumption: Eliminates failure of AC power to the normal charging pump</i> (Analysis Case for SAMA No. 12)	<1%	<1%	<1%	\$59,400 \$122,000
12—Install modification to power the normal charging pump from an existing spare breaker from the alternate emergency power system				\$350,000
Case 16. Reactor Coolant Pump Seals <i>Assumption: Eliminates RCP Seal LOCA scenarios</i> (Analysis Case for SAMA Nos. 24, 25, & 26)	16%	32%	31%	\$2,476,000 \$5,100,000
24—Install an independent reactor coolant pump seal injection system, with dedicated diesel				\$8,233,000 <sup>(e)</sup>
25—Install an independent reactor coolant pump seal injection system, without dedicated diesel				\$8,233,000 <sup>(e)</sup>
26—Install improved reactor coolant pump seals				\$2,000,000

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
Case 17. Main Feedwater System Reliability <i>Assumption: Eliminates loss of main feedwater as an accident initiator</i> (Analysis Case for SAMA No. 33)	33%	19%	19%	\$1,734,000
33—Add a motor-driven feedwater pump				\$10,000,000
Case 18. EDG Fuel Oil <i>Assumption: Eliminates failure of fuel oil pumps</i> (Analysis Case for SAMA No. 11)	17%	21%	22%	\$1,816,000
11—Install a large volume EDG fuel oil tank at an elevation greater than the EDG fuel oil day tanks				\$26,300,000 <sup>(c)</sup>
Case 20. Create a Reactor Coolant Depressurization System <i>Assumption: Eliminates small LOCA events</i> (Analysis Case for SAMA No. 18)	15%	2%	<1%	\$204,000
18—Create a reactor coolant depressurization system				\$1,000,000 <sup>(e)</sup>
Case 21. Steam Generator Inventory <i>Assumption: Reduces frequency of loss of feedwater by ANDING a new basic event, having a failure probability of <math>1 \times 10^{-3}</math>, for loss of backup inventory source</i> (Analysis Case for SAMA No. 34)	67%	63%	66%	\$5,511,000
34—Use fire water system as a backup for steam generator inventory				\$3,073,000
Case 22. Instrument Air Reliability <i>Assumption: Eliminates loss of instrument air as an accident initiator</i> (Analysis Case for SAMA No. 37)	<1%	<1%	<1%	\$2,780
37—Replace service and instrument air compressors with more reliable compressors which have self-contained air cooling by shaft driven fans				\$500,000
Case 23. Increased Availability of HVAC <i>Assumption: Eliminates failure of cooling in EDG room 3A</i> (Analysis Case for SAMA Nos. 35 & 36)	9%	12%	13%	\$1,031,000
35—Provide a redundant train or means of ventilation				\$3,574,000
36—Implement procedures for temporary HVAC				\$100,000

Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>	
	CDF	PDR	OECR		
<p>Case 24. Debris Coolability and Core Concrete Interaction  <i>Assumption: Eliminates failure of debris cooling and core-concrete interaction</i>            (Analysis Case for SAMA Nos. 38, 47, 72, &amp; 73)</p> <p>38—Create a reactor cavity flooding system \$1,742,000            47—Provide a reactor vessel exterior cooling system \$2,500,000            72—Provide water from the fire protection system to the containment sump \$716,000            73—Enhance communication between sump and cavity \$703,000</p>	0%	<1%	<1%	\$42,500	\$87,500
<p>Case 25. Decay Heat Removal Capability  <i>Assumption: Eliminates late containment failure due to over-pressurization</i>            (Analysis Case for SAMA Nos. 41 &amp; 42)</p> <p>41—Install an unfiltered, hardened containment vent \$15,083,000<sup>(c)</sup>            42—Install a filtered containment vent to remove decay heat \$20,000,000</p>	0%	20%	23%	\$1,690,000	\$3,482,000
<p>Case 26. Improve Containment Spray Capability  <i>Assumption: Reduces failure of the Containment Spray system by ANDing a new basic event, having a failure probability of <math>1 \times 10^{-3}</math>, for loss of additional redundant system and reducing the failure probability of the Containment Spray system and of associated operator actions to <math>1 \times 10^{-3}</math> each</i>            (Analysis Case for SAMA Nos. 39, 40, &amp; 50)</p> <p>39—Install a passive containment spray system \$10,000,000            40—Use the fire water system as a backup source for the containment spray system \$2,456,000            50—Install a redundant containment spray system \$10,000,000</p>	6%	45%	52%	\$3,909,000	\$8,052,000
<p>Case 27. Reduce Hydrogen Ignition  <i>Assumption: Eliminates hydrogen detonation</i>            (Analysis Case for SAMA Nos. 43, 51, &amp; 52)</p> <p>43—Provide post-accident containment inerting capability \$100,000            51—Install an independent power supply to the hydrogen control system using either new batteries, a non-safety grade portable generator, existing station batteries, or existing AC/DC independent power supplies, such as the security system \$100,000            52—Install a passive hydrogen control system \$100,000</p>	0%	<1%	<1%	\$3,430	\$7,080

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
Case 28 <sup>(f)</sup> . Increase Cooling and Containment of Molten Core Debris <i>Assumption: Eliminates propagation of molten core debris outside of containment</i> (Analysis Case for SAMA Nos. 44, 45, & 46)	0%	54%	61%	\$3,491,000
44 <sup>(f)</sup> —Create a large concrete crucible with heat removal potential to contain molten core debris				\$10,000,000
45 <sup>(f)</sup> —Create a core melt source reduction system				\$10,000,000
Case 29 <sup>(f)</sup> . High Pressure Core Ejection Occurrences <i>Assumption: Eliminates high pressure core ejection occurrences</i> (Analysis Case for SAMA No. 53)	0%	54%	61%	\$3,460,000
53 <sup>(f)</sup> —Erect a barrier that would provide enhanced protection of the containment walls (shell) from ejected core debris following a core melt scenario at high pressure				\$10,000,000
Case 30. Reduce Probability of Containment Failure <i>Assumption: Eliminates failure of containment</i> (Analysis Case for SAMA No. 48)	0%	86%	93%	\$6,947,000
48—Construct a building to be connected to primary/secondary containment and maintained at a vacuum				\$56,700,000
Case 31. Containment Isolation <i>Assumption: Eliminates failure of containment isolation</i> (Analysis Case for SAMA No. 55)	0%	<1%	<1%	\$9,150
55—Add redundant and diverse limit switches to each containment isolation valve				\$692,000

Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
Case 32. Reduce Frequency of Steam Generator Tube Rupture <i>Assumption: Eliminates steam generator tube rupture scenarios</i> (Analysis Case for SAMA Nos. 56, 57, 58, 59, & 60) 56—Institute a maintenance practice to perform a 100% inspection of steam generator tubes during each refueling outage 57—Increase the pressure capacity of the secondary side so that a steam generator tube rupture would not cause the relief valves to lift 58—Install a redundant spray system to depressurize the primary system during a steam generator tube rupture 59—Route the discharge from the main steam safety valves through a structure where a water spray would condense the steam and remove most of the fission products 60—Install a highly reliable (closed loop) steam generator shell-side heat removal system that relies on natural circulation and stored water sources	1%	6%	6%	\$886,000
				\$430,000
Case 33. Reduce Consequences of Steam Generator Tube Ruptures <i>Assumption: Reassigns the SGTR CDF contribution from the High-Early (H-E) release category to the Low-Intermediate (L-I) release category</i> (Analysis Case for SAMA Nos. 61 & 71) 61—Direct steam generator flooding after a steam generator tube rupture, prior to core damage 71—Manufacture a gagging device for a steam generator safety valve and develop a procedure or work order for closing a stuck-open valve <sup>(g)</sup>	0%	3%	4%	\$558,000
				\$271,000
Case 34. Reduce ATWS Frequency <i>Assumption: Eliminates contribution from ATWS</i> (Analysis Case for SAMA Nos. 63, 64, 65, & 66) 63—Add an independent boron injection system 64—Add a system of relief valves to prevent equipment damage from pressure spikes during an ATWS 65—Install motor generator set trip breakers in control room 66—Provide capability to remove power from the bus powering the control rods	1%	<1%	<1%	\$43,400
				\$21,100

Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>	
	CDF	PDR	OECR		Internal & External Benefit <sup>(a)</sup>
Case 37. Reduce Probability of a LOCA <i>Assumption: Eliminates large and medium LOCA scenarios</i> (Analysis Case for SAMA No. 69) 69—Install digital large break LOCA protection system	<1%	<1%	<1%	\$17,600	\$36,200
Case 38. Prevent Secondary Side Depressurization <i>Assumption: Eliminates steam line break outside of containment scenarios and inadvertent closure of MSIV scenarios</i> (Analysis Case for SAMA No. 70) 70—Install secondary side guard pipes up to the main steam isolation valves	<1%	<1%	0%	\$6,390	\$13,200
Case 39. Eliminate Thermally Induced Tube Ruptures Following Core Damage <i>Assumption: Eliminates thermally induced steam generator tube rupture scenarios</i> (Analysis Case for SAMA No. 54) 54—Modify procedures such that the water loop seals in the RCS cold legs are not cleared following core damage	0%	<1%	<1%	\$18,400	\$37,800
Case 40. Replace CARMVAAA201-B with a Fail Closed Air Operated Valve (AOV) <i>Assumption: Eliminates failure of motor-operated valve (MOV) CARMVAAA201-B due to loss of AC power</i> (Analysis Case for SAMA No. 62) 62—Hardware change to eliminate MOV CS-V-17 AC power dependency	0%	0%	0%	\$0	\$0
Case 41. Improve Internal Flooding Response Procedures and Training <sup>(k)</sup> <i>Assumption: Eliminates contribution from internal flooding in the Turbine Generator Building +15 elevation and Reactor Auxiliary Building +46 elevation</i> (Analysis Case for SAMA No. 67) 67—Improve internal flooding response procedures and training to improve the response to internal flooding events	n/a	n/a	n/a	\$15,700	\$32,400
Case 42. Water Tight Doors for the Largest Contributor to Internal Flooding <sup>(k)</sup> <i>Assumption: Eliminates contribution from internal flooding in flood zone RAB21-212/225B</i> (Analysis Case for SAMA No. 68) 68—Install flood doors to prevent water propagation in the electric board room	n/a	n/a	n/a	\$161,000	\$332,000
					\$1,268,000 <sup>(h)</sup>

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
Case 44. CCW Backup Auto-Start Signal <sup>(m)</sup> Assumption: <i>Eliminates failure to manually align CCW train AB to replace lost train A or B</i> (Analysis Case for SAMA No. 77) 77—Provide a diverse backup auto-start signal for the standby CCW trains on loss of the running train \$1,091,000	14%	28%	27%	\$2,196,000 \$4,525,000
SAMA Candidates Retained Without Evaluation as They are Already Commitments in the NFA 805 LAR (Entergy 2011) <sup>(i)</sup> (SAMA Nos. 74, 75, & 76) 74 <sup>(i)</sup> —Update six fire area heat detectors that have incorrect trip set points 75 <sup>(i)</sup> —In Fire Area RAB 27 remove personnel offices and other combustible materials 76—In Fire Area RAB 6 install a 1-hour fire resistance rating electrical raceway fire barrier system (ERFBS) fire wrap barrier from fire damage	n/a	n/a	n/a	n/a n/a n/a

	% Risk Reduction			Internal & External Benefit with Uncertainty <sup>(a)</sup>
	CDF	PDR	OECR	
<b>Analysis Case, Analysis Assumption, Individual SAMAs, and Cost Estimates</b>				
(a)	Risk reduction and benefit estimates were updated in response to NRC staff RAIs (Entergy 2017a).			
(b)	The cost estimate for SAMA 8 was updated in response to RAI 6.j (Entergy 2017a).			
(c)	The cost estimate for SAMA 21 was updated with a WF3-specific estimate (Entergy 2017a).			
(d)	SAMA 23 has already been implemented and was removed from the applicant's revised Table D.2-2 (Entergy 2017a). It is retained in this table for completeness.			
(e)	The cost estimate for SAMAs 18, 24, and 25 were originally based on one plant's estimate but subsequently changed to that of another (Entergy 2017a). The benefits remained below the cost estimates for each SAMA.			
(f)	SAMAs 44, 45, 46, and 53 were not retained in the applicant's revised Table D.2-2 because the applicant determined it not to be practical to implement at WF3 (Entergy 2017a). These SAMAs and the associated benefits for Analysis Cases 28 and 29 are retained in this table from the original analysis in the ER for completeness.			
(g)	SAMA 71 was updated in response to RAI 6.g to utilize the benefit of Case 33 rather than Case 43, which was removed from the applicant's revised Table D.2-2 (Entergy 2017a).			
(h)	The cost estimate for SAMA 68 was updated in response to RAI 6.i (Entergy 2017a). In response to RAI 2 (Entergy 2017b), lower cost alternatives (i.e., curb and flood barrier) were considered; however, these alternatives were not found to be cost beneficial.			
(i)	As indicated in the response to RAI 5.c, SAMAs 74, 75, and 76 have already been implemented (Entergy 2017a).			
(j)	The description of SAMAs 74 and 75 were updated consistent with the response to RAI 5.c (Entergy 2017a).			
(k)	Analysis Cases 41 and 42 only affected internal flooding events and were evaluated differently than the other SAMAs (see Section F.4).			
(l)	SAMA 9 was identified as cost beneficial based on a sensitivity study provided in response to RAI 4.g (Entergy 2017a). See Section F.6.1 for further discussion.			
(m)	Case 44 and SAMA 77 were added in response to RAI 7.b (Entergy 2017a).			
Key: n/a = not applicable				

## 1 F.6 Cost Impacts of Candidate Plant Improvements

2 As enumerated in Table F–5, Entergy estimated the costs of implementing 72 Phase II SAMAs  
 3 through the use of other licensees’ estimates for similar improvements and the development of  
 4 site-specific cost estimates, where appropriate. Cost estimates were not developed for the  
 5 three fire-related Phase II SAMAs that were retained without evaluation because they are  
 6 already commitments to be implemented in the NFPA 805 LAR (Entergy 2011). In response to  
 7 an RAI, Entergy stated that each of these fire-related SAMAs has already been implemented  
 8 (Entergy 2017a).

9 Entergy stated in the ER that the following cost ranges were used based on the review of  
 10 previous SAMA applications.

11 **Table F–5. Estimated Cost Ranges for SAMA Applications**

Type of Change	Estimated Cost Range
Procedural only	\$25K–\$50K
Procedural change with engineering or training required	\$50K–\$200K
Procedural change with engineering and testing or training required	\$200K–\$300K
Hardware modification	\$100K to >\$1000K

12 Entergy also stated that the WF3 site-specific cost estimates were based on the engineering  
 13 judgment of project engineers experienced in performing design changes at the facility.  
 14 The detailed cost estimates considered engineering, labor, materials, and support functions,  
 15 such as planning, scheduling, health physics, quality assurance, security, safety, and fire watch.  
 16 The estimates conservatively included a 20-30 percent contingency on the design costs and a  
 17 30-40 percent contingency on the installation costs but did not account for inflation, replacement  
 18 power during extended outages necessary for SAMA implementation, or increased maintenance  
 19 or operation costs following SAMA implementation.

20 The staff reviewed the applicant’s cost estimates, presented in Table D.2–2 of Attachment D to  
 21 the ER (Entergy 2016). For certain improvements, the staff also compared the cost estimates to  
 22 estimates developed elsewhere for similar improvements, including estimates developed as part  
 23 of other licensees’ analyses of SAMAs for operating reactors.

24 Entergy was asked in an RAI to provide more details on the WF3 specific cost estimate for  
 25 SAMA 35, “Provide a redundant train or means of ventilation,” since it is not clear if the scope of  
 26 the cost estimate is consistent with the stated intent of Case 23 “...to evaluate the change in  
 27 plant risk from a loss of HVAC in the battery, EDG, and main control rooms with temporary  
 28 HVAC such as fans, portable coolers, or opening doors” (NRC 2016a). In response to the RAI,  
 29 Entergy indicated that the cost estimate is consistent with providing a redundant train of EDG  
 30 room ventilation for EDG 3A [*which is the basis for the Case 23 benefit assessment*]. The cost  
 31 estimate assumes that the train would include instruments, an exhaust fan, and exhaust damper  
 32 controls. A redundant power source is not needed because the EDG ventilation system is  
 33 designed to maintain room temperature whenever the EDGs are in operation. Therefore, the  
 34 existing EDG ventilation system is powered by the EDG, through a safety-related bus and motor  
 35 control center, and the cost estimate assumes the new train would also be powered by the  
 36 EDG. Since a new train of ventilation for a battery room or the main control room would need a  
 37 redundant source of power, the implementation cost for such a modification would be larger for  
 38 those rooms (Entergy 2017a).

1 The NRC staff noted in an RAI that the cost for SAMA 68, “Install flood doors to prevent water  
 2 propagation in the electric board room,” is given as \$4,695,000 and stated to be from the  
 3 Sequoyah cost estimate. The Sequoyah License Renewal Application (LRA) ER indicates that  
 4 this is the cost for both Sequoyah units. Furthermore, the cost of such a modification would  
 5 appear to be strongly dependent on a specific plant layout. Entergy was asked in the RAI to  
 6 provide a cost that is valid for the WF3 plant configuration and also discuss if something, less  
 7 than a full flood door, such as a flood barrier, might achieve the same risk reduction benefit  
 8 (NRC 2016a). Entergy responded to the RAI that a plant-specific WF3 cost estimate was  
 9 developed to modify doors D16 and D9 to be flood doors to prevent water propagation to the  
 10 other electric board rooms. The WF3 plant specific cost estimate is \$1.27M (Energy 2017a).

11 The staff noted in an RAI that the cost for SAMA 8, “Use fire water system as a backup source  
 12 for diesel cooling,” is given as \$2,000,000 and stated to be from the Seabrook cost estimate.  
 13 Implementation of a similar SAMA for the Grand Gulf plant (SAMA 9) was estimated to cost  
 14 \$1,344,000. This is very near the assessed benefit at WF3 of \$1,338,000. Entergy was asked  
 15 in the RAI to provide a WF3-specific justification for the cost estimate for SAMA 8 (NRC 2016a).  
 16 Entergy responded to the RAI that the implementation cost estimate for the Grand Gulf plant  
 17 was a conceptual estimate performed using 2012 dollars. A recent PWR implementation  
 18 estimate was considered more applicable than the Grand Gulf estimate. Escalating the Grand  
 19 Gulf 2012 estimate to current dollars using a ratio of the consumer price indices would increase  
 20 the estimate to just over \$1.4M. Entergy concluded that SAMA 8 is now potentially cost  
 21 beneficial (Entergy 2017a).

22 The staff concludes that the cost estimates provided by Entergy are sufficient for use in the  
 23 SAMA evaluation because economic viability of the proposed modification could be adequately  
 24 gauged and the process meets the guidance provided in NEI 05-01A.

## 25 **F.7 Cost-Benefit Comparison**

26 Entergy’s cost-benefit analysis and the staff’s review are described in the following sections.

### 27 **F.7.1 Entergy’s Evaluation**

28 The methodology used by Entergy was based primarily on NRC’s guidance for performing  
 29 cost-benefit analysis (i.e., NUREG/BR-0184 (NRC 1997a)), which is referenced in the guidance  
 30 provided in NEI 05-01A. As described in Section 4.15.1.4 of the ER (Entergy 2016), the net  
 31 value was determined for each SAMA according to the following formula:

$$32 \quad \text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$

33 where

34 APE (averted public exposure) = present value of APE costs (\$)

35 AOC (averted offsite property damage costs) = present value of AOC costs (\$)

36 AOE (averted occupational exposure) = present value of AOE costs (\$)

37 AOSC (averted onsite costs) = present value of AOSC (\$)

38 COE = cost of enhancement (\$)

39 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the  
 40 benefit associated with the SAMA, and it is not considered to be cost beneficial. Entergy’s  
 41 derivation of each of the associated costs is summarized next.

## Appendix F

1 NEI 05-01 states that two sets of estimates should be developed for discount rates of 7 percent  
2 and 3 percent (NEI 2005). Entergy provided a base set of results using a discount rate of  
3 7 percent and a 20-year license renewal period.

### 4 *F.7.1.1 Averted Public Exposure (APE) Costs*

5 Entergy defined APE cost as the monetary value of accident risk avoided from population doses  
6 after discounting (Entergy 2016). The APE costs were calculated using the following formula:

$$\begin{aligned} 7 \quad \text{APE} &= \text{Annual reduction in public exposure } (\Delta \text{ person-rem per year}) \\ 8 \quad &\quad \times \text{monetary equivalent of unit dose } (\$2,000 \text{ per person-rem}) \\ 9 \quad &\quad \times \text{present value conversion (NRC 1997a)} \end{aligned}$$

10 The annual reduction in public exposure was calculated according to the following formula:

$$\begin{aligned} 11 \quad \text{Annual reduction in public exposure} &= (\text{Accident frequency without} \\ 12 \quad \text{modification} \times \text{accident population dose without modification}) &- (\text{Accident frequency} \\ 13 \quad \text{with modification} \times \text{accident population dose with modification}) \end{aligned}$$

14 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of  
15 the public health risk after discounting does not represent the expected reduction in public  
16 health risk due to a single accident. Rather, it is the present value of a stream of potential  
17 losses extending over the remaining lifetime (in this case, the 20-year renewal period) of the  
18 facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that  
19 such an accident could occur at any time over the renewal period, and the effect of discounting  
20 these potential future losses to present value. For a discount rate of 7 percent and a 20-year  
21 license renewal period with a CDF of  $1.05 \times 10^{-5}$  per year and a monetary equivalent of unit dose  
22 of \$2,000 per person-rem, the applicant calculated an APE cost of approximately \$342,000 for  
23 internal events (Entergy 2016). The NRC staff estimated a revised APE cost of approximately  
24 \$369,000 for internal events based on the revised analyses of the PDR and OECR summarized  
25 in Table F-2 because of changes that indirectly affect the APE provided in the RAI responses.

### 26 *F.7.1.2 Averted Offsite Property Damage Costs*

27 Entergy defined averted offsite property damage costs (AOC) as the monetary value of risk  
28 avoided from offsite property damage after discounting (Entergy 2011). The AOC values were  
29 calculated using the following formula:

$$30 \quad \text{AOC} = \text{Annual reduction in offsite property damage} \times \text{present value conversion}$$

31 The annual reduction in offsite property damage was calculated according to the  
32 following formula:

$$\begin{aligned} 33 \quad \text{Annual reduction in offsite property damage} &= (\text{Accident frequency without} \\ 34 \quad \text{modification} \times \text{accident property damage without modification}) &- (\text{Accident frequency} \\ 35 \quad \text{with modification} \times \text{accident property damage with modification}) \end{aligned}$$

36 For a discount rate of 7 percent and a 20-year license renewal period with a CDF of  $1.05 \times 10^{-5}$   
37 per year, the applicant calculated an AOC of approximately \$1,587,000 for internal events  
38 (Entergy 2016). The NRC staff estimated a revised AOC cost of approximately \$1,751,000 for  
39 internal events based on the revised analyses of the PDR and OECR summarized in Table F-2  
40 because of changes that indirectly affect the AOC provided in the RAI responses.

1 *F.7.1.3 Averted Occupational Exposure Costs*

2 Entergy defined AOE as the avoided onsite exposure (Entergy 2016). Similar to the APE  
3 calculations, the applicant calculated costs for immediate onsite exposure. Long-term onsite  
4 exposure costs were calculated consistent with guidance in NUREG/BR-0184 (NRC 1997a).

5 Entergy derived the values for AOE from information provided in Section 5.7.3 of  
6 NUREG/BR-0184 (NRC 1997a). Best estimate values provided for immediate occupational  
7 dose (3,300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year  
8 cleanup period) were used. The present value of these doses was calculated using the  
9 equations provided in the NUREG/BR-0184 handbook with a monetary equivalent of unit dose  
10 of \$2,000 per person-rem, a real discount rate of 7 percent, and a time period of 20 years to  
11 represent the license renewal period. Entergy assumed an accident frequency with modification  
12 of zero to overestimate and bound the long-term onsite exposure costs. Immediate and  
13 long-term onsite exposure costs were summed to determine AOE cost. For a CDF of  $1.05 \times 10^{-5}$   
14 per year, the applicant calculated an AOE cost of approximately \$4,000 for internal events  
15 (Entergy 2016). The AOE cost did not change as a result of the NRC staff RAIs.

16 *F.7.1.4 Averted Onsite Costs*

17 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted  
18 power replacement costs. Repair and refurbishment costs are considered for recoverable  
19 accidents only and not for severe accidents. The applicant derived the values for AOSC based  
20 on information provided in Section 5.7.6 of NUREG/BR-0184 (NRC 1997a). This cost element  
21 was divided into two parts: the onsite cleanup and decontamination cost, also commonly  
22 referred to as averted cleanup and decontamination costs; and the replacement power cost  
23 (RPC).

24 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} 25 \quad \text{ACC} &= \text{Annual CDF reduction} \\ 26 \quad &\quad \times \text{present value of cleanup costs per core damage event} \\ 27 \quad &\quad \times \text{present value conversion factor} \end{aligned}$$

28 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in  
29 NUREG/BR-0184 to be  $\$1.5 \times 10^9$  (undiscounted). This value was converted to present costs  
30 spread over a 10-year cleanup period and integrated over the term of the proposed license  
31 extension.

32 Long-term RPCs were calculated using the following formula:

$$\begin{aligned} 33 \quad \text{RPC} &= \text{Annual CDF reduction} \\ 34 \quad &\quad \times \text{present value of replacement power for a single event} \\ 35 \quad &\quad \times \text{factor to account for remaining service years for which replacement power} \\ 36 \quad &\quad \text{is required} \\ 37 \quad &\quad \times \text{reactor power scaling factor} \end{aligned}$$

38 Accounting for the WF3 EPU, the applicant based its calculations on a net electric output of  
39 1,188 megawatts-electric (MWe) and scaled up from the 910 MWe reference plant in  
40 NUREG/BR-0184 (NRC 1997a). Therefore, the applicant applied a power-scaling factor of  
41 1.31 (1188/910) to determine the RPC. For a CDF of  $1.05 \times 10^{-5}$  per year, Entergy calculated an  
42 AOSC of approximately \$230,000 from internal events for the 20-year license renewal period  
43 (Entergy 2016). The AOSC did not change as a result of the NRC staff RAIs.

1 Using the above equations, Entergy estimated the total present dollar value equivalent  
2 associated with completely eliminating severe accidents due to internal events at WF3 to be  
3 about \$2,163,000 (Entergy 2016, Table 4.15–1). The NRC staff estimated a revised value of  
4 approximately \$2,354,000 based on the NRC staff’s revised estimates for APE and AOC  
5 discussed above.

6 As clarified in response to an NRC staff RAI, the applicant multiplied the internal events  
7 estimated benefit by 3.57 to account for the risk contributions from external and internal flooding  
8 events to yield the internal and external benefit (Entergy 2017a). Additionally, as noted in  
9 response to another NRC staff RAI, the internal and external benefits were multiplied by a factor  
10 of 2.06 to account for uncertainties in the CDF calculation (Entergy 2017a). In total, a  
11 multiplication factor of 7.35 was applied to the estimated benefit from internal events to obtain  
12 the total estimated benefit for internal and external events with uncertainty, which was used in  
13 Entergy’s cost-benefit comparisons.

#### 14 *F.7.1.5 Entergy’s Results*

15 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA  
16 was determined not cost beneficial. If the benefit exceeded the estimated cost, the SAMA  
17 candidate was considered cost beneficial. In Entergy’s revised analysis, 13 SAMA candidates  
18 were found to be potentially cost beneficial (Entergy 2017a). One additional SAMA candidate  
19 was found to be potentially cost beneficial based on the results of sensitivity analyses. The  
20 results of the cost-benefit evaluation are presented in Table F–5.

21 The potentially cost-beneficial SAMAs are:

- 22 • SAMA No. 1—Provide additional DC battery capacity.
- 23 • SAMA No. 2—Replace lead-acid batteries with fuel cells.
- 24 • SAMA No. 3—Provide DC bus cross-ties.
- 25 • SAMA No. 5—Improve 4.16-kV bus cross-tie ability.
- 26 • SAMA No. 7—Install a gas turbine generator.
- 27 • SAMA No. 8—Bury off-site power lines.
- 28 • SAMA No. 9—Add a new backup source of diesel cooling.
- 29 • SAMA No. 26—Install improved reactor coolant pump seals.
- 30 • SAMA No. 34—Use fire water system as a backup for steam generator inventory.
- 31 • SAMA No. 36—Implement procedures for temporary HVAC.
- 32 • SAMA No. 40—Use the fire water system as a backup source for the containment  
33 spray system.
- 34 • SAMA No. 61—Direct steam generator flooding after a SGTR rupture, prior to core  
35 damage.
- 36 • SAMA No. 71—Manufacture a gagging device for a steam generator safety valve  
37 and developing a procedure or work order for closing a stuck-open valve.
- 38 • SAMA No. 77—Provide a diverse backup auto-start signal for the standby CCW  
39 trains on loss of the running train.

1 In response to an RAI, Entergy stated that each of these potentially cost-beneficial SAMAs has  
2 been submitted for detailed engineering project cost-benefit analysis to further evaluate their  
3 implementation (Entergy 2017b).

#### 4 **F.7.2 Review of Entergy's Cost-Benefit Evaluation**

5 Based primarily on NUREG/BR-0184 (NRC 1997a) and NEI guidelines on discount rates  
6 (NEI 2005), the staff determined the cost-benefit analysis performed by Entergy was consistent  
7 with the guidance. Nine SAMA candidates (i.e., SAMAs 1, 3, 5, 7, 26, 34, 36, 40, and 61) were  
8 found to be potentially cost beneficial based on the benefit from internal and external events,  
9 assuming an external events multiplier of 3.57 (Entergy 2017a).

10 The applicant considered possible increases in benefits from analysis uncertainties on the  
11 results of the SAMA assessment. In the ER (Entergy 2016a), Entergy stated that the  
12 95th percentile value of the WF3 CDF was a factor of 1.99 greater than the mean CDF.  
13 A multiplication factor of 1.99 was selected by the applicant to account for uncertainty. In an  
14 RAI, the NRC staff questioned the use of the mean CDF in the uncertainty analysis because the  
15 SAMA analysis was based on the point estimate CDF (NRC 2016a). In response to the RAI,  
16 Entergy revised the uncertainty multiplier to be the ratio of the 95th percentile CDF ( $2.164 \times 10^{-5}$   
17 per year) to the point estimate CDF ( $1.05 \times 10^{-5}$  per year), or 2.06. Based on this result, Entergy  
18 revised the uncertainty analysis to utilize the 2.06 uncertainty multiplier in addition to the  
19 external events multiplier of 3.57 to account for CDF increases due to external events. Three  
20 additional SAMA candidates (i.e., SAMAs 2, 8, and 71) were determined to be potentially cost  
21 beneficial as a result of the revised uncertainty analysis (Entergy 2017a).

22 The NRC staff considers the multipliers of 2.06 to account for uncertainty and 3.57 to account  
23 for external events provide adequate margin and are acceptable for the SAMA analysis.

24 In the ER, Entergy analyzed the sensitivity of the cost-benefit analysis results to a lower  
25 discount rate of 3 percent and a longer time period of 29 years for remaining plant life  
26 (20-year license renewal period + 9 years remaining on the original plant operating license).  
27 These sensitivity analyses were performed applying the external events multiplier of 3.57 to  
28 account for external events. No additional cost-beneficial SAMAs were identified as a result of  
29 these sensitivity analyses (Entergy 2016a). Entergy did not provide revised sensitivity analyses  
30 in their responses to the RAIs. The NRC staff considers this acceptable because the results of  
31 the uncertainty analysis bound these sensitivity analysis results.

32 The NRC staff noted in an RAI that uncertainties associated with two inputs (TIMDEC and  
33 CDNFRM) used in the MACCS computer analyses could potentially affect the SAMA analysis  
34 cost-benefit conclusions (NRC 2016a). In response to the RAI, Entergy provided a sensitivity  
35 analysis for all release categories that applied the maximum values specified by the staff for  
36 these inputs (i.e., 1 year (365 days)) for TIMDEC and \$100,000 for the CDNFRM values for the  
37 decontamination factor of 15. Based on its sensitivity analysis, Entergy concluded and the staff  
38 agreed that the uncertainties associated with the TIMDEC and CDNFRM input parameters are  
39 bound by the 95th percentile uncertainty multiplier of 2.06 discussed above. Therefore, there  
40 were no additional cost-beneficial SAMAs identified (Entergy 2017a).

41 In the ER, Entergy performed additional sensitivity analyses on MACCS input parameters for an  
42 increased evacuation time delay and for a slower evacuation speed. Entergy reported  
43 increases in population dose of less than 1 percent for each of these sensitivity cases. Based  
44 on these results, additional cost-beneficial SAMAs were not identified (Entergy 2016). Entergy  
45 did not provide revised sensitivity analyses of these MACCS input parameters in their  
46 responses to the RAIs. The NRC staff considers this acceptable because the SAMA analysis  
47 results are insensitive to these sensitivity analysis results.

## Appendix F

1 In response to an NRC staff RAI, Entergy evaluated potentially new and significant information  
2 with regard to the monetary equivalent of unit dose. Consistent with draft guidance in  
3 Revision 1 of NUREG–1530 (NRC 2015b), Entergy provided a sensitivity analysis replacing the  
4 current \$2,000 per person-rem with the anticipated new value of \$5,200 per person-rem. Based  
5 on its sensitivity analysis, Entergy identified one additional potentially cost-beneficial SAMA  
6 (i.e., SAMA 9) (Entergy 2017a).

7 The NRC staff asked the applicant in RAIs to evaluate potentially lower-cost alternatives to the  
8 candidate SAMAs evaluated in the ER, as summarized below (NRC 2016a):

- 9 • As an alternative to SAMA 27, “Install an additional component cooling water pump,”  
10 replace one of the CCW pumps with a diverse design that would lower the common  
11 cause pump failure. In response to the RAI, Entergy indicated that the common  
12 cause failure of the CCW pumps is not an important contributor to risk and that the  
13 benefit associated with eliminating them is insignificant (Entergy 2017a).
- 14 • As an alternative to SAMA 27, “Install an additional component cooling water pump,”  
15 provide diverse backup auto-start signals for the standby CCW trains on loss of the  
16 running train. In response to the RAI, Entergy estimated the implementation cost of  
17 this alternative to be \$1.1M and the benefit to be from \$2.1M (risk reduction from  
18 internal and external events) to \$4.5M (risk reduction from internal and external  
19 events and accounting for uncertainties). Based on these results, Entergy found this  
20 alternative to be potentially cost beneficial and designated it in the SAMA evaluation  
21 as SAMA 77 (Entergy 2017a).
- 22 • As an alternative to SAMA 68, “Install flood doors to prevent water propagation in the  
23 electric board room,” install something less than a full flood door, such as a flood  
24 barrier. As discussed above in Section F.3.2, in response to an NRC staff RAI,  
25 Entergy provided an evaluation of the benefit of such a barrier and concluded that it  
26 would not be cost-beneficial (Entergy 2017b).

27 The staff agrees with Entergy’s disposition of the above lower-cost alternatives because the  
28 lower-cost alternative evaluation was reasonable and consistent with NEI 05-01A guidance.

### 29 **F.8 Conclusions**

30 Entergy considered 201 candidate SAMAs based on risk-significant contributors at WF3 from  
31 current PSA models, its review of SAMA analyses from other PWR plants, NRC and industry  
32 documentation of potential plant improvements, and WF3 IPE and IPEEE. Phase I screening  
33 reduced the list to 74 unique SAMA candidates by eliminating SAMAs that were not applicable  
34 to WF3, had already been implemented at WF3, or were combined into a more comprehensive  
35 or plant-specific SAMA.

36 For the remaining SAMA candidates, Entergy performed a cost-benefit analysis with results  
37 shown in Table F–5. The cost-benefit analysis identified 12 potentially cost-beneficial SAMAs  
38 (Phase II SAMA Nos. 1, 2, 3, 5, 7, 8, 26, 34, 36, 40, 61, and 71). Sensitivity cases were  
39 analyzed for the present value discount rate, the time period for remaining plant life, the MACCS  
40 input parameters, and the monetary equivalent of unit dose. One additional SAMA  
41 (i.e., SAMA 9) was identified as potentially cost beneficial from these sensitivity analyses. In  
42 response to an NRC staff RAI concerning potential lower-cost alternatives, Entergy identified  
43 one additional potentially cost-beneficial SAMA (i.e., SAMA 177).

44 The staff reviewed the Entergy SAMA analysis and concludes that, subject to the discussion  
45 in this appendix, the methods used and implementation of the methods were sound. On the

1 basis of the applicant's treatment of SAMA benefits and costs, the staff finds that the  
2 SAMA evaluations performed by Entergy are reasonable and sufficient for the license  
3 renewal submittal.

4 The staff agrees with Entergy's conclusion that the 14 candidate SAMAs discussed in this  
5 section are potentially cost beneficial, which was based on generally conservative treatment of  
6 costs, benefits, and uncertainties. This conclusion of a small number of potentially  
7 cost-beneficial SAMAs is consistent with the low residual level of risk indicated in the WF3 PSA  
8 and the fact that Entergy has already implemented the plant improvements identified from the  
9 IPE and IPEEE. Because the potentially cost-beneficial SAMAs do not relate to aging  
10 management during the period of extended operation, they do not need to be implemented as  
11 part of license renewal in accordance with Title 10 of the Code of Federal Regulations, Part 54.  
12 Nevertheless, Entergy stated that each of these potentially cost-beneficial SAMAs has been  
13 submitted for detailed engineering project cost-benefit analysis to further evaluate their  
14 implementation.

## 15 **F.9 References**

16 [ASME] American Society of Mechanical Engineers. 2005. "Addenda to ASME RA-S-2002  
17 Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," New York,  
18 NY, ASME RA-Sb-2005, December 30, 2005.

19 [ASME/ANS] American Society of Mechanical Engineers and American Nuclear Society. 2009.  
20 Standard ASME/ANS RA-Sa-2009, "Addenda to ASME/ANS RA-S-2008, Standard for  
21 Level 1/Large Early Release Frequency Probabilistic Risk Assessment for Nuclear Power Plant  
22 Applications," February 2, 2009.

23 [EPRI] Electric Power Research Institute. 1992. "Fire-Induced Vulnerability Evaluation (FIVE),"  
24 TR-100370. Professional Loss Control, Inc. Palo Alto, CA. April 1992.

25 [EPRI] Electric Power Research Institute. 2014. Letter from S. Lewis, EPRI, to  
26 A.R. Petrangelo, Nuclear Energy Institute. Subject: Fleet Seismic Core Damage Frequency  
27 Estimates for Central and Eastern U.S. Nuclear Power Plants Using New Site-Specific Seismic  
28 Hazard Estimates. March 11, 2014. ADAMS Accession No. ML14083A586.

29 [Entergy] Entergy Operations, Inc. 1992. Letter from R.F. Burski, Entergy to U.S. Nuclear  
30 Regulatory Commission Document Control Desk. Subject: Waterford 3 SES, Docket  
31 No. 50-382, License No. NPF-38, Response to Generic Letter 88-20 "Individual Plant  
32 Examination for Severe Accident Vulnerabilities, 10 CFR 50.54(f)." August 1992.

33 [Entergy] Entergy Operations, Inc. 1995. Letter from R.F. Burski, Entergy, to U.S. Nuclear  
34 Regulatory Commission Document Control Desk. Subject: Waterford 3 SES, Docket  
35 No. 50-382, License No. NPF-38, Response to Generic Letter 88-20, Supplement 4, "Individual  
36 Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities."  
37 July 28, 1995.

38 [Entergy] Entergy Operations, Inc. 2014a. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
39 Regulatory Commission Document Control Desk. Subject: "License Amendment Request  
40 Technical Specification Change to Extend the Type A Test Frequency to 15 Years, Waterford  
41 Steam Electric Station, Unit 3, Docket No. 50-382, License No. NPF-38." Killona, LA.  
42 August 28, 2014. ADAMS Accession No. ML14241A305.

## Appendix F

- 1 [Entergy] Entergy Operations, Inc. 2014b. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
2 Regulatory Commission Document Control Desk. Subject: "Response to Request for  
3 Additional Information Regarding Adoption of the National Fire Protection Association Standard  
4 NFPA 805 License Amendment Request (LAR) Waterford Steam Electric Station, Unit 3  
5 (Waterford 3), Docket No. 50-382, License No. NPF-38." Killona, LA. June 11, 2014. ADAMS  
6 Accession No. ML14162A506.
- 7 [Entergy] Entergy Operations, Inc. 2014c. Letter from M. Chisum, Entergy, to U.S. Nuclear  
8 Regulatory Commission Document Control Desk. Subject: "Response to NRC Request for  
9 Information Pursuant to 10 CFR 50.54(f) Regarding Recommendation 2.1 of the Near-Term  
10 Task Force Review of Insights from the Fukushima Dai-ichi Accident." March 27, 2014.  
11 ADAMS Accession No. ML14086A427.
- 12 [Entergy] Entergy Operations, Inc. 2015a. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
13 Regulatory Commission Document Control Desk. Subject: "Response to Request for  
14 Additional Information Regarding Adoption of the National Fire Protection Association Standard  
15 NFPA 805 License Amendment Request (LAR) Waterford Steam Electric Station, Unit 3  
16 (Waterford 3), Docket No. 50-382, License No. NPF-38." Killona, LA. May 14, 2015. ADAMS  
17 Accession No. ML15138A057.
- 18 [Entergy] Entergy Operations, Inc. 2016. "Applicant's Environmental Report Operating License  
19 Renewal Stage Waterford Steam Electric Station, Unit 3." Appendix E to Waterford Steam  
20 Electric Station, Unit 3 License Renewal Application (LRA). March 2016. ADAMS Accession  
21 No. ML16088A324.
- 22 [Entergy] Entergy Operations, Inc. 2017a. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
23 Regulatory Commission Document Control Desk. Subject: "Responses to Request for  
24 Additional Information for the Environmental Review of the Waterford Steam Electric Station,  
25 Unit 3 (Waterford 3). February 7, 2017. ADAMS Accession No. ML17038A436.
- 26 [Entergy] Entergy Operations, Inc. 2017b. Letter from M.R. Chisum, Entergy, to U.S. Nuclear  
27 Regulatory Commission Document Control Desk. Subject: "Responses to Request for  
28 Additional Information for the Environmental Review of the Waterford Steam Electric Station,  
29 Unit 3 (Waterford 3). April 21, 2017. ADAMS Accession No. ML17114A432
- 30 [NEI] Nuclear Energy Institute. 2005. "Severe Accident Mitigation Alternative (SAMA) Analysis  
31 Guidance Document." NEI 05-01, Rev. A. Washington, DC. November 2005.
- 32 [NEI] Nuclear Energy Institute. 2008. "Process for Performing Internal Events PRA Peer  
33 Reviews Using the ASME/ANS PRA Standard, Revision 2," NEI 05-04, Washington, DC,  
34 November 2008.
- 35 [NRC] U.S. Nuclear Regulatory Commission. 1988. "Individual Plant Examination for Severe  
36 Accident Vulnerabilities." Generic Letter 88-20. November 23, 1988. ADAMS Accession  
37 No. ML031470299.
- 38 [NRC] U.S. Nuclear Regulatory Commission. 1990. *Severe Accident Risks: An Assessment  
39 for Five U.S. Nuclear Power Plants.* NUREG-1150. Washington, DC. ADAMS Accession  
40 Nos. ML040140729 and ML120960691.
- 41 [NRC] U.S. Nuclear Regulatory Commission. 1991a. "Individual Plant Examination of External  
42 Events (IPEEE) for Severe Accident Vulnerabilities." Generic Letter 88-20, Supplement 4.  
43 Washington, DC. June 28, 1991. ADAMS Accession No. ML031150485.
- 44 [NRC] U.S. Nuclear Regulatory Commission. 1991b. *Procedural and Submittal Guidance for  
45 the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities.*  
46 NUREG-1407. Washington, DC. May 1991. ADAMS Accession No. ML063550238.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 1997a. *Regulatory Analysis Technical Evaluation*  
2 *Handbook*. NUREG/BR-0184. Washington, DC. ADAMS Accession No. ML050190193.
- 3 [NRC] U.S. Nuclear Regulatory Commission. 1997b. *Individual Plant Examination Program:*  
4 *Perspectives on Reactor Safety and Plant Performance Parts 2-5, Final Report.*  
5 NUREG-1560, Vol. 2. Washington, DC. December 31, 1997. ADAMS Accession  
6 No. ML0635550228 (*nonpublic document*).
- 7 [NRC] U.S. Nuclear Regulatory Commission. 2000. Letter from N. Kalyanam, NRC, to  
8 C.M. Dugger, Entergy. Subject: "Waterford Steam Electric Station, Unit 3 – Re: Safety  
9 Evaluation of Licensee Response to Generic Letter 88-20, Supplement 4, 'Individual Plant  
10 Examination for Severe Accident Vulnerabilities' (TAC No. M83692)." July 27, 2000. ADAMS  
11 Accession No. ML003737109.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 2005. *EPRI/NRC-RES Fire PSA Methodology*  
13 *for Nuclear Power Facilities*. NUREG/CR-6850. Vols. 1 and 2. Washington, DC.  
14 September 2005. ADAMS Accession Nos. ML052580075 and ML052580118.
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2007. "An Approach for Determining the  
16 Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities,"  
17 Washington, DC, Regulatory Guide 1.200, Revision 1. January 2007.
- 18 [NRC] U.S. Nuclear Regulatory Commission. 2009. "An Approach for Determining the  
19 Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities."  
20 Regulatory Guide 1.200, Revision 2. March 2009. ADAMS Accession No. ML090410014.
- 21 [NRC] U.S. Nuclear Regulatory Commission. 2010. "NRC Information Notice 2010-18:  
22 Generic Issue 199, Implications of Updated Probabilistic Seismic Hazard Estimates in Central  
23 and Eastern United States on Existing Plants." Washington, DC. September 2, 2010.  
24 ADAMS Accession No. ML101970221.
- 25 [NRC] U.S. Nuclear Regulatory Commission. 2014. Letter from A. Wang, NRC, to Vice  
26 President, Operations, Entergy. Subject: "Waterford Steam Electric Station, Unit 3 – Staff  
27 Assessment of the Seismic Walkdown Report Supporting Implementation of Near-Term Task  
28 Force Recommendation 2.3 Related to the Fukushima Dai-ichi Nuclear Power Plant Accident  
29 (TAC No. MF0191)." May 8, 2014. ADAMS Accession No. ML14087A181.
- 30 [NRC] U.S. Nuclear Regulatory Commission. 2015a. Letter from F. Vega, NRC, to Site Vice  
31 President, Entergy. Subject: "Waterford Steam Electric Station, Unit 3 – Staff Assessment of  
32 Information Provided Pursuant to Title 10 *Code of Federal Regulations* Part 50,  
33 Section 50.54(f), Seismic Hazard Reevaluations for Recommendation 2.1 of the Near-Term  
34 Task Force Review of Insights from the Fukushima Dai-ichi Nuclear Power Plant Accident  
35 (TAC No. MF3712)." December 15, 2015. ADAMS Accession No. ML15335A050.
- 36 [NRC] U.S. Nuclear Regulatory Commission. 2015b. *Reassessment of NRC's Dollar per*  
37 *Person-Rem Conversion Factor Policy* (Draft Report for Comment). NUREG-1530, Rev. 1.  
38 Washington, DC. August 2015. ADAMS Accession No. ML15237A211.
- 39 [NRC] U.S. Nuclear Regulatory Commission. 2016a. Letter from E.M. Keegan, NRC, to  
40 M.R. Chisum, Entergy. Subject: "Request for Additional Information for the Environmental  
41 Review of Waterford Steam Electric Station, Unit 3, November 22, 2016. ADAMS Accession  
42 No. ML16309A580.
- 43 [NRC] U.S. Nuclear Regulatory Commission. 2016b. Letter from S. Wyman, NRC, to Site Vice  
44 President, Entergy. Subject: Staff Review High Frequency Confirmation Associated with  
45 Reevaluated Seismic Hazard Response to March 12, 2012 50.54(f) Request for Information.  
46 February 18, 2016. ADAMS Accession No. ML15364A544.

## Appendix F

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2016c. Letter from A.L. Pulvirenti, NRC, to Site  
2 Vice President, Entergy Operations, Inc. Subject: "Waterford Steam Electric Station,  
3 Unit 3—Issuance of Amendment Regarding Transition to a Risk-Informed Performance-Based  
4 Fire Protection Program in Accordance with 10 CFR 50.48(c) (CAC No. ME7602).  
5 June 27, 2016. ADAMS Accession No. ML16126A033.
- 6 [NRC] U.S. Nuclear Regulatory Commission. 2016d. Letter from V. Hall, NRC, to Site Vice  
7 President, Entergy. Subject: "Waterford Steam Electric Station, Unit 3—Interim Staff Response  
8 to Reevaluated Flood Hazards Submitted in Response to 10 CFR 50.54(f) Information  
9 Request—Flood Causing Mechanisms Reevaluation (CAC No. MF7125). April 12, 2016.  
10 ADAMS Accession No. ML16090A327.
- 11 [NRC] U.S. Nuclear Regulatory Commission. 2017. Letter from E.M. Keegan, NRC, to  
12 M.R. Chisum, Entergy. Subject: "Request for Additional Information for the Environmental  
13 Review of Waterford Steam Electric Station, Unit 3, March 28, 2017. ADAMS Accession  
14 No. ML17086A585.

**BIBLIOGRAPHIC DATA SHEET**

(See instructions on the reverse)

1. REPORT NUMBER  
(Assigned by NRC, Add Vol., Supp., Rev.,  
and Addendum Numbers, if any.)  
NUREG-1437  
Supplement 59

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 59  
Regarding Waterford Steam Electric Station, Unit 3

3. DATE REPORT PUBLISHED

MONTH	YEAR
August	2018

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 6

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of Materials and License Renewal  
Office of Nuclear Regulatory Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Same as above.

10. SUPPLEMENTARY NOTES

Docket No. 50-382

11. ABSTRACT (200 words or less)

The U.S. Nuclear Regulatory Commission (NRC) staff prepared this draft supplemental environmental impact statement (SEIS) in response to Entergy Louisiana, LLC and Entergy Operations, Inc.'s application to renew the operating license for Waterford Steam Electric Station, Unit 3 (Waterford 3) for an additional 20 years. This draft SEIS includes the NRC staff's preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include: (1) new nuclear power generation, (2) supercritical pulverized coal, (3) natural gas combined cycle, and (4) a combination of natural gas combined-cycle, biomass, and demand-side management, and (5) the no-action alternative (i.e. the operating license is not renewed). The NRC staff's preliminary recommendation is that the adverse environmental impacts of license renewal for Waterford are not so great that preserving the option of license renewal for energy planning decisionmakers would be unreasonable.

The NRC staff based its recommendation on the following factors:

- the analysis and findings in NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants"
- the environmental report submitted by Entergy
- the NRC staff's consultation with Federal, State, Tribal, and local agencies
- the NRC staff's independent environmental review

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Waterford 3  
Entergy Operations, Inc.  
Entergy Louisiana, LLC  
Supplement to the Generic Environmental Impact Statement, SEIS  
Generic Environmental Impact Statement, GEIS  
National Environmental Policy Act, NEPA  
NUREG-1437, Supplement 59  
Pressurized Water Reactor, PWR

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program





**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, DC 20555-0001  
\_\_\_\_\_  
OFFICIAL BUSINESS



**NUREG-1437  
Supplement 59  
Draft**

**Generic Environmental Impact Statement for License Renewal of Nuclear Plants  
Regarding Waterford Steam Electric Station, Unit 3**

**August 2018**