

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)  
DISTRIBUTION FOR INCOMING MATERIAL

50-250-251/335

REC:  
NRC

ORG: SCHMIDT A D  
FL PWR & LIGHT

DOC DATE: 02/14/78  
DATE RCVD: 02/21/78

DOCTYPE: LETTER NOTARIZED: NO  
SUBJECT: MONTHLY OPERATING REPT FOR SUBJECT UNITS 3 & 4 AND UNIT 1. FOR  
JANUARY, 1978.

COPIES RECEIVED  
LTR 1 ENCL 1

PLANT NAME: TURKEY PT #3  
TURKEY PT #3  
ST LUCIE #1

REVIEWER INITIAL: XJM  
DISTRIBUTER INITIAL:

\*\*\*\*\* DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS \*\*\*\*\*

MONTHLY OPERATING REPORT FOR GRAY BOOK PREPARATION.  
(DISTRIBUTION CODE A003)

FOR ACTION: BR CHIEF SCHWENGER\*\*W/2 ENCL

INTERNAL: REG FILE\*\*W/ENCL NRC PDR\*\*W/ENCL  
MIPC FOR ACTION\*\*W/2 ENCL

EXTERNAL: LPDR'S  
MIAMI, FL\*\*W/ENCL  
TIC\*\*W/ENCL  
NSIC\*\*W/ENCL  
BNL(NATLAB)\*\*W/ENCL  
ACRS CAT B\*\*W/O ENCL

DISTRIBUTION: LTR 10 ENCL 10  
SIZE: 1P+1P+2P

CONTROL NBR: 780530005

\*\*\*\*\* THE END \*\*\*\*\*





February 14, 1978

Office of Management Information  
and Program Controls  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:


Attached are the January, 1978, Operating Summary Reports  
for Turkey Point Unit Nos. 3 and 4 and St. Lucie Unit No. 1.

Very truly yours,

A. D. Schmidt  
Vice President  
Power Resources

VTC/bab

cc: Mr. James P. O'Reilly  
Robert Lowenstein, Esquire



A003/S  
1/1

780530005

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250

Turkey Point  
UNIT Unit No. 3

DATE February 14, 1978

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3830

REPORT MONTH January 1978

Turkey Point Unit No. 3 scheduled refueling, maintenance, and inspections continued.

Major Safety-related maintenance performed during the month will be included in a separate Refueling Outage Report to be submitted after the unit is returned to service.

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251  
Turkey Point  
UNIT Unit No. 4

DATE February 14, 1978

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3824

REPORT MONTH January 1978

Turkey Point Unit No. 4 operated at approximately 100% R.P. except for outage of January 25, 1978. Refer to Unit Shutdowns and Power Reduction Sections of the Operating Status Report for details of this outage.

Major Safety-related Maintenance performed during the month included the corrective actions taken to ensure operability of the flow path from the Boric Acid Storage Tank to the charging pump suction line. Refer to Licensee Event Report No. 251-78-1 for additional details.

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-335

UNIT St. Lucie Unit No. 1

DATE February 14, 1978

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3824

REPORT MONTH January 1978

St. Lucie Unit No. 1 operated at approximately 100% R. P. except for outages of January 13, 23 - 25; 28, 29, and 31, 1978. Refer to Unit Shutdowns and Power Reduction Section of the Operating Status Report for additional details of these outages.

Major Safety-related maintenance performed during the month included the replacement of a failed gasket on the pressurizer manway closure head and the replacement of five (5) pressurizer manway closure head retaining studs. Refer to Licensee Event Report No. 335-78-5 for additional details of the inspection and replacement of the pressurizer manway closure head retaining studs.



Handwritten mark or signature at the top right corner.