

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: V. STELLO, JR.

FROM: FLORIDA POWER & LIGHT CO.
MIAMI, FLORIDA
R.E. UHRIG

DATE OF DOCUMENT
12/30/76

DATE RECEIVED
1/6/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1

DESCRIPTION

LETTERS RE: THEIR SUBMITTAL OF 12/9/76 TRANS THE FOLLOWING.....

PLANT NAME: TURKEY PT # 3 & 4

ENCLOSURE

SUPPLEMENTAL INFORMATION PERTAINING TO THE ECCS REEVALUATION

(1 CARBON SIGNED CY. RECEIVED)
(15 PAGES)

SAFETY

FOR ACTION/INFORMATION

ENVIRO

SAB 1/11/77

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST. :

LEAR (6)

ELLIOTT

PARRISH

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST.:

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> (REG FILE)	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> R & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
<input checked="" type="checkbox"/> OELD		LAINAS	
<input checked="" type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
<input checked="" type="checkbox"/> MIPC	MACARRY	KIRKWOOD	ERNST
<input checked="" type="checkbox"/> CASE	KNIGHT		BALLARD
<input checked="" type="checkbox"/> HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
<input checked="" type="checkbox"/> HARLESS	PAWLICKI	STELLO	
			SITE TECH.
<input checked="" type="checkbox"/> PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
<input checked="" type="checkbox"/> BOYD	ROSS	EISENHUT	STEPP
<input checked="" type="checkbox"/> P. COLLINS	NOVAK (3)	SHAO	HULMAN
<input checked="" type="checkbox"/> HOUSTON	ROSZTOCZY	BAER	
<input checked="" type="checkbox"/> PETERSON	CHECK	BUTLER	SITE ANALYSIS
<input checked="" type="checkbox"/> MELTZ		GRIMES	VOLLNER
<input checked="" type="checkbox"/> HELTEMES	AT & I		BUNCH
<input checked="" type="checkbox"/> SKOVHOLT	SALTZMAN		J. COLLINS
<input checked="" type="checkbox"/> DEYOUNG	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: MIAMI, FL.	NAT. LAB:	BROOKHAVEN NAT. LAB.
<input checked="" type="checkbox"/> TIC:	REG V. IE	ULRIKSON (ORNL)
<input checked="" type="checkbox"/> NSIC:	IA PDR	
<input checked="" type="checkbox"/> ASLB:	CONSULTANTS:	
<input checked="" type="checkbox"/> ACRS 16 CYS HOLDING/SENT		

CATEGORY-B DOCUMENT
FINFO ACRS

25.


ECCS
1



Regulatory

File Cy-

P. O. BOX 013100, MIAMI, FL 33101




December 30, 1976
L-76-439

Office of Nuclear Reactor Regulation
Attn: Victor Stello, Jr., Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
ECCS Reevaluation
Supplemental Information



The ECCS Reevaluation performed for Turkey Point Units 3 and 4 was submitted by Florida Power & Light Company on December 9, 1976, (L-76-419).

Attached herewith is supplemental information related to the reevaluation which was requested by your staff.

Very truly yours,

E. J. Adomat

for.

Robert E. Uhrig
Vice President

REU/GDW/hlc
Attachment

cc: Norman C. Moseley, Region II
Robert Lowenstein, Esq.



QUESTION

Justify the statement, made in the L-76-419 letter of December 9, 1976, that Cycle 3 is more limiting than Cycle 4 in terms of the parameters used in determining the ECCS performance.

ANSWER

The following response addresses Turkey Point Unit 3. The Unit 4 response will be included in the Unit 4 Cycle 4 RSE which will be submitted at a future date.

The ECCS analysis was performed for Cycle 3, Region 3. Region 3 fuel, which has the lowest theoretical density (92.0%) has the largest stored energy of any fuel region in the core, and therefore results in the highest calculated peak clad temperature for the ECCS analysis. Unit 3, Cycle 4 will not contain any Region 3 fuel, and the new fuel added (Region 6) has a higher theoretical density (94.5%) and lower stored energy than Region 3 fuel. Therefore Cycle 3 is more limiting than Cycle 4 with respect to ECCS performance.



QUESTION - Show which of the curves in Figures 1a through 8d correspond to hot spot location and which to clad burst location (most of the curves are unlabeled).

ANSWER - Figures 1a through 4d and 7a through 8d have been labeled so that comparison with Table 2 will show which curves correspond to hot spot location and which to clad burst location. The labeled curves are attached:




Figure 1a. Fluid Quality — DECLG ($C_D = 1.0$)




Figure 1b. Fluid Quality - DECLG ($C_D = 0.6$)




Figure 1c. Fluid Quality - DECLG ($C_D = 0.4$)




Figure 1d. Fluid Quality - DECLG ($C_D = 0.4$)




Figure 2a. Mass Velocity -- DECLG ($C_D = 1.0$)




Figure 2b. Mass Velocity -- DECLG ($C_D = 0.6$)




Figure 2c. Mass Velocity -- DECLG ($C_D = 0.4$)




Figure 2d. Mass Velocity - DECLG ($C_D = 0.4$)




Figure 3a, Heat Transfer Coefficient - DECLG ($C_D = 1.0$)




Figure 3b. Heat Transfer Coefficient - DECLG ($C_D = 0.6$)




Figure 3c. Heat Transfer Coefficient -- DECLG ($C_D = 0.4$)






Figure 3d. Heat Transfer Coefficient · DECLG ($C_D \cdot 0.4$)




Figure 4a. Core Pressure - DECLG ($C_D = 1.0$)






Figure Bcl. Fluid Temperature - DFGI G ($G_D = 0.4$)




Figure 8c. Fluid Temperature -- DECLG ($C_D = 0.4$)




Figure 8b. Fluid Temperature - DECLG ($C_D = 0.8$)




Figure 8a. Fluid Temperature. - DECLG ($C_D = 1.0$)




Figure 7d, Peak Clad Temperature - DECLG ($C_D = 0.4$)




Figure 7c. Peak Clad Temperature - DECLG ($C_D = 0.4$)




Figure 7b. Peak Clad Temperature - DECLG ($C_D = 0.6$)




Figure 7a. Peak Clad Temperature -- DECLG ($C_D = 1.0$)




Figure 4d. Core Pressure -- DECLG ($C_D = 0.4$)





Figure 4c, Core Pressure -- DECLG ($C_D = 0.4$)



0
1
2




Figure 4b. Core Pressure -- DECLG ($C_D = 0.6$)

