





May 5, 1977

Office of Management Information
and Program Controls
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Regulatory

File On

Gentlemen:

Attached are the April, 1977, Operating Status Reports
for Turkey Point Unit Nos. 3 and 4 and St. Lucie Unit
No. 1.


Very truly yours,

A handwritten signature in cursive script, appearing to read "A. D. Schmidt".

A. D. Schmidt
Vice President
Power Resources

VTC/DDC

cc: Mr. Norman C. Moseley
Robert Lowenstein, Esquire



771340018



APPENDIX B
AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 250
Turkey Point
UNIT Unit No. 3

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

MONTH April 1977

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>677</u>
2	<u>673</u>
3	<u>673</u>
4	<u>669</u>
5	<u>672</u>
6	<u>673</u>
7	<u>623</u>
8	<u>567</u>
9	<u>683</u>
10	<u>680</u>
11	<u>678</u>
12	<u>683</u>
13	<u>682</u>
14	<u>676</u>
15	<u>671</u>
16	<u>668</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>671</u>
18	<u>666</u>
19	<u>667</u>
20	<u>665</u>
21	<u>656</u>
22	<u>341</u>
23	<u>603</u>
24	<u>---</u>
25	<u>---</u>
26	<u>---</u>
27	<u>---</u>
28	<u>---</u>
29	<u>308</u>
30	<u>666</u>
31	<u>---</u>

NOTE: Average daily power
greater than 666 MWe
due to cooler condenser
cooling water.

APPENDIX C
OPERATING DATA REPORT

DOCKET NO. 50 - 250
Turkey Point
 UNIT Unit No. 3

REPORT MONTH April 1977

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

OPERATING STATUS

1. REPORTING PERIOD: 0001,77,04,01 GROSS HOURS IN REPORTING PERIOD: 719.0*
 THROUGH 2400,77,04,30
2. CURRENTLY AUTHORIZED POWER LEVEL (MWe): 2200
 MAX. DEPEND. CAPACITY (MWe-Net): 666
 DESIGN ELECTRICAL RATING (MWe-Net): 693
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): NONE
4. REASONS FOR RESTRICTION (IF ANY):

	THIS MONTH	YEAR TO DATE	CUMULATIVE
5. NUMBERS OF HOURS REACTOR WAS CRITICAL.....	<u>594.2</u>	<u>2 388.8</u>	<u>30 428.9</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>67.4</u>
7. HOURS GENERATOR ON LINE.....	<u>579.6</u>	<u>2 246.5</u>	<u>29 285.7</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>85.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH).....	<u>1 244 675</u>	<u>4 783 145</u>	<u>56 512 733</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)...	<u>401 220</u>	<u>1 554 580</u>	<u>18 125 031</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH).....	<u>380 593</u>	<u>1 474 705</u>	<u>17 150 690</u>
12. REACTOR SERVICE FACTOR.....	<u>82.6</u>	<u>83.0</u>	<u>78.8</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>82.6</u>	<u>83.0</u>	<u>79.0</u>
14. UNIT SERVICE FACTOR.....	<u>80.6</u>	<u>78.0</u>	<u>75.8</u>
15. UNIT AVAILABILITY FACTOR.....	<u>80.6</u>	<u>78.0</u>	<u>76.1</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>79.5</u>	<u>76.9</u>	<u>67.5</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>76.4</u>	<u>73.9</u>	<u>64.1</u>
18. UNIT FORCED OUTAGE RATE.....	<u>1.7</u>	<u>1.5</u>	<u>2.8</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):
Steam Generator Inspection - July 10 - Aug. 6, 1977
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NOTE: * Change to Daylight Saving Time

APPENDIX D

UNIT SHUTDOWNS AND POWER REDUCTIONS

BUCKET NO. 50 - 250

UNIT NAME Turkey Point Unit No. 3

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

REPORT MONTH April 1977

- 1) REASON
 A: EQUIPMENT FAILURE (EXPLAIN)
 B: MAINT. OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION
 E: OPERATOR TRAINING AND LICENSE EXAMINATION
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN)
 H: OTHER (EXPLAIN)

- 2) METHOD
 1: MANUAL
 2: MANUAL SCRAM
 3: AUTOMATIC SCRAM
 4: OTHER (EXPLAIN)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
11	77-04-07	S	-0-	B	4	Load reduction to perform periodic test of turbine main steam stop, reheat stop, and reheat intercept valves. (Non-nuclear system)
12	77-04-22	F	9.8	B	1	Unit No. 3 was removed from service to repair stem packing leak on drain valve located inside containment. (Nuclear system)
13	77-04-24	S	129.6	B	1	Unit No. 3 was removed from service for maintenance. (Nuclear and Non-nuclear system)

SUMMARY: Unit No. 3 operated at approximately 100% R.P. except for load reduction on April 7, 1977, and outages on April 22, and April 24 to 29, 1977.

APPENDIX C
OPERATING DATA REPORT

DOCKET NO. 50 - 251
Turkey Point
 UNIT Unit No. 4

REPORT MONTH April 1977

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

OPERATING STATUS


1. REPORTING PERIOD: 0001,77,04,01 GROSS HOURS IN REPORTING PERIOD: 719.0*
 THROUGH 2400,77,04,30
2. CURRENTLY AUTHORIZED POWER LEVEL (Mw): 2200
 MAX. DEPEND. CAPACITY (MWe-Net): 666
 DESIGN ELECTRICAL RATING (MWe-Net): 693
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): NONE
4. REASONS FOR RESTRICTION (IF ANY):

	THIS MONTH	YEAR TO DATE	CUMULATIVE
5. NUMBERS OF HOURS REACTOR WAS CRITICAL.....	<u>611.5</u>	<u>2 394.9</u>	<u>24 116.7</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>138.8</u>
7. HOURS GENERATOR ON LINE.....	<u>611.0</u>	<u>2 375.2</u>	<u>22 917.2</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
9. GROSS THERMAL ENERGY GENERATED (MWH).....	<u>1 334 083</u>	<u>5 164 436</u>	<u>48 223 806</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)....	<u>433 400</u>	<u>1 685 065</u>	<u>15 642 748</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH).....	<u>412 373</u>	<u>1 602 874</u>	<u>14 833 340</u>
12. REACTOR SERVICE FACTOR.....	<u>85.0</u>	<u>83.2</u>	<u>74.6</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>85.0</u>	<u>83.2</u>	<u>75.0</u>
14. UNIT SERVICE FACTOR.....	<u>85.0</u>	<u>82.5</u>	<u>70.9</u>
15. UNIT AVAILABILITY FACTOR.....	<u>85.0</u>	<u>82.5</u>	<u>70.9</u>
16. UNIT CAPACITY FACTOR (Using (MDC).....	<u>86.1</u>	<u>83.6</u>	<u>69.5</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>82.8</u>	<u>80.3</u>	<u>66.2</u>
18. UNIT FORCED OUTAGE RATE.....	<u>-0-</u>	<u>-0-</u>	<u>3.2</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):
 Refueling, maintenance, and inspections - May 9 - July 9, 1977
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: May 4, 1977

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICITY	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

NOTE: * Change to Daylight Saving Time



APPENDIX B
AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 251
Turkey Point
UNIT Unit No. 4

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

MONTH April 1977

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>671</u>
2	<u>670</u>
3	<u>673</u>
4	<u>673</u>
5	<u>674</u>
6	<u>673</u>
7	<u>683</u>
8	<u>682</u>
9	<u>682</u>
10	<u>684</u>
11	<u>691</u>
12	<u>692</u>
13	<u>687</u>
14	<u>679</u>
15	<u>682</u>
16	<u>676</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>680</u>
18	<u>682</u>
19	<u>678</u>
20	<u>675</u>
21	<u>675</u>
22	<u>672</u>
23	<u>671</u>
24	<u>641</u>
25	<u>671</u>
26	<u>282</u>
27	<u>---</u>
28	<u>---</u>
29	<u>---</u>
30	<u>---</u>
31	<u>---</u>

NOTE: Average daily power greater than 666 MWe due to cooler condenser cooling water.

- 1) REASON
 A: EQUIPMENT FAILURE (EXPLAIN)
 B: MAINT. OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION
 E: OPERATOR TRAINING AND
 LICENSE EXAMINATION
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN)
 H: OTHER (EXPLAIN)

APPENDIX D

UNIT SHUTDOWNS AND POWER REDUCTIONS


REPORT MONTH April 1977

DOCKET NO. 50 - 251
 UNIT NAME Turkey Point Unit No. 4
 DATE May 5, 1977
 COMPLETED BY V. T. Chilson
 TELEPHONE (305) 552-3769

- 2) METHOD
 1: MANUAL
 2: MANUAL SCRAM
 3: AUTOMATIC SCRAM
 4: OTHER (EXPLAIN)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
4	77-04-26	S	108.0	A	1	Unit No. 4 was removed from service to repair steam generator No. 4C tube leak. Corrective actions included plugging three leaking tubes. Additional tubes were plugged as a preventative measure. (Nuclear system)

SUMMARY: Unit No. 4 operated at approximately 100% R.P. except for outage of April 26 to May 4, 1977.



APPENDIX B
AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 335

St. Lucie
UNIT Unit No. 1

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

MONTH April 1977

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>755</u>
2	<u>773</u>
3	<u>181</u>
4	<u>---</u>
5	<u>---</u>
6	<u>---</u>
7	<u>---</u>
8	<u>---</u>
9	<u>---</u>
10	<u>---</u>
11	<u>188</u>
12	<u>786</u>
13	<u>794</u>
14	<u>776</u>
15	<u>509</u>
16	<u>---</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>---</u>
18	<u>---</u>
19	<u>---</u>
20	<u>---</u>
21	<u>---</u>
22	<u>---</u>
23	<u>---</u>
24	<u>---</u>
25	<u>---</u>
26	<u>---</u>
27	<u>---</u>
28	<u>---</u>
29	<u>150</u>
30	<u>242</u>
31	<u>---</u>

NOTE: Average daily power
greater than 777 MWe
due to cooler condenser
cooling water.

APPENDIX C
OPERATING DATA REPORT

DOCKET NO. 50 - 335
St. Lucie
 UNIT Unit No. 1

REPORT MONTH April 1977

DATE May 5, 1977

COMPLETED BY V. T. Chilson

TELEPHONE (305) 552-3769

OPERATING STATUS

1. REPORTING PERIOD: 0001,77,04,01 GROSS HOURS IN REPORTING PERIOD: 719.0*
 THROUGH 2400,77,04,30
2. CURRENTLY AUTHORIZED POWER LEVEL (MWe): 2560
 MAX. DEPEND. CAPACITY (MWe-Net): 777 (Est.)
 DESIGN ELECTRICAL RATING (MWe-Net): 802
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): NONE
4. REASONS FOR RESTRICTION (IF ANY):


	THIS MONTH	YEAR TO DATE	CUMULATIVE
5. NUMBERS OF HOURS REACTOR WAS CRITICAL.....	<u>207.4</u>	<u>2 313.6</u>	<u>2 577.6</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
7. HOURS GENERATOR ON LINE.....	<u>181.8</u>	<u>2 217.4</u>	<u>2 481.4</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
9. GROSS THERMAL ENERGY GENERATED (MWH).....	<u>407 185</u>	<u>4 706 482</u>	<u>5 054 085</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)...	<u>133 040</u>	<u>1 545 000</u>	<u>1 653 270</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH).....	<u>118 624</u>	<u>1 440 576</u>	<u>1 539 551</u>
12. REACTOR SERVICE FACTOR.....	<u>28.8</u>	<u>80.3</u>	<u>82.0</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>28.8</u>	<u>80.3</u>	<u>82.0</u>
14. UNIT SERVICE FACTOR.....	<u>25.3</u>	<u>77.0</u>	<u>79.0</u>
15. UNIT AVAILABILITY FACTOR.....	<u>25.3</u>	<u>77.0</u>	<u>79.0</u>
16. UNIT CAPACITY FACTOR (Using (MDC).....	<u>21.2</u>	<u>64.4</u>	<u>63.0</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>20.6</u>	<u>62.4</u>	<u>61.1</u>
18. UNIT FORCED OUTAGE RATE.....	<u>74.7</u>	<u>21.1</u>	<u>19.3</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NOTE: * Change to Daylight Saving Time



(1) REASON

- A: EQUIPMENT FAILURE (EXPLAIN)
 B: MAINT. OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION
 E: OPERATOR TRAINING AND
 LICENSE EXAMINATION
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN)
 H: OTHER (EXPLAIN)

APPENDIX D

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH April 1977DOCKET NO. 50 - 335UNIT NAME St. Lucie Unit No. 1DATE May 5, 1977COMPLETED BY V. T. ChilsonTELEPHONE (305) 552-3769

(2) METHOD

- 1: MANUAL
 2: MANUAL SCRAM
 3: AUTOMATIC SCRAM
 4: OTHER (EXPLAIN)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
12	77-04-03	F	200.0	A	2	Unit was manually tripped when a fire occurred in the area of the generator main lead box. Corrective actions included repairing hydrogen leak and modifying generator main lead box. Outage was extended to perform other maintenance work. (Non-nuclear system)
13	77-04-15	F	332.5	A	2	Unit was manually tripped due to loss of containment instrument air which resulted in loss of component cooling water to equipment located inside containment. Corrective actions included replacing the instrument air compressor discharge check valves and providing an automatic redundant instrument air supply. (Nuclear System)
14	77-04-30	F	4.6	A	3	Unit was tripped during transient condition caused by malfunction of heater drain pump control system. (Non-nuclear system)

SUMMARY: Unit operated at approximately 99% R.P. except for unit outages on April 3 to 11, April 15 to 29, and April 30, 1977.

