

C 07/13/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-250/251

REC: STELLO V
NRC

ORG: UHRIG R E
FL PWR & LIGHT

DOC DATE: 07/10/78
DATE RCVD: 07/12/78

DOCTYPE: LETTER NOTARIZED: YES
SUBJECT:

COPIES RECEIVED
LTR 3 ENCL 40

FORWARDING LIC NOS DPR-31 & 41 APPL FOR AMEND: TECH SPEC PROPOSED CHANGE
CONCERNING PROPOSED CHANGES TO ALLOW FULL PWR OPERATION WITH UP TO 25% OF THE
STEAM GENERATOR TUBES PLUGGED... NOTARIZED 07/10/78... W/ATT NAD-1483 REPT,
VOLUME 1, TITLE AS LISTED.

PLANT NAME: TURKEY PT #3
TURKEY PT #4

566
Rpts

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF ORB#1 BC**W/5 ENCL

INTERNAL: REG FILE**W/ENCL
I & E**W/2 ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
REACTOR SAFETY BR**W/ENCL
EEB**W/ENCL
J. MCGOUGH**W/ENCL

NRC PDR**W/ENCL
OELD**LTR ONLY
CORE PERFORMANCE BR**W/ENCL
ENGINEERING BR**W/ENCL
PLANT SYSTEMS BR**W/ENCL
EFFLUENT TREAT SYS**W/ENCL

EXTERNAL: LPDR'S
MIAMI, FL**W/ENCL
TERA**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 40 ENCL 39
SIZE: 3P+55P+75P

CONTROL NBR: 781940005

AA2

***** THE END *****





July 10, 1978
L-78-230

REGISTRATION
SERVICES

JUL 12 1978

REGISTRATION

Office of Nuclear Reactor Regulation
Attention: Mr. Victor Stello, Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed Amendment to
Facility Operating Licenses
DPR-31 and DPR-41

Turkey Point Units 3 and 4 are presently authorized to operate with up to 19% of the steam generator tubes plugged. Florida Power & Light Company requests an amendment to Facility Operating Licenses DPR-31 and DPR-41 to allow full power operation with up to 25% of the steam generator tubes plugged. The safety analysis performed for the LOCA transient and the associated proposed changes to Facility Technical Specifications will be submitted by August 10, 1978.

The following changes to Technical Specifications are proposed to allow full power operation with up to 25% of the steam generator tubes plugged. These proposed changes result from the analysis of non-LOCA transients with 25% steam generator tubes plugged.

Figure 2.1-1b Reactor Core Thermal and Hydraulic Limits are added for operation with steam generator tube plugging between 19% and 25%.

Page 2.3-2 This page is revised to be effective for up to 25% steam generator tubes plugged.

Page 2.3-3 This page is revised to be effective for up to 25% steam generator tubes plugged.

Page 3.1-7 This page is revised to be effective for up to 25% steam generator tubes plugged.

REGULATORY DOCKET FILE COPY

781940005

ADD
3/40
D.C. (5)



1
2


Mr. Victor Stello, Director
U. S. Nuclear Regulatory Commission
Page Two

July 10, 1978
L-78-230

These proposed changes have been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board. They determined that these changes will not endanger the health and safety of the public. A written safety evaluation is attached.

Florida Power & Light Company Topical Report NAD-1483, "Safety and Fuel Management Analysis Methods," is referenced by the attached safety evaluation. Volume I of NAD-1483, subtitled "Methodology for Analysis of Operational Transients," is enclosed for your review. Volume II of NAD-1483 subtitled "Neutronics and Fuel Management Analysis Methods," will be forwarded shortly.

Very truly yours,



Robert E. Uhrig
Vice President

REU/GDW/ma1

Attachment
Enclosure

cc: James P. O'Reilly, Region II (w/o enclosure)
Robert Lowenstein, Esquire (w/o enclosure)



STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

Robert E. Uhrig, being first duly sworn, deposes and says:

That he is a Vice President of Florida Power & Light Company,
the Licensee herein;

That he has executed the foregoing document; that the state-
ments made in this said document are true and correct to the
best of his knowledge, information, and belief, and that he
is authorized to execute the document on behalf of said
Licensee.



Robert E. Uhrig

Subscribed and sworn to before me this

10 day of July, 19 78



NOTARY PUBLIC, in and for the County of Dade,
State of Florida

My commission expires: NOTARY PUBLIC STATE OF FLORIDA at LARGE
MY COMMISSION EXPIRES MAY 6, 1981
BONDED THRU MAYNARD BONDING AGENCY

1137

1137