

1008/29/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-250 251

REC: STELLO V
NRC

ORG: UHRIG R E
FL PWR & LIGHT

DOC DATE: 08/16/78
DATE RCVD: 08/22/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 3 ENCL 3

FURNISHING CLARIFICATION TO APPLICANT'S 07/10/78 PROPOSED TECH SPEC CHANGES
RE ALLOWING FULL PWR OPERATION WITH UP TO 25% OF THE STEAM GENERATOR TUBES
PLUGGED, PERTAINING TO THE REACTOR CORE THERMAL HYDRAULIC LIMITS...W/ATT
SUPPORTING FIGURES.

PLANT NAME: TURKEY PT. #3
TURKEY PT #4

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL: DL

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF ORB#1 BC**W/7 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
REACTOR SAFETY BR**W/ENCL
EEB**W/ENCL
J. MCGOUGH**W/ENCL

NRC PDR**W/ENCL
OELD**LTR ONLY
CORE PERFORMANCE BR**W/ENCL
ENGINEERING BR**W/ENCL
PLANT SYSTEMS BR**W/ENCL
EFFLUENT TREAT SYS**W/ENCL

EXTERNAL:

LPDR'S
MIAMI, FL**W/ENCL
TERA**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

App 2 CCP

DISTRIBUTION: LTR 40 ENCL 39
SIZE: 2P+2P


CONTROL NBR: 782340172

***** THE END *****



19

REGULATORY FILE COPY



August 16, 1978
L-78-271

Office of Nuclear Reactor Regulation
Attention: Mr. Victor Stello, Jr., Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Thermal and Hydraulic Safety Limits

Florida Power and Light Company (FPL) letter L-78-230 of July 10, 1978 contained proposed changes to the Technical Specifications of Turkey Point Units 3 and 4 to allow full power operation with up to 25% of the steam generator tubes plugged. The staff has asked FPL to clarify the derivation of the Reactor Core Thermal Hydraulic Limits, Figure 2.1-lb, which are to be added to the Technical Specifications to permit operation with steam generator tube plugging between 19% and 25%.

The basic methods used to produce this figure are described in FPL report NAD-QR-25, submitted with letter L-77-106 on April 4, 1977. A subchannel of the fuel assembly consisting of a RCCA guide thimble and 11 surrounding fuel rods was modeled by means of the COBRA IIIC thermal-hydraulics code; the geometry is shown in Figure 1. Of the eight subchannels, channels one and five contain an allowance for a water gap between adjacent assemblies.


A number of COBRA computer runs were made with the following input. For power levels $\geq 100\%$ of rated the $F_{\Delta H}^N$ for each fuel rod was 1.55, while for lower power levels $F_{\Delta H}^N$ was taken to be the highest value permitted by the Technical Specifications,

$$F_{\Delta H}^N = 1.55[1 + 0.2(1-P)]$$

where P is the fractional power. The axial power distribution for all fuel rods was a center peaked chopped cosine with a peak to average ratio of 1.55. Fuel densification was accounted for by a reduction in active fuel length from 144 to 142 inches.

782340172

1001
5/3




Mr. Victor Stell
Page Two
August 10, 1978

Cross flow mixing parameters and flow correlations were taken to be those listed in Table 4 of NAD-QR-25. In accordance with the methods described in that report the core coolant average mass velocity of $2.32 * 10^6$ lb/hr ft² was reduced by 5% to allow for inlet flow maldistribution. Flow was reduced by another 1% to account for flow redistribution and the effects of interassembly mixing. To generate Figure 2.1-lb the coolant flow was further reduced by another 5% to account for the effects of the 25% steam generator tube plugging. Appropriate uncertainty factors were included for power levels, pressures and temperatures.

The curves of Figure 2.1-lb, covering a range of pressure levels, were generated by varying the average coolant temperature for a given power level until the minimum DNBR, as calculated with the COBRA model described above, was 1.24 with the rod bow penalty included. Thus each curve represents the locus of points of the DNBR limit. The DNBR was calculated with the W-3 correlation and the "L" grid correction for LOPAR 15x15 Westinghouse fuel. The DNBRs obtained from the COBRA computer runs were reduced by 28.9% to account for the rod bow penalty prescribed for fuel with the highest burnup.

At the lower power levels the average coolant temperature at the reactor exit reaches the saturation temperature before the DNB limit is reached. The saturation line then represents the limiting condition. Figure 2 shows these saturation limit curves as well as the DNB limit curves. To be consistent with the Reactor Core Thermal and Hydraulic Safety Limit curves presently in the Technical Specifications and those submitted for less than 25% tube plugging on June 22, 1978 (letter L-78-217), horizontal limit lines are conservatively prescribed in Figure 2.1-lb instead of the higher saturation limit lines.

Very truly yours,


Robert E. Uhrig
Vice President


REU:RDH:lc

cc: Mr. Robert Lowenstein, Esquire
Mr. James P. O'Reilly, Region II



FIGURE 1

SUBCHANNEL GEOMETRY





[Faint, illegible text or markings on the right side of the page, possibly bleed-through from the reverse side.]




Figure 2. Reactor Core Thermal and Hydraulic Safety Limits

11-11-64



11-11-64

1
V