



August 26, 1977  
L-77-259

*Central file*  
*50-250*  
*251*

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
230 Peachtree Street, N. W., Suite 1217  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Changes, Tests, and Experiments

In accordance with 10 CFR Part 50.59(b) (Changes, Tests, and Experiments) and Regulatory Guide 10.1 (Compilation of Reporting Requirements for Persons Subject to NRC Regulations), two copies of the subject report are attached. The report covers the period July 1, 1976 through June 30, 1977.

Very truly yours,

Robert E. Uhrig  
Vice President

REU/MAS/cpc

Attachments

cc: Director, Office of Inspection and Enforcement (40)  
Robert Lowenstein, Esquire

*MAJ*

*B*

NOV 17 1977

Distribution

- ✓ Docket
- ORB #3
- Local PDR
- NRC PDR
- VStello
- KGoller
- GLear
- CParrish
- RClark
- Attorney, OELD
- OI&E (3)
- DEisenhut
- TBAbernathy
- JRBuchanan
- ACRS (16)

Dockets Nos. 50-250  
and 50-251

Florida Power & Light Company  
ATTN: Dr. Robert E. Uhrig  
Vice President  
P. O. Box 013100  
Miami, Florida 33101

Gentlemen:

Reference is made to your letters of October 17, 1977 and September 2, 1977 responding to our letter of June 30, 1977 on flow throttling in safety injection systems. We have reviewed your submittals and have concluded that the existing surveillance requirements on the one valve in the RHR discharge header are adequate. This item is considered closed.

Sincerely,

Original signed by

George Lear, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

cc:  
Mr. Jack R. Newman, Esquire  
Lowenstein, Newman, Reis & Axelrad  
1025 Connecticut Avenue, N. W.  
Suite 1214  
Washington, D. C. 20036

Environmental & Urban Affairs Library  
Florida International University  
Miami, Florida 33199

OFFICE >	ORB #3 <i>DM</i>	ORB #3				
CURNAME >	<i>JR</i> RClark:mjf	GLear <i>GL</i>				
DATE >	11/16/77	11/17/77				



March 31, 1977

L-77-105

*Confidential File*

*50-250  
251*

Norman C. Moseley, Director  
Office of Inspection & Enforcement, Region II  
U. S. Nuclear Regulatory Commission  
230 Peachtree Street, N. W., Suite 818  
Atlanta, Georgia 30303

Dear Mr. Moseley:

Re: IE: II: AKH  
50-250/76-1  
50-251/76-1

This letter is submitted in accordance with the commitments made in my letter dated March 29, 1976. The status of the Turkey Point Drawings Program is as follows:

1. As of March 30, 1977, a total of nine-hundred & six (906) drawings have been updated as built in the field.
2. Of these, eight-hundred & thirty-four (834) have received final approval and released to the field; thirteen (13) in the final approval cycle; and fifty-nine (59) are undergoing drafting and final review for adequacy.

Very truly yours,

Robert E. Uhrig  
Vice President

REU/NFA/hlc

cc: Robert Lowenstein, Esq.