

NRC DISTRIBUTION PART 50 DOCKET MATERIAL

FILE NUMBER

TO: V. Stello

FROM: Florida Power & Light Co,
Miami, Florida
R.E. Uhrig

DATE OF DOCUMENT

7-8-76

DATE RECEIVED

7-12-76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1

DESCRIPTION

Ltr: re. their 6-23-76 ltr.....
Supplemental Information concerning the transfer
of spent fuel between Unit # 3 & 4.....

(1 Signed Cy. REceived)
(3 Pages)

PLANT NAME: Turkey Pt. # 3 & 4

ENCLOSURE


DO NOT REMOVE
ACKNOWLEDGED

SAFETY	FOR ACTION/INFORMATION	ENVIRO	SAB: 7-15-76
ASSIGNED AD:		ASSIGNED AD:	
BRANCH CHIEF:	Lear W/G	BRANCH CHIEF:	
PROJECT MANAGER:		PROJECT MANAGER:	
LIC ASST.:	Rarrish	LIC ASST.:	

INTERNAL DISTRIBUTION			
<input checked="" type="checkbox"/> REG FILE	<input type="checkbox"/> SYSTEMS SAFETY	<input type="checkbox"/> PLANT SYSTEMS	<input type="checkbox"/> SITE SAFETY &...
<input checked="" type="checkbox"/> NRC PDR	<input type="checkbox"/> HEINEMAN	<input type="checkbox"/> TEDESCO	<input type="checkbox"/> ENVIRO ANALYSIS
<input type="checkbox"/> T & E (2)	<input type="checkbox"/> SCHROEDER	<input type="checkbox"/> BENAKOYA	<input type="checkbox"/> DENTON & MULLER
<input type="checkbox"/> OELD	<input type="checkbox"/> ENGINEERING	<input type="checkbox"/> LAINAS	<input type="checkbox"/> ENVIRO TECH
<input type="checkbox"/> GOSSICK & STAFF	<input type="checkbox"/> MACCARRY	<input type="checkbox"/> KIRKWOOD	<input type="checkbox"/> ERNST
<input type="checkbox"/> MIPC	<input type="checkbox"/> KNIGHT	<input type="checkbox"/> P. NIGRA	<input type="checkbox"/> BALLARD
<input type="checkbox"/> CASE	<input type="checkbox"/> SINNELL	<input type="checkbox"/> OPERATING REACTORS	<input type="checkbox"/> SPANGLER
<input type="checkbox"/> HANAUER	<input type="checkbox"/> PAWLICKI	<input type="checkbox"/> STELLO	<input type="checkbox"/> SITE TECH
<input type="checkbox"/> HARLESS	<input type="checkbox"/> REACTOR SAFETY	<input type="checkbox"/> OPERATING TECH.	<input type="checkbox"/> GAMILL
<input type="checkbox"/> PROJECT MANAGEMENT	<input type="checkbox"/> ROSS	<input checked="" type="checkbox"/> EISENHUT	<input type="checkbox"/> STEPP
<input type="checkbox"/> BOYD	<input type="checkbox"/> NOVAK	<input checked="" type="checkbox"/> SHAO	<input type="checkbox"/> HULMAN
<input type="checkbox"/> P. COLLINS	<input type="checkbox"/> ROSZTOCZY	<input checked="" type="checkbox"/> BAER	<input type="checkbox"/> SITE ANALYSIS
<input type="checkbox"/> HOUSTON	<input type="checkbox"/> CHECK	<input checked="" type="checkbox"/> BUTLER	<input type="checkbox"/> VOLLMER
<input type="checkbox"/> PETERSON	<input type="checkbox"/> AT & I	<input checked="" type="checkbox"/> GRIMES	<input type="checkbox"/> BUNCH
<input type="checkbox"/> MELTZ	<input type="checkbox"/> SALTZMAN		<input checked="" type="checkbox"/> J. COLLINS
<input type="checkbox"/> HELTENES	<input type="checkbox"/> RUTBERG		<input type="checkbox"/> KREGER
<input type="checkbox"/> SKOVHOLT			

EXTERNAL DISTRIBUTION			CONTROL NUMBER
<input checked="" type="checkbox"/> PDR: Miami, FL	<input type="checkbox"/> NAT LAB:	<input type="checkbox"/> BROOKHAVEN NAT LAB	6942
<input checked="" type="checkbox"/> TIC:	<input type="checkbox"/> REG. VIE	<input type="checkbox"/> ULRIKSON (ORNL)	
<input checked="" type="checkbox"/> NSIC:	<input type="checkbox"/> LA PDR		
<input checked="" type="checkbox"/> ASLB:	<input type="checkbox"/> CONSULTANTS		
<input checked="" type="checkbox"/> ACRS 16CYS			

INFORMATION
CIRCULAR NUMBER



Regulatory

File 67




FLORIDA POWER & LIGHT COMPANY

July 8, 1976
L-76-248

Office of Nuclear Reactor Regulation
Attn: Mr. Victor Stello, Jr., Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: Turkey Point Plant - Unit Nos. 3 and 4
Docket Nos. 50-250 and 50-251
Supplemental Information



Our letter to you dated June 23, 1976 (L-76-234) forwarded information concerning the transfer of spent fuel between Turkey Point Units 3 and 4. This letter provides supplemental information, and documents the results of recent discussions with members of your staff.

In order to preclude vertical movement of the cask during the transfer between Units 3 and 4, control power to the hoist will be de-energized while the cask is in the alley between the units. This requirement has been incorporated into our Turkey Point operating procedures.

In our June 23, 1976 letter, we estimated that it would be necessary to transfer some fuel assemblies after about 90 days of decay. Due to the delays in initiating the transfer operation, all of the fuel assemblies will have decayed at least 120 days prior to being transferred. Our calculations show that 120 days of decay ensures that all assemblies have a decay heat of less than 10.6 KW. The Turkey Point Unit No. 4 (cycle 2) calculated maximum assembly decay heat load is 8.95 KW after 120 days decay. The calculation is based on the ANS decay heat curves (Draft of Proposed Standard Decay Energy Release Rates Following Shutdown of Uranium - Fueled Thermal Reactors, October 1971) with the adjustment applied for a finite operating time. The calculation also includes a calculated factor of 1.05 to account for the relative power distribution among assemblies while they were in the reactor. An 18% margin exists between the calculated decay heat load and 10.6 KW which is the design thermal rating for the spent fuel cask. The calculation contains some added conservatism in that the cycle 1 effect does not consider that the reactor was shut down for slightly more than two months for the re-fueling between cycle 1 and cycle 2. The above notwithstanding

6942



To: Victor Stello, Jr.
Re: Turkey Point Plant Unit Nos. 3 & 4
Docket Nos. 50-250 and 50-251
Supplemental Information

July 8, 1976
Page -2-

the heatup rate of the cask with one of the 40 least decayed spent fuel assemblies will still be determined prior to transferring any of these assemblies as indicated in our June 23, 1976, letter.

In addition to reducing the decay heat of the fuel assemblies, the additional decay time (minimum of 2880 hours) will significantly reduce the radiological inventory of the spent fuel, thereby further reducing the already acceptable consequences of a postulated fuel handling accident. With the assumptions provided in Table 5 of our June 23, 1976, letter and deleting the pool DF of 100 and with 2000 hours of decay, the potential offsite radiological consequences of a rupture of one fuel assembly outside of the spent fuel pool is 1.6 rem thyroid and 0.0003 rem whole body. The cask is designed for dry transfer. Thus, loss of water from the cask is not expected to result in unacceptable damage to the fuel element. However, even if a TID-14844 release were assumed, the resulting site boundary dose would be less than the 17 rem thyroid and the 2 rem whole body found acceptable by the Staff in its Safety Evaluation Report. Since the spent fuel will have a minimum of 2880 hours decay prior to transfer, the potential site boundary dose associated with mishaps in transfer, is significantly less than the values found acceptable by the Staff.

An uncontrolled descent of the cask of approximately 41 feet can be postulated. The probability of such an event is small since the cask is at the height of 41 feet only briefly after crossing the lip of the fuel pool prior to being lowered to the transfer height of less than 12 inches above grade. Assuming that such an event did occur, we expect that the cask would remain structurally intact, i.e., unacceptable damage is not anticipated. We also expect the cask shielding to remain essentially intact. The cask is designed to meet the rigorous requirements of 10 CFR 71, including an uncontrolled descent of 30 feet onto an unyielding surface. In our judgment, the actual conditions surrounding our intended use of the cask, including the postulated uncontrolled descent of 41 feet, are not significantly more severe than the requirements of 10 CFR 71. Even if the loss of cask integrity did occur, the radiological consequences associated with this postulated event are less than previously found acceptable by the Staff,

To: Victor Stello, Jr.
Re: Turkey Point Plant Unit Nos. 3 and 4
Docket Nos. 50-250 and 50-251
Supplemental Information

July 8, 1976
Page -3-

and, therefore, further analysis of this event is not required.

Very truly yours,



for Robert E. Uhrig
Vice President

REU/GDW/hlc

cc: Norman C. Moseley, Region II
Jack R. Newman, Esq.

