

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-250

REC: BROIDO J H
AMER NUC SOC

ORG: LEAR G
FL PWR & LIGHT

DOCDATE: 02/03/78
DATE RCVD: 02/07/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED
LTR 1 ENCL 1

SUBJECT:
SUMMARY COVER SHEET & SUMMARY FOR A PAPER DESCRIBING FLORIDA POWERS
PROGRAM FOR STEAM GENERATOR REPAIR & THE INFLUENCE OF WATER
CHEMISTRY.

PLANT NAME: TURKEY POINT - UNIT 3

REVIEWER INITIAL: XRL
DISTRIBUTOR INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.
(DISTRIBUTION CODE A001)

FOR ACTION: BRANCH CHIEF LEAR**W/7 ENCL

INTERNAL:

REG FILE**W/ENCL
~~1 & E**W/2 ENCL~~
HANAUER**W/ENCL
EISENHUT**W/ENCL
BAER**W/ENCL
GRIMES**W/ENCL
J. MCGOUGH**W/ENCL

NRC PDR**W/ENCL
OELD**LTR ONLY
CHECK**W/ENCL
SHAO**W/ENCL
BUTLER**W/ENCL
J. COLLINS**W/ENCL

EXTERNAL:

LPDR'S
MIAMI, FL**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 40 ENCL 39
SIZE: 1P+4P

CONTROL NBR: 780390017


***** THE END *****

5
may



50-250

REGULATORY DOCKET FILE COPY




FLORIDA POWER & LIGHT COMPANY

February 3, 1978

PRN-SP-78-014

File



Mr. Jeffrey H. Broido
ANS Technical Program Chairman
Attn: Ruth Farmakes
American Nuclear Society
555 North Kensington Avenue
LaGrange Park, Illinois 60525

Dear Mr. Broido:

Enclosed are four copies of the Summary Cover Sheet and Summary for a paper describing Florida Power & Light Company's program for steam generator repair and the influence of water chemistry.

If the paper is accepted for presentation, please forward your invoice for page charges to me.

Very truly yours,

H. N. Paduano

H. N. Paduano
Power Resources-Section Supervisor

HNP:dt
Enclosure

cc: Mr. George Lear, Chief
Operating Reactors Branch No. 3, DOR
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

780390017

As of 1/5



2
2
2
2

SUMMARY COVER SHEET

CONTRIBUTED PAPER

INVITED PAPER

ORIGINAL AND THREE COPIES REQUIRED

TITLE: TURKEY POINT STEAM GENERATOR REPAIR AND INFLUENCE OF WATER CHEMISTRY

AUTHOR(S): (List authors in the proper order and exactly as they are to be published. PLACE AN ASTERISK AFTER EACH AUTHOR WHO IS AN ANS MEMBER; AN "S" AFTER STUDENT AUTHOR.)

1. H. N. Paduano *
2. R. J. Acosta *
3. A. J. Gould *

AFFILIATION(S): (List corresponding author's affiliation and complete mailing address.)

1. Florida Power & Light Co., Power Resources Dept., P.O. Box 529100, Miami, FL 33152
2. " " "
3. " " "

Indicate number of author to whom correspondence should be addressed 1, and complete page 4.

To whom should the page charge be billed? H. N. Paduano

Preferred: Attach purchase order with appropriate purchase order number to original copy of the summary.

FOR CONTRIBUTED SUMMARY:

Identify ANS Division or Technical Group having cognizance of your subject _____

In which subject category (from page 3) do you feel this summary belongs? _____

Alternative Category: _____

Has the substance of this summary been presented or published previously (including U.S. ERDA or equivalent reports)?

YES NO Give details _____

Has the paper been submitted for publication in a technical journal?

YES NO Give details _____

Have you presented related papers?

YES NO Give details _____

Has this summary been approved for publication by your institution or company?

YES NO Give details _____

FOR INVITED SUMMARY:

Which ANS Division or Technical Group invited you? Power Division

Person who invited you Mr. Thomas J. Pashos Session No. _____

FOR CONTRIBUTED OR INVITED SUMMARY:


Number of: Pages 1 1/4 Tables 0 Figures 0

Word Count: Text 550 + (No. of figures plus tables) × 150 _____ + (No. of lines of equations × 10) _____

Total 550

Original line drawings or glossy black-and-white prints of each figure must be attached to original.

A COMPLETED SUMMARY COVER SHEET, TOGETHER WITH THE INFORMATION REQUESTED ON PAGE 4, MUST BE ATTACHED TO EACH OF THE FOUR SETS OF THE SUMMARY. Please have copies made to complete your four sets.



FILING AND MAILING INFORMATION

Name and full mailing address of author to whom correspondence should be sent. (Type or print legibly - form used for mailing.)

LOG # _____ (leave blank)

MR. H. N. PADUANO
FLORIDA POWER & LIGHT COMPANY
POWER RESOURCES DEPARTMENT
P. O. BOX 529100
MIAMI, FLORIDA 33152

Telephone: (305)552-3798
Commercial:
FTS:

Title of Summary TURKEY POINT STEAM GENERATOR REPAIR AND INFLUENCE OF WATER CHEMISTRY

This is to acknowledge receipt of your summary. Please use the log number above in future correspondence.

This summary will be considered for inclusion in the program of the American Nuclear Society's 1978 Annual Meeting, San Diego, CA, June 18 - 23, 1978. Another copy of this form will be sent to you about March 4, 1978 informing you of the Program Committee action.

Your paper has been reviewed and:

- 1. Accepted for presentation at the 1978 Annual Meeting. (See Attached Instructions)
- 2. It is suggested that your summary be revised. (See Attachment)
- 3. It is suggested that your summary be combined with the summary referenced as Log # _____ (See Attachment)
- 4. Rejected. (See Attached Comments)

In all correspondence regarding your summary, please refer to the Log Number shown above.

Thank you for submitting this summary.

Sincerely,

Jeffrey H. Broido
ANS Technical Program Chairman
1978 Annual Meeting

Turkey Point Steam Generator Repair

and

Influence of Water Chemistry

By

H. N. Paduano, R. J. Acosta, and A. J. Gould

Due to the progression of steam generator tube denting in the Turkey Point steam generators, FPL made the decision to begin a program aimed at repairing the steam generators. The program included evaluation of various repair alternatives, including retubing of the steam generators in place. The evaluation concluded that a replacement of the lower assembly (primary channel head plus tube bundle and secondary shell) was the best alternative. Such a repair was evaluated to offer the least construction process uncertainties, the shortest estimated outage time, and also enabled the repaired steam generator to incorporate all of the latest design improvements.

The repaired steam generators will have the following improvements:

- a) thermally treated inconel tubes
- b) stainless steel broached tube support plates
- c) full depth expansion of tubes into the tube sheet
- d) increased recirculation ratio
- e) improved blowdown design
- f) improved moisture separation equipment
- g) capability for wet layup recirculation
- h) improved access for secondary side inspections

Along with the steam generator repair program, FPL also has a program aimed at improved "water chemistry" for the steam generators and feedwater cycle. As a part of this program, FPL is investigating systems that will be designed to address problems associated with sludge, copper, chloride, oxygen, and other contaminants. Consideration is being given to shutdown and startup as well as normal operating modes. Areas under investigation include a feedwater recirculation cleanup system, magnetic filtration of the main feedwater, retubing of the main feedwater heaters with stainless steel, and deaeration of the condensate storage tank.

Also included in the program is the most important effort to obtain a leak free main condenser. In this regard, FPL believes that titanium tubing provides the greatest assurance for eliminating leakage and has already retubed three out of the eight waterboxes at Turkey Point Unit Nos. 3 and 4 with titanium. The experience thus far, after about two years of operation has been excellent.

While the exact schedule for repair of the steam generators is not finalized, it is possible that it could begin during the first quarter of 1979 on Turkey Point Unit 4. Following the repair, Florida Power & Light Company will implement a water

chemistry program which closely follows the latest recommendations of the NSSS vendor. Presently, it is anticipated that an All Volatile Treatment (AVT) program will be utilized with major emphasis on limiting operation outside the specified normal chemistry limits. The water chemistry program will be designed to provide increased protection of the repaired steam generator. The operating limits are expected to be very stringent, thus requiring procedural and equipment modifications, such as discussed above, to enable desired unit performance.

In summary, FPL has implemented a repair program that will result in improved steam generators. Along with the repair effort, a companion program whose aim is for increased protection of the steam generators through improved water chemistry has also been initiated. Through these programs, FPL intends to ensure continued, safe, and reliable operation of the Turkey Point nuclear units.

RECEIVED DOCUMENT
CONTROL DESK

1978 FEB 7 AM 10 08

U.S. PRO
DISTRIBUTION SERVICES
BRANCH