



NOTES:
 1. LOCATE CONNECTION ABOVE MIN. WATER LEVEL IN TECH. SPEC.
 2. TWO MINUTE DELAY AFTER INITIATION OF 'SP' SIGNAL BEFORE VALVE OPENS.

AMENDMENT NO. 13

CAROLINA POWER & LIGHT COMPANY
 SHEARON HARRIS NUCLEAR POWER PLANT
 UNITS 1, 2, 3 & 4

CONTAINMENT SPRAY SYSTEM

6.3-1